

© Copyright SEK. Reproduction in any form without permission is prohibited.

Anordningar för skydd mot nätfrekventa överspänningar för användning i hushåll och liknande (POP)

Power frequency overvoltage protective device for household and similar applications (POP)

Som svensk standard gäller europastandarden EN 50550:2011. Den svenska standarden innehåller den officiella engelska språkversionen av EN 50550:2011.

ICS 29.120.50

Denna standard är fastställd av SEK Svensk Elstandard,
som också kan lämna upplysningar om **sakinnehållet** i standarden.
Postadress: SEK, Box 1284, 164 29 KISTA
Telefon: 08 - 444 14 00. Telefax: 08 - 444 14 30
E-post: sek@elstandard.se. Internet: www.elstandard.se

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

Power frequency overvoltage protective device for household and similar applications (POP)

Dispositif de protection contre les
surtensions à fréquence industrielle pour
les applications domestiques et analogues

Schutzeinrichtung gegen netzfrequente
Überspannungen für Hausinstallationen
und für ähnliche Anwendungen

This European Standard was approved by CENELEC on 2011-01-17. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

This European Standard was prepared by the CENELEC BTTF 128-1, Power frequency overvoltage protective device for household and similar applications.

It was submitted to the formal vote and was approved by CENELEC as EN 50550 on 2011-01-17.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates are proposed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2012-01-17
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2014-01-17

This European Standard has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association and covers essential requirements of EC Directive 2004/108/EC. See Annex ZZ.

ANM – (sv anm) Uppgifter om andra, felaktiga datum har tidigare cirkulerat i CENELEC.

Contents

1	Scope.....	5
2	Normative references.....	6
3	Terms and definitions	7
4	Classification	8
4.1	According to the method of construction.....	8
4.2	According to the main protective device	8
4.3	According to the range of ambient air temperature (only for POP according to 4.2.2 and 4.2.3)	8
4.4	According to the number of monitored line to neutral conductor voltages.....	8
5	Characteristics.....	9
5.1	Summary of characteristics.....	9
5.2	Limit values of the break times and non-actuating times	9
6	Marking and other product information.....	9
6.1	Standard marking.....	9
6.2	Additional marking.....	10
7	Standard conditions for operation in service.....	11
7.1	General.....	11
7.2	Conditions of installation	11
7.3	Pollution degree	11
8	Requirements for construction and operation.....	11
8.1	Mechanical design	11
8.2	Protection against electric shock	16
8.3	Dielectric properties and isolating capability	16
8.4	Temperature rise	16
8.5	Operating characteristic	16
8.6	Mechanical and electrical endurance.....	16
8.7	Performance at short-circuit currents.....	17
8.8	Resistance to mechanical shock and impact.....	17
8.9	Resistance to heat	17
8.10	Resistance to abnormal heat and to fire	17
8.11	Ageing of electronic components.....	17
8.12	Behaviour at low ambient air temperature	18
8.13	Electromagnetic compatibility	18
8.14	Safety performance of overstressed POPs.....	18
9	Tests	18
9.1	General.....	18
9.2	Test condition.....	19
9.3	Verification of the influence of the POP on the correct operation of the main protective device.....	19
9.4	Test of dielectric properties.....	21
9.5	Temperature rise.....	21
9.6	Verification of the operating characteristics	21
9.7	Verification of the mechanical and electrical endurance.....	23
9.8	Tests of creepage distances and clearances for electronic circuits (abnormal conditions).....	24
9.9	Requirements for capacitors and specific resistors and inductors used in electronic circuits.....	27
9.10	Electromagnetic compatibility	28
9.11	Test of safety performance of overstressed POPs	32
9.12	Test of reliability of screws, current-carrying parts and connections	32
9.13	Test of reliability of terminals for external conductors.....	32
9.14	Verification of protection against electric shock.....	32
9.15	Verification of resistance to mechanical shock and impact	33
9.16	Test of resistance to heat.....	33
9.17	Resistance to abnormal heat and to fire	33
9.18	Verification of the correct operation at low ambient air temperatures for RCDs for use at temperatures between -25 °C and +40 °C.....	33

Annex A (normative) Test sequences	36
Annex B (normative) Determination of clearances and creepage distances.....	37
Annex C (informative) Examples of terminal designs	39
Annex D (normative) Number of samples for full test procedure	42
Annex ZZ (informative) Coverage of Essential Requirements of EC Directives	44
Bibliography	45

Figures

Figure 1 – Minimum creepage distances and clearances measured in millimetres	34
Figure 2 – Minimum creepage distances and clearances as a function of peak value of operating voltage	35
Figure B.1 – Illustrations of the application of creepage distances	38
Figure C.1 – Examples of pillar terminals	39
Figure C.2 – Examples of screw terminals and stud terminals.....	40
Figure C.3 – Examples of saddle terminals	41
Figure C.4 – Examples of lug terminals	41

Tables

Table 1 – Limit values of break times and non-actuating times.....	9
Table 2 – Minimum clearances and creepage distances.....	13
Table 3 – Maximum permissible temperatures under abnormal conditions	26
Table 4 – Low frequency immunity test conditions	29
Table 5 – High frequency immunity test conditions	30
Table 6 – Test conditions for electrostatic discharges.....	31
Table 7 – Emissions test conditions.....	31
Table A.1 – Test sequences	36
Table D.1 – Number of samples for full test procedure	42
Table D.2 – Additional tests for POP already fully tested together with one kind of main protective device	43

1 Scope

This European Standard applies to power frequency overvoltage protection devices (hereafter referred to as “POP”) for household and similar uses, with a rated frequency of 50 Hz, a rated voltage 230 V a.c. (between phase and neutral), intended to be used in combination with a main protective device being either a CB in compliance with EN 60898-1 or EN 60898-2, a RCCB in compliance with EN 61008-1 or a RCBO in compliance with EN 61009-1.

NOTE 1 Requirements for POPs in combination with switching devices other than a main protective device, or a POP integrated in a MPD, are under consideration.

NOTE 2 Requirements for POP with functional earth connection regarding temporary overvoltage withstand are under consideration.

NOTE 3 A POP is not a protective device to be used for automatic disconnection of the supply in the meaning of HD 60364-4-41.

They are intended for use in an environment with pollution degree 2 and overvoltage category III.

They can be designed for factory assembly or for assembly on site.

These devices are intended to mitigate the effects of power frequency overvoltages between phase and neutral conductor (e.g. caused by loss of neutral conductor in the three phase supply upstream the POP) for downstream equipment by actuating the main protective device when an overvoltage between phase and neutral is detected.

NOTE 4 To mitigate means in this context that the POP will provide protection in most cases of power frequency overvoltages.

NOTE 5 Protection in case of overvoltage between phases is under consideration. In case of phase to phase electrical supply system with rated voltage between phases 230 V a.c. and no neutral conductor, one line monitored POP in compliance to this standard can be used according to manufacturer's instruction.

The POP does not impair the protective function of the main protective device.

This European Standard does not apply for protection against common mode over voltages.

This European Standard does not apply to surge protective devices.

This European Standard states:

- the definitions of terms used for POP (Clause 3);
- the classification of POP (Clause 4);
- the characteristics of POP (Clause 5);
- the preferred values of the operating and influencing quantities (Clause 5);
- the marking and information to be provided for POP (Clause 6);
- the standard conditions for installation and operation in service (Clause 7);
- the requirements for construction and operation (Clause 8);
- the list of minimum requirements to be tested (Clause 9).

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50160:2010	Voltage characteristics of electricity supplied by public electricity networks
EN 55014-1:2006 + A1:2009	Electromagnetic compatibility – Requirements for household appliances, electric tools and similar apparatus – Part 1: Emission (CISPR 14-1:2005 + A1:2008)
EN 55022:2010	Information technology equipment – Radio disturbance characteristics – Limits and methods of measurement (CISPR 22:2008, mod.)
EN 60065:2002 + corr. Aug. 2007	Audio, video and similar electronic apparatus – Safety requirements (IEC 60065:2001, mod.)
EN 60384-14	Fixed capacitors for use in electronic equipment – Part 14: Sectional specification – Fixed capacitors for electromagnetic interference suppression and connection to the supply mains (IEC 60384-14)
EN 60664-1:2007	Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests (IEC 60664-1:2007)
EN 60664-3	Insulation coordination for equipment within low-voltage systems – Part 3: Use of coating, potting or moulding for protection against pollution (IEC 60664-3)
EN 60898-1:2003 + corr. Feb. 2004 + A1:2004 + A11:2005 + A12:2008	Electrical accessories – Circuit breakers for overcurrent protection for household and similar installations – Part 1: Circuit-breakers for a.c. operation (IEC 60898-1:2002, mod. + A1:2002, mod.)
EN 60898-2:2006	Electrical accessories – Circuit-breakers for overcurrent protection for household and similar installations – Part 2: Circuit-breakers for a.c. and d.c. operation (IEC 60898-2:2000, mod. + A1:2003, mod.)
EN 60998-2-3	Connecting devices for low-voltage circuits for household and similar purposes – Part 2-3: Particular requirements for connecting devices as separate entities with insulation-piercing clamping units (IEC 60998-2-3)
EN 61000 series	Electromagnetic compatibility (EMC) (IEC 61000 series)
EN 61008 series	Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCB's) (IEC 61008 series)
EN 61008-1:2004 + A11:2007 + A12:2009	Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCB's) – Part 1: General rules (IEC 61008-1:1996, mod. + A1:2002, mod.)
EN 61009 series	Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBO's) (IEC 61009 series)
EN 61009-1:2004 + corr. Jul. 2006 + A11:2008 + A12:2009 + A13:2009	Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBO's) – Part 1: General rules (IEC 61009-1:1996, mod. + A1:2002, mod. + corrigendum May 2003)

EN 61543:1995 + corr. Dec. 1997 + A11:2003 + corr. May. 2004 + A12:2005 + A2:2006	Residual current-operated protective devices (RCDs) for household and similar use – Electromagnetic compatibility (IEC 61543:1995 + A2:2005)
EN 61558-1	Safety of power transformers, power supplies, reactors and similar products – Part 1: General requirements and tests (IEC 61558-1)
EN 61558-2 series	Safety of power transformers, power supplies, reactors and similar products – Part 2-X: Particular requirements and tests (IEC 61558-2 series)
EN ISO 306	Plastics – Thermoplastic materials – Determination of Vicat softening temperature (VST) (ISO 306:2004)
EN 61249-2 series	Base materials for printed circuits – Part 2: Specifications