

© Copyright SEK. Reproduction in any form without permission is prohibited.

Utrustning för avbrottsfri elförsörjning, UPS – Del 3: Egenskaper och provning

Uninterruptible power systems (UPS) –

Part 3: Method of specifying the performance and test requirements

Som svensk standard gäller europastandarden EN 62040-3:2011. Den svenska standarden innehåller den officiella engelska språkversionen av EN 62040-3:2011.

Nationellt förord

Europastandarden EN 62040-3:2011

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 62040-3, Second edition, 2011^{*)} - Uninterruptible power systems (UPS) - Part 3: Method of specifying the performance and test requirements**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 62040-3, utg 1, 2001 och SS-EN 62040-3/A11, utg 1, 2010, gäller ej fr o m 2014-04-18.

^{*)} Corrigendum, September 2011 till IEC 62040-3:2011 är inarbetat i standarden.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

**Uninterruptible power systems (UPS) -
Part 3: Method of specifying the performance and test requirements
(IEC 62040-3:2011)**

Alimentations sans interruption (ASI) -
Partie 3: Méthode de spécification des
performances et exigences d'essais
(CEI 62040-3:2011)

Unterbrechungsfreie
Stromversorgungssysteme (USV) -
Teil 3: Methoden zum Festlegen der
Leistungs- und Prüfungsanforderungen
(IEC 62040-3:2011)

This European Standard was approved by CENELEC on 2011-04-18. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 22H/129/FDIS, future edition 2 of IEC 62040-3, prepared by SC 22H, Uninterruptible power systems (UPS), of IEC TC 22, Power electronic systems and equipment, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 62040-3 on 2011-04-18.

This European Standard supersedes EN 62040-3:2001 + A11:2009.

The significant technical changes are:

- reference test load – definition and application revised (3.3.5 and 6.1.1.3);
- test schedule – presented as a single table grouped by revised type and routine tests (see 6.1.6, Table 3);
- dynamic output voltage performance characteristics – guidance to measure – addition (Annex H);
- UPS efficiency – requirements and methods of measure – addition (Annexes I and J);
- functional availability – guidance for UPS reliability integrity level classification – addition (Annex K).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

- | | | |
|--|-------|------------|
| – latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement | (dop) | 2012-01-18 |
| – latest date by which the national standards conflicting with the EN have to be withdrawn | (dow) | 2014-04-18 |

In this standard, the following print types are used:

- requirements proper and normative annexes: in roman type;
- compliance statements and test specifications: *in italic type*;
- notes and other informative matter: in smaller roman type;
- normative conditions within tables: in smaller roman type;
- terms that are defined in Clause 3: **bold**.

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 62040-3:2011 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

- | | |
|------------------|--|
| IEC 60034-22 | NOTE Harmonized as EN 60034-22. |
| IEC 60068-1:1988 | NOTE Harmonized as EN 60068-1:1994 (not modified). |

IEC 60068-2 series	NOTE	Harmonized in EN 60068-2 series (not modified).
IEC 60068-3-3:1991	NOTE	Harmonized as EN 60068-3-3:1993 (not modified).
IEC 60146-1-3:1991	NOTE	Harmonized as EN 60146-1-3:1993 (not modified).
IEC 60664-1:2007	NOTE	Harmonized as EN 60664-1:2007 (not modified).
IEC/TR 61508 series	NOTE	Harmonized in EN 61508 series (not modified).

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60038	-	IEC standard voltages	FprEN 60038 ¹	-
IEC 60068-2-1	-	Environmental testing - Part 2-1: Tests - Test A: Cold	EN 60068-2-1	-
IEC 60068-2-2	-	Environmental testing - Part 2-2: Tests - Test B: Dry heat	EN 60068-2-2	-
IEC 60068-2-27	-	Environmental testing - Part 2-27: Tests - Test Ea and guidance: Shock	EN 60068-2-27	-
IEC 60068-2-31	2008	Environmental testing - Part 2-31: Tests - Test Ec: Rough handling shocks, primarily for equipment-type specimens	EN 60068-2-31	2008
IEC 60068-2-78	-	Environmental testing - Part 2-78: Tests - Test Cab: Damp heat, steady state	EN 60068-2-78	-
IEC 60146-1-1	2009	Semiconductor converters - General requirements and line commutated converters - Part 1-1: Specification of basic requirements	EN 60146-1-1	2010
IEC 60146-2	1999	Semiconductor converters - Part 2: Self-commutated semiconductor converters including direct d.c. converters	EN 60146-2	2000
IEC 60196	-	IEC standard frequencies	EN 60196	-
IEC 60364-1	-	Low-voltage electrical installations - Part 1: Fundamental principles, assessment of general characteristics, definitions	HD 60364-1	-
IEC 60364-5-52	-	Low-voltage electrical installations - Part 5-52: Selection and erection of electrical equipment - Wiring systems	HD 60364-5-52	-
IEC 60947-3	-	Low-voltage switchgear and controlgear - Part 3: Switches, disconnectors, switch- disconnectors and fuse-combination units	EN 60947-3	-
IEC 60947-6-1	-	Low-voltage switchgear and controlgear - Part 6-1: Multiple function equipment - Transfer switching equipment	EN 60947-6-1	-

¹ At draft stage.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60950-1	-	Information technology equipment - Safety - Part 1: General requirements	EN 60950-1	-
IEC 60990	-	Methods of measurement of touch current and protective conductor current	EN 60990	-
IEC 61000-2-2	2002	Electromagnetic compatibility (EMC) - Part 2-2: Environment - Compatibility levels for low-frequency conducted disturbances and signalling in public low-voltage power supply systems	EN 61000-2-2	2002
IEC 61000-3-2	-	Electromagnetic compatibility (EMC) - Part 3-2: Limits - Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)	EN 61000-3-2	-
IEC/TS 61000-3-4	-	Electromagnetic compatibility (EMC) - Part 3-4: Limits - Limitation of emission of harmonic currents in low-voltage power supply systems for equipment with rated current greater than 16 A	-	-
IEC 61000-3-12	-	Electromagnetic compatibility (EMC) - Part 3-12: Limits - Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current > 16 A and ≤ 75 A per phase	EN 61000-3-12	-
IEC 61000-4-30	-	Electromagnetic compatibility (EMC) - Part 4-30 : Testing and measurement techniques - Power quality measurement methods	EN 61000-4-30	-
IEC 61672-1	-	Electroacoustics - Sound level meters - Part 1: Specifications	EN 61672-1	-
IEC 62040-1 + corr. September	2008 2008	Uninterruptible Power Systems (UPS) - Part 1: General and safety requirements for UPS	EN 62040-1 + corr. February	2008 2009
IEC 62040-2	-	Uninterruptible power systems (UPS) - Part 2: Electromagnetic compatibility (EMC) requirements	EN 62040-2	-
IEC 62310-3	2008	Static transfer systems (STS) - Part 3: Method for specifying performance and test requirements	EN 62310-3	2008
ISO 7779	2010	Acoustics - Measurement of airborne noise emitted by information technology and telecommunications equipment	EN ISO 7779	2010

CONTENTS

1	Scope	8
2	Normative references	9
3	Terms and definitions	10
3.1	Systems and components	10
3.2	Performance of systems and components	14
3.3	Specified values- General	18
3.4	Input values	22
3.5	Output values	24
4	Environmental conditions	26
4.1	Introduction	26
4.2	Normal conditions	26
4.2.1	Operation	26
4.2.2	Storage and transportation	27
4.3	Unusual conditions	28
4.3.1	Introduction	28
4.3.2	Operation	28
4.3.3	Storage and transportation	28
5	Electrical conditions, performance and declared values	28
5.1	General	28
5.1.1	UPS configuration	28
5.1.2	Markings and instructions	29
5.1.3	Safety	29
5.1.4	Electromagnetic compatibility	29
5.2	UPS input specification	29
5.2.1	Conditions for normal mode operation	29
5.2.2	Characteristics to be declared by the manufacturer	30
5.2.3	Characteristics and conditions to be identified by the purchaser	30
5.3	UPS output specification	31
5.3.1	Conditions for the UPS to supply a load	31
5.3.2	Characteristics to be declared by the manufacturer	31
5.3.3	Characteristics and conditions to be identified by the purchaser	32
5.3.4	Performance classification	32
5.4	Stored energy specification	37
5.4.1	General	37
5.4.2	Battery	37
5.5	UPS switch specification	38
5.6	Communication circuits	38
6	UPS tests	39
6.1	Summary	39
6.1.1	Venue, instrumentation and load	39
6.1.2	Routine test	40
6.1.3	Site test	40
6.1.4	Witness test	40
6.1.5	Type test	40
6.1.6	Schedule of tests	40

6.2	Routine test procedure	42
6.2.1	Environmental	42
6.2.2	Electrical	42
6.3	Site test procedure	44
6.4	Type test procedure (electrical)	44
6.4.1	Input – a.c. supply compatibility	44
6.4.2	Output – Linear load	47
6.4.3	Output – Non-linear load	52
6.4.4	Stored and restored energy	54
6.5	Type test procedure (environmental)	55
6.5.1	Environmental and transportation test methods	55
6.5.2	Transportation	55
6.5.3	Storage	56
6.5.4	Operation	57
6.5.5	Acoustic noise	57
6.6	UPS functional unit tests (where not tested as a complete UPS)	58
6.6.1	UPS rectifier tests	58
6.6.2	UPS inverter tests	58
6.6.3	UPS switch tests	58
6.6.4	Stored energy / battery tests	58
Annex A (informative)	Uninterruptible power system (UPS) configurations	59
Annex B (informative)	Topologies – Uninterruptible power system (UPS)	65
Annex C (informative)	UPS switch applications	68
Annex D (informative)	Purchaser specification guidelines	74
Annex E (normative)	Reference non-linear load	81
Annex F (informative)	Information on backfeed protection	83
Annex G (normative)	Input mains failure – Test method	84
Annex H (informative)	Dynamic output performance – Measurement techniques	85
Annex I (informative)	UPS Efficiency values	87
Annex J (normative)	UPS efficiency – Methods of measurement	96
Annex K (informative)	UPS functional availability	99
Bibliography		102
Figure 1	– Typical “non-sinusoidal” output voltage waveform	34
Figure 2	– Curve 1 – Dynamic output performance classification 1	35
Figure 3	– Curve 2 – Dynamic output performance classification 2	36
Figure 4	– Curve 3 – Dynamic output performance classification 3	36
Figure 5	– Linear load test method	51
Figure 6	– Reference non-linear load test method	53
Figure A.1	– Single UPS – Basic	60
Figure A.2	– Single UPS with bypass	60
Figure A.3	– Parallel UPS with common bypass	61
Figure A.4	– Parallel UPS with distributed bypass	62
Figure A.5	– Stand-by redundant UPS	63
Figure A.6	– Dual bus UPS	63

Figure A.7 – Stand-by redundant dual bus UPS	64
Figure B.1 – Double conversion topology	65
Figure B.2 – Line-interactive topology	66
Figure B.3 – Stand-by topology	67
Figure C.1 – UPS interrupter	68
Figure C.2 – UPS interrupters in parallel UPS application	68
Figure C.3 – UPS interrupters in split load application	69
Figure C.4 – Bypass transfer switch	69
Figure C.5 – Isolation of bypass transfer switch	70
Figure C.6 – Isolation of interrupters	70
Figure C.7 – Isolation switches with interrupter function	71
Figure C.8 – Internal maintenance bypass switch	71
Figure C.9 – External maintenance bypass switch	71
Figure C.10 – Tie switch in dual bus application	72
Figure C.11 – Tie switches in triple bus application	72
Figure C.12 – Multiple function bypass, interrupter and isolation switch	73
Figure E.1 – Reference non-linear load	81
Figure G.1 – Connection of test circuit	84
Figure H.1 – Example: instantaneous voltage variation in compliance with curve 1 of Figure 2	86
Figure I.1 – Example of VFI-S stand-by allowance	92
Figure I.2 – Example of VFI-S duty allowance	93
Figure I.3 – Example of VFI-S stand-by and duty allowance	94
Figure I.4 – Example of VFD duty allowance calculation	95
Figure K.1 – Reliability % over time	100
Figure K.2 – Maintainability % over time	101
Table 1 – Power derating factors for use at altitudes above 1 000 m	27
Table 2 – Compatibility levels for individual harmonic voltages in low voltage networks	30
Table 3 – UPS test schedule	40
Table 4 – Free fall testing	56
Table D.1 – UPS technical data – Manufacturer's declaration	76
Table I.1 – Efficiency for UPS rated from 0,3 kVA to less than 10,0 kVA with classification "VFI – S..."	88
Table I.2 – Efficiency for UPS rated from 0,3 kVA to less than 10,0 kVA with classification VI and VFI, except "VFI – S..."	88
Table I.3 – Efficiency for UPS rated from 0,3 kVA to less than 10,0 kVA with classification VFD	89
Table I.4 – Efficiency for UPS rated from 10,0 kVA (inclusive) and above with classification "VFI – S..."	89
Table I.5 – Efficiency for UPS rated from 10,0 kVA (inclusive) and above with classification VI and VFI, except "VFI – S..."	90
Table I.6 – Efficiency for UPS rated from 10,0 kVA (inclusive) and above with classification VFD	90
Table I.7 – UPS efficiency allowances for input or output isolation transformer	91

Table I.8 – UPS efficiency allowances for input harmonic current filtering	91
Table K.1 – Reliability integrity levels for UPS	99

UNINTERRUPTIBLE POWER SYSTEMS (UPS) –

Part 3: Method of specifying the performance and test requirements

1 Scope

This International Standard applies to movable, stationary and fixed electronic **uninterruptible power systems** (UPS) that deliver single or three-phase fixed frequency a.c. output voltage not exceeding 1 000 V a.c. and that incorporate an **energy storage system**, generally connected through a d.c. link.

This standard is intended to specify performance and test requirements of a complete UPS and not of individual **UPS functional units**. The individual UPS functional units are dealt with in IEC publications referred to in the bibliography that apply so far that they are not in contradiction with this standard.

The primary function of the UPS covered by this standard is to ensure continuity of an a.c. power source. The UPS may also serve to improve the quality of the power source by keeping it within specified characteristics. UPS have been developed over a wide range of power, from less than hundred watts to several megawatts, to meet requirements for availability and quality of power to a variety of loads. Refer to Annexes A and B for information on typical UPS configurations and topologies.

This standard also covers UPS test and performance when power switches form integral part of a UPS and are associated with its output. Included are interrupters, bypass switches, isolating switches, and tie switches. These switches interact with other functional units of the UPS to maintain **continuity of load power**.

This standard does not cover

- conventional a.c. input and output distribution boards or d.c. boards and their associated switches (e.g. switches for batteries, rectifier output or inverter input);
- stand-alone static transfer systems covered by IEC 62310-3;
- systems wherein the output voltage is derived from a rotating machine.

NOTE 1 This standard recognises that power availability to information technology (IT) equipment represents a major UPS application. The UPS output characteristics specified in this standard are therefore also aimed at ensuring compatibility with the requirements of IT equipment. This, subject any limitation stated in the manufacturer's declaration, includes requirements for steady state and transient voltage variation as well as for the supply of both linear and non-linear load characteristics of IT equipment.

NOTE 2 Test loads specified in this standard simulate both linear and non-linear load characteristics. Their use is prescribed with the objective of verifying design and performance, as declared by the manufacturer, and also of minimising any complexity and energy consumption during the tests.

NOTE 3 This standard is aimed at 50 Hz and 60 Hz applications but does not exclude other frequency applications within the domain of IEC 60196. This is subject to an agreement between manufacturer and purchase in respect to any particular requirements arising.

NOTE 4 Single phase and three-phase voltage UPS covered by this standard include without limitation UPS supplying single-phase, two-wire; single-phase, three-wire; two-phase, three-wire, three-phase, three-wire and three-phase, four-wire loads.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038, *IEC standard voltages*

IEC 60068-2-1, *Environmental testing - Part 2-1: Tests – Test A: Cold*

IEC 60068-2-2, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-27, *Environmental testing – Part 2-27: Tests – Test Ea and guidance: Shock*

IEC 60068-2-31:2008, *Environmental testing – Part 2-31: Tests – Test Ec: Rough handling shocks, primarily for equipment-type specimens*

IEC 60068-2-78, *Environmental testing – Part 2-78: Tests – Test Cab: Damp heat, steady state*

IEC 60146-1-1:2009, *Semiconductor converters – General requirements and line commutated converters – Part 1-1: Specification of basic requirements*

IEC 60146-2:1999, *Semiconductor converters – Part 2: Self-commutated semiconductor converters including direct d.c. converters*

IEC 60196, *IEC standard frequencies*

IEC 60364-1, *Low-voltage electrical installations – Part 1: Fundamental principles, assessment of general characteristics, definitions*

IEC 60364-5-52, *Low-voltage electrical installations – Part 5-52: Selection and erection of electrical equipment – Wiring systems*

IEC 60947-3, *Low-voltage switchgear and controlgear – Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units*

IEC 60947-6-1, *Low-voltage switchgear and controlgear – Part 6-1: Multiple function equipment – Transfer switching equipment*

IEC 60950-1, *Information technology equipment – Safety – Part 1: General requirements*

IEC 60990, *Methods of measurement of touch current and protective conductor current*

IEC 61000-2-2:2002, *Electromagnetic compatibility (EMC) – Part 2-2: Environment – Compatibility levels for low-frequency conducted disturbances and signalling in public low-voltage power supply systems*

IEC 61000-3-2, *Electromagnetic compatibility (EMC) – Part 3-2: Limits – Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)*

IEC/TS 61000-3-4, *Electromagnetic compatibility (EMC) – Part 3-4: Limits – Limitation of emission of harmonic currents in low-voltage power supply systems for equipment with rated current greater than 16 A*

IEC 61000-3-12, *Electromagnetic compatibility (EMC) – Part 3-12: Limits – Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current > 16 A and ≤ 75 A per phase*

IEC 61000-4-30, *Electromagnetic compatibility (EMC) – Part 4-30: Testing and measurement techniques – Power quality measurement methods*

IEC 61672-1, *Electroacoustics – Sound level meters – Part 2: Pattern evaluation tests*

IEC 62040-1:2008, *Uninterruptible power systems (UPS) – Part 1: General and safety requirements for UPS*

IEC 62040-2, *Uninterruptible power systems (UPS) – Part 2: Electromagnetic compatibility (EMC) requirements*

IEC 62310-3:2008, *Static transfer systems (STS) – Part 3: Method for specifying performance and test requirements*

ISO 7779:2010, *Acoustics – Measurement of airborne noise emitted by information technology and telecommunications equipment*