

INTERNATIONAL STANDARD

IEC
60092-376

Second edition
2003-05

Electrical installations in ships –

Part 376: Cables for control and instrumentation circuits 150/250 V (300 V)

Installations électriques à bord des navires –

*Partie 376:
Câbles pour circuits de commande et d'instrumentation
150/250 V (300 V)*

© IEC 2003 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE

S

For price, see current catalogue

CONTENTS

FOREWORD	4
1 Scope and object	5
2 Normative references	5
3 Definitions	6
4 Rated voltage	7
5 Types of insulating compounds	7
6 Types of sheathing compounds	7
7 Markings	7
7.1 Indication of origin and voltage rating	7
7.2 Continuity	8
7.3 Durability	8
7.4 Legibility	8
7.5 Core identification	8
7.6 Unit identification	9
8 General description	9
9 Conductors	10
10 Insulation system	10
10.1 Material	10
10.2 Electrical and non-electrical characteristics of the insulation system	10
10.3 Application to the conductor	11
10.4 Thickness of insulation	11
11 Cabling	11
11.1 Core assembly (multicore cables)	11
11.2 Forming pair, triple or quad units	11
11.3 Unit assembly (multiunit cables)	12
11.4 Fillers	12
11.5 Number of cores, pairs, triples or quads.	12
12 Electrostatic screen	12
12.1 Individually taped screened pair, triple or quad constructions	12
12.2 Individually braided screened pair, triple or quad constructions	12
12.3 Collectively screened constructions	13
13 Inner Coverings and binders	14
13.1 General	14
13.2 Thickness of inner covering	14
14 Sheath(s)	15
14.1 Thickness of sheath(s)	15
14.2 Colour of sheath	16
15 Metal braid armour	16
15.1 Braid wire diameter	16
15.2 Coverage density	16
15.3 Application of the braid armour	16
16 Particular tests	17
16.1 Additional compatibility test	17
16.2 Durability	17

17 Tests on completed cables	17
17.1 Routine tests	17
17.2 Special tests	18
17.3 Type tests, non-electrical	18
17.4 Type tests, electrical	18
Annex A (informative) Core identification	19
Annex B (informative) Number of cores and pair, triple or quad units	20
Table 1 – Dimension of the marks	9
Table 2 – Specified thickness of insulation	11
Table 3 – Requirements of drain wire	13
Table 4 – thickness of inner covering	14
Table 5 –Coefficient <i>cf</i>	15
Table 6 – Electrical resistance of conductors	17
Table A.1 – Typical colour code for single unit cables	19

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRICAL INSTALLATIONS IN SHIPS –**Part 376: Cables for control and instrumentation
circuits 150/250 V (300 V)**

FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60092-376 has been prepared by subcommittee 18A: Cables and cable installations, of IEC technical committee 18: Electrical installations of ships and of mobile and fixed offshore units

This second edition of IEC 60092-376 cancels and replaces the first edition published in 1983, of which it constitutes a technical revision.

The text of this standard is based on the following documents:

FDIS	Report on voting
18A/242/FDIS	18A/244/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until 2008. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

ELECTRICAL INSTALLATIONS IN SHIPS –

Part 376: Cables for control and instrumentation circuits 150/250 V (300 V)

1 Scope and object

This part of IEC 60092 is applicable to screened and unscreened cables for control and instrumentation circuits on ships and offshore units. The cables have extruded solid insulation with a voltage rating of 150/250V (300V) (see Clause 4) and are intended for fixed installations.

The various types of cables are given in Clause 8. The construction requirements and test methods are expected to comply with those indicated in IEC 60092-350, unless otherwise specified in this standard.

NOTE Provision is made for fire resistant (limited circuit integrity) cables to be specified if required.

The object of this part of IEC 60092 is

- to standardise cables whose safety and reliability are ensured when they are installed in accordance with the requirements of IEC 60092-352;
- to lay down standard manufacturing requirements and characteristics of such cables directly or indirectly bearing on safety;
- to specify test methods for checking conformity with those requirements.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60228, *Conductors of insulated cables*

IEC 60092-350:2001, *Electrical installations in ships – Part 350: Shipboard power cables – General construction and test requirements*

IEC 60092-351, *Electrical installations in ships – Part 351: Insulating materials for shipboard and mobile and fixed offshore units power, telecommunication, and control data cables*

IEC 60092-352, *Electrical installation in ships – Part 352: Choice and installation of cables for low-voltage power systems*

IEC 60092-359, *Electrical installations in ships – Part 359: Sheathing materials for shipboard power and telecommunication cables*

IEC 60331-21, *Tests for electric cables under fire conditions – Circuit integrity – Part 21: Procedures and requirements – cables of rated voltage up to and including 0,6 / 1 kV*

IEC 60332-1, *Tests on electric cables under fire conditions – Part 1: Test on a single vertical insulated wire or cable*

IEC 60332-3-22, *Tests on electric cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A*

IEC 60811 (all parts), *Common test methods for insulating and sheathing materials of electric cables*

IEC 61034-1, *Measurement of smoke density of cables burning under defined conditions – Part 1: Test apparatus*

IEC 61034-2, *Measurement of smoke density of cables burning under defined conditions – Part 2: Test procedure and requirements*

IEC 60092-353, *Electrical installations in ships – Part 353: Single and multicore non-radial field power cables with extruded solid insulation for rated voltages 1 kV and 3 kV*