



SIS - Standardiseringskommissionen i Sverige

Handläggande organ

SEK, SVENSKA ELEKTRISKA KOMMISSIONEN

SVENSKA ELEKTROTEKNISKA NORMER, SEN

SVENSK STANDARD SS-EN 50 086-2-4

Fastställt

1994-09-30

Utgåva

1

Sida

1 (1 + 12)

Ingår i

SEK Översikt 113

Registrering

Reg 424 10 34

SIS FASTSTÄLLER OCH UTGER SVENSK STANDARD SAMT SÄLJER NATIONELLA OCH INTERNATIONELLA STANDARDPUBLIKATIONER ©

Elinstallationsrör med tillbehör - Del 2-4: Kabelskyddsrör för förläggning i mark

*Conduit systems for electrical installations -
Part 2-4: Particular requirements for conduit systems
buried underground*

Som svensk standard gäller europastandarden EN 50 086-2-4: 1994. Den svenska standarden innehåller den officiella engelska språkversionen av EN 50 086-2-4: 1994.

Standarden kompletterar och modifierar motsvarande avsnitt i SS-EN 50 086-1: 1994, Elinstallationsrör med tillbehör - Del 1: Allmänna fordringar.

UDK 621.315.2:696.6

Standarder kan beställas hos SIS som även lämnar allmänna upplysningar om svensk och utländsk standard.
Postadress: SIS, Box 3295, 103 66 Stockholm
Telefon: 08 - 613 52 00. Telefax: 08 - 411 70 35

Upplysningar om **sakinnehållet** i standarden lämnas av SEK.
Telefon: 08 - 750 78 20. Telefax: 08 - 751 84 70

Prisgrupp N

Tryckt i december 1994

UDC 621.315.2:696.6

Descriptors: Electric wiring system, conduit buried underground, mechanical characteristics, electrical characteristics, test

English version

**Conduit systems for electrical installations
Part 2-4: Particular requirements for conduit systems
buried underground**

Systèmes de conduits pour installations
électriques
Partie 2-4: Règles particulières pour
les systèmes de conduits enterrés
dans le sol

Elektroinstallationsrohrsysteme für
elektrische Installationen
Teil 2-4: Besondere Anforderungen
für erdverlegte Elektroinstallations-
rohrsysteme

This European Standard was approved by CENELEC on 1993-09-22. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

This European Standard has been prepared by CENELEC Technical Committee TC 113, Cable Management Systems.

This Part 2-4 specifies particular requirements for conduit systems buried underground.

A conduit system which conforms to this standard, is deemed safe for use.

The text of this standard was submitted to the formal vote and was approved by CENELEC as EN 50086-2-4 on 1993-09-22.

The following dates were fixed.

- latest date of publication of
an identical national standard (dop) 1994-10-01
- latest date of withdrawal of
conflicting national standards (dow) 1994-10-01

For products which have complied with the relevant national standard before 1994-10-01, as shown by the manufacturer or by a certification body, this previous standard may continue to apply for production until 1999-10-01.

This Part 2-4 supplements or modifies the corresponding clauses of EN 50086-1:1993, Conduit systems for electrical installations, Part 1: General requirements.

Where a particular clause or subclause of Part 1 is not mentioned in this Part 2-4, that clause or subclause applies as far as is reasonable. Where this Part 2-4 states "addition", "modification" or "replacement", the relevant text of Part 1 is to be adapted accordingly.

Subclauses and figures which are in addition to those in Part 1 are numbered starting with 101.

Contents

Clause

- 1 Scope
- 2 Normative references
- 3 Definitions
- 4 General requirements
- 5 General conditions for test
- 6 Classification
- 7 Marking and documentation
- 8 Dimensions
- 9 Construction
- 10 Mechanical properties
- 11 Electrical properties
- 12 Thermal properties
- 13 Fire effects
- 14 External influences
- 15 Electromagnetic compatibility

Tables

- Table 101 Outside diameters - Preferred values
- Table 102 Impact test energy values

Figures

- Figure 101 Impact test apparatus
- Figure 102 Bending test apparatus

1 Scope

Replacement:

This standard specifies requirements and tests for conduit systems buried underground including conduits and conduit fittings for the protection and management of insulated conductors and/or cables in electrical installations or in communication systems. This standard applies to metallic, non-metallic and composite systems including threaded and non-threaded entries which terminate the system.

Conduit systems which are used as an integral part of other equipment shall also be tested according to the relevant specification for that equipment.