

© Copyright SEK. Reproduction in any form without permission is prohibited.

## Bränsleceller – Del 3-300: Stationära system – Installation

*Fuel cell technologies –  
Part 3-300: Stationary fuel cell power systems –  
Installation*

Som svensk standard gäller europastandarden EN 62282-3-300:2012. Den svenska standarden innehåller den officiella engelska språkversionen av EN 62282-3-300:2012.

### Nationellt förord

Europastandarden EN 62282-3-300:2012

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 62282-3-300, First edition, 2012 - Fuel cell technologies - Part 3-300: Stationary fuel cell power systems - Installation**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 62282-3-3, utgåva 1, 2008, gäller ej fr o m 2015-07-19.

---

ICS 27.070

---

Denna standard är fastställd av SEK Svensk Elstandard, som också kan lämna upplysningar om **sakinnehållet** i standarden.  
Postadress: SEK, Box 1284, 164 29 KISTA  
Telefon: 08 - 444 14 00. Telefax: 08 - 444 14 30  
E-post: sek@elstandard.se. Internet: www.elstandard.se

---

### *Standarder underlättar utvecklingen och höjer elsäkerheten*

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

### *SEK är Sveriges röst i standardiseringsarbetet inom elområdet*

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

### *Stora delar av arbetet sker internationellt*

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

### *Var med och påverka!*

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

### **SEK Svensk Elstandard**

Box 1284  
164 29 Kista  
Tel 08-444 14 00  
[www.elstandard.se](http://www.elstandard.se)

English version

**Fuel cell technologies -  
Part 3-300: Stationary fuel cell power systems -  
Installation**  
(IEC 62282-3-300:2012)

Technologies des piles à combustible -  
Partie 3-300: Systèmes à piles à  
combustible stationnaires -  
Installation  
(CEI 62282-3-300:2012)

Brennstoffzellentechnologien -  
Teil 3-300: Stationäre-Brennstoffzellen-  
Energiesysteme -  
Installation  
(IEC 62282-3-300:2012)

This European Standard was approved by CENELEC on 2012-07-19. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Management Centre: Avenue Marnix 17, B - 1000 Brussels**

## Foreword

The text of document 105/377/FDIS, future edition 1 of IEC 62282-3-300, prepared by IEC/TC 105 "Fuel cell technologies" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62282-3-300:2012.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2013-04-19
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2015-07-19

This document supersedes EN 62282-3-3:2008.

EN 62282-3-300:2012 includes the following significant technical changes with respect to EN 62282-3-3:2008:

- addition in the scope to avoid overlapping between EN 62282-3-100 and EN 62282-3-300 concerning safety related requirements;
- updating normative references and definitions;
- requirements applicable to the stationary fuel cell removed, so that the target of this standard focuses on "installation risks";
- level of CO reduced for small fuel cell power systems which exhaust directly into a utility shed where they are installed, and where the shed is to ensure safety;
- requirement for using a combustible gas detection system modified;
- reference to the gas valve standard ISO 23551-1 added.

This standard covers the Principle Elements of the Safety Objectives for Electrical Equipment Designed for Use within Certain Voltage Limits (LVD - 2006/95/EC).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

## Endorsement notice

The text of the International Standard IEC 62282-3-300:2012 was approved by CENELEC as a European Standard without any modification.

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60079-10	Series	Explosive atmospheres - Part 10: Classification of areas	EN 60079-10	Series
IEC 60079-29-1	-	Explosive atmospheres - Part 29-1: Gas detectors - Performance requirements of detectors for flammable gases	EN 60079-29-1	-
IEC 60079-29-2	-	Explosive atmospheres - Part 29-2: Gas detectors - Selection, installation, use and maintenance of detectors for flammable gases and oxygen	EN 60079-29-2	-
IEC 62282-3-100	2012	Fuel cell technologies - Part 3-100: Stationary fuel cell power systems - Safety	EN 62282-3-100	2012
ISO 1182	-	Reaction to fire tests for building products - Non-combustibility test	EN ISO 1182	-
ISO 14121	-	Safety of machinery - Principles of risk assessment	-	-
ISO 23551-1	-	Safety and control devices for gas burners and gas-burning appliances - Particular requirements - Part 1: Automatic valves	-	-

## CONTENTS

INTRODUCTION.....	6
1 Scope.....	7
2 Normative references .....	8
3 Terms and definitions .....	9
4 General safety requirements and strategy .....	10
5 Siting considerations .....	11
5.1 General siting.....	11
5.2 Outdoor installations .....	12
5.2.1 Air intakes and vents .....	12
5.2.2 Air intakes and exhaust .....	12
5.2.3 Exhaust outlets.....	12
5.2.4 Area around outlets .....	12
5.2.5 Enclosures .....	12
5.3 Indoor installations .....	12
5.3.1 General .....	12
5.3.2 Small fuel cell power systems.....	13
5.4 Rooftop installation.....	13
6 Ventilation and exhaust .....	13
6.1 General .....	13
6.2 Ventilation .....	13
6.3 Exhaust system .....	13
6.3.1 General .....	13
6.3.2 Small fuel cell systems .....	13
6.4 Purging and venting processes.....	13
7 Fire protection and gas detection.....	14
7.1 Fire protection and detection .....	14
7.1.1 Site fire protection .....	14
7.1.2 Combustible gas detection (indoor installations only).....	14
7.2 Fire prevention and emergency planning .....	14
8 Interconnections with site interfaces .....	15
8.1 General.....	15
8.2 Connections to fuel supplies – General .....	15
8.3 Fuel shut-off and piping.....	15
8.4 Connections to auxiliary media supply and media disposal .....	15
8.4.1 General .....	15
8.4.2 Combustible auxiliary gases .....	15
8.4.3 Non-combustible or inert auxiliary gases .....	15
8.4.4 Water .....	15
8.4.5 Waste water and condensate disposal .....	16
8.4.6 Discharge pipe .....	16
9 Environmental requirements .....	16
10 Approval tests .....	16
10.1 Gas leakage .....	16

10.2	Site specific shut-down devices .....	16
11	Maintenance tests .....	16
12	Documentation .....	17
12.1	Markings and instructions .....	17
12.2	Inspection checklist .....	17
12.3	Installation manual .....	17
12.4	User's information manual .....	17
12.5	Maintenance manual .....	17
Figure 1 – Fuel cell power system.....		8

## INTRODUCTION

This International Standard covers the installation of stationary fuel cell power systems that are built in compliance with IEC 62282-3-100.

The requirements of this standard are not intended to constrain innovation. Installations employing materials and/or methods differing from those detailed in this standard may be examined and tested according to the intent of the requirements and, if found to be substantially equivalent, may be considered to comply with the standard.

## FUEL CELL TECHNOLOGIES –

### Part 3-300: Stationary fuel cell power systems – Installation

#### 1 Scope

This part of IEC 62282 provides minimum safety requirements for the installation of indoor and outdoor stationary fuel cell power systems in compliance with IEC 62282-3-100 and applies to the installation of the following systems:

- intended for electrical connection to mains directly or with a readily accessible, manually operable switch or circuit-breaker;
- intended for a stand-alone power distribution system;
- intended to provide AC or DC power;
- with or without the ability to recover useful heat.


This standard is limited to those conditions that may be created by the installation process that can lead to personnel hazards or damage to equipment or property external to the fuel cell power system.

This standard does not cover the safety requirements of the stationary fuel cell power system which are covered by IEC 62282-3-100.

Additionally, this standard does not cover:

- fuel supply and/or fuel storage systems;
- auxiliary media supply and disposal;
- switches or circuit-breakers;
- portable fuel cell power systems;
- propulsion fuel cell power systems;
- APU (auxiliary power units) applications.

A typical stationary fuel cell power system installation is represented in Figure 1.



IEC 105/12

**Key**

EMD electromagnetic disturbance  
EMI electromagnetic interference

**Figure 1 – Fuel cell power system**

Fuel cell power systems are divided into two categories:

- small systems;
- large systems.

Terms and definitions are given in Clause 3.

**2 Normative references**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079-10 (all parts), *Explosive atmospheres – Part 10: Classification of areas*

IEC 60079-29-1, *Explosive atmospheres – Part 29-1: Gas detectors – Performance requirements of detectors for flammable gases*

IEC 60079-29-2, *Explosive atmospheres – Part 29-2: Gas detectors – Selection, installation, use and maintenance of detectors for flammable gases and oxygen*

IEC 62282-3-100:2012, *Fuel cell technologies – Part 3-100: Stationary fuel cell power systems – Safety*

ISO 1182, *Reaction to fire tests for building and transport products – Non-combustibility test*

ISO 14121, *Safety of machinery – Risk assessment*

ISO 23551-1, *Safety and control devices for gas burners and gas-burning appliances – Particular requirements – Part 1: Automatic valves*