

© Copyright SEK. Reproduction in any form without permission is prohibited.

## **Funktionsblock – Del 1: Arkitektur**

*Function blocks –  
Part 1: Architecture*

Som svensk standard gäller europastandarden EN 61499-1:2013. Den svenska standarden innehåller den officiella engelska språkversionen av EN 61499-1:2013.

### **Nationellt förord**

Europastandarden EN 61499-1:2013

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 61499-1, Second edition, 2012 - Function blocks - Part 1: Architecture**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 61499-1, utgåva 1, 2005, gäller ej fr o m 2015-12-12.

---

ICS 25.040; 35.240.50

## *Standarder underlättar utvecklingen och höjer elsäkerheten*

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

## *SEK är Sveriges röst i standardiseringssarbetet inom elområdet*

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

## *Stora delar av arbetet sker internationellt*

Utdriften av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringssarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringssverksamhet och medlemsavgift till IEC och CENELEC.

## *Var med och påverka!*

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtidens standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

### **SEK Svensk Elstandard**

Box 1284  
164 29 Kista  
Tel 08-444 14 00  
[www.elstandard.se](http://www.elstandard.se)

English version

**Function blocks -  
Part 1: Architecture  
(IEC 61499-1:2012)**

Blocs fonctionnels -  
Partie 1: Architecture  
(CEI 61499-1:2012)

Funktionsbausteine für industrielle  
Leitsysteme -  
Teil 1: Architektur  
(IEC 61499-1:2012)

This European Standard was approved by CENELEC on 2012-12-12. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Management Centre: Avenue Marnix 17, B - 1000 Brussels**

## Foreword

The text of document 65B/845/FDIS, future edition 2 of IEC 61499-1, prepared by SC 65B "Measurement and control devices" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61499-1:2013.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2013-09-12
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2015-12-12

This document supersedes EN 61499-1:2005.

EN 61499-1:2013 includes the following significant technical changes with respect to EN 61499-1:2005:

- *Execution control* in basic function blocks (5.2) has been clarified and extended:
  - dynamic and static parts of the EC transition condition are clearly delineated by using the `ec_transition_event[guard_condition]` syntax of the Unified Modeling Language (UML) (5.2.1.3, B.2.1);
  - the terminology "crossing of an EC transition" (3.10) is used preferentially to "clearing" to avoid the misinterpretation that the entire transition condition corresponds to a Boolean variable that can be "cleared.:";
  - operation of the ECC state machine in 5.2.2.2 has been clarified and made more rigorous;
  - event and data outputs of adapter instances (plugs and sockets) can be used in EC transition conditions, and event inputs of adapter instances can be used as EC action outputs.
- *Temporary variables* (3.97) can be declared (B.2.1) and used in algorithms of basic function blocks.
- *Service sequences* (6.1.3) can now be defined for basic and composite function block types and adapter types, as well as service interface types.
- *The syntax for mapping* of FB instances from applications to resources has been simplified (Clause B.3).
- Syntax for definition of *segment types* (7.2.3) for network segments of system configurations has been added (Clause B.3).
- Function block types for interoperation with programmable controllers are defined (Clause D.6).
- The READ/WRITE management commands (Table 8) now apply only to *parameters*.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

### **Endorsement notice**

The text of the International Standard IEC 61499-1:2012 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61131-5:2000	NOTE	Harmonised as EN 61131-5:2001 (not modified).
IEC 61499 Series	NOTE	Harmonised as EN 61499 Series (not modified).
IEC 61499-2:2012	NOTE	Harmonised as EN 61499-2:2013 (not modified).
IEC 61499-4	NOTE	Harmonised as EN 61499-4.

**Annex ZA**  
(normative)**Normative references to international publications  
with their corresponding European publications**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61131-1	-	Programmable controllers - Part 1: General information	EN 61131-1	-
IEC 61131-3	2003	Programmable controllers - Part 3: Programming languages	EN 61131-3	2003
ISO/IEC 7498-1	1994	Information technology - Open Systems Interconnection - Basic Reference Model: The Basic Model	-	-
ISO/IEC 8824-1	2008	Information technology - Abstract Syntax Notation One (ASN.1): Specification of basic notation	-	-
ISO/IEC 10646	2003	Information technology - Universal multiple-octet coded character set (UCS)	-	-

## CONTENTS

INTRODUCTION.....	7
1 Scope.....	8
2 Normative references .....	8
3 Terms and definitions .....	9
4 Reference models .....	18
4.1 System model.....	18
4.2 Device model .....	19
4.3 Resource model .....	19
4.4 Application model.....	21
4.5 Function block model.....	21
4.5.1 Characteristics of function block instances .....	21
4.5.2 Function block type specifications .....	23
4.5.3 Execution model for basic function blocks .....	23
4.6 Distribution model .....	25
4.7 Management model .....	25
4.8 Operational state models.....	27
5 Specification of function block, subapplication and adapter interface types.....	27
5.1 Overview .....	27
5.2 Basic function blocks.....	28
5.2.1 Type declaration .....	28
5.2.2 Behavior of instances .....	30
5.3 Composite function blocks.....	33
5.3.1 Type specification.....	33
5.3.2 Behavior of instances .....	35
5.4 Subapplications .....	36
5.4.1 Type specification.....	36
5.4.2 Behavior of instances .....	37
5.5 Adapter interfaces .....	38
5.5.1 General principles .....	38
5.5.2 Type specification.....	38
5.5.3 Usage.....	39
5.6 Exception and fault handling.....	41
6 Service interface function blocks .....	41
6.1 General principles .....	41
6.1.1 General .....	41
6.1.2 Type specification.....	42
6.1.3 Behavior of instances .....	43
6.2 Communication function blocks .....	45
6.2.1 Type specification.....	45
6.2.2 Behavior of instances .....	46
6.3 Management function blocks .....	47
6.3.1 Requirements .....	47
6.3.2 Type specification.....	47
6.3.3 Behavior of managed function blocks.....	50
7 Configuration of functional units and systems .....	52

7.1	Principles of configuration .....	52
7.2	Functional specification of resource, device and segment types .....	52
7.2.1	Functional specification of resource types .....	52
7.2.2	Functional specification of device types .....	53
7.2.3	Functional specification of segment types .....	53
7.3	Configuration requirements .....	53
7.3.1	Configuration of systems .....	53
7.3.2	Specification of applications .....	54
7.3.3	Configuration of devices and resources .....	54
7.3.4	Configuration of network segments and links .....	55
Annex A (normative)	Event function blocks .....	56
Annex B (normative)	Textual syntax .....	63
Annex C (informative)	Object models .....	74
Annex D (informative)	Relationship to IEC 61131-3 .....	82
Annex E (informative)	Information exchange .....	92
Annex F (normative)	Textual specifications .....	100
Annex G (informative)	Attributes .....	113
Bibliography .....	117	
Figure 1 – System model .....	18	
Figure 2 – Device model .....	19	
Figure 3 – Resource model .....	20	
Figure 4 – Application model .....	21	
Figure 5 – Characteristics of function blocks .....	22	
Figure 6 – Execution model .....	24	
Figure 7 – Execution timing .....	24	
Figure 8 – Distribution and management models .....	26	
Figure 9 – Function block and subapplication types .....	28	
Figure 10 – Basic function block type declaration .....	29	
Figure 11 – ECC example .....	30	
Figure 12 – ECC operation state machine .....	32	
Figure 13 – Composite function block PI_REAL example .....	34	
Figure 14 – Basic function block PID_CALC example .....	35	
Figure 15 – Subapplication PI_REAL_APPL example .....	37	
Figure 16 – Adapter interfaces – Conceptual model .....	38	
Figure 17 – Adapter type declaration – graphical example .....	39	
Figure 18 – Illustration of provider and acceptor function block type declarations .....	40	
Figure 19 – Illustration of adapter connections .....	41	
Figure 20 – Example service interface function blocks .....	43	
Figure 21 – Example service sequence diagrams .....	44	
Figure 22 – Generic management function block type .....	47	
Figure 23 – Service primitive sequences for unsuccessful service .....	48	
Figure 24 – Operational state machine of a managed function block .....	51	
Figure A.1 – Event split and merge .....	62	

Figure C.1 – ESS overview .....	74
Figure C.2 – Library elements .....	75
Figure C.3 – Declarations .....	76
Figure C.4 – Function block network declarations .....	77
Figure C.5 – Function block type declarations .....	79
Figure C.6 – IPMCS overview .....	79
Figure C.7 – Function block types and instances .....	81
Figure D.1 – Example of a “simple” function block type .....	82
Figure D.2 – Function block type READ .....	85
Figure D.3 – Function block type UREAD .....	87
Figure D.4 – Function block type WRITE .....	88
Figure D.5 – Function block type TASK .....	90
Figure E.1 – Type specifications for unidirectional transactions .....	93
Figure E.2 – Connection establishment for unidirectional transactions .....	93
Figure E.3 – Normal unidirectional data transfer .....	93
Figure E.4 – Connection release in unidirectional data transfer .....	94
Figure E.5 – Type specifications for bidirectional transactions .....	94
Figure E.6 – Connection establishment for bidirectional transaction .....	95
Figure E.7 – Bidirectional data transfer .....	95
Figure E.8 – Connection release in bidirectional data transfer .....	95
 Table 1 – States and transitions of ECC operation state machine .....	32
Table 2 – Standard inputs and outputs for service interface function blocks .....	42
Table 3 – Service primitive semantics .....	45
Table 4 – Variable semantics for communication function blocks .....	46
Table 5 – Service primitive semantics for communication function blocks .....	46
Table 6 – CMD input values and semantics .....	48
Table 7 – STATUS output values and semantics .....	48
Table 8 – Command syntax .....	49
Table 9 – Semantics of actions in Figure 24 .....	52
Table A.1 – Event function blocks .....	57
Table C.1 – ESS class descriptions .....	75
Table C.2 – Syntactic productions for library elements .....	75
Table C.3 – Syntactic productions for declarations .....	77
Table C.4 – IPMCS classes .....	80
Table D.1 – Semantics of STATUS values .....	83
Table D.2 – Source code of function block type READ .....	86
Table D.3 – Source code of function block type UREAD .....	87
Table D.4 – Source code of function block type WRITE .....	89
Table D.5 – Source code of function block type TASK .....	90
Table D.6 – IEC 61499 interoperability features .....	91
Table E.1 – COMPACT encoding of fixed length data types .....	99
Table G.1 – Elements of attribute definitions .....	114

## INTRODUCTION

IEC 61499 consists of the following parts, under the general title *Function blocks*:

- Part 1 (this document) contains:
  - general requirements, including scope, normative references, definitions, and reference models;
  - rules for the declaration of *function block types*, and rules for the behavior of *instances* of the types so declared;
  - rules for the use of function blocks in the *configuration* of distributed industrial-process measurement and control systems (IPMCSs);
  - rules for the use of function blocks in meeting the communication requirements of distributed IPMCSs;
  - rules for the use of function blocks in the management of *applications, resources and devices* in distributed IPMCSs.
- Part 2 defines requirements for *software tools* to support the following systems engineering tasks:
  - the specification of *function block types*;
  - the functional specification of *resource types* and *device types*;
  - the specification, analysis, and validation of distributed IPMCSs;
  - the *configuration, implementation, operation, and maintenance* of distributed IPMCSs;
  - the exchange of *information* among *software tools*.
- Part 3 (Tutorial information) has been withdrawn due to the widespread current availability of tutorial and educational materials regarding IEC 61499. However, an updated 2<sup>nd</sup> Edition of Part 3 may be developed in the future.
- Part 4 defines rules for the development of *compliance profiles* which specify the features of IEC 61499-1 and IEC 61499-2 to be implemented in order to promote the following attributes of IEC 61499-based systems, devices and software tools:
  - interoperability of devices from multiple suppliers;
  - portability of software between software tools of multiple suppliers; and
  - configurability of devices from multiple vendors by software tools of multiple suppliers.

## FUNCTION BLOCKS –

### Part 1: Architecture

#### 1 Scope

This part of IEC 61499 defines a generic architecture and presents guidelines for the use of *function blocks* in distributed industrial-process measurement and control systems (IPMCSSs). This architecture is presented in terms of implementable reference *models*, textual syntax and graphical representations. These models, representations and syntax **can be used for**:

- the specification and standardization of *function block types*;
- the functional specification and standardization of system elements;
- the implementation independent specification, analysis, and validation of distributed IPMCSSs;
- the *configuration, implementation, operation, and maintenance* of distributed IPMCSSs;
- the exchange of *information* among *software tools* for the performance of the above *functions*.

This part of IEC 61499 does not restrict or specify the functional capabilities of IPMCSSs or their system elements, except as such capabilities are represented using the elements defined herein. IEC 61499-4 addresses the extent to which the elements defined in this standard may be restricted by the functional capabilities of compliant systems, subsystems, and devices.

Part of the purpose of this standard is to provide reference models for the use of function blocks in other standards dealing with the support of the system life cycle, including system planning, design, implementation, validation, operation and maintenance. The models given in this standard are intended to be generic, domain independent and extensible to the definition and use of function blocks in other standards or for particular applications or application domains. It is intended that specifications written according to the rules given in this standard be concise, implementable, complete, unambiguous, and consistent.

NOTE 1 The provisions of this standard alone are not sufficient to ensure interoperability among devices of different vendors. Standards complying with this part of IEC 61499 can specify additional provisions to ensure such interoperability.

NOTE 2 Standards complying with this part of IEC 61499 can specify additional provisions to enable the performance of *system, device, resource and application management functions*.

#### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61131-1, *Programmable controllers – Part 1: General*

IEC 61131-3:2003, *Programmable controllers – Part 3: Programming languages*

IEC/ISO 7498-1:1994, *Information technology – Open systems interconnection – Basic reference model: The basic model*

ISO/IEC 8824-1:2008, *Information technology – Abstract Syntax Notation One (ASN.1): Specification of basic notation*

ISO/IEC 10646:2003, *Information technology – Universal Multiple-Octet Coded Character Set (UCS)*