

© Copyright SEK. Reproduction in any form without permission is prohibited.

Communication networks and systems for power utility automation – Part 1: Introduction and overview

(IEC/TR 61850-1:2013)

Den internationella standarden IEC 61850 behandlar system för kraftföretagsautomation och spelar en central roll för arbetet med så kallade smarta elnät. Denna tekniska rapport ger en inledande beskrivning av IEC 61850, dess syfte, grundläggande principer och uppbyggnad. Den ger också en överblick innehållet i standardens olika delar. De flesta av dem har också fastställts som europeisk standard och som svensk standard, SS-EN.

ISSN 1651-1417

ICS 33.200.00

Upplysningar om **sakinnehållet** i rapporten lämnas av
SEK Svensk Elstandard.

Postadress: SEK, Box 1284, 164 29 KISTA

Telefon: 08 - 444 14 00. Telefax: 08 - 444 14 30

E-post: sek@elstandard.se. Internet: www.elstandard.se

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

CONTENTS

INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms, definitions and abbreviations	9
3.1 Terms and definitions	9
3.2 Abbreviated terms	11
4 Objectives	12
5 Approach of the IEC 61850 standard	13
5.1 Scope of application.....	13
5.2 IEC 61850 within the IEC Power Utility control system reference architecture	14
5.3 IEC 61850 within Smart Grid reference architecture	15
5.4 Standardization approach.....	15
5.5 How to cope with fast innovation of communication technology	16
5.6 Representation of functions and communication interfaces.....	16
5.7 Requirements for a physical communication system	20
6 Content of the IEC 61850 series	20
6.1 IEC 61850 general requirements (parts 1 to 5)	20
6.2 Three pillars of interoperability and conformance testing (Part 6 and above)	21
6.3 Understanding the structure of the IEC 61850 documentation	22
6.4 IEC 61850 data modelling	24
6.4.1 Main principle (explained in IEC 61850-7-1)	24
6.4.2 Standard name space introduction.....	25
6.4.3 Name space extension	26
6.5 IEC 61850 communication services	26
6.6 IEC 61850 SCL language	28
6.7 IEC 61850 data and communication security	29
6.8 IEC 61850 conformance testing.....	29
6.9 UCA/IEC 61850 international users group	30
6.10 IEC 61850 maintenance	30
6.11 Quality assurance process	30
7 IEC 61850 system life cycle.....	31
7.1 Reason for inclusion.....	31
7.2 Engineering-tools and parameters	31
7.3 Main tools and configuration data flows	32
7.4 Quality and life-cycle management.....	32
7.5 General requirements.....	32
Figure 1 – Scope of application of IEC 61850	14
Figure 2 – Power utility control system reference architecture (IEC 62357).....	15
Figure 3 – IEC 61850 specifying approach.....	16
Figure 4 – Interface model within substation and between substations.....	17
Figure 5 – Relationship between functions, logical nodes, and physical nodes (examples).....	19
Figure 6 – Links between IEC 61850 parts	22

Figure 7 – IEC 61850 Data modelling.....	24
Figure 8 – Basic reference model.....	28
Figure 9 – Exchange of system parameters	31

INTRODUCTION

IEC 61850 consists of the following parts, under the general title *Communication networks and systems for power utility automation* (all parts may have not been published yet).

- Part 1: Introduction and overview
- Part 2: Glossary
- Part 3: General requirements
- Part 4: System and project management
- Part 5: Communication requirements for functions and device models
- Part 6: Configuration description language for communication in electrical substations related to IEDs
- Part 7-1: Basic communication structure – Principles and models
- Part 7-2: Basic communication structure – Abstract communication service interface (ACSI)
- Part 7-3: Basic communication structure – Common data classes
- Part 7-4: Basic communication structure – Compatible logical node classes and data classes
- Part 7-410: Hydroelectric power plants – Communication for monitoring and control
- Part 7-420: Basic communication structure – Distributed energy resources logical nodes
- Part 7-5: IEC 61850 – Modelling concepts¹
- Part 7-500: Use of logical nodes to model functions of a substation automation system¹
- Part 7-510: Use of logical nodes to model functions of a hydro power plant
- Part 7-520: Use of logical nodes to model functions of distributed energy resources¹
- Part 8-1: Specific communication service mapping (SCSM) – Mappings to MMS (ISO 9506-1 and ISO 9506-2) and to ISO/IEC 8802-3
- Part 80-1: Guideline to exchange information from a CDC based data model using IEC 60870-5-101/104
- Part 9-2: Specific communication service mapping (SCSM) – Sampled values over ISO/IEC 8802-3
- Part 90-1: Use of IEC 61850 for the communication between substations
- Part 90-2: Using IEC 61850 for the communication between substations and control centres¹
- Part 90-3: Using IEC 61850 for condition monitoring¹
- Part 90-4: Network Engineering Guidelines - Technical report¹
- Part 90-5: Using IEC 61850 to transmit synchrophasor information according to IEEE C37.118
- Part 10: Conformance testing

In addition to the above parts IEC technical committee 88 has published the IEC 61850 basic communication structure for Wind Turbines as IEC 61400-25, *Wind turbines – Communications for monitoring and control of wind power plants*.

IEC 61850-1 is an introduction and overview of the IEC 61850 standard series. It describes the philosophy, work approach and contents of the other parts.

¹ Under consideration.

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 1: Introduction and overview

1 Scope

This technical report is applicable to *power utility automation systems* (PUAS). It defines the communication between intelligent electronic devices (IEDs) in such a system, and the related system requirements.

This part gives an introduction and overview of the IEC 61850 standard series. It refers to and might include text and figures coming from other parts of the IEC 61850 standard series.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60870-5-103, *Telecontrol equipment and systems – Part 5-103: Transmission Protocols - Companion standard for the informative interface of protection equipment*

IEC 60870-5-104, *Telecontrol equipment and systems – Part 5-104: Transmission protocols – Network access for IEC 60870-5-101 using standard transport profiles*

IEC 61400-25 (all parts), *Communications for monitoring and control of wind power plants*

IEC 61850-2, *Communication networks and systems in substations – Part 2: Glossary*

IEC 61850-3, *Communication networks and systems in substations – Part 3: General requirements*

IEC 61850-4, *Communication networks and systems for power utility automation – Part 4: System and project management*

IEC 61850-5, *Communication networks and systems in substations – Part 5: Communication requirements for functions and device models*

IEC 61850-6, *Communication networks and systems for power utility automation – Part 6: Configuration description language for communication in electrical substations related to IEDs*

IEC 61850-7-1, *Communication networks and systems for power utility automation – Part 7-1: Basic communication structure – Principles and models*

IEC 61850-7-2, *Communication networks and systems for power utility automation – Part 7-2: Basic information and communication structure – Abstract communication service interface (ACSI)*

IEC 61850-7-3, *Communication networks and systems for power utility automation – Part 7-3: Basic communication structure – Common data classes*

IEC 61850-7-4, *Communication networks and systems for power utility automation – Part 7-4: Basic communication structure – Compatible logical node classes and data object classes*

IEC 61850-7-410, *Communication networks and systems for power utility automation – Part 7-410: Hydroelectric power plants – Communication for monitoring and control*

IEC 61850-7-420, *Communication networks and systems for power utility automation – Part 7-420: Basic communication structure – Distributed energy resources logical nodes*

IEC 61850-7-510, *Communication networks and systems for power utility automation – Part 7-510: Basic communication structure – Hydroelectric power plants – Modelling concepts and guidelines*

IEC 61850-8-1, *Communication networks and systems for power utility automation – Part 8-1: Specific communication service mapping (SCSM) – Mappings to MMS (ISO 9506-1 and ISO 9506-2) and to ISO/IEC 8802-3*

IEC 61850-80-1, *Communication networks and systems for power utility automation – Part 80-1: Guideline to exchanging information from a CDC-based data model using IEC 60870-5-101 or IEC 60870-5-104*

IEC 61850-9-2, *Communication networks and systems for power utility automation – Part 9-2: Specific communication service mapping (SCSM) – Sampled values over ISO/IEC 8802-3*

IEC/TR 61850-90-1, *Communication networks and systems for power utility automation – Part 90-1: Use of IEC 61850 for the communication between substations*

IEC 61850-10, *Communication networks and systems in substations – Part 10: Conformance testing*

IEC 62351 (all parts), *Power systems management and associated information exchange – Data and communications security*

IEC/TR 62357-1, *Power systems management and associated information exchange – Part 1: Reference architecture*

IEC 81346-1, *Industrial systems, installations and equipment and industrial products – Structuring principles and reference designations – Part 1: Basic rules*

ISO 9001:2008, *Quality management systems – Requirements*

IEEE C37.2, *IEEE standard electrical power system device function numbers, acronyms and contact designations*

IEEE 100:2000, *The authoritative dictionary of IEEE standards terms seventh edition*

IEEE-SA TR 1550, *Utility Communications Architecture (UCA) Version 2.0 – Part 4: UCA Generic Object Models for Substation and Feeder Equipment (GOMSFE)*

RFC 2246, *The TLS Protocol, Version 1.0*