

© Copyright SEK. Reproduction in any form without permission is prohibited.

Industriell processtyrning – Del 2: Metoder för utvärdering av prestanda hos intelligenta ventillägesställare med pneumatisk utgång, monterade på ventilens ställdon

*Industrial process control systems –
Part 2: Methods of evaluating the performance of intelligent valve
positioners with pneumatic outputs mounted on an actuator valve assembly*

Som svensk standard gäller europastandarden EN 61514-2:2013. Den svenska standarden innehåller den officiella engelska språkversionen av EN 61514-2:2013.

Nationellt förord

Europastandarden EN 61514-2:2013

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 61514-2, Second edition, 2013 - Industrial process control systems - Part 2: Methods of evaluating the performance of intelligent valve positioners with pneumatic outputs mounted on an actuator valve assembly**

utarbetad inom International Electrotechnical Commission, IEC.

Standarden ska användas tillsammans med SS-EN 61514, utgåva 1, 2002.

Tidigare fastställd svensk standard SS-EN 61514-2, utgåva 1, 2007, gäller ej fr o m 2016-08-01.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English version

**Industrial process control systems -
Part 2: Methods of evaluating the performance of intelligent valve
positioners with pneumatic outputs mounted on an actuator valve
assembly
(IEC 61514-2:2013)**

Systèmes de commande des processus
industriels -
Partie 2: Méthodes d'évaluation des
performances des positionneurs de vanne
intelligents à sorties pneumatiques
montés sur un ensemble
actionneur/vanne
(CEI 61514-2:2013)

Systeme der industriellen
Prozessleittechnik – Teil 2: Verfahren zur
Bewertung des Betriebsverhaltens von
intelligenten Ventilstellungsreglern mit
pneumatischem Ausgang, die an Ventil-
Stellantrieben montiert sind
(IEC 61514-2:2013)

This European Standard was approved by CENELEC on 2013-08-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 65B/868/FDIS, future edition 2 of IEC 61514-2, prepared by SC 65B, "Devices & process analysis", of IEC TC 65, "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61514-2:2013.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2014-05-01
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2016-08-01

This document supersedes EN 61514-2:2004.

EN 61514-2:2013 includes the following significant technical changes with respect to EN 61514-2:2004:

- The standard has been optimized for usability.
- The test procedures have been reviewed regarding applicability for use in test facilities. Impractical test procedures were removed or modified.

EN 61514-2:2013 is to be used in conjunction with EN 61514:2002.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 61514-2:2013 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050	Series	International Electrotechnical Vocabulary (IEV)	-	-
IEC 60068-2-1	1990	Environmental testing - Part 2: Tests - Tests A: Cold	EN 60068-2-1 ¹⁾	1993
IEC 60068-2-2	1974	Environmental testing - Part 2: Tests - Tests B: Dry heat	EN 60068-2-2 ^{2) 3)}	1993
IEC 60068-2-6	1995	Environmental testing - Part 2: Tests - Test Fc: Vibration (sinusoidal)	EN 60068-2-6 ⁴⁾	1995
IEC 60068-2-31	1969	Environmental testing. Part 2: Tests. Test Ec: Drop and topple, primarily for equipment-type specimens	EN 60068-2-31 ^{5) 6)}	1993
IEC 60068-2-78	2001	Environmental testing - Part 2-78: Tests - Test Cab: Damp heat, steady state	EN 60068-2-78 ⁷⁾	2001
EN 60079	Series	Electrical apparatus for explosive gas atmospheres	-	-
IEC 60529	1989	Degrees of protection provided by enclosures (IP Code)	EN 60529 + corr. May	1991 1993
IEC 60534-1	-	Industrial-process control valves - Part 1: Control valve terminology and general considerations	EN 60534-1	-
IEC 60654	Series	Industrial-process measurement and control equipment - Operating conditions	EN 60654	Series
IEC 60721-3	-	Classification of environmental conditions - Part 3: Classification of groups of environmental parameters and their severities	EN 60721-3	-
IEC 61000-4-11	-	Electromagnetic compatibility (EMC) - Part 4-11: Testing and measurement techniques - Voltage dips, short interruptions and voltage variations immunity tests	EN 61000-4-11	-

¹⁾ EN 60068-2-1 is superseded by EN 60068-2-1:2007, which is based on IEC 60068-2-1:2007.

²⁾ EN 60068-2-2 includes supplement(s) A to IEC 60068-2-2.

³⁾ EN 60068-2-2 is superseded by EN 60068-2-2:2007, which is based on IEC 60068-2-2:2007.

⁴⁾ EN 60068-2-6 is superseded by EN 60068-2-6:2008, which is based on IEC 60068-2-6:2007.

⁵⁾ EN 60068-2-31 includes A1 to IEC 60068-2-31.

⁶⁾ EN 60068-2-31 is superseded by EN 60068-2-31:2008, which is based on IEC 60068-2-31:2008.

⁷⁾ EN 60068-2-78 is superseded by EN 60068-2-78:2013, which is based on IEC 60068-2-78:2012.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61010-1	2001	Safety requirements for electrical equipment	EN 61010-1	2001
+ corr. May	2001	for measurement, control, and laboratory use -	+ corr. June ⁹⁾	2002
+ corr. April	2003	Part 1: General requirements		
IEC 61032	1997	Protection of persons and equipment by	EN 61032	1998
+ corr. January	2003	enclosures - Probes for verification		
EN 61069	Series	Industrial-process measurement and control -	-	-
		Evaluation of system properties for the		
		purpose of system assessment		
IEC 61158	Series	Industrial communication networks - Fieldbus	EN 61158	Series
		specifications		
IEC 61298	Series	Process measurement and control devices -	EN 61298	Series
		General methods and procedures for		
		evaluating performance		
IEC 61298-1	2008	Process measurement and control devices -	EN 61298-1	2008
		General methods and procedures for		
		evaluating performance -		
		Part 1: General considerations		
IEC 61298-2	2008	Process measurement and control devices -	EN 61298-2	2008
		General methods and procedures for		
		evaluating performance -		
		Part 2: Tests under reference conditions		
IEC 61298-3	2008	Process measurement and control devices -	EN 61298-3	2008
		General methods and procedures for		
		evaluating performance -		
		Part 3: Tests for the effects of influence		
		quantities		
IEC 61298-4	2008	Process measurement and control devices -	EN 61298-4	2008
		General methods and procedures for		
		evaluating performance -		
		Part 4: Evaluation report content		
IEC 61326-1	2005	Electrical equipment for measurement, control	EN 61326-1 ¹¹⁾	2006
+ corr. February	2010	and laboratory use - EMC requirements -		
+ corr. February	2008	Part 1: General requirements		
IEC/PAS 61499	Series	Function blocks for industrial-process	-	-
		measurement and control systems		
IEC 61514 (mod)	2000	Industrial-process control systems - Methods	EN 61514	2002
		of evaluating the performance of valve		
		positioners with pneumatic outputs		
IEC/TS 62098	-	Evaluation methods for microprocessor-based -		-
		instruments		
CISPR 11	-	Industrial, scientific and medical equipment -	EN 55011	-
		Radio-frequency disturbance characteristics -		
		Limits and methods of measurement		

⁹⁾ EN 61010-1 is superseded by EN 61010-1:2010, which is based on IEC 61010-1:2010.

¹¹⁾ EN 61326-1 is superseded by EN 61326-1:2013, which is based on IEC 61326-1:2012.

CONTENTS

INTRODUCTION	6
1 Scope	7
2 Normative references	7
3 Terms and definitions	9
4 Design review	10
4.1 General	10
4.2 Positioner identification	11
4.2.1 Overview	11
4.2.2 Power supply unit	11
4.2.3 Sensor/input assembly	11
4.2.4 Auxiliary sensor assembly	11
4.2.5 Human interface	12
4.2.6 Communication interface	12
4.2.7 Data processing unit	12
4.2.8 Output subsystem	12
4.2.9 External functionality	13
4.3 Aspects of functionality and capabilities to be reviewed	13
4.3.1 Checklist	13
4.3.2 Reporting	19
4.4 Documentary information	19
5 Performance testing	21
5.1 General	21
5.2 Reference conditions for performance tests	21
5.2.1 Overview	21
5.2.2 Valve characteristics	21
5.3 General testing procedures	23
5.3.1 Test set-up	23
5.3.2 Testing precautions	24
5.4 Initial observations and measurements	24
5.4.1 Overview	24
5.4.2 Mounting procedure	24
5.4.3 Configuration procedures	24
5.4.4 Stem position calibration procedure	25
5.4.5 Stem position tuning procedure	25
5.5 Performance test procedures	26
5.5.1 General	26
5.5.2 Effects of influence quantities	29
6 Other considerations	35
6.1 Safety	35
6.2 Degree of protection provided by enclosures	35
6.3 Electromagnetic emission	35
6.4 Variants	35
7 Evaluation report	35
Annex A (normative) Vibration test set-up	37
Bibliography	38

Figure 1 – Positioner model in extensive configuration	11
Figure 2 – Basic design for positioners with analogue outputs	13
Figure 3 – Basic design for positioners with pulsed output	13
Figure 4 – Basic test set-up	24
Figure 5 – Examples of step responses of positioners	28
Figure A.1 – Test set-up for vibration test	37
Table 1 – Functionality (1 of 2)	14
Table 2 – Configurability	16
Table 3 – Hardware configuration	17
Table 4 – Operability	17
Table 5 – Dependability (1 of 2)	18
Table 6 – Fail safe behaviour	19
Table 7 – Reporting	19
Table 8 – Document information	20
Table 9 – Test under reference conditions (1 of 3)	26
Table 10 – Matrix of instrument properties and tests (1 of 6)	30

INTRODUCTION

New instruments for process control and measurement including valve positioners are mainly equipped with microprocessors, thereby utilising digital data processing and communication methods and/or artificial intelligence, making them more complex and giving them a considerable added value.

Modern intelligent valve positioners are no longer only controlling the valve position, but they are in many cases also equipped with various facilities for self-testing, actuator/valve condition monitoring and alarming. The variety of added functionalities is large. They can no longer be compared with the single function "cam-type" positioners. Therefore, accuracy related performance testing, although still very important, is no longer sufficient to demonstrate their flexibility, capabilities and other features with respect to engineering, installation, maintainability, reliability and operability.

In this standard the evaluation considers performance testing and a design review of both hardware and software. The layout of this document follows to some extent the framework of IEC/TS 62098. A number of performance tests described in IEC 61514 are still valid for intelligent valve positioners. Further reading of IEC 61069 is recommended.

INDUSTRIAL PROCESS CONTROL SYSTEMS –

Part 2: Methods of evaluating the performance of intelligent valve positioners with pneumatic outputs mounted on an actuator valve assembly

1 Scope

This part of IEC 61514 specifies design reviews and tests intended to measure and determine the static and dynamic performance, the degree of intelligence and the communication capabilities of single-acting or double-acting intelligent valve positioners. The tests may be applied to positioners which receive standard analogue electrical input signals (as specified in IEC 60381) and/or digital signals via a data communication link and have a pneumatic output. An intelligent valve positioner as defined in Clause 3 is an instrument that uses for performing its functions digital techniques for data processing, decision-making and bi-directional communication. It may be equipped with additional sensors and additional functionality supporting the main function.

The performance testing of an intelligent valve positioner needs to be conducted with the positioner mounted on and connected to the actuator/valve assembly the positioner is to be used on. The specific characteristic parameters of these combinations such as size, stroke, friction (hysteresis), type of packing, spring package and supply pressure for the pneumatic part, should be carefully chosen and reported, since the performance of a positioner is greatly dependent on the used actuator.

The methods of evaluation given in this standard are intended for testing laboratories to verify equipment performance specifications. The manufacturers of intelligent positioners are urged to apply this standard at an early stage of development.

This standard is intended to provide guidance for designing evaluations of intelligent valve positioners by providing:

- a checklist for reviewing their hardware and software design in a structured way;
- test methods for measuring and qualifying their performance under various environmental and operational conditions;
- methods for reporting the data obtained.

When a full evaluation, in accordance with this standard, is not required or possible, the tests which are required should be performed and the results should be reported in accordance with the relevant parts of this standard. In such cases, the test report should state that it does not cover the full number of tests specified herein. Furthermore, the items omitted should be mentioned, to give the reader of the report a clear overview.

The standard is also applicable for non-intelligent microprocessor-based valve positioners without means for bi-directional communication. In that case an evaluation should be reduced to a limited programme of performance testing and a short review of the construction.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050 (all parts), *International Electrotechnical Vocabulary (IEV)* (available at <http://www.electropedia.org>)

IEC 60068-2-1:1990, *Environmental testing – Part 2: Tests. Tests A: Cold*

IEC 60068-2-2:1974, *Environmental testing – Part 2: Tests. Tests B: Dry heat*

IEC 60068-2-6:1995, *Environmental testing – Part 2: Tests. Test Fc: Vibration (sinusoidal)*

IEC 60068-2-31:1969, *Environmental testing – Part 2: Tests. Test Ec: Drop and topple, primarily for equipment-type specimens*

IEC 60068-2-78:2001, *Environmental testing – Part 2-78: Tests. Test Cab: Damp heat, steady state*

IEC 60079 (all parts), *Electrical apparatus for explosive gas atmospheres*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*

IEC 60534-1, *Industrial-process control valves – Part 1: Control valve terminology and general considerations*

IEC 60654 (all parts), *Operating conditions for industrial-process measurement and control equipment*

IEC 60721-3, *Classification of environmental conditions – Part 3 Classification of groups of environmental parameters and their severities*

IEC 61000-4-11, *Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests*

IEC 61010-1:2001, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 1: General requirements*

IEC 61032:1997, *Protection of persons and equipment by enclosures – Probes for verification*

IEC 61069 (all parts), *Industrial-process measurement and control – Evaluation of system properties for the purpose of system assessment*

IEC 61158 (all parts), *Digital data communications for measurement and control – Fieldbus for use in industrial control systems*

IEC 61298 (all parts), *Process measurement and control devices – General methods and procedures for evaluating performance*

IEC 61298-1:2008, *Process measurement and control devices – General methods and procedures for evaluating performance – Part 1: General considerations*

IEC 61298-2:2008, *Process measurement and control devices – General methods and procedures for evaluating performance – Part 2: Tests under reference conditions*

IEC 61298-3:2008, *Process measurement and control devices – General methods and procedures for evaluating performance – Part 3: Tests for the effects of influence quantities*

IEC 61298-4:2008, *Process measurement and control devices – General methods and procedures for evaluating performance – Part 4: Evaluation report content*

IEC 61326-1:2005, *Electrical equipment for measurement, control and laboratory use – EMC requirements*

IEC/PAS 61499 (all parts), *Function blocks for industrial-process measurement and control systems*

IEC 61514:2000, *Industrial-process control systems – Methods of evaluating the performance of valve positioners with pneumatic outputs*

IEC/TS 62098, *Evaluation methods for microprocessor-based instruments*

CISPR 11, *Information technology equipment – Radio disturbance characteristics – Limits and methods of measurement*