



IEC 61892-6

Edition 2.0 2007-11

INTERNATIONAL STANDARD

**Mobile and fixed offshore units – Electrical installations –
Part 6: Installation**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE

W

ICS 29.260.99; 47.020.60

ISBN 2-8318-9392-5

CONTENTS

| | |
|---|----|
| FOREWORD..... | 5 |
| INTRODUCTION..... | 7 |
| 1 Scope..... | 8 |
| 2 Normative references..... | 8 |
| 3 Terms and definitions | 9 |
| 4 Equipment earthing and bonding | 10 |
| 4.1 General | 10 |
| 4.2 Earthing of exposed conductive parts..... | 11 |
| 4.3 Equipotential bonding | 12 |
| 4.4 Bonding connections..... | 12 |
| 4.5 Connections to the unit structure..... | 12 |
| 4.6 Protection against galvanic corrosion | 13 |
| 4.7 Metal coverings of cables | 13 |
| 4.8 Cable racks and cable tray..... | 14 |
| 4.9 Ductings of heating, ventilation, air-condition (HVAC) and vessels..... | 14 |
| 5 Cables and wiring | 15 |
| 5.1 General | 15 |
| 5.2 Installation..... | 15 |
| 5.3 Cable-runs..... | 16 |
| 5.4 Cable cleating and strapping..... | 16 |
| 5.5 Joints and tappings..... | 16 |
| 5.6 Cable ends | 16 |
| 5.7 Cable termination | 17 |
| 5.8 Cable ladders and trays | 18 |
| 5.9 Cables and wiring for interconnection of equipment..... | 18 |
| 6 Generators and motors | 19 |
| 6.1 General | 19 |
| 6.2 Installation..... | 19 |
| 7 Transformers..... | 19 |
| 7.1 General | 19 |
| 7.2 Installation and location | 19 |
| 7.3 Isolation of windings | 20 |
| 8 Switchgear and controlgear assemblies | 20 |
| 8.1 General | 20 |
| 8.2 Location | 20 |
| 8.3 Insulating mats | 20 |
| 8.4 Passageways in front of switchgear and controlgear assemblies | 21 |
| 8.5 Space at the rear and passageways..... | 21 |
| 8.6 Positions of section and distribution boards..... | 21 |
| 9 Semiconductor converters..... | 21 |
| 10 Secondary cells and batteries | 21 |
| 10.1 Location | 21 |
| 10.2 Access | 23 |
| 10.3 Electrical installation in secondary battery compartments | 23 |
| 10.4 Protection against corrosion..... | 23 |

| | | |
|---------|---|----|
| 10.5 | Fixing and supports | 23 |
| 10.6 | Protection of circuits from secondary batteries | 23 |
| 10.7 | Additional requirements for valve regulated lead acid (VRLA) type batteries | 24 |
| 10.8 | Protection against electric shock..... | 24 |
| 10.9 | Identification labels or marking | 24 |
| 11 | Luminaires..... | 25 |
| 11.1 | General | 25 |
| 11.2 | Degree of protection and safety requirements | 25 |
| 11.3 | Discharge lighting of voltage above 250 V | 25 |
| 11.4 | Emergency and escape lighting..... | 25 |
| 11.5 | Navigation aid system | 25 |
| 12 | Heating and cooking appliances..... | 26 |
| 12.1 | Guarding of combustible materials | 26 |
| 12.2 | Position of controlgear and switchgear | 26 |
| 12.3 | Mounting of space-heating appliances | 26 |
| 13 | Trace and surface heating | 26 |
| 13.1 | General | 26 |
| 13.2 | Trace heating cables | 26 |
| 13.3 | Marking | 27 |
| 13.4 | Protection | 27 |
| 13.5 | Requirements for installation in hazardous areas | 27 |
| 13.6 | Mechanical protection | 27 |
| 13.7 | Junction boxes | 27 |
| 14 | Control and instrumentation | 27 |
| 14.1 | General | 27 |
| 14.2 | Layout | 27 |
| 14.3 | Labelling..... | 27 |
| 14.4 | Labels | 28 |
| 14.5 | Display colours | 28 |
| 14.6 | Protection against fluid leakage | 28 |
| 14.7 | Protection from condensation..... | 28 |
| 14.8 | Protection during installation period | 28 |
| 14.9 | Sensors..... | 28 |
| 14.9.1 | Location of sensors..... | 28 |
| 14.9.2 | Temperature sensors..... | 28 |
| 14.9.3 | Pressure sensors..... | 28 |
| 14.9.4 | Enclosure | 28 |
| 14.9.5 | Testing and calibration..... | 29 |
| 14.10 | Measurements and indications..... | 29 |
| 14.10.1 | Instrument similarity | 29 |
| 14.10.2 | Direction of scale values..... | 29 |
| 14.10.3 | Scale division | 29 |
| 14.10.4 | Automatic control sequence..... | 29 |
| 14.10.5 | Centralized control..... | 29 |
| 14.11 | Controls..... | 29 |
| 14.11.1 | Direction of motion | 29 |
| 14.11.2 | Control levers | 29 |
| 14.11.3 | Identification..... | 30 |

| | |
|--|----|
| 14.12 Alarm system..... | 30 |
| 15 Communication..... | 30 |
| 16 Lightning protection | 30 |
| 16.1 General | 30 |
| 16.2 Protection against primary structural damage..... | 30 |
| 16.3 Air terminals | 31 |
| 16.4 Down conductors | 31 |
| 16.5 Protection against secondary damage..... | 31 |
| 17 Test of completed installation..... | 32 |
| 17.1 General | 32 |
| 17.2 Inspections and tests | 32 |
| 17.3 Insulation-testing instruments | 32 |
| 17.4 Insulation resistance..... | 33 |
| 17.4.1 Wiring..... | 33 |
| 17.4.2 Generators and motors | 33 |
| 17.4.3 Switchboards, section boards and distribution boards..... | 33 |
| 17.5 Generators | 34 |
| 17.6 Switchgear | 34 |
| 17.7 Lighting, heating and galley equipment..... | 34 |
| 17.8 Communication systems | 34 |
| 17.9 Emergency and safety systems..... | 34 |
| 17.10 Earthing..... | 34 |
| 17.11 Voltage drop | 34 |
| 17.12 Requirements of International Convention and regulations | 34 |
| 18 Documentation | 35 |
| 18.1 General | 35 |
| 18.2 Equipment | 35 |
| 18.3 Testing | 35 |
| 18.4 Maintenance..... | 35 |
| Annex A (informative) Performance test | 36 |
| Bibliography | 38 |
| Table 1 – Sizes of protective-earthing (PE) conductors and earthing connections..... | 14 |
| Table 2 – Enclosure-gland type | 17 |
| Table 3 – Location of batteries versus charging current | 22 |
| Table 4 – Test voltages | 33 |

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**MOBILE AND FIXED OFFSHORE UNITS –
ELECTRICAL INSTALLATIONS –****Part 6: Installation**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61892-6 has been prepared by IEC technical committee 18: Electrical installations of ships and of mobile and fixed offshore units.

This second edition cancels and replaces the first edition published in 1999. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) clauses regarding installation of cables have been added;
- b) the clause regarding secondary cells and batteries have been modified to give requirements also to installation of valve regulated (VRLA) type batteries;
- c) an informative annex regarding testing of installation has been added.

The text of this standard is based on the following documents:

| FDIS | Report on voting |
|--------------|------------------|
| 18/1065/FDIS | 18/1071/RVD |

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61892 series, under the general title *Mobile and fixed offshore units – Electrical installations*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

INTRODUCTION

IEC 61892 forms a series of International Standards intended to ensure safety in the design, selection, installation, maintenance and use of electrical equipment for the generation, storage, distribution and utilization of electrical energy for all purposes in offshore units which are used for the exploration or exploitation of petroleum resources.

This part of IEC 61892 also incorporates and co-ordinates, as far as possible, existing rules and forms a code of interpretation, where applicable, of the requirements laid down by the International Maritime Organization, and constitutes a guide for future regulations which may be prepared and a statement of practice for offshore unit owners, constructors and appropriate organizations.

This standard is based on equipment and practices which are in current use, but it is not intended in any way to impede development of new or improved techniques.

The ultimate aim has been to produce a set of International Standards exclusively for the offshore petroleum industry.

MOBILE AND FIXED OFFSHORE UNITS – ELECTRICAL INSTALLATIONS –

Part 6: Installation

1 Scope

This part of IEC 61892 contains provisions for electrical installation in mobile and fixed offshore units including pipeline, pumping or 'pigging' stations, compressor stations and exposed location single buoy moorings, used in the offshore petroleum industry for drilling, processing and for storage purposes.

It applies to all installations, whether permanent, temporary, transportable or hand-held, to a.c. installations up to and including 35 000 V and d.c. installations up to and including 750 V (a.c. and d.c. voltages are nominal values).

This standard does not apply to electrical installations in rooms used for medical purposes, or in tankers.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079-14:2002, *Electrical apparatus for explosive gas atmospheres – Part 14: Electrical installations in hazardous areas (other than mines)*

IEC 60447:2004, *Basic and safety principles for man-machine interface – Actuating principles*

IEC 60502-1:2004, *Power cables with extruded insulation and their accessories for rated voltages from 1 kV ($U_m = 1,2$ kV) up to 30 kV ($U_m = 36$ kV) – Part 1: Cables for rated voltages of 1 kV ($U_m = 1,2$ kV) up to 3 kV ($U_m = 3,6$ kV)*

IEC 60502-2:2005, *Power cables with extruded insulation and their accessories for rated voltages from 1 kV ($U_m = 1,2$ kV) up to 30 kV ($U_m = 36$ kV) – Part 2: Cables for rated voltages from 6 kV ($U_m = 7,2$ kV) up to 30 kV ($U_m = 36$ kV)*

IEC 60623:2001, *Secondary cells and batteries containing alkaline or other non-acid electrolytes – Vented nickel-cadmium prismatic rechargeable single cells*

IEC 60825 (all parts), *Safety of laser products*

IEC 60896-11:2002, *Stationary lead-acid batteries – Part 11: Vented types – General requirements and methods of test*

IEC 61892-1, *Mobile and fixed offshore units – Electrical installations – Part 1: General requirements and conditions*

IEC 61892-2, *Mobile and fixed offshore units – Electrical installations – Part 2: System design*

IEC 61892-3, *Mobile and fixed offshore units – Electrical installations – Part 3: Equipment*

IEC 61892-4, *Mobile and fixed offshore units – Electrical installations – Part 4: Cables*

IEC 61892-7, *Mobile and fixed offshore units – Electrical installations – Part 7: Hazardous areas*

ISO 8468:1990, *Ship's bridge layout and associated equipment – Requirements and guidelines*