

© Copyright SEK. Reproduction in any form without permission is prohibited.

Gränssnitt för EMS (EMS-API) – Del 452: CIM-profiler för statisk modellering av transmissionsnät

*Energy management system application program interface (EMS-API) –
Part 452: CIM Static transmission network model profiles*

Som svensk standard gäller europastandarden EN 61970-452:2013. Den svenska standarden innehåller den officiella engelska språkversionen av EN 61970-452:2013.

Nationellt förord

Europastandarden EN 61970-452:2013

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 61970-452, First edition, 2013 - Energy management system application program interface (EMS-API) - Part 452: CIM Static transmission network model profiles**

utarbetad inom International Electrotechnical Commission, IEC.

ICS 33.200.00

Denna standard är fastställd av SEK Svensk Elstandard, som också kan lämna upplysningar om **sakinnehållet** i standarden.
Postadress: Box 1284, 164 29 KISTA
Telefon: 08 - 444 14 00.
E-post: sek@elstandard.se. Internet: www.elstandard.se

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English version

**Energy management system application program interface (EMS-API) -
Part 452: CIM Static transmission network model profiles
(IEC 61970-452:2013)**

Interface de programmation d'application pour
système de gestion d'énergie (EMS-API) -
Partie 452: Profils du modèle de réseau de
transport statique CIM
(CEI 61970-452:2013)

Schnittstelle für Anwendungsprogramme für
Netzführungssysteme (EMS-API) -
Teil 452: CIM-Statistische-
Übertragungsnetzwerk-Modell-Profile
(IEC 61970-452:2013)

This European Standard was approved by CENELEC on 2013-09-16. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 57/1366/FDIS, future edition 1 of IEC 61970-452, prepared by IEC/TC 57 "Power systems management and associated information exchange" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61970-452:2013.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2014-06-20
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2016-09-16

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

Endorsement notice

The text of the International Standard IEC 61970-452:2013 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following note has to be added for the standard indicated :

IEC 61970-552 NOTE Harmonised as EN 61970-552.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61970-1	-	Energy management system application program interface (EMS-API) - Part 1: Guidelines and general requirements	EN 61970-1	-
IEC/TS 61970-2	-	Energy management system application program interface (EMS-API) - Part 2: Glossary	CLC/TS 61970-2	-
IEC 61970-301	-	Energy management system application program interface (EMS-API) - Part 301: Common information model (CIM) base	EN 61970-301	-
IEC 61970-501	-	Energy management system application program interface (EMS-API) - Part 501: Common Information Model Resource Description Framework (CIM RDF) schema	EN 61970-501	-

CONTENTS

INTRODUCTION.....	8
1 Scope.....	9
2 Normative references.....	10
3 Overview of data requirements.....	10
3.1 Overview.....	10
3.2 General requirements.....	10
3.3 Transformer modeling.....	11
3.4 Modeling authorities.....	12
3.5 Use of measurement classes.....	13
3.5.1 General.....	13
3.5.2 ICCP data exchange.....	14
3.6 Voltage or active power regulation.....	14
3.7 Use of curves.....	14
3.7.1 General.....	14
3.7.2 Generating unit reactive power limits.....	14
3.8 Definition of schedules.....	15
4 CIM Equipment Profile.....	15
4.1 CIM Equipment Profile General.....	15
4.2 Concrete Classes.....	15
4.2.1 Accumulator.....	15
4.2.2 AccumulatorValue.....	16
4.2.3 ACLineSegment.....	17
4.2.4 ActivePowerLimit.....	18
4.2.5 Analog.....	19
4.2.6 AnalogValue.....	20
4.2.7 ApparentPowerLimit.....	20
4.2.8 BaseVoltage.....	21
4.2.9 Bay.....	21
4.2.10 Breaker.....	22
4.2.11 BusbarSection.....	23
4.2.12 ConformLoad.....	23
4.2.13 ConformLoadGroup.....	24
4.2.14 ConformLoadSchedule.....	25
4.2.15 ConnectivityNode.....	26
4.2.16 ControlArea.....	26
4.2.17 ControlAreaGeneratingUnit.....	27
4.2.18 CurrentLimit.....	27
4.2.19 CurveData.....	28
4.2.20 DayType.....	29
4.2.21 Disconnecter.....	29
4.2.22 Discrete.....	30
4.2.23 DiscreteValue.....	30
4.2.24 EnergyConsumer.....	31
4.2.25 EquivalentBranch.....	32
4.2.26 EquivalentInjection.....	33
4.2.27 EquivalentNetwork.....	34

4.2.28	EquivalentShunt.....	34
4.2.29	FossilFuel.....	35
4.2.30	GeneratingUnit.....	35
4.2.31	GeographicalRegion.....	38
4.2.32	GrossToNetActivePowerCurve.....	38
4.2.33	HydroGeneratingUnit.....	39
4.2.34	HydroPump.....	41
4.2.35	IEC61970CIMVersion.....	41
4.2.36	ImpedanceVariationCurve.....	42
4.2.37	Line.....	42
4.2.38	LoadArea.....	43
4.2.39	LoadBreakSwitch.....	43
4.2.40	LoadResponseCharacteristic.....	44
4.2.41	MeasurementValueSource.....	47
4.2.42	MutualCoupling.....	47
4.2.43	NonConformLoad.....	48
4.2.44	NonConformLoadGroup.....	50
4.2.45	NonConformLoadSchedule.....	50
4.2.46	NuclearGeneratingUnit.....	51
4.2.47	OperationalLimitSet.....	52
4.2.48	OperationalLimitType.....	53
4.2.49	PhaseTapChanger.....	54
4.2.50	PhaseVariationCurve.....	56
4.2.51	PowerTransformer.....	56
4.2.52	RatioTapChanger.....	57
4.2.53	RatioVariationCurve.....	58
4.2.54	ReactiveCapabilityCurve.....	59
4.2.55	RegularTimePoint.....	60
4.2.56	RegulatingControl.....	61
4.2.57	RegulationSchedule.....	62
4.2.58	Season.....	63
4.2.59	SeriesCompensator.....	63
4.2.60	ShuntCompensator.....	64
4.2.61	StaticVarCompensator.....	65
4.2.62	StationSupply.....	67
4.2.63	SubGeographicalRegion.....	68
4.2.64	SubLoadArea.....	68
4.2.65	Substation.....	69
4.2.66	Switch.....	69
4.2.67	SwitchSchedule.....	70
4.2.68	SynchronousMachine.....	71
4.2.69	TapSchedule.....	73
4.2.70	Terminal.....	74
4.2.71	ThermalGeneratingUnit.....	75
4.2.72	TieFlow.....	76
4.2.73	TransformerWinding.....	77
4.2.74	Unit.....	79
4.2.75	VoltageLevel.....	79
4.2.76	VoltageLimit.....	80

4.2.77	WindGeneratingUnit.....	81
4.3	Abstract Classes.....	82
4.3.1	BasicIntervalSchedule.....	82
4.3.2	ConductingEquipment.....	82
4.3.3	Conductor.....	83
4.3.4	ConnectivityNodeContainer.....	84
4.3.5	Curve.....	84
4.3.6	EnergyArea.....	85
4.3.7	Equipment.....	85
4.3.8	EquipmentContainer.....	86
4.3.9	EquivalentEquipment.....	86
4.3.10	IdentifiedObject.....	87
4.3.11	LoadGroup.....	88
4.3.12	Measurement.....	88
4.3.13	MeasurementValue.....	90
4.3.14	OperationalLimit.....	90
4.3.15	PowerSystemResource.....	91
4.3.16	RegularIntervalSchedule.....	91
4.3.17	RegulatingCondEq.....	92
4.3.18	SeasonDayTypeSchedule.....	93
4.3.19	TapChanger.....	93
4.4	Enumerations.....	95
4.4.1	ControlAreaTypeKind.....	95
4.4.2	CurveStyle.....	95
4.4.3	FuelType.....	96
4.4.4	GeneratorControlSource.....	96
4.4.5	OperationalLimitDirectionKind.....	96
4.4.6	PhaseTapChangerKind.....	97
4.4.7	RegulatingControlModeKind.....	97
4.4.8	SeasonName.....	98
4.4.9	SVCControlMode.....	98
4.4.10	SynchronousMachineOperatingMode.....	98
4.4.11	SynchronousMachineType.....	99
4.4.12	TapChangerKind.....	99
4.4.13	TransformerControlMode.....	99
4.4.14	UnitSymbol.....	100
4.4.15	WindingConnection.....	101
4.4.16	WindingType.....	102
4.5	Datatypes.....	102
4.5.1	ActivePower.....	102
4.5.2	AngleDegrees.....	102
4.5.3	ApparentPower.....	102
4.5.4	Conductance.....	103
4.5.5	CurrentFlow.....	103
4.5.6	Length.....	103
4.5.7	Money.....	103
4.5.8	PerCent.....	103
4.5.9	Reactance.....	104
4.5.10	ReactivePower.....	104

4.5.11 Resistance.....	104
4.5.12 Seconds	104
4.5.13 Susceptance.....	104
4.5.14 Voltage	105
4.5.15 VoltagePerReactivePower.....	105
5 Amplifications and conventions	105
5.1 Overview	105
5.2 XML file validity	105
5.3 Normative string tables	105
5.4 Roles and multiplicity.....	107
Annex A (informative) Model exchange use cases	108
Annex B (informative) Modeling authorities.....	112
Annex C (informative) Common power system model (CPSM) minimum data requirements.....	114
Bibliography.....	119
Figure 1 – Two winding transformer impedance	11
Figure 2 – Three winding transformer impedance	12
Figure A.1 – Security coordinators.....	108
Figure A.2 – CIM model exchange.....	109
Figure A.3 – Revised CIM model exchange.....	110
Figure A.4 – Hierarchical modeling	111
Figure C.1 – Example model configuration.....	118
Table 1 – Valid measurementTypes.....	13
Table 2 – Profiles defined in this document.....	15
Table 3 – Valid attribute values	105

INTRODUCTION

This international standard is one of the IEC 61970 series that define an application program interface (API¹) for an energy management system (EMS²).

The IEC 61970-3x series of documents specify a Common Information Model (CIM). The CIM is an abstract model that represents all of the major objects in an electric utility enterprise typically needed to model the operational aspects of a utility. It provides the semantics for the IEC 61970 APIs specified in the IEC 61970-4x series of Component Interface Standards (CIS). The IEC 61970-3x series includes IEC 61970-301: Common Information Model (CIM³) base, and draft standard IEC 61970-302: Common Information Model (CIM) Financial, EnergyScheduling, and Reservation.

This standard is one of the IEC 61970-4x series of Component Interface Standards that specify the functional requirements for interfaces that a component (or application) shall implement to exchange information with other components (or applications) and/or to access publicly available data in a standard way. The component interfaces describe the specific message contents and services that can be used by applications for this purpose. The implementation of these messages in a particular technology is described in IEC 61970-5.

This standard specifies the specific profiles (or subsets) of the CIM for exchange of static power system data between utilities, security coordinators and other entities participating in an interconnected power system, such that all parties have access to the modeling of their neighbor's systems that is necessary to execute state estimation or power flow applications. Currently only one profile, the Equipment Profile, has been defined. A companion standard, 61970-552⁴, defines the CIM XML Model Exchange Format based on the Resource Description Framework (RDF) Schema specification language which is recommended to be used to transfer power system model data for the 61970-452 profile.

1 Footnote 1 applies to the French version only.

2 Footnote 2 applies to the French version only.

3 Footnote 3 applies to the French version only.

4 To be published.

ENERGY MANAGEMENT SYSTEM APPLICATION PROGRAM INTERFACE (EMS-API) –

Part 452: CIM Static transmission network model profiles

1 Scope

This part of IEC 61970 forms part of the IEC 61907-450 to 499 series that, taken as a whole, defines at an abstract level the content and exchange mechanisms used for data transmitted between control centers and/or control center components.

The purpose of this document is to rigorously define the subset of classes, class attributes, and roles from the CIM necessary to execute state estimation and power flow applications. The North American Electric Reliability Council (NERC) Data Exchange Working Group (DEWG) Common Power System Modeling group (CPSM) produced the original data requirements, which are shown in Annex C. These requirements are based on prior industry practices for exchanging power system model data for use primarily in planning studies. However, the list of required data has been extended to facilitate a model exchange that includes parameters common to breaker-oriented applications. Where necessary this document establishes conventions, shown in Clause 5, with which an XML data file must comply in order to be considered valid for exchange of models.

This document is intended for two distinct audiences, data producers and data recipients, and may be read from two perspectives.

From the standpoint of model export software used by a data producer, the document describes a minimum subset of CIM classes, attributes, and associations which must be present in an XML formatted data file for model exchange. This standard does not dictate how the network is modelled, however. It only dictates what classes, attributes, and associations are to be used to describe the source model as it exists. All classes, attributes, and associations not explicitly labeled as recommended or conditionally required should be considered required with the following caveat. Consider, as an example, the situation in which an exporter produces an XML data file describing a small section of the exporter's network that happens to contain no breakers. The resulting XML data file should, therefore, not contain an instance of the Breaker class. On the other hand, if the section of the exporter's network does contain breakers, the resulting data file should contain instances of the Breaker class that include, at a minimum, the attributes and roles described herein for Breakers. Furthermore, it should be noted that an exporter may, at his or her discretion, produce an XML data file containing additional class data described by the CIM RDF Schema but not required by this document provided these data adhere to the conventions established in Clause 5.

From the standpoint of the model import used by a data recipient, the document describes a subset of the CIM that importing software must be able to interpret in order to import exported models. As mentioned above, data providers are free to exceed the minimum requirements described herein as long as their resulting data files are compliant with the CIM RDF Schema and the conventions established in Clause 5. The document, therefore, describes additional classes and class data that, although not required, exporters will, in all likelihood, choose to include in their data files. The additional classes and data are labeled as recommended or as not required to distinguish them from their required counterparts. Please note, however, that data importers could potentially receive data containing instances of any and all classes described by the CIM RDF Schema.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE For general glossary definitions, see the International Electrotechnical Vocabulary, IEC 60050.

IEC 61970-1, *Energy management system application program interface (EMS-API) – Part 1: Guidelines and general requirements*

IEC 61970-2, *Energy management system application program interface (EMS-API) – Part 2: Glossary*

IEC 61970-301, *Energy management system application program interface (EMS-API) – Part 301: Common information model (CIM) base*

IEC 61970-501, *Energy management system application program interface (EMS-API) – Part 501: Common Information Model Resource Description Framework (CIM RDF) schema*