

© Copyright SEK. Reproduction in any form without permission is prohibited.

## **Kopplingsapparater för högst 1000 V – Del 4-3: Kontaktorer och startkopplare – Halvledarbaserade kontaktorer och startkopplare för annat än motordrifter**

*Low-voltage switchgear and controlgear –  
Part 4-3: Contactors and motor-starters –  
AC semiconductor controllers and contactors for non-motor loads*

Som svensk standard gäller europastandarden EN 60947-4-3:2014. Den svenska standarden innehåller den officiella engelska språkversionen av EN 60947-4-3:2014.

### **Nationellt förord**

Europastandarden EN 60947-4-3:2014

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 60947-4-3, Second edition, 2014 - Low-voltage switchgear and controlgear - Part 4-3: Contactors and motor-starters - AC semiconductor controllers and contactors for non-motor loads**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 60947-4-3, utgåva 1, 2000, SS-EN 60947-4-3/A1, utgåva 1, 2007 och SS-EN 60947-4-3/A2, utgåva 1, 2012, gäller ej fr o m 2017-06-11.

### *Standarder underlättar utvecklingen och höjer elsäkerheten*

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

### *SEK är Sveriges röst i standardiseringsarbetet inom elområdet*

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

### *Stora delar av arbetet sker internationellt*

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

### *Var med och påverka!*

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

### **SEK Svensk Elstandard**

Box 1284  
164 29 Kista  
Tel 08-444 14 00  
[www.elstandard.se](http://www.elstandard.se)

English Version

**Low-voltage switchgear and controlgear - Part 4-3: Contactors  
and motor-starters - AC semiconductor controllers and  
contactors for non-motor loads  
(IEC 60947-4-3:2014)**

Appareillage à basse tension - Partie 4-3: Contacteurs et  
démarreurs de moteurs - Gradateurs et contacteurs à  
semiconducteurs pour charges, autres que des moteurs, à  
courant alternatif  
(CEI 60947-4-3:2014)

Niederspannungsschaltgeräte - Teil 4-3: Schütze und  
Motorstarter - Halbleiter-Steuergeräte und -Schütze für  
nichtmotorische Lasten für Wechselspannung  
(IEC 60947-4-3:2014)

This European Standard was approved by CENELEC on 2014-06-11. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

## Foreword

The text of document 121A/2/FDIS, future edition 2 of IEC 60947-4-3, prepared by SC 17B "Low-voltage switchgear and controlgear" of IEC/TC 17 "Switchgear and controlgear" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60947-4-3:2014.

The following dates are fixed:

- latest date by which the document has to be (dop) 2015-03-11  
implemented at national level by  
publication of an identical national  
standard or by endorsement
- latest date by which the national (dow) 2017-06-11  
standards conflicting with the  
document have to be withdrawn

This European Standard has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association and covers essential requirements of EU Directive 2004/108/EC.

For relationship with EU Directive(s), see informative Annex ZZ, which is an integral part of this document.

This document supersedes EN 60947-4-3:2000.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This standard covers the Principle Elements of the Safety Objectives for Electrical Equipment Designed for Use within Certain Voltage Limits (LVD - 2006/95/EC).

## Endorsement notice

The text of the International Standard IEC 60947-4-3:2014 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60085:2007	NOTE	Harmonized as EN 60085:2008 (modified).
IEC 60146 (series)	NOTE	Harmonized as EN 60146 (series) (not modified).
IEC 60664 (series)	NOTE	Harmonized as EN 60664 (series) (not modified).
IEC 60947-4-2:2011	NOTE	Harmonized as EN 60947-4-2:2012 (modified).
IEC 61439 (series)	NOTE	Harmonized as EN 61439 (series) (not modified).

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: [www.cenelec.eu](http://www.cenelec.eu)

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60269-1	2006	Low-voltage fuses -- Part 1: General requirements	EN 60269-1	2007
IEC 60410	1973	Sampling plans and procedures for inspection by attributes	-	-
IEC 60947-1	2007	Low-voltage switchgear and controlgear -- Part 1: General rules	EN 60947-1	2007
+A1	2010		+A1	2011
IEC 61000-4 (series)	-	Electromagnetic compatibility (EMC) -- Part 4-1: Testing and measurement techniques (series) - Overview of IEC 61000-4 series	EN 61000-4	-
IEC 61000-4-5	2005	Electromagnetic compatibility (EMC) -- Part 4-5: Testing and measurement techniques - Surge immunity test	EN 61000-4-5	2006
CISPR 11 (mod)	2009	Industrial, scientific and medical equipment - Radio-frequency disturbance characteristics - Limits and methods of measurement	EN 55011	2009
CISPR 11:2009/A1	2010		EN 55011:2009/A1	2010

## CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references .....	10
3 Terms, definitions, symbols and abbreviations.....	10
3.1 Terms and definitions concerning a.c. semiconductor (non-motor-load) control devices.....	11
3.1.1 AC semiconductor controllers and contactors (solid-state contactors) (see Figure 1).....	11
3.1.2 Hybrid controllers and contactors (see Figure 1).....	14
3.2 Vacant .....	18
3.3 Symbols and abbreviations .....	18
4 Classification.....	18
5 Characteristics of a.c. semiconductor controllers and contactors .....	19
5.1 Summary of characteristics .....	19
5.2 Type of equipment .....	19
5.3 Rated and limiting values for main circuits .....	22
5.3.1 Rated voltages .....	22
5.3.2 Currents .....	22
5.3.3 Rated frequency .....	22
5.3.4 Rated duty .....	22
5.3.5 Normal load and overload characteristics .....	23
5.3.6 Rated conditional short-circuit current.....	24
5.4 Utilization category .....	24
5.4.1 Assignment of ratings based on the results of tests .....	25
5.5 Control circuits.....	26
5.6 Auxiliary circuits.....	26
5.7 Vacant .....	26
5.8 Coordination with short-circuit protective devices (SCPD).....	26
6 Product information .....	26
6.1 Nature of information .....	26
6.2 Marking.....	28
6.3 Instructions for installation, operation and maintenance .....	28
7 Normal service, mounting and transport conditions.....	28
7.1 Normal service conditions .....	28
7.1.1 Ambient air temperature .....	28
7.1.2 Altitude .....	28
7.1.3 Atmospheric conditions.....	28
7.1.4 Shock and vibrations .....	29
7.2 Conditions during transport and storage.....	29
7.3 Mounting.....	29
7.4 Electrical system disturbances and influences .....	29
8 Constructional and performance requirements .....	29
8.1 Constructional requirements .....	29
8.1.1 General .....	29

8.1.2	Materials .....	29
8.1.3	Current-carrying parts and their connections .....	29
8.1.4	Clearances and creepage distances .....	29
8.1.5	Actuator.....	30
8.1.6	Indication of the contact position .....	30
8.1.7	Additional requirements for equipment suitable for isolation.....	30
8.1.8	Terminals .....	30
8.1.9	Additional requirements for equipment provided with a neutral pole .....	30
8.1.10	Provisions for protective earthing.....	30
8.1.11	Enclosures for equipment .....	30
8.1.12	Degrees of protection of enclosed equipment .....	30
8.1.13	Conduit pull-out, torque and bending with metallic conduits .....	30
8.2	Performance requirements.....	30
8.2.1	Operating conditions.....	30
8.2.2	Temperature rise .....	32
8.2.3	Dielectric properties.....	34
8.2.4	Normal load and overload performance requirements .....	35
8.2.5	Coordination with short-circuit protective devices .....	42
8.3	EMC requirements .....	42
8.3.1	General .....	42
8.3.2	Emission.....	43
8.3.3	Immunity.....	43
9	Tests .....	45
9.1	Kinds of tests .....	45
9.1.1	General .....	45
9.1.2	Type tests.....	45
9.1.3	Routine tests .....	45
9.1.4	Sampling tests.....	45
9.1.5	Special tests.....	46
9.2	Compliance with constructional requirements.....	46
9.3	Compliance with performance requirements .....	46
9.3.1	Test sequences .....	46
9.3.2	General test conditions .....	47
9.3.3	Performance under no load, normal load and overload conditions .....	47
9.3.4	Performance under short-circuit conditions .....	54
9.3.5	Disponible .....	58
9.4	General.....	58
9.4.1	EMC emission tests .....	58
9.4.2	EMC immunity tests.....	59
9.5	Routine and sampling tests .....	61
9.5.1	General .....	61
9.5.2	Operation and operating limits .....	61
9.5.3	Dielectric tests.....	61
Annex A (normative)	Marking and identification of terminals .....	62
A.1	General.....	62
A.2	Marking and identification of terminals of controller and contactors .....	62
A.2.1	Marking and identification of terminals of main circuits .....	62

A.2.2	Marking and identification of terminals of control circuits .....	62
A.2.3	Marking and identification of auxiliary circuits .....	62
Annex B (informative)	Typical service conditions for controllers and contactors .....	65
B.1	Control of resistive heating elements .....	65
B.2	Switching of electric discharge lamp controls .....	65
B.3	Switching of incandescent lamps .....	66
B.4	Switching of transformers.....	66
B.5	Switching of capacitor banks.....	66
Annex C	Vacant.....	67
Annex D	Vacant.....	68
Annex E	Vacant.....	69
Annex F (informative)	Operating capability.....	70
Annex G	Vacant.....	73
Annex H	Vacant.....	74
Annex I (normative)	Modified test circuit for short-circuit testing of semiconductor contactors and controllers.....	75
Annex J (informative)	Flowchart for constructing bypassed semiconductor controllers tests .....	77
Bibliography	.....	78
Figure 1	– Graphical possibilities of controllers .....	13
Figure 2	– Methods of connecting .....	21
Figure F.1	– Thermal stability test profile .....	70
Figure F.2	– Overload capability test profile .....	71
Figure F.3	– Blocking and commutating capability test profile .....	72
Figure I.1	– Modified circuit for short-circuit testing of semiconductor devices.....	75
Figure I.2	– Time line for the short-circuit test of 9.3.4.1.6 .....	76
Table 1	– Functional possibilities of controllers and contactors .....	14
Table 2	– Utilization categories .....	25
Table 3	– Relative levels of severity.....	25
Table 4	– Temperature rise limits for insulated coils in air and in oil.....	34
Table 5	– Intermittent duty test cycle data.....	34
Table 6	– Minimum overload current withstand time ( $T_X$ ) in relation to overload current ratio ( $X$ ) .....	36
Table 7	– Minimum requirements for thermal stability test conditions .....	37
Table 8	– Minimum requirements for overload capability test conditions .....	38
Table 9	– Minimum requirements and conditions for performance testing, including blocking and commutating capability.....	39
Table 10	– Making and breaking capacity test – Making and breaking conditions according to utilization categories for the mechanical switching device of hybrid semiconductor controller and contactor H4, H5.....	40
Table 11	– Conventional operational performance – Making and breaking conditions according to utilization categories for the mechanical switching device of hybrid controllers and contactors H4B, H5B .....	41
Table 12	– Specific performance criteria when EM disturbances are present .....	44

Table 13 – Thermal stability test specifications .....	51
Table 14 – Initial case temperature requirements.....	52
Table 15 – Terminal disturbance voltage limits for conducted radiofrequency emission.....	59
Table 16 – Radiated emissions test limits .....	59
Table A.1 – Main circuit terminal markings.....	62

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

### LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

#### **Part 4-3: Contactors and motor-starters – AC semiconductor controllers and contactors for non-motor loads**

### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60947-4-3 has been prepared by subcommittee 17B: Low-voltage switchgear and controlgear, of IEC technical committee 17: Switchgear and controlgear.

This second edition cancels and replaces the first edition published in 1999, Amendment 1:2006 and Amendment 2:2011. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Update of the marking requirements (6.1);
- b) Update of the EMC requirements (8.3.2); and
- c) Update of the tests requirements (9.3.1, 9.4, 9.4.1.1, 9.4.1.2, 9.4.2.1, 9.4.2.2, 9.4.2.3, 9.4.2.4, 9.4.2.6).

The text of this standard is based on the following documents:

FDIS	Report on voting
121A/2/FDIS	121A/14/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60947 series, published under the general title *Low-voltage switchgear and controlgear*, can be found on the IEC website.

This standard shall be read in conjunction with IEC 60947-1, *Low voltage switchgear and controlgear – Part 1: General rules*. The provisions of the general rules are applicable to this standard, where specifically called for.

The provisions of the general rules (IEC 60947-1) are applicable to this standard, where specifically called for. Clauses and subclauses thus applicable, as well as tables, figures, and annexes, are identified by reference to IEC 60947-1, for example 1.2.3 of IEC 60947-1:2007, Amendment 1 (2010), Table 4 of IEC 60947-1:2007, Amendment 1 (2010) or Annex A of IEC 60947-1:2007.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

## INTRODUCTION

This part of IEC 60947 covers low-voltage a.c. semiconductor controllers and contactors (solid-state contactors) intended for the use with non-motor loads. As controllers, they have many capabilities beyond the simple switching on and off of non-motor loads. As contactors, they perform the same functions as mechanical contactors, but utilize one or more semiconductor switching devices in their main poles.

The devices may be single-pole or multi-pole (see 2.3.1 of IEC 60947-1:2007,). This standard refers to complete devices rated as a unit incorporating all necessary heat-sinking material and terminals. It includes devices with all necessary terminals, which are supplied with or without heat-sink in knocked-down form for combination by the users, when the manufacturer gives with the device detailed information about choosing the heat-sink and mounting the device on the heat-sink.

The generic term, "controller", is used in this standard wherever the unique features of the power semiconductor switching elements are the most significant points of interest. The generic term "contactor" is used in this standard wherever the feature of simple switching on and off is the most significant point of interest. Specific designations (for example, form 4, form HxB, etc.) are used wherever the unique features of various configurations comprise significant points of interest.

## LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

### Part 4-3: Contactors and motor-starters – AC semiconductor controllers and contactors for non-motor loads

#### 1 Scope

This part of IEC 60947 applies to a.c. semiconductor non-motor load controllers and contactors intended for performing electrical operations by changing the state of a.c. electric circuits between the ON-state and the OFF-state. Typical applications are classified by utilization categories given in Table 2.

As controllers, they may be used to reduce the amplitude of the r.m.s. a.c. voltage on the load terminals from that of the applied voltage – either continuously or for a specified period of time. The half-wave period of the a.c. wave form remains unchanged from that of the applied voltage.

They may include a series mechanical switching device and are intended to be connected to circuits, the rated voltage of which does not exceed 1 000 V a.c.

This standard characterizes controllers and contactors for use with or without bypass switching devices.

The semiconductor controllers and contactors dealt with in this standard are not normally intended to interrupt short-circuit currents. Therefore, suitable short-circuit protection (see 8.2.5) should form part of the installation but not necessarily of the controller itself.

In this context, this standard gives requirements for semiconductor controllers and contactors associated with separate short-circuit protective devices.

This standard does not apply to:

- operation of a.c. and d.c. motors;
- low-voltage a.c. semiconductor motor controllers and starters covered by IEC 60947-4-2;
- electronic a.c. power controllers covered by the IEC 60146 series;
- all-or-nothing solid-state relays.

Contactors and control-circuit devices used in semiconductor controllers and contactors should comply with the requirements of their relevant product standard. Where mechanical switching devices are used, they should meet the requirements of their own IEC product standard and the additional requirements of this standard.

The object of this standard is to state

- a) the characteristics of semiconductor controllers and contactors and associated equipment;
- b) the conditions with which semiconductor controllers and contactors should comply with reference to:
  - their operation and behaviour;
  - their dielectric properties;
  - the degrees of protection provided by their enclosures, where applicable;

- their construction;
- c) the tests intended for confirming that these conditions have been met, and the methods to be adopted for these tests;
- d) the information to be given with the equipment or in the manufacturer's literature.

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60269-1:2006, *Low-voltage fuses – Part 1: General requirements*

IEC 60410:1973, *Sampling plans and procedures for inspection by attributes*

IEC 60947-1:2007, *Low-voltage switchgear and controlgear – Part 1: General rules*  
Amendment 1:2010

IEC 61000-4 (all parts), *Electromagnetic compatibility (EMC) – Part 4: Testing and measurement techniques*

IEC 61000-4-5:2005, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*

CISPR 11:2009, *Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement*  
Amendment 1:2010