

© Copyright SEK. Reproduction in any form without permission is prohibited.

Elektromagnetisk kompatibilitet (EMC) – Del 4-5: Mät- och provningsmetoder – Provning av immunitet mot stötpulser

*Electromagnetic compatibility (EMC) –
Part 4-5: Testing and measurement techniques –
Surge immunity test*

Som svensk standard gäller europastandarden EN 61000-4-5:2014. Den svenska standarden innehåller den officiella engelska språkversionen av EN 61000-4-5:2014.

Nationellt förord

Europastandarden EN 61000-4-5:2014

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 61000-4-5, Third edition, 2014 - Electromagnetic compatibility (EMC) - Part 4-5: Testing and measurement techniques - Surge immunity test**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 61000-4-5, utgåva 2, 2006, gäller ej fr o m 2017-06-19.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English Version

**Electromagnetic compatibility (EMC) - Part 4-5: Testing and
measurement techniques - Surge immunity test
(IEC 61000-4-5:2014)**

Compatibilité électromagnétique (CEM) - Partie 4-5:
Techniques d'essai et de mesure - Essai d'immunité aux
ondes de choc
(CEI 61000-4-5:2014)

Elektromagnetische Verträglichkeit (EMV) - Teil 4-5: Prüf-
und Messverfahren - Prüfung der Störfestigkeit gegen
Stoßspannungen
(IEC 61000-4-5:2014)

This European Standard was approved by CENELEC on 2014-06-19. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 77B/711/FDIS, future edition 3 of IEC 61000-4-5, prepared by SC 77B "High frequency phenomena", of IEC/TC 77 "Electromagnetic compatibility" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61000-4-5:2014.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-03-19
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2017-06-19

This document supersedes EN 61000-4-5:2006.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 61000-4-5:2014 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60060-2	NOTE	Harmonized as EN 60060-2.
IEC 60364-4-44	NOTE	Harmonized as HD 60364-4-442 and HD 60364-4-444.
IEC 60664-1	NOTE	Harmonized as EN 60664-1.
IEC 61000-4-4	NOTE	Harmonized as EN 61000-4-4.
IEC 61643	NOTE	Harmonized in EN 61643 series and in CLC/TS 61643 series (partly modified).
IEC 61643-11	NOTE	Harmonized as EN 61643-11.
IEC 61643-12	NOTE	Harmonized as CLC/TS 61643-12.
IEC 61643-21:2000 + A1:2008 + A2:2012	NOTE	Harmonized as EN 61643-21:2000 (not modified). + A1:2009 (modified) + A2:2013 (not modified)
IEC 62305-1	NOTE	Harmonized as EN 62305-1.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050	series	International Electrotechnical Vocabulary (IEV)	-	-

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope and object.....	9
2 Normative references	9
3 Terms, definitions and abbreviations	10
3.1 Terms and definitions.....	10
3.2 Abbreviations.....	13
4 General	13
4.1 Power system switching transients.....	13
4.2 Lightning transients.....	14
4.3 Simulation of the transients.....	14
5 Test levels.....	14
6 Test instrumentation	15
6.1 General.....	15
6.2 1,2/50 µs combination wave generator	15
6.2.1 General	15
6.2.2 Performance characteristics of the generator	16
6.2.3 Calibration of the generator	18
6.3 Coupling/decoupling networks.....	19
6.3.1 General	19
6.3.2 Coupling/decoupling networks for a.c./d.c. power port rated up to 200 A per line	20
6.3.3 Coupling/decoupling networks for interconnection lines	24
6.4 Calibration of coupling/decoupling networks.....	27
6.4.1 General	27
6.4.2 Calibration of CDNs for a.c./d.c. power port rated up to 200 A per line	27
6.4.3 Calibration of CDNs for interconnection lines.....	28
7 Test setup	30
7.1 Test equipment.....	30
7.2 Verification of the test instrumentation	31
7.3 Test setup for surges applied to EUT power ports	31
7.4 Test setup for surges applied to unshielded unsymmetrical interconnection lines	32
7.5 Test setup for surges applied to unshielded symmetrical interconnection lines.....	32
7.6 Test setup for surges applied to shielded lines.....	32
8 Test procedure	33
8.1 General.....	33
8.2 Laboratory reference conditions.....	34
8.2.1 Climatic conditions	34
8.2.2 Electromagnetic conditions	34
8.3 Execution of the test	34
9 Evaluation of test results	35
10 Test report.....	35

Annex A (normative) Surge testing for unshielded outdoor symmetrical communication lines intended to interconnect to widely dispersed systems	37
A.1 General.....	37
A.2 10/700 μ s combination wave generator	37
A.2.1 Characteristics of the generator	37
A.2.2 Performances of the generator	38
A.2.3 Calibration of the generator	40
A.3 Coupling/decoupling networks.....	40
A.3.1 General	40
A.3.2 Coupling/decoupling networks for outdoor communication lines	41
A.4 Calibration of coupling/decoupling networks.....	41
A.5 Test setup for surges applied to outdoor unshielded symmetrical communication lines	42
Annex B (informative) Selection of generators and test levels	44
B.1 General.....	44
B.2 The classification of environments	44
B.3 The definition of port types.....	44
B.4 Generators and surge types	45
B.5 Tables.....	45
Annex C (informative) Explanatory notes	47
C.1 Different source impedance	47
C.2 Application of the tests.....	47
C.2.1 Equipment level immunity	47
C.2.2 System level immunity	47
C.3 Installation classification	48
C.4 Minimum immunity level of ports connected to the a.c./d.c. mains supply.....	49
C.5 Equipment level immunity of ports connected to interconnection lines.....	49
Annex D (informative) Considerations for achieving immunity for equipment connected to low voltage power distribution systems	51
Annex E (informative) Mathematical modelling of surge waveforms	53
E.1 General.....	53
E.2 Normalized time domain voltage surge (1,2/50 μ s).....	54
E.3 Normalized time domain current surge (8/20 μ s)	55
E.4 Normalized time domain voltage surge (10/700 μ s).....	57
E.5 Normalized time domain current surge (5/320 μ s)	59
Annex F (informative) Measurement uncertainty (MU) considerations	62
F.1 Legend	62
F.2 General.....	62
F.3 Uncertainty contributors to the surge measurement uncertainty	63
F.4 Uncertainty of surge calibration.....	63
F.4.1 General	63
F.4.2 Front time of the surge open-circuit voltage	63
F.4.3 Peak of the surge open-circuit voltage	65
F.4.4 Duration of the surge open-circuit voltage.....	66
F.4.5 Further MU contributions to time and amplitude measurements	67
F.4.6 Rise time distortion due to the limited bandwidth of the measuring system.....	67

F.4.7	Impulse peak and width distortion due to the limited bandwidth of the measuring system	68
F.5	Application of uncertainties in the surge generator compliance criterion	69
Annex G (informative)	Method of calibration of impulse measuring systems	70
G.1	General	70
G.2	Estimation of measuring system response using the convolution integral	70
G.3	Impulse measuring system for open-circuit voltage (1,2/50 μ s, 10/700 μ s)	71
G.4	Impulse measuring system for short-circuit current (8/20 μ s, 5/320 μ s)	71
Annex H (informative)	Coupling/decoupling surges to lines rated above 200 A	73
H.1	General	73
H.2	Considerations of coupling and decoupling	73
H.3	Additional precautions	74
Bibliography	75
Figure 1	– Simplified circuit diagram of the combination wave generator	16
Figure 2	– Waveform of open-circuit voltage (1,2/50 μ s) at the output of the generator with no CDN connected	17
Figure 3	– Waveform of short-circuit current (8/20 μ s) at the output of the generator with no CDN connected	18
Figure 4	– Selection of coupling/decoupling method	20
Figure 5	– Example of coupling network and decoupling network for capacitive coupling on a.c./d.c. lines line-to-line coupling	22
Figure 6	– Example of coupling network and decoupling network for capacitive coupling on a.c./d.c. lines: line-to-ground coupling	23
Figure 7	– Example of coupling network and decoupling network for capacitive coupling on a.c. lines (3 phases): line L2-to-line L3 coupling	23
Figure 8	– Example of coupling network and decoupling network for capacitive coupling on a.c. lines (3 phases): line L3-to-ground coupling	24
Figure 9	– Example of coupling network and decoupling network for unshielded unsymmetrical interconnection lines: line-to-line and line-to-ground coupling	25
Figure 10	– Example of coupling and decoupling network for unshielded symmetrical interconnection lines: lines-to-ground coupling	26
Figure 11	– Example of coupling and decoupling network for unshielded symmetrical interconnection lines: lines-to-ground coupling via capacitors	27
Figure 12	– Example of test setup for surges applied to shielded lines	33
Figure A.1	– Simplified circuit diagram of the combination wave generator (10/700 μ s – 5/320 μ s)	38
Figure A.2	– Waveform of open-circuit voltage (10/700 μ s)	39
Figure A.3	– Waveform of the 5/320 μ s short-circuit current waveform	39
Figure A.4	– Example of test setup for unshielded outdoor symmetrical communication lines: lines-to-ground coupling, coupling via gas arrestors (primary protection fitted)	41
Figure E.1	– Voltage surge (1,2/50 μ s): width time response T_w	54
Figure E.2	– Voltage surge (1,2/50 μ s): rise time response T_r	55
Figure E.3	– Voltage surge (1,2/50 μ s): spectral response with $\Delta f = 3,333$ kHz	55
Figure E.4	– Current surge (8/20 μ s): width time response T_w	56
Figure E.5	– Current surge (8/20 μ s): rise time response T_r	57
Figure E.6	– Current surge (8/20 μ s): spectral response with $\Delta f = 10$ kHz	57

Figure E.7 – Voltage surge (10/700 μ s): width time response T_w	58
Figure E.8 – Voltage surge (10/700 μ s): rise time response T_r	59
Figure E.9 – Voltage surge (10/700 μ s): spectral response with $\Delta f = 0,2$ kHz	59
Figure E.10 – Current surge (5/320 μ s): width time response T_w	60
Figure E.11 – Current surge (5/320 μ s): rise time response T_r	61
Figure E.12 – Current surge (5/320 μ s): spectral response with $\Delta f = 0,4$ kHz	61
Figure G.1 – Simplified circuit diagram of the current step generator	72
Table 1 – Test levels	15
Table 2 – Definitions of the waveform parameters 1,2/50 μ s and 8/20 μ s	17
Table 3 – Relationship between peak open-circuit voltage and peak short-circuit current	17
Table 4 – Voltage waveform specification at the EUT port of the CDN	21
Table 5 – Current waveform specification at the EUT port of the CDN	21
Table 6 – Relationship between peak open-circuit voltage and peak short-circuit current at the EUT port of the CDN	22
Table 7 – Summary of calibration process for CDNs for unsymmetrical interconnection lines	28
Table 8 – Surge waveform specifications at the EUT port of the CDN for unsymmetrical interconnection lines	29
Table 9 – Summary of calibration process for CDNs for symmetrical interconnection lines	30
Table 10 – Surge waveform specifications at the EUT port of the CDN for symmetrical interconnection lines	30
Table A.1 – Definitions of the waveform parameters 10/700 μ s and 5/320 μ s	39
Table A.2 – Relationship between peak open-circuit voltage and peak short-circuit current	40
Table A.3 – Summary of calibration process for CDNs for unshielded outdoor symmetrical communication lines	42
Table A.4 – Surge waveform specifications at the EUT port of the CDN for unshielded outdoor symmetrical communication lines	42
Table B.1 – Power ports: selection of the test levels (depending on the installation class)	45
Table B.2 – Circuits/lines: selection of the test levels (depending on the installation class)	46
Table F.1 – Example of uncertainty budget for surge open-circuit voltage front time (T_{fv})	64
Table F.2 – Example of uncertainty budget for surge open-circuit voltage peak value (V_p)	65
Table F.3 – Example of uncertainty budget for surge open-circuit voltage duration (T_d)	66
Table F.4 – α factor, Equation (F.5), of different unidirectional impulse responses corresponding to the same bandwidth of the system B	68
Table F.5 – β factor, Equation (F.9), of the standard surge waveforms	69
Table H.1 – Recommended inductance values for decoupling lines (> 200 A)	73

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

ELECTROMAGNETIC COMPATIBILITY (EMC) –**Part 4-5: Testing and measurement techniques –
Surge immunity test**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61000-4-5 has been prepared by subcommittee 77B: High frequency phenomena, of IEC technical Committee 77: Electromagnetic compatibility.

It forms Part 4-5 of IEC 61000. It has the status of a basic EMC publication in accordance with IEC Guide 107.

This third edition cancels and replaces the second edition published in 2005, and constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) new Annex E on mathematical modelling of surge waveforms;
- b) new Annex F on measurement uncertainty;
- c) new Annex G on method of calibration of impulse measuring systems;

- d) new Annex H on coupling/decoupling surges to lines rated above 200 A;
- e) moreover while surge test for ports connected to outside telecommunication lines was addressed in 6.2 of the second edition (IEC 61000-4-5:2005), in this third edition (IEC 61000-4-5:2014) the normative Annex A is fully dedicated to this topic. In particular it gives the specifications of the 10/700 μ s combined wave generator.

The text of this standard is based on the following documents:

FDIS	Report on voting
77B/711/FDIS	77B/715/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61000 series, published under the general title *Electromagnetic compatibility (EMC)*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC 61000 is published in separate parts according to the following structure:

Part 1: General

General considerations (introduction, fundamental principles)

Definitions, terminology

Part 2: Environment

Description of the environment

Classification of the environment

Compatibility levels

Part 3: Limits

Emission limits

Immunity limits (insofar as they do not fall under the responsibility of the product committees)

Part 4: Testing and measurement techniques

Measurement techniques

Testing techniques

Part 5: Installation and mitigation guidelines

Installation guidelines

Mitigation methods and devices

Part 6: Generic standards

Part 9: Miscellaneous

Each part is further subdivided into several parts, published either as international standards or as technical specifications or technical reports, some of which have already been published as sections. Others will be published with the part number followed by a dash and a second number identifying the subdivision (example: IEC 61000-6-1).

This part is an International Standard which gives immunity requirements and test procedures related to surge voltages and surge currents.

ELECTROMAGNETIC COMPATIBILITY (EMC) –

Part 4-5: Testing and measurement techniques – Surge immunity test

1 Scope and object

This part of IEC 61000 relates to the immunity requirements, test methods, and range of recommended test levels for equipment with regard to unidirectional surges caused by over-voltages from switching and lightning transients. Several test levels are defined which relate to different environment and installation conditions. These requirements are developed for and are applicable to electrical and electronic equipment.

The object of this standard is to establish a common reference for evaluating the immunity of electrical and electronic equipment when subjected to surges. The test method documented in this part of IEC 61000 describes a consistent method to assess the immunity of an equipment or system against a defined phenomenon.

NOTE As described in IEC Guide 107, this is a basic EMC publication for use by product committees of the IEC. As also stated in Guide 107, the IEC product committees are responsible for determining whether this immunity test standard is applied or not, and if applied, they are responsible for determining the appropriate test levels and performance criteria. TC 77 and its sub-committees are prepared to co-operate with product committees in the evaluation of the value of particular immunity test levels for their products.

This standard defines:

- a range of test levels;
- test equipment;
- test setups;
- test procedures.

The task of the described laboratory test is to find the reaction of the equipment under test (EUT) under specified operational conditions to surge voltages caused by switching and lightning effects.

It is not intended to test the capability of the EUT's insulation to withstand high-voltage stress. Direct injections of lightning currents, i.e. direct lightning strikes, are not considered in this standard.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050 (all parts), *International Electrotechnical Vocabulary (IEV)* (available at www.electropedia.org)