

© Copyright SEK. Reproduction in any form without permission is prohibited.

Industriell processtyrning – Mätgivare med analoga ut signaler – Del 3: Utvärdering av prestanda hos intelligenta mätgivare

*Transmitters for use in industrial-process control systems –
Part 3: Methods for performance evaluation of intelligent transmitters*

Som svensk standard gäller europastandarden EN 60770-3:2014. Den svenska standarden innehåller den officiella engelska språkversionen av EN 60770-3:2014.

Nationellt förord

Europastandarden EN 60770-3:2014

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 60770-3, Second edition, 2014 - Transmitters for use in industrial-process control systems - Part 3: Methods for performance evaluation of intelligent transmitters**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 60770-3, utgåva 1, 2007, gäller ej fr o m 2017-06-27.

ICS 25.040.40

Denna standard är fastställd av SEK Svensk Elstandard, som också kan lämna upplysningar om **sakinnehållet** i standarden.
Postadress: Box 1284, 164 29 KISTA
Telefon: 08 - 444 14 00.
E-post: sek@elstandard.se. Internet: www.elstandard.se

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English Version

Transmitters for use in industrial-process control systems - Part 3: Methods for performance evaluation of intelligent transmitters (IEC 60770-3:2014)

Transmetteurs utilisés dans les systèmes de commande des processus industriels - Partie 3: Méthodes d'évaluation des performances des transmetteurs intelligents (CEI 60770-3:2014)

Messumformer für industrielle Prozessleittechnik - Teil 3: Verfahren zur Bewertung der Leistungsfähigkeit von intelligenten Messumformern (IEC 60770-3:2014)

This European Standard was approved by CENELEC on 2014-06-27. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 65B/917/FDIS, future edition 2 of IEC 60770-3, prepared by SC 65B "Measurement and control devices" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60770-3:2014.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-03-27
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2017-06-27

This document supersedes EN 60770-3:2006.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 60770-3:2014 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60068-2-1	NOTE	Harmonized as EN 60068-2-1.
IEC 60068-2-2	NOTE	Harmonized as EN 60068-2-2.
IEC 60068-2-6	NOTE	Harmonized as EN 60068-2-6.
IEC 60068-2-31	NOTE	Harmonized as EN 60068-2-31.
IEC 60068-2-78	NOTE	Harmonized as EN 60068-2-78.
IEC 60654 Series	NOTE	Harmonized as EN 60654 Series (not modified).
IEC 61298 Series	NOTE	Harmonized as EN 61298 Series (not modified).
IEC 61508 Series	NOTE	Harmonized as EN 61508 Series (not modified).

Annex ZA
(normative)

**Normative references to international publications
with their corresponding European publications**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050	Series	International Electrotechnical Vocabulary (IEV)	-	-
IEC 60381	Series	Analogue signals for process control systems	HD 452.1 S1	
IEC 60529	-	Degrees of protection provided by enclosures (IP Code)	EN 60529	-
IEC 60721-3	Series	Classification of environmental conditions - Part 3: Classification of groups of environmental parameters and their severities	EN 60721-3	Series
IEC 61010-1	-	Safety requirements for electrical equipment for measurement, control and laboratory use - Part 1: General requirements	EN 61010-1	-
IEC 61032	-	Protection of persons and equipment by enclosures - Probes for verification	EN 61032	-
IEC 61158	Series	Industrial communication networks - Fieldbus specifications	EN 61158	Series
IEC 61298	Series	Process measurement and control devices - General methods and procedures for evaluating performance	EN 61298	Series
IEC 61298-1	2008	Process measurement and control devices - General methods and procedures for evaluating performance - Part 1: General considerations	EN 61298-1	2008
IEC 61298-2	2008	Process measurement and control devices - General methods and procedures for evaluating performance - Part 2: Tests under reference conditions	EN 61298-2	2008

IEC 61298-3	2008	Process measurement and control devices - General methods and procedures for evaluating performance - Part 3: Tests for the effects of influence quantities	EN 61298-3	2008
IEC 61298-4	-	Process measurement and control devices - General methods and procedures for evaluating performance - Part 4: Evaluation report content	EN 61298-4	-
IEC 61326	Series	Electrical equipment for measurement, control and laboratory use - EMC requirements	EN 61326	Series
IEC 61326-1	-	Electrical equipment for measurement, control and laboratory use - EMC requirements - Part 1: General requirements	EN 61326-1	-
IEC 61499	Series	Function blocks	EN 61499	Series
IEC 61804	Series	Function Blocks (FB) for process control	EN 61804	Series
CISPR 11	-	Industrial, scientific and medical equipment - Radio-frequency disturbance characteristics - Limits and methods of measurement	EN 55011	-

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references.....	8
3 Terms and definitions	9
4 Design assessment.....	10
4.1 General.....	10
4.2 Transmitter analysis	11
4.2.1 General	11
4.2.2 Data processing subsystem.....	12
4.2.3 Sensor subsystem.....	12
4.2.4 Human interface	13
4.2.5 Communication interface.....	13
4.2.6 Electrical output subsystem.....	13
4.2.7 Power supply unit.....	14
4.2.8 External functionality.....	14
4.2.9 Cycle times (<i>ct</i>).....	14
4.3 Aspects to be reviewed	14
4.3.1 General	14
4.3.2 Functionality	15
4.3.3 Configurability.....	16
4.3.4 Hardware configuration	17
4.3.5 Adjustment and tuning	18
4.3.6 Operability	19
4.3.7 Dependability.....	20
4.3.8 Manufacturer's support	21
4.3.9 Reporting.....	22
4.4 Documentary information.....	22
5 Performance testing.....	23
5.1 General.....	23
5.2 Instrument considerations	23
5.2.1 General	23
5.2.2 Example of a single variable transmitter	24
5.2.3 Example of a derived variable transmitter	24
5.3 Measurement considerations	25
5.3.1 General	25
5.3.2 Single variables	25
5.3.3 Derived variable.....	26
5.4 Test facilities.....	26
5.4.1 General	26
5.4.2 Signal generator	27
5.4.3 Output load/receiver.....	27
5.4.4 Control and data acquisition	28
5.5 Transmitter under test (testing precautions).....	28
5.6 Reference conditions for performance tests.....	28
5.7 Test procedures for tests under reference conditions.....	29

5.8	Test procedures for determination of the effects of influence quantities.....	32
5.8.1	General	32
5.8.2	Process domain	34
5.8.3	Utility domain	39
5.8.4	Environmental domain.....	41
5.8.5	Time domain.....	43
6	Other considerations.....	43
6.1	Safety	43
6.2	Degree of protection provided by enclosures	43
6.3	Electromagnetic emission.....	44
6.4	Variants	44
7	Evaluation report.....	44
Annex A (informative) Dependability testing.....		45
A.1	General.....	45
A.2	Design analysis	45
A.3	Reference conditions.....	45
A.4	Fault injection test for internal instrument failures	47
A.5	Observations.....	47
A.5.1	General	47
A.5.2	Reporting and ranking of fault behaviour	48
A.6	Human faults.....	50
A.6.1	Mis-operation test	50
A.6.2	Maintenance error test	51
A.6.3	Expectations and reporting.....	51
Annex B (informative) Throughput testing		52
B.1	General.....	52
B.2	Transmitter throughput (stand-alone).....	53
B.2.1	Reference conditions	53
B.2.2	Test conditions	53
B.2.3	Observations and measurements	54
B.3	Throughput in a fieldbus configuration	54
B.3.1	Reference conditions	54
B.3.2	Test conditions	54
B.3.3	Observations and measurements	55
B.3.4	Precautions.....	55
Annex C (informative) Function block testing		56
C.1	General.....	56
C.2	General qualitative checks	56
C.3	Time-dependent function blocks	56
C.4	Time-independent function blocks	56
Bibliography.....		57
Figure 1 – Intelligent transmitter model.....		12
Figure 2 – Basic test set-up.....		27
Figure 3 – Examples of step responses of electrical outputs of transmitters		31
Figure A.1 – Example schematic of a transmitter		46
Figure A.2 – Test tool for low impedance circuits and shared circuits		47

Figure A.3 – Matrix for reporting fault behaviour	49
Figure A.4 – Ranking of various types of failure modes.....	50
Figure B.1 – Transmitter in stand-alone configuration	52
Figure B.2 – Transmitter as a participant in a fieldbus installation	53
Table 1 – Checklist for mapping functionality.....	15
Table 2 – Checklist for mapping configurability	16
Table 3 – Checklist for mapping hardware-configuration	17
Table 4 – Checklist for mapping adjustment and tuning procedures	18
Table 5 – Checklist for mapping operability.....	19
Table 6 – Checklist for mapping dependability	20
Table 7 – Checklist for mapping manufacturer’s support.....	21
Table 8 – Reporting format for design review.....	22
Table 9 – Checklist on available documentation.....	22
Table 10 – Listing of functions of a single variable transmitter.....	24
Table 11 – Listing of functions of derived variable transmitter	25
Table 12 – Reference environmental and operational test conditions	29
Table 13 – Procedures for tests under reference conditions	29
Table 14 – Methods for testing immunity to sensor disturbances – Matrix of instrument properties and tests	35
Table 15 – Methods for testing immunity to wiring disturbances	37
Table 16 – Methods for testing the immunity to disturbances of the power utilities.....	39
Table 17 – Methods for testing the immunity to environmental disturbances	41
Table 18 – Methods for testing the immunity to degradation in time.....	43

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**TRANSMITTERS FOR USE IN INDUSTRIAL-PROCESS
CONTROL SYSTEMS –****Part 3: Methods for performance evaluation
of intelligent transmitters**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The International Standard IEC 60770-3 has been prepared by subcommittee 65B: Measurement and control devices, of IEC technical committee 65: Industrial-process measurement, control and automation.

This second edition cancels and replaces the first edition published in 2006. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Introduction.
- b) Terms and definitions: all definitions already present in IEC 60050 and in IEC 61298 have been deleted.
- c) All parts: added concept of wireless transmitters.

The text of this standard is based on the following documents:

FDIS	Report on voting
65B/917/FDIS	65B/930/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60770, published under the general title *Transmitters for use in industrial-process control systems*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

New transmitters for use in industrial process control systems are now equipped with micro-processors which utilise digital data processing and communication methods, auxiliary sensors and artificial intelligence. This makes them more complex than conventional analogue transmitters and gives them considerable added value.

An intelligent transmitter is an instrument that uses digital data processing and communication methods for performing its functions and for safeguarding and communicating data and information on its operation. It may be equipped with additional sensors and functionality which support the main function of the intelligent transmitter. The variety of added functionality can for instance enhance accuracy and rangeability, self-test capabilities, and alarm and condition monitoring. Therefore accuracy-related performance testing, although still a major tool for evaluation, is no longer sufficient to show the flexibility, capability and other features with respect to engineering, installation, maintainability, reliability and operability.

Because of the complexity of intelligent transmitters, a close collaboration should be maintained between the evaluating body and the manufacturer during the evaluation. Note should be taken of the manufacturer's specifications for the instrument, when the test programme is being decided, and the manufacturer should be invited to comment on both the test programme and the results. His comments on the results should be included in any report produced by the testing organisation.

This part of IEC 60770 addresses, in its main body, structured and mandatory methods for a design review and performance testing of intelligent transmitters. Intelligent transmitters will, in many cases, also have the capacity to be integrated into digital communication (bus) systems, where they have to co-operate with a variety of devices. In this case, dependability, (inter)operability and real-time behaviour are important issues. The testing of these aspects depends largely on the internal structure and organisation of the intelligent transmitter and the architecture and size of the bus system. The Annexes A, B and C give a non-mandatory methodology and framework for designing specific evaluation procedures for dependability and throughput testing and function block testing in a specific case.

When a full evaluation, in accordance with this part of IEC 60770, is not required or possible, those tests which are required, should be performed and the results reported in accordance with the relevant parts of this standard. In such cases, the test report should state that it does not cover the full number of tests specified herein. Furthermore, the items omitted should be mentioned, in order to give the reader of the report a clear overview.

The structure of this part of IEC 60770 largely follows the framework of IEC 62098. For performance testing, the IEC 61298 series should also be consulted. A number of tests described there are still valid for intelligent transmitters. Further reading of the IEC 61069 series is recommended, as some notions in this part of IEC 60770 are based on concepts brought forward therein.

TRANSMITTERS FOR USE IN INDUSTRIAL-PROCESS CONTROL SYSTEMS –

Part 3: Methods for performance evaluation of intelligent transmitters

1 Scope

This part of IEC 60770 specifies the following methods.

- Methods for
 - assessment of the functionality of intelligent transmitters;
 - testing the operational behaviour, as well as the static and dynamic performance of an intelligent transmitter.
- Methodologies for
 - determining the reliability and diagnostic features used to detect malfunctions;
 - determining the communication capabilities of the intelligent transmitters in a communication network.

The methods and methodologies are applicable to intelligent transmitters, which convert one or more physical, chemical or electrical quantities into digital signals for use in a communication network (as specified in the IEC 61158 series or others) or into analogue electrical signals (as specified in the IEC 60381 series).

The methods and methodologies listed in this part of IEC 60770 are intended for use by:

- manufacturers to determine the performance of their products, and
- users or independent testing laboratories to verify equipment performance specifications.

Manufacturers of intelligent transmitters are urged to apply this part of IEC 60770 at an early stage of development.

This standard is intended to provide guidance for designing evaluations of intelligent transmitters by providing:

- a checklist for reviewing the hardware and software design in a structured way;
- test methods for measuring and qualifying the performance, dependability and operability under various environmental and operational conditions;
- methods for reporting the data obtained.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050 (all parts), *International Electrotechnical Vocabulary* (available at <http://www.electropedia.org>)

IEC 60381 (all parts), *Analogue signals for process control systems*

IEC 60529, *Degree of protection provided by enclosures (IP Code)*

IEC 60721-3 (all parts), *Classification of environmental conditions – Part 3: Classification of groups of environmental parameters and their severities*

IEC 61010-1, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 1: General requirements*

IEC 61032, *Protection of persons and equipment by enclosures – Probes for verification*

IEC 61158 (all parts), *Industrial communication networks – Fieldbus specifications*

IEC 61298 (all parts), *Process measurement and control devices – General methods and procedures for evaluating performance*

IEC 61298-1:2008, *Process measurement and control devices – General methods and procedures for evaluating performance – Part 1: General considerations*

IEC 61298-2:2008, *Process measurement and control devices – General methods and procedures for evaluating performance – Part 2: Tests under reference conditions*

IEC 61298-3:2008, *Process measurement and control devices – General methods and procedures for evaluating performance – Part 3: Tests for the effects of influence quantities*

IEC 61298-4, *Process measurement and control devices – General methods and procedures for evaluating performance – Part 4: Evaluation report content*

IEC 61326 (all parts), *Electrical equipment for measurement, control and laboratory use – EMC requirements*

IEC 61326-1, *Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 1: General requirements*

IEC 61499 (all parts), *Function blocks*

IEC 61804 (all parts), *Function blocks (FB) for process control*

CISPR 11, *Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement*