

© Copyright SEK. Reproduction in any form without permission is prohibited.

## Industriell processtyrning – Fältbuss – Del 6-3: Specifikation av protokoll i applikationsskiktet – Delar i fältbuss, Typ 3

*Industrial communication networks –  
Fieldbus specifications –  
Part 6-3: Application layer protocol specification –  
Type 3 elements*

Som svensk standard gäller europastandarden EN 61158-6-3:2014. Den svenska standarden innehåller den officiella engelska språkversionen av EN 61158-6-3:2014.

### Nationellt förord

Europastandarden EN 61158-6-3:2014

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 61158-6-3, Third edition, 2014 - Industrial communication networks - Fieldbus specifications - Part 6-3: Application layer protocol specification - Type 3 elements**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 61158-6-3, utgåva 2, 2012, gäller ej fr o m 2017-09-23.

---

ICS 25.040.40; 35.100.70; 35.110.00

---

Denna standard är fastställd av SEK Svensk Elstandard, som också kan lämna upplysningar om **sakinnehållet** i standarden.  
Postadress: Box 1284, 164 29 KISTA  
Telefon: 08 - 444 14 00.  
E-post: [sek@elstandard.se](mailto:sek@elstandard.se). Internet: [www.elstandard.se](http://www.elstandard.se)

---

### *Standarder underlättar utvecklingen och höjer elsäkerheten*

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

### *SEK är Sveriges röst i standardiseringsarbetet inom elområdet*

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

### *Stora delar av arbetet sker internationellt*

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

### *Var med och påverka!*

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

### **SEK Svensk Elstandard**

Box 1284  
164 29 Kista  
Tel 08-444 14 00  
[www.elstandard.se](http://www.elstandard.se)

English Version

**Industrial communication networks - Fieldbus specifications -  
Part 6-3: Application layer protocol specification - Type 3  
elements  
(IEC 61158-6-3:2014)**

Réseaux de communication industriels - Spécifications des  
bus de terrain - Partie 6-3: Spécification du protocole de la  
couche application - Éléments de type 3  
(CEI 61158-6-3:2014)

Industrielle Kommunikationsnetze - Feldbusse - Teil 6-3:  
Protokollspezifikation des Application Layer  
(Anwendungsschicht) - Typ 3-Elemente  
(IEC 61158-6-3:2014)

This European Standard was approved by CENELEC on 2014-09-23. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

## Foreword

The text of document 65C/764/FDIS, future edition 3 of IEC 61158-6-3, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61158-6-3:2014.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-06-23
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2017-09-23

This document supersedes EN 61158-6-3:2012.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

## Endorsement notice

The text of the International Standard IEC 61158-6-3:2014 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61158-1:2014	NOTE	Harmonized as EN 61158-1:2014 (not modified).
IEC 61784-1	NOTE	Harmonized as EN 61784-1.
IEC 61784-2	NOTE	Harmonized as EN 61784-2.

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: [www.cenelec.eu](http://www.cenelec.eu).

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61158-3-3	2014	Industrial communication networks - Fieldbus specifications - Part 3-3: Data-link layer service definition - Type 3 elements	EN 61158-3-3	2014
IEC 61158-4-3	2014	Industrial communication networks - Fieldbus specifications - Part 4-3: Data-link layer protocol specification - Type 3 elements	EN 61158-4-3	<sup>1)</sup>
IEC 61158-5-3	2014	Industrial communication networks - Fieldbus specifications - Part 5-3: Application layer service definition - Type 3 elements	EN 61158-5-3	2014
IEC 61158-5-10	2014	Industrial communication networks - Fieldbus specifications - Part 5-10: Application layer service definition - Type 10 elements	EN 61158-5-10	2014
IEC 61158-6-10	2014	Industrial communication networks - Fieldbus specifications - Part 6-10: Application layer protocol specification - Type 10 elements	EN 61158-6-10	2014
ISO/IEC 7498-1	-	Information technology - Open Systems Interconnection - Basic Reference Model: The Basic Model	-	-
ISO/IEC 8822	-	Information technology - Open Systems Interconnection - Presentation service definition	-	-
ISO/IEC 8824-1	-	Information technology - Abstract Syntax Notation One (ASN.1): Specification of basic notation	-	-

---

<sup>1)</sup> To be published.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
ISO/IEC 9545	-	Information technology - Open Systems Interconnection - Application layer structure	-	-
ISO/IEC 10731	-	Information technology - Open Systems Interconnection - Basic Reference Model - Conventions for the definition of OSI services	-	-
IEEE 754	-	IEEE Standard for Floating-Point Arithmetic	-	-

## CONTENTS

FOREWORD.....	8
INTRODUCTION.....	10
1 Scope.....	11
1.1 General.....	11
1.2 Specifications.....	12
1.3 Conformance.....	12
2 Normative references .....	12
3 Terms, definitions, abbreviations, symbols and conventions .....	13
3.1 Referenced terms and definitions .....	13
3.2 Additional definitions .....	14
3.3 Abbreviations and symbols.....	17
3.4 Conventions .....	18
3.5 Conventions used in state machines .....	20
4 FAL syntax description .....	23
4.1 APDU abstract syntax .....	23
4.2 Data types.....	27
5 Transfer syntax .....	28
5.1 Coding of basic data types .....	28
5.2 Coding section related to data exchange PDUs .....	30
5.3 Coding section related to slave diagnosis PDUs.....	30
5.4 Coding section related to parameterization PDU.....	41
5.5 Coding section related to configuration PDUs.....	49
5.6 Coding section related to global control PDUs.....	51
5.7 Coding section related to clock-value-PDUs .....	53
5.8 Coding section related to function identification and errors .....	54
5.9 Coding section related to master diagnosis PDU .....	57
5.10 Coding section related to upload/download/act para PDUs .....	60
5.11 Coding section related to the bus parameter set.....	62
5.12 Coding section related to the slave parameter set .....	64
5.13 Coding section related to statistic counters .....	68
5.14 Coding section related to set slave address PDU .....	68
5.15 Coding section related to initiate/abort PDUs .....	68
5.16 Coding section related to read/write/data transport PDUs.....	72
5.17 Coding section related to load region and function invocation PDUs.....	72
5.18 Examples of diagnosis-RES-PDUs .....	76
5.19 Example of Chk_Cfg-REQ-PDU.....	78
5.20 Examples of Chk_Cfg-REQ-PDUs with DPV1 data types .....	78
5.21 Example structure of the Data_Unit for Data_Exchange .....	80
6 FAL protocol state machines .....	81
6.1 Overall structure.....	81
6.2 Assignment of state machines to devices .....	83
6.3 Overview DP-slave.....	84
6.4 Overview DP-master (class 1) .....	86
6.5 Overview DP-master (class 2) .....	87
6.6 Cyclic communication between DP-master (class 1) and DP-slave .....	88

6.7	Acyclic communication between DP-master (class 2) and DP-master (class 1) .....	89
6.8	Acyclic communication between DP-master (class 1) and DP-slave .....	91
6.9	Application relationship monitoring .....	93
7	AP-context state machine .....	98
8	FAL service protocol machines (FSPMs) .....	99
8.1	FSPMS .....	99
8.2	FSPMM1 .....	134
8.3	FSPMM2 .....	169
9	Application relationship protocol machines (ARPMs) .....	186
9.1	MSCY1S .....	186
9.2	MSAC1S .....	216
9.3	SSCY1S .....	229
9.4	MSRM2S .....	232
9.5	MSAC2S .....	238
9.6	MSCS1S .....	254
9.7	MSCY1M .....	256
9.8	MSAL1M .....	274
9.9	MSAC1M .....	283
9.10	MMAC1 .....	296
9.11	MSCS1M .....	303
9.12	MSAC2M .....	307
9.13	MMAC2 .....	322
10	DLL mapping protocol machines (DMPMs) .....	329
10.1	DMPMS .....	329
10.2	DMPMM1 .....	343
10.3	DMPMM2 .....	358
11	Parameters for a DP-slave .....	366
	Bibliography .....	367
	Figure 1 – Common structure of specific fields .....	19
	Figure 2 – Example Modul_Status_Array .....	36
	Figure 3 – Example of Ext_Diag_Data in case of DPV1 diagnosis format with alarm and status PDU .....	76
	Figure 4 – Example of Ext_Diag_Data in case of the basic diagnosis format .....	78
	Figure 5 – Example of a special identifier format .....	78
	Figure 6 – Example of a special identifier format with data types .....	79
	Figure 7 – Example of a special identifier format with data types .....	79
	Figure 8 – Example of an empty slot with data types .....	80
	Figure 9 – Example for multi-variable device with AI and DO function blocks .....	80
	Figure 10 – Identifiers (ID) .....	81
	Figure 11 – Identifier list .....	81
	Figure 12 – Structure of the Data_Unit for the request- and response-DLPDU .....	81
	Figure 13 – Structuring of the protocol machines and adjacent layers in a DP-slave .....	85
	Figure 14 – Structuring of the protocol machines and adjacent layers in a DP-master (class 1) .....	86



Figure 15 – Structuring of the protocol machines and adjacent layers in a DP-master (class 2).....	87
Figure 16 – Sequence of the communication between DP-master and DP-slave .....	89
Figure 17 – Sequence of communication between DP-master (class 2) and DP-master (class 1).....	91
Figure 18 – Sequence of acyclic communication between DP-master (class 1) and DP-slave.....	93
Figure 19 – Example for connection establishment on MS2.....	96
Figure 20 – Idle at master-side on MS2.....	97
Figure 21 – Idle at slave-side on MS2 .....	98
Figure 22 – Example for connection establishment on MS2(server-side).....	234
Figure 23 – Structure of RM entries in the RM_Register.....	235
Table 1 – State machine description elements .....	20
Table 2 – Description of state machine elements .....	21
Table 3 – Conventions used in state machines .....	21
Table 4 – APDU syntax.....	23
Table 5 – Substitutions .....	25
Table 6 – Block_Length range .....	32
Table 7 – Selection range .....	33
Table 8 – Alarm_Type range.....	33
Table 9 – Status_Type value range.....	33
Table 10 – Alarm_Specifier.....	34
Table 11 – Range of Modul_Status_Entry (1-4).....	36
Table 12 – Input_Output_Selection .....	38
Table 13 – Error type .....	38
Table 14 – Channel_Type .....	38
Table 15 – Specification of the bits Lock_Req and Unlock_Req .....	42
Table 16 – Range of Length_of_Manufacturer_Specific_Data if used in Chk_Cfg-REQ-PDU.....	50
Table 17 – Range of Length_of_Manufacturer_Specific_Dat if used in Get_Cfg-RES-PDU .....	50
Table 18 – Data types .....	51
Table 19 – Specification of the bits for Un-/Freeze.....	52
Table 20 – Specification of the bits for Un-/Sync.....	52
Table 21 – Coding of the Function_Code/ Function_Num.....	54
Table 22 – Coding of the Error_Code / Function_Num .....	55
Table 23 – Values of Error_Decode .....	56
Table 24 – Coding of Error_Code_1 at DPV1.....	57
Table 25 – Values of MDiag_Identifier .....	58
Table 26 – Values for Area_Code_UpDownload.....	60
Table 27 – Values for Area_CodeActBrct.....	61
Table 28 – Values for Area_CodeAct .....	61
Table 29 – Values for Activate .....	61
Table 30 – Values for Data_rate .....	62

Table 31 – Values for Slave_Type .....	65
Table 32 – Values for Alarm_Mode .....	66
Table 33 – Values for Subnet.....	71
Table 34 – Values of reason code if instance is DLL .....	71
Table 35 – Values of reason code if instance is MS2 .....	71
Table 36 – Values of Extended_Function_Num .....	72
Table 37 – Values of FI_Index .....	74
Table 38 – Values of FI_State.....	74
Table 39 – IMData_Execution_Argument .....	75
Table 40 – IMData_Result_Argument.....	75
Table 41 – Assignment of state machines .....	84
Table 42 – Primitives issued by AP-Context to FSPMS .....	99
Table 43 – Primitives issued by FSPMS to AP-Context .....	101
Table 44 – FSPMS state table .....	108
Table 45 – Functions used by the FSPMS.....	132
Table 46 – Primitives issued by AP-Context to FSPMM1.....	134
Table 47 – Primitives issued by FSPMM1 to AP-Context.....	136
Table 48 – FSPMM1 state table .....	143
Table 49 – Functions used by the FSPMM1 .....	168
Table 50 – Primitives issued by AP-Context to FSPMM2.....	169
Table 51 – Primitives issued by FSPMM2 to AP-Context.....	171
Table 52 – FSPMM2 state table .....	174
Table 53 – Functions used by the FSPMM2 .....	185
Table 54 – Primitives issued by FSPMS to MSCY1S .....	186
Table 55 – Primitives issued by MSCY1S to FSPMS .....	186
Table 56 – Rules for DPV1_Status_1, DPV1_Status_2 and DPV1_Status_3 check .....	188
Table 57 – MSCY1S state table .....	193
Table 58 – Functions used by the MSCY1S .....	214
Table 59 – Primitives issued by FSPMS to MSAC1S .....	216
Table 60 – Primitives issued by MSAC1S to FSPMS .....	217
Table 61 – Primitives issued by MSCY1S to MSAC1S.....	217
Table 62 – Primitives issued by MSAC1S to MSCY1S.....	217
Table 63 – Parameter used with primitives exchanged between MSAC1S and MSCY1S .....	217
Table 64 – MSAC1S state table .....	219
Table 65 – Functions used by the MSAC1S .....	228
Table 66 – Primitives issued by FSPMS to SSCY1S .....	229
Table 67 – Primitives issued by SSCY1S to FSPMS .....	229
Table 68 – SSCY1S state table.....	230
Table 69 – Functions used by the SSCY1S.....	232
Table 70 – Primitives issued by FSPMS to MSRM2S .....	232
Table 71 – Primitives issued by MSRM2S to FSPMS .....	232
Table 72 – MSRM2S state table.....	236
Table 73 – Primitives issued by FSPMS to MSAC2S .....	238

Table 74 – Primitives issued by MSAC2S to FSPMS .....	239
Table 75 – Primitives issued by MSRM2S to MSAC2S .....	240
Table 76 – Primitives issued by MSAC2S to MSRM2S .....	240
Table 77 – Parameter used with primitives exchanged with MSAC2S.....	240
Table 78 – MSAC2S state table .....	243
Table 79 – Primitives issued by MSCS1S to FSPMS .....	254
Table 80 – MSCS1S state table .....	255
Table 81 – Primitives issued by FSPMM1 to MSCY1M .....	256
Table 82 – Primitives issued by MSCY1M to FSPMM1 .....	256
Table 83 – Parameters used with primitives exchanged between FSPMM1 and MSCY1M .....	257
Table 84 – MSCY1M state table.....	260
Table 85 – Primitives issued by FSPMM1 to MSAL1M .....	275
Table 86 – Primitives issued by MSAL1M to FSPMM1 .....	275
Table 87 – Primitives issued by MSCY1M to MSAL1M .....	275
Table 88 – Primitives issued by MSAL1M to MSCY1M .....	275
Table 89 – Parameter used with primitives exchanged between MSAL1M and MSCY1M.....	276
Table 90 – Possible values in the Alarm_State_Table .....	277
Table 91 – MSAL1M state table .....	279
Table 92 – Primitives issued by FSPMM1 to MSAC1M .....	284
Table 93 – Primitives issued by MSAC1M to FSPMM1 .....	284
Table 94 – Primitives issued by MSAL1M to MSAC1M .....	285
Table 95 – Primitives issued by MSAC1M to MSAL1M .....	285
Table 96 – Parameter used with primitives exchanged between MSAL1M and MSCY1M.....	285
Table 97 – MSAC1M state table.....	291
Table 98 – Primitives issued by FSPMM1 to MMAC1 .....	297
Table 99 – Primitives issued by MMAC1 to FSPMM1 .....	297
Table 100 – MMAC1 state table .....	298
Table 101 – Primitives issued by FSPMM1 to MSCS1M .....	303
Table 102 – Primitives issued by MSCS1M to FSPMM1 .....	304
Table 103 – MSCS1M state table.....	305
Table 104 – Primitives issued by FSPMM2 to MSAC2M .....	308
Table 105 – Primitives issued by MSAC2M to FSPMM2 .....	308
Table 106 – Parameters used with primitives exchanged with MSAC2M .....	309
Table 107 – MSAC2M state table.....	313
Table 108 – Primitives issued by FSPMM2 to MMAC2 .....	323
Table 109 – Primitives issued by MMAC2 to FSPMM2 .....	323
Table 110 – Parameters used with primitives exchanged with MMAC2.....	324
Table 111 – MMAC2 state table .....	325
Table 112 – Primitives issued by FSPMS to DMPMS .....	330
Table 113 – Primitives issued by DMPMS to FSPMS .....	330
Table 114 – Primitives issued by MSCY1S to DMPMS .....	330
Table 115 – Primitives issued by DMPMS to MSCY1S .....	331

Table 116 – Primitives issued by DMPMS to SSCY1S.....	331
Table 117 – Primitives issued by MSAC1S, MSRM2S, MSAC2S to DMPMS.....	332
Table 118 – Primitives issued by DMPMS to MSAC1S, MSRM2S, MSAC2S.....	332
Table 119 – Primitives issued by DMPMS to MSCS1S .....	332
Table 120 – Primitives issued by DMPMS to DL.....	333
Table 121 – Primitives issued by DL to DMPMS.....	333
Table 122 – Parameters used with primitives exchanged with DMPMS .....	334
Table 123 – DMPMS state table.....	336
Table 124 – Functions used by the DMPMS.....	342
Table 125 – Primitives issued by FSPMM1 to DMPMM1 .....	343
Table 126 – Primitives issued by DMPMM1 to FSPMM1 .....	343
Table 127 – Primitives issued by MSCY1M to DMPMM1 .....	344
Table 128 – Primitives issued by DMPMM1 to MSCY1M .....	344
Table 129 – Primitives issued by MSAL1M, MSAC1M to DMPMM1 .....	345
Table 130 – Primitives issued by DMPMM1 to MSAL1M, MSAC1M .....	345
Table 131 – Primitives issued by MMAC1 to DMPMM1 .....	345
Table 132 – Primitives issued by DMPMM1 to MMAC1 .....	345
Table 133 – Primitives issued by MSCS1M to DMPMM1 .....	346
Table 134 – Primitives issued by DMPMM1 to MSCS1M .....	346
Table 135 – Primitives issued by DMPMM1 to DL .....	346
Table 136 – Primitives issued by DL to DMPMM1 .....	347
Table 137 – Parameters used with primitives exchanged with DMPMM1 .....	348
Table 138 – Possible values of status .....	349
Table 139 – DMPMM1 state table .....	350
Table 140 – Functions used by the DMPMM1 .....	357
Table 141 – Primitives issued by FSPMM2 to DMPMM2 .....	358
Table 142 – Primitives issued by DMPMM2 to FSPMM2 .....	358
Table 143 – Primitives issued by MSAC2M to DMPMM2 .....	359
Table 144 – Primitives issued by DMPMM2 to MSAC2M .....	359
Table 145 – Primitives issued by MMAC2 to DMPMM2 .....	359
Table 146 – Primitives issued by DMPMM2 to MMAC2 .....	360
Table 147 – Primitives issued by DMPMM2 to DL .....	360
Table 148 – Primitives issued by DL to DMPMM2 .....	360
Table 149 – Parameters used with primitives exchanged with DMPMM2.....	361
Table 150 – DMPMM2 state Table .....	362
Table 151 – Functions used by DMPMM2 .....	365
Table 152 – Bus parameter/reaction times for a DP-slave.....	366

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

### INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

#### Part 6-3: Application layer protocol specification – Type 3 elements

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in IEC 61784-1 and IEC 61784-2.

International Standard IEC 61158-6-3 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This third edition cancels and replaces the second edition published in 2010. This edition constitutes a technical revision.

The main changes with respect to the previous edition are listed below:

- corrections, in Table 4, Table 5, Table 6, and Table 7;

- added references for data types;
- corrected state machine in Table 91 and Table 97;
- updated macro START\_MSAL1M,
- spelling and grammar.

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/764/FDIS	65C/774/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

## INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The application protocol provides the application service by making use of the services available from the data-link or other immediately lower layer. The primary aim of this standard is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer application entities (AEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- as a guide for implementors and designers;
- for use in the testing and procurement of equipment;
- as part of an agreement for the admittance of systems into the open systems environment;
- as a refinement to the understanding of time-critical communications within OSI.

This standard is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this standard together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems may work together in any combination.

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document may involve the use of patents concerning Type 3 elements and possibly other types given in the normative elements of this standard.

The following patent rights for Type 3 have been announced by [SI]:

Publication	Title
EP 1253494	Control device with fieldbus

IEC takes no position concerning the evidence, validity and scope of these patent rights.

The holder of these patent rights has assured the IEC that he/she is willing to negotiate licences under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of these patent rights is registered with IEC. Information may be obtained from:

[SI]: Siemens AG  
CT IP M&A  
Otto-Hahn-Ring 6  
D-81739 Munich  
Germany

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. IEC shall not be held responsible for identifying any or all such patent rights.

ISO ([www.iso.org/patents](http://www.iso.org/patents)) and IEC ([http://www.iec.ch/tctools/patent\\_decl.htm](http://www.iec.ch/tctools/patent_decl.htm)) maintain on-line data bases of patents relevant to their standards. Users are encouraged to consult the data bases for the most up to date information concerning patents.

## **INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –**

### **Part 6-3: Application layer protocol specification – Type 3 elements**

## **1 Scope**

### **1.1 General**

The Fieldbus Application Layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This standard provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 3 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible behavior provided by the Type 3 fieldbus application layer in terms of

- a) the abstract syntax defining the application layer protocol data units conveyed between communicating application entities,
- b) the transfer syntax defining the application layer protocol data units conveyed between communicating application entities,
- c) the application context state machine defining the application service behavior visible between communicating application entities; and
- d) the application relationship state machines defining the communication behavior visible between communicating application entities.

The purpose of this standard is to define the protocol provided to

- a) define the wire-representation of the service primitives specified in IEC 61158-5-3, and
- b) define the externally visible behavior associated with their transfer.

This standard specifies the protocol of the Type 3 fieldbus application layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498-1) and the OSI Application Layer Structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented Application Service Elements (ASEs) and a Layer Management Entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the



applications are not specified; only a definition of what requests and responses they can send/receive is specified. This permits greater flexibility to the FAL users in standardizing such object behavior. In addition to these services, some supporting services are also defined in this standard to provide access to the FAL to control certain aspects of its operation.

## 1.2 Specifications

The principal objective of this standard is to specify the syntax and behavior of the application layer protocol that conveys the application layer services defined in IEC 61158-5-3.

A secondary objective is to provide migration paths from previously-existing industrial communications protocols. It is this latter objective which gives rise to the diversity of protocols standardized in parts of the IEC 61158-6 subparts.

## 1.3 Conformance

This standard does not specify individual implementations or products, nor does it constrain the implementations of application layer entities within industrial automation systems.

There is no conformance of equipment to the application layer service definition standard. Instead, conformance is achieved through implementation of this application layer protocol specification.

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE All parts of the IEC 61158 series, as well as IEC 61784-1 and IEC 61784-2 are maintained simultaneously. Cross-references to these documents within the text therefore refer to the editions as dated in this list of normative references.

IEC 61158-3-3:2014, *Industrial communication networks - Fieldbus specifications – Part 3-3: Data-link layer service definition – Type 3 elements*

IEC 61158-4-3:2014, *Industrial communication networks – Fieldbus specifications – Part 4-3: Data-link layer protocol specification – Type 3 elements*

IEC 61158-5-3:2014, *Industrial communication networks – Fieldbus specifications – Part 5-3: Application layer service definition – Type 3 elements*

IEC 61158-5-10:2014, *Industrial communication networks – Fieldbus specifications – Part 5-10: Application layer service definition – Type 10 elements*

IEC 61158-6-10:2014, *Industrial communication networks – Fieldbus specifications – Part 6-10: Application layer protocol specification – Type 10 elements*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC 8822, *Information technology – Open Systems Interconnection – Presentation service definition*

ISO/IEC 8824-1, *Information technology – Abstract Syntax Notation One (ASN.1): Specification of basic notation*

ISO/IEC 9545, *Information technology – Open Systems Interconnection – Application Layer structure*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

IEEE 754, *IEEE Standard for Floating-Point Arithmetic*, available at <<http://www.ieee.org>>