

© Copyright SEK. Reproduction in any form without permission is prohibited.

Kablar – Provning av motståndsförmåga mot brand hos oskyddade kablar med liten diameter för användning i nödströmskretsar

Method of test for resistance to fire of unprotected small cables for use in emergency circuits

Som svensk standard gäller europastandarden EN 50200:2015. Den svenska standarden innehåller den officiella engelska språkversionen av EN 50200:2015.

Nationellt förord

Tidigare fastställd svensk standard SS-EN 50200, utgåva 2, 2006, gäller ej fr o m 2018-09-14.

ICS 13.220.40; 29.035.20

Denna standard är fastställd av SEK Svensk Elstandard,
som också kan lämna upplysningar om **sakinnehållet** i standarden.
Postadress: Box 1284, 164 29 KISTA
Telefon: 08 - 444 14 00.
E-post: sek@elstandard.se. Internet: www.elstandard.se

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English Version

**Method of test for resistance to fire of unprotected small cables
for use in emergency circuits**

Méthode d'essai de la résistance au feu des câbles de
petites dimensions sans protection pour utilisation dans les
circuits de secours

Prüfung des Isolationserhaltes im Brandfall von Kabeln mit
kleinen Durchmessern für die Verwendung in
Notstromkreisen bei ungeschützter Verlegung

This European Standard was approved by CENELEC on 2015-09-14. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents	Page
European foreword	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	6
4 Test environment	6
5 Test apparatus	6
5.1 Test equipment	6
5.2 Test wall and mounting	7
5.3 Continuity checking arrangement for electric power and control cables with rated voltage up to and including 600 V/1 000 V	7
5.4 Source of heat	8
5.5 Shock producing device	8
5.6 Positioning of source of heat	8
5.7 Fuses	9
6 Verification procedure for source of heat	9
6.1 Measuring equipment	9
6.2 Procedure	9
6.3 Evaluation	9
6.4 Further verification	10
6.5 Verification report	10
7 Test sample (Electric power and control cables with rated voltage up to and including 600 V/1 000 V)	10
7.1 Sample preparation	10
7.2 Sample mounting	10
8 Cable test procedure (Electric power and control cables with rated voltage up to and including 600 V/1 000 V)	10
8.1 General	10
8.2 Electrical connections	10
8.3 Flame and shock application	11
8.4 Electrification	11
8.5 Duration of survival	12
8.6 Point of failure	12
9 Test report (Electric power and control cables with rated voltage up to and including 600 V/1 000 V)	12
Annex A (informative) Guidance on the choice of recommended test equipment	22
A.1 Burner and Venturi	22
A.2 Test wall material	22
A.3 Rubber bushing	22

Annex B (normative) Field of direct application and extended application of test results (Electric power and control cables with rated voltage up to and including 600 V/1 000 V).....	23
B.1 Definitions.....	23
B.2 Field of direct application	23
B.3 Extended Application of test results (EXAP).....	24
Annex C (normative) Fuse characteristic curve.....	26
Annex D (informative) Information regarding classification	27
D.1 General.....	27
D.2 Functional requirement (PH) and Interpretation.....	27
D.3 Classification	27
Annex E (informative) Guidance for using optional water spray protocol.....	28
E.1 General.....	28
E.2 Modifications for optional water spray protocol.....	28
Bibliography	31

Figures

Figure 1 — Schematic of test configuration	13
Figure 2 — Plan view of test equipment.....	14
Figure 3 — End elevation of test equipment (not to scale).....	15
Figure 4 — Typical rubber bush (hardness: 50-60 shore A) for fastening the wall to the rigid supports	16
Figure 5 — Burner face	17
Figure 6 — Schematic diagram of an example of a burner control system	18
Figure 7 — Temperature measuring arrangement.....	19
Figure 8 — Example of method of mounting a sample for test	20
Figure 9 — Basic circuit diagram — Electric power and control cables with rated voltage up to and including 600 V/1 000 V.....	21
Figure C.1 — Fuse characteristic curve	26
Figure E.1 — Water spray tube	29
Figure E.2 — Water spray application	29

European foreword

This document (EN 50200:2015) has been prepared by Working Group 10 of CLC/TC 20 "Electric cables".

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2016-09-14
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2018-09-14

This document supersedes EN 50200:2006.

The main changes compared to EN 50200:2006 are as follows (minor changes are not listed):

- detailed procedures for metallic data cables and for optical fibre cables have been removed as they are now given in the relevant standards of CLC/TC 46X and CLC/TC 86A. These standards refer to EN 50200 for the basic test method;
- recasting and extension of the existing Annex D into two new Annexes, Annex B "Field of direct application and extended application of test results (Electric power and control cables with rated voltage up to and including 600 V/1 000 V) and Annex D "Information regarding classification".

The cable is tested in a representative installed condition, under conditions of minimum bending radius, and the test is based upon a constant temperature attack at a minimum test temperature of 830 °C. This is typical of the gas temperature reached after 30 min exposure to the time/temperature conditions prescribed in EN 1363-1.

The test method in this document includes exposure to fire with mechanical shock under specified conditions and satisfies the requirements of Mandate M/117 for the PH classification. This European Standard also includes (Annex E) a means of applying a water spray to the cable during the test, which is not required under Mandate M/117.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

1 Scope

This European Standard specifies the test method for cables designed to have intrinsic resistance to fire and intended for use as emergency circuits for alarm, lighting and communication purposes.

This European Standard is applicable to cables for emergency circuits of rated voltage not exceeding 600 V/1 000 V, including those of rated voltage below 80 V and optical fibre cables.

This European Standard includes details for the specific point of failure, continuity checking arrangement, test sample, test procedure and test report relevant to electric power and control cables with rated voltage up to and including 600 V/1 000 V. Details for the specific point of failure, continuity checking arrangement, test sample, test procedure and test report relevant to copper data and telecom cables and optical cables are given in the relevant standards of CLC/TC 46X and CLC/TC 86A.

The test method is limited to cables with an overall diameter not exceeding 20 mm.

The test method is based on the direct impingement of flame from a propane burner giving a constant temperature attack of a notional 842 °C. It is intended to be used for cables for emergency circuits suitable for alarm, emergency lighting and communication.

NOTE When the test method is used in support of EN 13501-3, it only applies to cables of less than 20 mm diameter, and, for metallic conductor cables, to those with conductor sizes up to and including 2,5 mm². For optical cables, only the less than 20 mm diameter limit applies.

This European Standard includes (Annex B) the field of direct application and rules for extended application of test results (EXAP). Details regarding classification using data from this test are given in EN 13501-3 ¹⁾. Information regarding classification is given in Annex D.

This European Standard also includes informative guidance (Annex E) on a means of applying a water spray to the cable during the test. Such a requirement may be a feature of particular product standards.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 13501-3, *Fire classification of construction products and building elements - Part 3: Classification using data from fire resistance tests on products and elements used in building service installations: fire resisting ducts and fire dampers*

EN 60584-1, *Thermocouples - Part 1: EMF specifications and tolerances (IEC 60584-1)*

EN 60695-4, *Fire hazard testing - Part 4: Terminology concerning fire tests for electrotechnical products (IEC 60695-4)*

EN ISO 13943, *Fire safety - Vocabulary (ISO 13943)*

¹⁾ At the time of finalizing EN 50200, an amendment to EN 13501-3:2005+A1:2009 concerning cables is under consideration in CEN/TC 127.

IEC 60269-3:2010 and IEC 60269-3:2010/A1:2013, *Low-voltage fuses – Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household and similar applications) - Examples of standardized systems of fuses A to F*