

© Copyright SEK. Reproduction in any form without permission is prohibited.

Omriktare för solcellsanläggningar – EMC – Fordringar och provningsmetoder

*Photovoltaic power generating systems –
EMC requirements and test methods for power conversion equipment*

Som svensk standard gäller europastandarden EN 62920:2017. Den svenska standarden innehåller den officiella engelska språkversionen av EN 62920:2017.

Nationellt förord

Europastandarden EN 62920:2017

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 62920, First edition, 2017 - Photovoltaic power generating systems - EMC requirements and test methods for power conversion equipment**

utarbetad inom International Electrotechnical Commission, IEC.

ICS 27.160.00

Denna standard är fastställd av SEK Svensk Elstandard, som också kan lämna upplysningar om **sakinnehållet** i standarden.
Postadress: Box 1284, 164 29 KISTA
Telefon: 08 - 444 14 00.
E-post: sek@elstandard.se. Internet: www.elstandard.se

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

ICS 27.160

English Version

Photovoltaic power generating systems - EMC requirements and
test methods for power conversion equipment
(IEC 62920:2017)

Systèmes de production d'énergie photovoltaïque -
Exigences de CEM et méthodes d'essai pour les
équipements de conversion de puissance
(IEC 62920:2017)

Photovoltaische Stromerzeugungssysteme - EMV-
Anforderungen und Prüfverfahren für Leistungsumrichter
(IEC 62920:2017)

This European Standard was approved by CENELEC on 2017-08-30. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

European foreword

The text of document 82/1288/FDIS, future edition 1 of IEC 62920, prepared by IEC/TC 82 "Solar photovoltaic energy systems" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62920:2017.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2018-05-30
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2020-08-30

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 62920:2017 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60364-1:2005	NOTE	Harmonized as HD 60364-1:2008.
IEC 60974-10	NOTE	Harmonized as EN 60974-10.
IEC 61000 (series)	NOTE	Harmonized as EN 61000 (series).
IEC 61800-3	NOTE	Harmonized as EN 61800-3.
IEC 61851-21-2 ¹⁾	NOTE	Harmonized as FprEN 61851-21-2.
IEC 62040-2	NOTE	Harmonized as EN 62040-2.

1) To be published. At draft stage.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61000-3-2	2014	Electromagnetic compatibility (EMC) - Part 3-2: Limits - Limits for harmonic current emissions (equipment input current 16 A per phase)	EN 61000-3-2	2014
IEC 61000-3-3	2013	Electromagnetic compatibility (EMC) - Part 3-3: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection	EN 61000-3-3	2013
IEC 61000-3-11	2000	Electromagnetic compatibility (EMC) -- Part 3-11: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems - Equipment with rated current ≤ 75 A and subject to conditional connection	EN 61000-3-11	2000
IEC 61000-3-12	2011	Electromagnetic compatibility (EMC) -- Part 3-12: Limits - Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current > 16 A and ≤ 75 A per phase	EN 61000-3-12	2011
IEC 61000-4-2	2008	Electromagnetic compatibility (EMC) -- Part 4-2: Testing and measurement techniques - Electrostatic discharge immunity test	EN 61000-4-2	2009
IEC 61000-4-3	2006	Electromagnetic compatibility (EMC) -- Part 4-3: Testing and measurement techniques - Radiated, radio-frequency, electromagnetic field immunity test	EN 61000-4-3	2006
+ A1	2007		+ A1	2008
+ A2	2010		+ A2	2010
IEC 61000-4-4	2012	Electromagnetic compatibility (EMC) -- Part 4-4: Testing and measurement techniques - Electrical fast transient/burst immunity test	EN 61000-4-4	2012
IEC 61000-4-5	2014	Electromagnetic compatibility (EMC) - Part 4-5: Testing and measurement techniques - Surge immunity test	EN 61000-4-5	2014
IEC 61000-4-6	2013	Electromagnetic compatibility (EMC) -- Part 4-6: Testing and measurement techniques - Immunity to conducted disturbances, induced by radio-frequency fields	EN 61000-4-6	2014
IEC 61000-4-7	2002	Electromagnetic compatibility (EMC) -- Part 4-7: Testing and measurement techniques - General guide on harmonics and interharmonics measurements and instrumentation, for power supply systems and equipment connected thereto	EN 61000-4-7	2002

EN 62920:2017

+ A1	2008		+ A1	2009
IEC 61000-4-11	2004	Electromagnetic compatibility (EMC) -- Part 4-11: Testing and measurement techniques - Voltage dips, short interruptions and voltage variations immunity tests	EN 61000-4-11	2004
IEC 61000-4-34	2005	Electromagnetic compatibility (EMC) -- Part 4-34: Testing and measurement techniques - Voltage dips, short interruptions and voltage variations immunity tests for equipment with input current more than 16 A per phase	EN 61000-4-34	2007
IEC/TR 61000-3-6	2008	Electromagnetic compatibility (EMC) - Part 3-6: Limits - Assessment of emission limits for the connection of distorting installations to MV, HV and EHV power systems		-
IEC/TR 61000-3-14	2011	Electromagnetic compatibility (EMC) - Part 3-14: Assessment of emission limits for harmonics, interharmonics, voltage fluctuations and unbalance for the connection of disturbing installations to LV power systems		-
CISPR 11 (mod)	2015	Industrial, scientific and medical equipment - Radio-frequency disturbance characteristics - Limits and methods of measurement	EN 55011	2016
+ A1	2016		+ A1	2017
CISPR 16-1-2	2014	Specification for radio disturbance and immunity measuring apparatus and methods - Part 1-2: Radio disturbance and immunity measuring apparatus - Coupling devices for conducted disturbance measurements	EN 55016-1-2	2014
CISPR 32	2015	Electromagnetic compatibility of multimedia equipment - Emission requirements	EN 55032	2015

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references	8
3 Terms and definitions	9
4 Classification of PCE	12
4.1 Category of environment.....	12
4.2 Division into classes	13
4.3 Information for users.....	13
5 Test setup for type test.....	14
5.1 General.....	14
5.2 Configuration of test setups	14
5.2.1 General	14
5.2.2 Setups for immunity requirement test.....	15
5.2.3 Setups for low frequency emission requirement test	16
5.2.4 Setups for high frequency emission requirement test	16
6 Operating conditions during testing.....	17
6.1 General.....	17
6.2 Operating conditions for immunity requirement test.....	17
6.3 Operating conditions for low frequency emission requirement test	17
6.4 Operating conditions for high frequency emission requirement test	17
7 Immunity requirements	18
7.1 Requirements	18
7.2 Performance criteria	21
8 Emission requirements	22
8.1 Low frequency	22
8.2 High frequency.....	24
8.2.1 Conducted emission	24
8.2.2 Radiated emission	27
9 Test results and test report.....	28
Annex A (informative) Configuration examples of test setups	29
A.1 General.....	29
A.2 Setups for immunity requirement test.....	29
A.2.1 Electrostatic discharge	29
A.2.2 Radiated disturbances	31
A.2.3 Electrical fast transient/burst	32
A.2.4 Surge	34
A.2.5 Conducted disturbances, induced by radio-frequency fields	36
A.2.6 Voltage dips and interruption	36
A.3 Setups for high frequency emission requirement test	37
A.3.1 Conducted disturbances	37
A.3.2 Radiated disturbances	39
Annex B (informative) Setups for low frequency emission requirement test	40
B.1 General.....	40
B.2 Example of a test circuit for low frequency emission requirement test	40
B.2.1 Harmonics	40

B.2.2	Voltage fluctuations and flicker	42
Annex C (informative)	Test setup for conducted disturbance measurement.....	44
C.1	General.....	44
C.2	Examples of a test setup.....	44
Annex D (informative)	Alternative test methods for high-power PCE	47
D.1	General.....	47
D.2	Alternative method for immunity requirement test.....	47
D.2.1	Alternative method for EFT/burst immunity test.....	47
D.2.2	Alternative method for surge test	47
D.2.3	Alternative test method for conducted disturbances, induced by radio- frequency fields	48
D.2.4	Conducted disturbances measurement	49
Bibliography.....		51
Figure 1 – Example of ports		10
Figure 2 – Examples of installation of PV systems in both environments.....		13
Figure 3 – Overview of harmonic requirements up to 75 A		23
Figure 4 – Overview of voltage change requirements up to 75 A		24
Figure A.1 – Example of a test setup for direct application of discharges to PCE		30
Figure A.2 – Example of a test setup for indirect application of discharges to PCE		30
Figure A.3 – Example of a test setup for wall-mounted PCE.....		32
Figure A.4 – Example of a test setup for direct coupling of the test voltage to AC mains power ports		33
Figure A.5 – Example of a test setup for application of the test voltage with a capacitive coupling clamp		34
Figure A.6 – Example of a test setup for AC mains power ports		35
Figure A.7 – Example of a test setup for DC power ports		35
Figure A.8 – Example of a setup of conducted disturbances immunity test applied for wall-mounted PCE		36
Figure A.9 – Example of a test setup using a generator for voltage dips and short interruptions.....		37
Figure A.10 – Example of a test setup of conducted disturbances measurement applied for wall-mounted PCE		38
Figure A.11 – Example of a test setup of conducted disturbances measurement applied for wall-mounted PCE with power circulation		38
Figure A.12 – Example of a test setup of conducted disturbances measurement applied for wall-mounted PCE with direct connection to AC mains		39
Figure A.13 – Example of a test setup of radiated disturbances measurement applied for wall-mounted PCE		39
Figure B.1 – Measurement circuit for single-phase two-wire PCE.....		40
Figure B.2 – Measurement circuit for single-phase three-wire PCE		41
Figure B.3 – Measurement circuit for three-phase three-wire PCE		41
Figure B.4 – Measurement circuit for three-phase four-wire PCE		41
Figure B.5 – Measurement circuit for single-phase two-wire PCE.....		42
Figure B.6 – Measurement circuit for single-phase three-wire PCE		42
Figure B.7 – Measurement circuit for three-phase three-wire PCE		43
Figure B.8 – Measurement circuit for three-phase four-wire PCE		43

Figure C.1 – Example of a standardized test setup for conducted disturbances measurement with AC mains power supply 45

Figure C.2 – Example of a standardized test setup for conducted disturbances measurement with a laboratory AC power source..... 46

Figure D.1 – Example of an alternative method for EFT/Burst immunity test 47

Figure D.2 – Example of an alternative coupling/decoupling network for AC mains power ports..... 48

Figure D.3 – Example of a test setup applying clamp injection method to AC mains power ports..... 49

Figure D.4 – Alternative test method of conducted disturbances measurement using artificial networks as voltage probes 50

Table 1 – Immunity requirements for class B PCE 19

Table 2 – Immunity requirements for class A PCE 20

Table 3 – Voltage dips and interruption immunity requirements for class B PCE 21

Table 4 – Voltage dips and interruption immunity requirements for class A PCE 21

Table 5 – Performance criteria for immunity tests 22

Table 6 – Disturbance voltage limits at the AC mains power port for class A PCE measured on a test site..... 25

Table 7 – Disturbance voltage limits at the AC mains power port for class B PCE measured on a test site..... 25

Table 8 – Disturbance limits at the DC power port for class A PCE measured on a test site .26

Table 9 – Disturbance limits at the DC power port for class B PCE measured on a test site .26

Table 10 – Limits of conducted common mode (asymmetric mode) disturbance at the wired port for class A PCE 27

Table 11 – Limits of conducted common mode (asymmetric mode) disturbance at the wired port for class B PCE 27

Table 12 – Electromagnetic radiation disturbance limits for class A PCE measured on a test site..... 27

Table 13 – Electromagnetic radiation disturbance limits for class B PCE measured on a test site..... 28

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**PHOTOVOLTAIC POWER GENERATING SYSTEMS –
EMC REQUIREMENTS AND TEST METHODS FOR
POWER CONVERSION EQUIPMENT**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62920 has been prepared by IEC technical committee 82: Solar photovoltaic energy systems.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
82/1288/FDIS	82/1313/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Background

Power conversion equipment (PCE) is indispensable for solar photovoltaic power energy systems in order to convert the DC electric power energy generated by solar photovoltaic panels into AC electric power, and to feed the AC power energy into the AC mains network or loads.

In recent years, standardization of EMC requirements for PCE has become more active. For example, CISPR/B has been considering the limits and measurement method for conducted disturbances at DC power ports of grid connected power converters since 2008. These proposed limits and measurement methods form the basis of the instructions for supplementing CISPR 11 in order to cover the set of EMC requirements for the PCE applying to the solar photovoltaic power energy systems. EMC requirements for PCE were added in CISPR 11 Ed.6.0 which was published in 2015. Some product committees, which consider products utilizing PCE, have their own product standards on EMC requirements. SC 22G has developed IEC 61800-3 to define the limits and test methods for power drive systems. SC 22H has IEC 62040-2 for uninterrupted power supplies, and TC 26 has IEC 60974-10 for arc welding. TC 9 sets the emission limits with IEC 62236 (all parts). Moreover, TC 69 will have IEC 61851-21-2¹ covering EMC requirements for conducted charging stations for electric vehicles.

Purpose of the development of a product EMC standard

IEC Guide 107 specifies that TC 77 and CISPR have responsibility for developing the basic and generic standards for EMC requirements of products. Therefore, product committees are not free to set their own emission limits. If product committees intend to require immunity to particular disturbances, they shall refer to these basic EMC immunity standards.

However, when the EMC standards which are developed by TC 77 and CISPR are not considered suitable for a particular product or electromagnetic environment, product committees shall seek their assistance and advice for any change in the emission limits and/or measurement requirements.

Product committees are responsible for selecting the appropriate immunity test items and levels for their products as well as for defining the relevant performance criteria for the evaluation of the immunity test results. Consequently, product committees, such as TC 22, TC 26, TC 9, and TC 69, have their own EMC standard to define EMC limits and test methods for their products.

On the other hand, TC 82 does not have its own product EMC standards. Therefore, TC 82 has to refer to the generic standards. Nevertheless, TC 82 has the responsibility to consider EMC requirements for PCE applying to the solar photovoltaic power energy systems, and TC 82 can take action as follows to develop its own product EMC standards:

- a) select the immunity test items in accordance with EMC environments for the solar photovoltaic power energy systems;
- b) supplement generic standards with a detailed description of test conditions and test set up;
- c) propose the conditional limits and alternative test methods in terms of installation environmental and operational conditions;
- d) develop appropriate requirements and test method for high power equipment.

This document presents the minimum EMC requirements for PCE applying to solar photovoltaic power energy systems.

¹ Under preparation. Stage at the time of publication: IEC AFDIS 61851-21-2:2017.

PHOTOVOLTAIC POWER GENERATING SYSTEMS – EMC REQUIREMENTS AND TEST METHODS FOR POWER CONVERSION EQUIPMENT

1 Scope

This document specifies electromagnetic compatibility (EMC) requirements for DC to AC power conversion equipment (PCE) for use in photovoltaic (PV) power systems.

The PCE covered by this document can be grid-interactive, which is termed as a grid connected power converter (GCPC), or stand-alone. It can be supplied by single or multiple photovoltaic modules grouped in various array configurations, and can be intended for use in conjunction with batteries or other forms of energy storage.

NOTE A micro inverter is an example of a GCPC supplied by a single photovoltaic module.

This document covers not only PCE connected to a public low voltage AC mains network or other low voltage AC mains installation, but also PCE connected to a medium or high voltage AC network with or without step-down power transformers. Requirements for the PCE connected to a medium or high voltage AC network are specified in this document. However, some requirements relevant to grid interconnection are addressed with other standards specifying power quality or their own grid codes in some countries.

NOTE DC/DC converters used for PV systems are not yet covered in this document. They can cause electromagnetic interference due to conducted disturbances at DC ports.

PCE is assessed with EMC requirements as a type test at a test site. This document provides test methods and test conditions for PCE as well as emission and immunity requirements, but not for photovoltaic modules and other balance of system components.

When compliance with EMC requirements at the test site cannot be shown due to technical reasons of the test site, PCE can be assessed in situ, such as at the manufacturer's premises or in the field where the PCE is assembled into a PV power system. However, only high frequency emission requirements for in situ assessment are specified in CISPR 11.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61000-3-2:2014, *Electromagnetic compatibility (EMC) – Part 3-2: Limits – Limits for harmonic current emissions (equipment with input current ≤ 16 A per phase)*

IEC 61000-3-3:2013, *Electromagnetic compatibility (EMC) – Part 3-3: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection*

IEC TR 61000-3-6:2008, *Electromagnetic compatibility (EMC) – Part 3-6: Limits – Assessment of emission limits for the connection of distorting installations to MV, HV and EHV power systems*

IEC 61000-3-11:2000, *Electromagnetic compatibility (EMC) – Part 3-11: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems – Equipment with rated current ≤ 75 A and subject to conditional connection*

IEC 61000-3-12:2011, *Electromagnetic compatibility (EMC) – Part 3-12: Limits – Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current > 16 A and ≤ 75 A per phase*

IEC TR 61000-3-14:2011, *Electromagnetic compatibility (EMC) – Part 3-14: Assessment of emission limits for harmonics, interharmonics, voltage fluctuations and unbalance for the connection of disturbing installations to LV power systems*

IEC 61000-4-2:2008, *Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test*

IEC 61000-4-3:2006, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test*
IEC 61000-4-3:2006/AMD1:2007
IEC 61000-4-3:2006/AMD2:2010

IEC 61000-4-4:2012, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-5:2014, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*

IEC 61000-4-6:2013, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields*

IEC 61000-4-7:2002, *Electromagnetic compatibility (EMC) – Part 4-7: Testing and measurement techniques – General guide on harmonics and interharmonics measurements and instrumentation, for power supply systems and equipment connected thereto*
IEC 61000-4-7:2002/AMD1:2008

IEC 61000-4-11:2004, *Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests*

IEC 61000-4-34:2005, *Electromagnetic compatibility (EMC) – Part 4-34: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests for equipment with input current more than 16 A per phase*

CISPR 11:2015, *Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement*
CISPR 11:2015/AMD1:2016

CISPR 16-1-2:2014, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-2: Radio disturbance and immunity measuring apparatus – Coupling devices for conducted disturbance measurements*

CISPR 32:2015, *Electromagnetic compatibility of multimedia equipment – Emission requirements*