

Svenska Elektriska Kommissionen, SEK

Fastställt	Utgåva	Sida	Ingår i
2007-02-26	1	1 (1+25)	SEK Område 13

© Copyright SEK. Reproduction in any form without permission is prohibited.

Elmätare –

Del 2: Fordringar på elektromekaniska mätare för aktiv energi av noggrannhetsklass A och B

*Electricity metering equipment (a.c.) –**Part 2: Particular requirements –**Electromechanical meters for active energy (class indexes A and B)*

Som svensk standard gäller europastandarden EN 50470-2:2006. Den svenska standarden innehåller den officiella engelska språkversionen av EN 50470-2:2006.

Nationellt förord

Standarden skall användas tillsammans med SS-EN 50470-1, utgåva 1, 2007.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

Svenska Elektriska Kommissionen, SEK, svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK

Box 1284
164 29 Kista
Tel 08-444 14 00
www.sekom.se

**Electricity metering equipment (a.c.)
Part 2: Particular requirements -
Electromechanical meters for active energy
(class indexes A and B)**

Equipement de comptage
d'électricité (c.a.)
Partie 2: Prescriptions particulières -
Compteurs électromécaniques
d'énergie active
(classes de précision A et B)

Wechselstrom-Elektrizitätszähler
Teil 2: Besondere Anforderungen -
Elektromechanische
Wirkverbrauchszähler
der Genauigkeitsklassen A und B

This European Standard was approved by CENELEC on 2006-05-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

This European Standard was prepared by the Technical Committee CENELEC TC 13, Equipment for electrical energy measurement and load control.

The text of the draft was submitted to the Unique Acceptance Procedure and was approved by CENELEC as EN 50470-2 on 2006-05-01.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2007-05-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2009-05-01

This EN 50470-2 is related to EN 62053-11:2003, *Electricity metering equipment (a.c.) – Particular requirements – Part 11: Electromechanical meters for active energy (classes 0,5, 1 and 2)*.

The structure of the two standards is similar, modifications in this European Standard are provided in the perspective of compliance with the Essential Requirements of the Directive 2004/22/EC on Measuring Instruments (MID).

This standard is to be used with EN 50470-1:2006, *Electricity metering equipment (a.c.) – Part 1: General requirements, tests and test conditions – Metering equipment (class indexes A, B and C)*.

This European Standard has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association and covers essential requirements of EC Directive 2004/22/EC. See Annex ZZ.

Contents

1	Scope.....	5
2	Normative references	5
3	Terms, definitions and abbreviations	5
4	Standard electrical values	6
5	Mechanical requirements.....	6
5.1	General.....	6
5.2	Register (counting mechanism)	6
5.3	Direction of rotation and marking of the rotor.....	6
6	Climatic conditions	6
7	Electrical requirements	6
7.1	Power consumption.....	6
7.1.1	Measuring method	6
7.1.2	Voltage circuits.....	7
7.1.3	Current circuits	7
7.2	AC voltage test.....	7
8	Accuracy requirements and tests.....	9
8.1	Limits of percentage error due to variation of the load	9
8.2	Repeatability	9
8.3	Limits of additional percentage error due to influence quantities.....	9
8.4	Maximum permissible error (MPE).....	11
8.5	Effect of disturbances of long duration.....	11
8.6	Short time overcurrents	13
8.7	Performing the tests	13
8.7.1	Accuracy test conditions	13
8.7.2	Accuracy test at reference conditions	15
8.7.3	Interpretation of accuracy test results	15
8.7.4	Repeatability	15
8.7.5	Test of effects of influence quantities.....	15
8.7.6	Calculation of the composite error	16
8.7.7	Test of effects of disturbances of long duration.....	16
8.7.8	Short time overcurrents	19
8.7.9	Test of starting and no-load condition	19
8.7.10	Meter constant.....	20
8.7.11	Adjustment	20
9	Durability.....	21
10	Reliability	21
11	Protection against corruption	21
	Annex A (informative) Calculation of the composite error	22
	Annex B (normative) Test circuit diagram for the test of immunity to earth fault	23
	Annex ZZ (informative) Coverage of Essential Requirements of EC Directives	24
	Bibliography.....	25

Figures

Figure B.1 – Circuit to simulate earth fault condition in phase 1	23
Figure B.2 – Voltages at the meter under test	23

Tables

Table 1 – Power consumption in voltage circuits	7
Table 2 – Power consumption in current circuits	7
Table 3 – AC voltage tests	8
Table 4 – Percentage error limits at reference conditions (single-phase meters and polyphase meters with balanced loads)	9
Table 5 – Percentage error limits at reference conditions (polyphase meters carrying a single-phase load, but with balanced polyphase voltages applied to voltage circuits)	9
Table 6 – Limits of additional percentage error due to influence quantities (single-phase meters and polyphase meters with balanced loads).....	10
Table 7 – Limits of additional percentage error due to influence quantities (polyphase meters carrying a single phase load, but with balanced polyphase voltages applied to voltage circuits).....	10
Table 8 – Maximum permissible error (MPE).....	11
Table 9 – Effect of disturbances of long duration – Critical change values	12
Table 10 – Effect of short time overcurrents – Critical change value	13
Table 11 – Voltage and current balance	13
Table 12 – Reference conditions.....	14
Table 13 – Test points for determining the intrinsic error and the additional percentage error due to influence quantities	15
Table 14 – Interpretation of test results.....	15
Table 15 – Starting current	20
Table 16 – Minimum range of adjustment.....	20

1 Scope

This European Standard applies to newly manufactured electromechanical watt-hour meters intended for residential, commercial and light industrial use, of class indexes A and B, for the measurement of alternating current electrical active energy in 50 Hz networks. It specifies particular requirements and type test methods.

It applies to electromechanical watt-hour meters for indoor and outdoor application, consisting of a measuring element and register(s) enclosed together in a meter case. It also applies to operation indicator(s) and test output(s).

If the meter has (a) measuring element(s) for more than one type of energy (multi-energy meters), or when other functional elements, like maximum demand indicators, electronic tariff registers, time switches, ripple control receivers, data communication interfaces etc. are enclosed in the meter case (multi-function meters) then this standard applies only for the active energy metering part.

This standard distinguishes between:

- meters of class indexes A and B;
- direct connected and transformer operated meters;
- meters for use in networks equipped with or without earth fault neutralizers.

It does not apply to:

- watt-hour meters where the voltage across the connection terminals exceeds 600 V (line-to-line voltage for meters for polyphase systems);
- portable meters.

Methods for acceptance testing are covered by the IEC 62058 series of standards ¹⁾.

The dependability aspect is covered by the documents of the IEC 62059 series.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

Publication	Year	Title
EN 50470-1	2006	<i>Electricity metering equipment (a.c.) – Part 1: General requirements, tests and test conditions – Metering equipment (class indexes A, B and C)</i>



¹⁾ At draft stage.