

© Copyright SEK. Reproduction in any form without permission is prohibited.

Larmsystem – Inbrotts- och överfallslarm – Del 6: Strömförsörjning

*Alarm systems –
Intrusion and hold-up systems –
Part 6: Power supplies*

Som svensk standard gäller europastandarden EN 50131-6:2017. Den svenska standarden innehåller den officiella engelska språkversionen av EN 50131-6:2017.

Nationellt förord

Tidigare fastställd svensk standard SS-EN 50131-6, utgåva 2, 2008 och SS-EN 50131-6/A1, utgåva 1, 2014, gäller ej fr o m 2020-09-18.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English Version

Alarm systems - Intrusion and hold-up systems - Part 6: Power supplies

Systèmes d'alarme - Systèmes d'alarme contre l'intrusion et les hold-up - Partie 6: Alimentation

Alarmanlagen - Einbruch- und Überfallmeldeanlagen - Teil 6: Energieversorgungen

This European Standard was approved by CENELEC on 2017-09-18. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

European foreword.....	4
Introduction.....	5
1 Scope.....	6
2 Normative references.....	6
3 Terms, definitions and abbreviations	7
3.1 Terms and definitions	7
3.2 Abbreviations	9
4 Functional requirements	9
4.1 PS configurations.....	9
4.2 General requirements	10
4.3 Monitoring of PS.....	13
4.4 APS capability	17
4.5 Recharging for PS Type A.....	17
4.6 Over-voltage protection.....	18
4.7 Short circuit protection.....	18
4.8 Overload protection	18
4.9 Deep discharge protection	18
4.10 Ripple	18
4.11 Tamper security.....	18
4.12 Environmental	21
4.13 Safety.....	22
4.14 EMC susceptibility	22
4.15 Electrical	22
5 Marking.....	23
6 Documentation	23
7 Tests	24
7.1 General	24
7.2 General test conditions	25
7.3 Reduced functional test	26
7.4 Monitoring: Loss of EPS	26
7.5 Monitoring: Storage Device Low Residual Energy.....	27
7.6 Monitoring: Storage Device Failure.....	30
7.7 Monitoring: Low Output Voltage	30
7.8 Monitoring: Power Unit Failure – Loss of PU Power Output	31

7.9	Monitoring: Power Unit Failure – Loss of SD Recharge	32
7.10	Test on demand.....	32
7.11	APS Capability.....	33
7.12	Recharging for PS Type A.....	34
7.13	Over voltage protection.....	35
7.14	Short Circuit Protection.....	36
7.15	Overload Protection	37
7.16	Deep Discharge Protection	38
7.17	Tamper security - Protection	39
7.18	Tamper Detection – Access to inside of the housing	39
7.19	Tamper detection – Removal from mounting.....	40
7.20	Tamper detection – Penetration of the housing	41
7.21	Environmental and EMC.....	42
7.22	PS Rating	42
7.23	Output voltage stability - Gradual load variation.....	45
7.24	Output Voltage Stability – Switched Load Variation	46
7.25	Marking and Documentation.....	47
Annex A	(informative) Determination of Storage Device failure	48
Annex B	(normative) Measurement of ripple voltage	49
B.1	General	49
B.2	Principle	49
B.3	Test conditions.....	49
B.4	Measurement	49
B.5	Pass/Fail Criteria	49
Annex C	(normative) Measurement of transients.....	50
C.1	General	50
C.2	Principle	50
C.3	Test conditions.....	50
C.4	Measurement	50
C.5	Pass/Fail Criteria	50
Annex D	(informative) Test on Demand signal or message timing and usage protocol.....	51
Annex E	(informative) Cross-reference between requirements and corresponding tests.....	52

European foreword

This document (EN 50131-6:2017) has been prepared by CLC/TC 79 “Alarm systems”.

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2018-09-18
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2020-09-18

This document supersedes EN 50131-6:2008.

The revision is to make the document less technology specific and more inclusive of the different types of power supplies found in I&HAS and the different types of technologies that are, and can be, employed within a power supply. It will make the document easier to use and more clearly applicable to the range of PSU configurations to be found in I&HAS.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Introduction

This European Standard deals with power supplies (PS) of intrusion and hold-up alarm systems (I&HAS) installed in buildings. It includes devices that are installed inside or outside of the supervised premises and mounted in indoor or outdoor environments.

The PS may be fully contained in its own housing or it may be integrated with other components within an I&HAS, e.g. the control and indicating equipment (CIE).

An I&HAS may use one or more PS.

1 Scope

This European Standard specifies the requirements, performance criteria and testing procedures for PS to be used as part of Intrusion and Hold up Alarm Systems. The PS will either be an integral part of an I&HAS component or stand-alone. The control functions of the PS may be incorporated as part of the PS device, or may be provided by another I&HAS component, e.g. a CIE.

This European Standard is not applicable when the PS requirements for I&HAS components are included within the relevant product standard.

The requirements correspond to each of the four security grades given in the European Standard EN 50131-1, *Alarm Systems – Intrusion and Hold-Up Systems – Part 1: System requirements*. Requirements are also given for four environmental classes covering applications in indoor and outdoor locations.

This standard covers:

- a) mandatory functions which will be provided on all PS; and
- b) optional functions which may be provided.

This European Standard does not deal with requirements for compliance with EC regulatory Directives, such as the EMC Directive, Low Voltage Directive, etc. except that it specifies the equipment operating conditions and reduced functional test for EMC susceptibility testing as required by EN 50130-4.

Other functions associated with I&HAS not specified in this standard may be provided. Such functions will not affect the requirements of any mandatory or optional functions.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50130-4, *Alarm systems - Part 4: Electromagnetic compatibility - Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems*

EN 50130-5, *Alarm systems - Part 5: Environmental test methods*

EN 50131-1, *Alarm systems - Intrusion and hold-up systems - Part 1: System requirements*

EN 60068-2-14:2009, *Environmental testing - Part 2-14: Tests - Test N: Change of temperature (IEC 60068-2-14:2009)*

EN 60529, *Degrees of protection provided by enclosures (IP Code) (IEC 60529)*

EN 62262, *Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code) (IEC 62262)*