

© Copyright SEK. Reproduction in any form without permission is prohibited.

Validering av bågsvetsutrustning

Validation of arc welding equipment

Som svensk standard gäller europastandarden EN 50504:2008. Den svenska standarden innehåller den officiella engelska språkversionen av EN 50504:2008.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

Validation of arc welding equipment

Validation du matériel de soudage à l'arc

Validierung von
Lichtbogenschweißeinrichtungen

This European Standard was approved by CENELEC on 2008-06-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

This European Standard has been prepared by the Technical Committee CENELEC TC 26A, Electric arc welding equipment.

The text of the draft was submitted to the formal vote and was approved by CENELEC as EN 50504 on 2008-06-01.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2009-06-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2011-06-01

This European Standard has been developed under the authority of CLC/TC 26A, Electric arc welding equipment. Welding is considered to be a special process because the final result may not always be capable of being verified by testing, hence it requires continuous control and/or adherence to documented procedures.

This European Standard has been developed to identify the controls and procedures required. It requires the use of calibrated welding equipment, then the quality/consistency of the weld depends upon accurate and repeatable setting of parameters such as current, voltage, speed, gas flow, etc.

This European Standard concentrates on validating equipment built to the constructional standard EN 60974-1. The accuracy of this equipment is designated as standard grade. A higher level of accuracy (precision grade) is introduced in this document.

As a code of practice, this European Standard takes the form of guidance and recommendations. It should not be quoted as if it were a specification and particular care should be taken to ensure that claims of compliance are not misleading.

A standard does not purport to include all necessary provisions of a contract. Users of standards are responsible for their correct application.

Compliance with a standard does not of itself confer immunity from legal obligations.

Contents

Introduction	4
1 Scope	6
2 Normative references	6
3 Terms and definitions	6
4 Validation accuracies	7
5 Consistency	8
6 Frequency of validation and calibration	8
7 Validators of welding equipment	8
8 Validation	8
8.1 General	8
8.2 Manual metal arc welding with covered electrodes	9
8.3 Tungsten inert gas	9
8.4 Metal inert/active gas and flux cored arc welding	10
8.5 Auxiliary components	10
9 Validation techniques	10
9.1 General	10
9.2 Safety precautions	10
9.3 Instrumentation	11
9.4 Power source loads	12
9.5 Method	13
10 Validation labels and certificates	14
10.1 Validation labels	14
10.2 Validation certificate	15
Annex A (informative) Accuracies for precision grade power sources	16
Annex B (informative) Wire feed equipment	17
B.1 Validation accuracies	17
B.2 Requirements for validation	17
B.3 Method	18
Annex C (informative) Slope, pulse and synergic controls	19
C.1 Validation accuracy	19
C.2 Requirements for validation	19
C.3 Method	19
C.4 Pulsed MIG and synergic controls	20
Annex D (informative) Precautions to be taken with TIG welding equipment	21
Annex E (informative) Validation of ancillary components in a welding system	22
Annex F (informative) Voltage drops in the welding circuit	23
Bibliography	25
Figure	
Figure F.1	23
Tables	
Table 1 – Validation accuracies for standard grade power sources	7
Table A.1 – Validation accuracies for precision grade power sources	16
Table B.1 – Validation accuracies for wire feed equipment	17
Table F.1 – Voltage drop in copper and aluminium welding cables at normal and elevated temperatures	24

Introduction

The quality and consistency of a weld depends on the welder, the materials and the welding equipment. Variability in the output of the welding equipment will affect the quality of the weld. In some arc welding processes, e.g. MMA, the welder controls the process through his experience and measurement of run out length is used to monitor the heat input. However, in other arc welding processes the quality of the weld depends upon accurate and repeatable setting of parameters such as current, voltage, speed, gas flow, pulse characteristics, etc.

The relevant construction standard for arc welding equipment is EN 60974-1. This standard sets the reference level for the accuracy and consistency of the welding output. EN 60974-1 derives its specification for performance accuracy from the requirements of manual welding. In manual welding the welder plays a key role in adapting and adjusting the output of the equipment to meet the requirements of the weld. This adaptability allows equipment to be constructed with a relaxed specification for calibration of output.

Mechanised welding methods lack the skilled adaptability of the manual welder and require precise control of all aspects of the welding process. The control of the output of the welding equipment is of particular importance. Manufacturers have responded to this need by producing equipment with an accuracy of output control and calibration, which exceed the requirements of EN 60974-1.

In addition to the demands of mechanized welding, manual welding methods have become more refined and welding procedures often call for the precise control of power source outputs to limit the freedom of the manual welder in order to produce particular results.

The improvement in equipment construction, the adoption of mechanized welding, the introduction of quality assurance programmes and the increased understanding of the factors which control weld quality have led to the demand for more rigorous calibration and validation of welding equipment performance.

The term calibration has been used in the foregoing text to introduce the general subject of checking that the welding equipment output meets the manufacturer's specification and is fit for the purpose of making welds. This is a commonly accepted term for this checking operation but it does not meet the strict definition of the word calibration.

Clause 3 of this document gives the definition of calibration. The operation of calibration can be applied only to determining and adjusting the errors of a measuring instrument. An item of welding equipment is not a measuring instrument though the meters fitted to the welding equipment are and can be calibrated. The difficulty of terminology and the checking task is further compounded as many pieces of welding equipment do not have calibrated outputs but are scaled in arbitrary units. Again this is a function of the manual welding usage in which the skill of the manual welder is used to adjust and set the welding variables. It is necessary to use an alternative term to describe the operation of verifying that the welding equipment is fit for the intended purpose. The term selected is validation.

Validation is the operation which verifies that the welding equipment conforms to the operating specification for that equipment. If the equipment fails to conform to the specification then the correction of the errors within the equipment is outside the scope of this European Standard. That operation is the province of the manufacturers or equipment specialists.

It is implicit in the introduction of a more rigorous standard of accuracy of control of output for welding equipment that the scope of application of that standard should be defined. This European Standard defines two levels of accuracy. One is derived directly from EN 60974-1 and is called standard grade. A higher level of accuracy for more exacting welding applications is defined, called precision grade, and this is given in Annex A for information. The use of precision grade is dependent upon the welding application.

The welding equipment covered by this European Standard will be fitted with controls intended to regulate the output of the welding equipment. The controls may be scaled in absolute units (amperes, volts and metres per minute) or in arbitrary units (numbers, letters, geometrical marks). Controls scaled in absolute units may be validated and the consistency of those controls scaled in arbitrary units may be assessed.

The welding equipment may be fitted with meters that measure the output of the equipment and these meters should normally be validated against the appropriate standard, unless a different method is used to control the welding process.

The use of meters and measuring instrument packages with welding equipment that is required to produce welds of integrity and reliability is strongly recommended.

This code of practice recommends the use of resistive loads to validate the power source and associated meters. Alternatively, independent instrumentation may be used to monitor the welding process, rather than validating the power source itself. The method of control and type of instrumentation should be detailed on the welding procedure sheet.

1 Scope

This European Standard specifies validation methods for arc welding equipment constructed and used to the accuracy specified in EN 60974-1 or other equivalent standards. The accuracy of this equipment is designated as standard grade.

This European Standard is applicable to

- a) arc welding power sources,
- b) wire feeders,
- c) welding instrumentation.

This European Standard is not applicable to arc striking and stabilizing device.

Calibration, verification and validation of equipment for other welding processes and ancillary equipment which may affect the quality of the weld, e.g. flow gauges, thermocouples, robots and manipulators are given in EN ISO 17662.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 60051-1:1998, *Direct acting indicating analogue electrical measuring instruments and their accessories – Part 1: Definitions and general requirements common to all parts* (IEC 60051-1:1997)

EN 60974-1, *Arc welding equipment – Part 1: Welding power sources* (IEC 60974-1)

EN ISO 17662, *Welding – Calibration, verification and validation of equipment used for welding, including ancillary activities* (ISO 17662)