

© Copyright SEK. Reproduction in any form without permission is prohibited.

Industriell processtyrning – Nät med hög driftsäkerhet – Del 2: Media Redundancy Protocol (MRP)

*Industrial communication networks –
High availability automation networks –
Part 2: Media Redundancy Protocol (MRP)*

Som svensk standard gäller europastandarden EN 62439-2:2017. Den svenska standarden innehåller den officiella engelska språkversionen av EN 62439-2:2017.

Nationellt förord

Europastandarden EN 62439-2:2017*)

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 62439-2, Second edition, 2016 - Industrial communication networks - High availability automation networks - Part 2: Media Redundancy Protocol (MRP)**

utarbetad inom International Electrotechnical Commission, IEC.

Standarden ska användas tillsammans med SS-EN 62439-1.

Tidigare fastställd svensk standard SS-EN 62439-2, utgåva 1, 2010, gäller ej fr o m 2020-11-24.

*)Corrigendum AC:2018-06 till EN 62439-2:2017 är inarbetat i standarden.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

**EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM**

EN 62439-2

November 2017

ICS 25.040, 35.040

Supersedes EN 62439-2:2010
Incorporates corrigendum June 2018

English Version

**Industrial communication networks - High availability automation
networks - Part 2: Media Redundancy Protocol (MRP)
(IEC 62439-2:2016)**

Réseaux de communication industriels - Réseaux
d'automatisme à haute disponibilité - Partie 2: Protocole de
redondance du support (MRP)
(IEC 62439-2:2016)

Industrielle Kommunikationsnetze: Hochverfügbare
Automatisierungsnetze - Teil 2: Medienredundanz-Protokoll
(MRP)
(IEC 62439-2:2016)

This European Standard was approved by CENELEC on 2016-03-30. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2017 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

Ref. No. EN 62439-2:2017 E

European foreword

The text of document 65C/583/FDIS, future edition 2 of IEC 62439-2, prepared by SC 65C "Industrial networks" of IEC/TC 65X "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62439-2:2017.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2018-05-24
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2020-11-24

This document supersedes EN 62439-2:2010.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

The contents of the corrigendum of June 2018 have been included in this copy.

Endorsement notice

The text of the International Standard IEC 62439-2:2016 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61158-2:2007	NOTE	Harmonized as EN 61158-2:2008 ¹ (not modified).
IEC 61158-5-10	NOTE	Harmonized as EN 61158-5-10.
IEC 61784-1:2007	NOTE	Harmonized as EN 61784-1:2008 ² (not modified).
IEC 61784-2:2007	NOTE	Harmonized as EN 61784-2:2008 ³ (not modified).
IEC 62439-3	NOTE	Harmonized as EN 62439-3.
IEC 62439-4	NOTE	Harmonized as EN 62439-4.
IEC 62439-6	NOTE	Harmonized as EN 62439-6.

¹ Withdrawn publication, the active edition is EN 61158-2:2014 (IEC 61158-2:2014).

² Withdrawn publication, the active edition is EN 61784-1:2014 (IEC 61784-1:2014).

³ Withdrawn publication, the active edition is EN 61784-2:2014 (IEC 61784-2:2014).

Annex ZA
(normative)

**Normative references to international publications
with their corresponding European publications**

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-191	-	International Electrotechnical Vocabulary - - Chapter 191: Dependability and quality of service	-	-
IEC 61158-6-10	2014	Industrial communication networks - Fieldbus specifications - Part 6-10: Application layer protocol specification - Type 10 elements	EN 61158-6-10	2014
IEC 61784-1	-	Digital data communications for measurement and control -- Part 1: Profile sets for continuous and discrete manufacturing relative to fieldbus use in industrial control systems	EN 61784-1	-
IEC 61784-2	-	Industrial communication networks - Profiles -- Part 2: Additional fieldbus profiles for real-time networks based on ISO/IEC 8802-3	EN 61784-2	-
IEC 62439-1	2010	Industrial communication networks - High availability automation networks -- Part 1: General concepts and calculation methods	EN 62439-1	2010
+ A1	2012		+A1	2012
ISO/IEC 10164-1	-	Information technology; Open Systems Interconnection; systems management: object management function	-	-
ISO/IEC/IEEE 8802-3 -		Standard for Ethernet	-	-
IEEE 802.1D	2004	IEEE Standard for local and metropolitan area networks - Media Access Control (MAC) Bridges	-	-
IEEE 802.1Q	2011	IEEE Standard for Local and metropolitan area networks - Media Access Control (MAC) Bridges and Virtual Bridged Local Area Networks	-	-

CONTENTS

FOREWORD.....	7
INTRODUCTION.....	9
1 Scope.....	11
2 Normative references.....	11
3 Terms, definitions, abbreviations, acronyms, and conventions	12
3.1 Terms and definitions	12
3.2 Abbreviations and acronyms.....	12
3.3 Conventions	12
4 MRP Overview.....	12
5 MRP Media redundancy behavior.....	16
5.1 General.....	16
5.2 Ring ports	16
5.3 Media Redundancy Manager (MRM)	17
5.4 Media Redundancy Client (MRC)	19
5.5 Redundancy domain.....	19
5.6 Media Link Check.....	19
5.7 Application of the Continuity Check protocol	19
5.7.1 General	19
5.7.2 Continuity Check Message Interval.....	20
5.7.3 Maintenance Domain Level	20
5.7.4 Maintenance Association ID (MAID).....	20
5.7.5 Maintenance Association End Point ID (MEPID).....	20
5.7.6 Sender ID TLV	20
5.7.7 Port Status TLV	21
5.7.8 Interface Status TLV	21
5.8 Usage with diagnosis and alarms.....	21
5.9 Ring diagnosis	21
5.10 Multiple MRM in a single ring: Manager voting option	21
5.10.1 General	21
5.10.2 Basic principle of the manager voting process	22
5.10.3 The manager voting process	23
5.11 BLOCKED not supported (Option).....	25
5.12 Interconnection port	25
5.13 Media redundancy Interconnection Manager (MIM)	26
5.14 Media redundancy Interconnection Client (MIC)	29
5.15 Interconnection domain	29
5.16 Interconnection diagnosis	30
6 MRP Class specification	30
6.1 General.....	30
6.2 Template.....	30
6.2.1 Media redundancy template.....	30
6.2.2 Media redundancy Interconnection template	31
6.3 Attributes	32
7 MRP Service specification	36
7.1 Start MRM	36

7.2	Stop MRM	38
7.3	State Change	38
7.4	Start MRC	39
7.5	Stop MRC	41
7.6	Read MRM.....	41
7.7	Read MRC	43
7.8	Start MIM.....	45
7.9	Stop MIM	46
7.10	Interconnection State Change.....	47
7.11	Start MIC	48
7.12	Stop MIC.....	49
7.13	Read MIM	50
7.14	Read MIC	52
8	MRP protocol specification.....	54
8.1	PDU description	54
8.1.1	Basic data types	54
8.1.2	DLPDU abstract syntax reference.....	54
8.1.3	Coding of the DLPDU field SourceAddress	54
8.1.4	Coding of the DLPDU field DestinationAddress	55
8.1.5	Coding of the field TagControllInformation	55
8.1.6	Coding of the field LT.....	56
8.1.7	MRP APDU abstract syntax	56
8.1.8	Coding of the field MRP_TLVHeader	57
8.1.9	Coding of the field MRP_SubTLVHeader	58
8.1.10	Coding of the field MRP_Ed1Type and MRP_Ed1ManufacturerData	58
8.1.11	Coding of the field MRP_Version	59
8.1.12	Coding of the field MRP_SequenceID	59
8.1.13	Coding of the field MRP_SA	59
8.1.14	Coding of the field MRP_OtherMRMSA.....	59
8.1.15	Coding of the field MRP_Prio	60
8.1.16	Coding of the field MRP_OtherMRMPrio	60
8.1.17	Coding of the field MRP_PortRole	60
8.1.18	Coding of the field MRP_RingState.....	60
8.1.19	Coding of the field MRP_Interval	61
8.1.20	Coding of the field MRP_Transition	61
8.1.21	Coding of the field MRP_TimeStamp	61
8.1.22	Coding of the field MRP_Blocked	61
8.1.23	Coding of the field MRP_ManufacturerOUI	62
8.1.24	Coding of the field MRP_IECOUI	62
8.1.25	Coding of the field MRP_ManufacturerData	62
8.1.26	Coding of the field MRP_DomainUUID.....	62
8.1.27	Coding of the field MRP_InState.....	62
8.1.28	Coding of the field MRP_InID	63
8.2	Protocol machines.....	63
8.2.1	MRM protocol machine.....	63
8.2.2	MRC protocol machine	74
8.2.3	MRA protocol machine	80
8.2.4	MRA, MRM and MRC functions	100
8.2.5	FDB clear timer.....	105

8.2.6	Topology change timer	105
8.2.7	MIM protocol machine	106
8.2.8	MIC protocol machine	115
8.2.9	MIM and MIC functions.....	123
8.2.10	Interconnection Topology Change timer.....	127
8.2.11	Interconnection Link Status Poll timer.....	127
9	MRP installation, configuration and repair	128
9.1	Ring port and Interconnection port parameters.....	128
9.2	Ring topology parameters.....	128
9.3	MRM parameters.....	128
9.4	MRC parameters and constraints.....	129
9.5	MRA compatibility to earlier Automanager protocol version	129
9.6	Interconnection topology parameters	130
9.7	MIM parameters	130
9.8	MIC parameters and constraints	130
9.9	Calculation of MRP ring recovery time	131
9.9.1	Overview	131
9.9.2	Deduction of formula	131
9.9.3	Worst case calculation for recovery time of 10 ms.....	133
9.9.4	Worst case calculation for 50 devices	134
9.10	Calculation of MRP Automanager voting time.....	134
10	MRP Management Information Base (MIB)	134
10.1	General.....	134
10.2	MRP MIB with a monitoring view.....	134
10.3	MRP MIB with a management and monitoring view	147
Annex A (normative)	Optional earlier version of the Automanager protocol.....	162
Bibliography	163	
Figure 1 – Two MRP rings redundantly connected via MRP Interconnection	14	
Figure 2 – MRP stack	16	
Figure 3 – MRP ring topology with one manager and clients	17	
Figure 4 – MRP open ring with MRM	18	
Figure 5 – MRP ring with MRA at network startup	22	
Figure 6 – MRP ring after the manager voting process.....	22	
Figure 7 – Manager voting process	24	
Figure 8 – MRA located outside the MRP ring.....	25	
Figure 9 – MRP Interconnection topology	27	
Figure 10 – MRP ring interconnection open	28	
Figure 11 – MRP protocol machine for MRM.....	63	
Figure 12 – MRP protocol machine for MRC	74	
Figure 13 – MRP protocol machine for MRA	81	
Figure 14 – MRP protocol machine for MIM in RC-mode and LC-mode.....	107	
Figure 15 – MRP protocol machine for MIC in RC-mode and LC-mode	116	
Table 1 – Patent information	9	
Table 2 – Coding of the Maintenance Association ID (MAID).....	20	

Table 3 – MRP Start MRM	36
Table 4 – MRP Stop MRM.....	38
Table 5 – MRP Change State.....	39
Table 6 – MRP Start MRC.....	40
Table 7 – MRP Stop MRC	41
Table 8 – MRP Read MRM.....	42
Table 9 – MRP Read MRC	44
Table 10 – MRP Start MIM	45
Table 11 – MRP Stop MIM	47
Table 12 – MRP Interconnection Change State.....	47
Table 13 – MRP Start MIC	48
Table 14 – MRP Stop MIC.....	50
Table 15 – MRP Read MIM	51
Table 16 – MRP Read MIC.....	53
Table 17 – MRP DLPDU syntax for ISO/IEC/IEEE 8802-3 (IEEE 802.3)	54
Table 18 – MRP OUI.....	55
Table 19 – MRP MulticastMACAddress	55
Table 20 – MRP TagControlInformation.Priority field.....	56
Table 21 – MRP LT field	56
Table 22 – MRP APDU syntax.....	56
Table 23 – MRP Substitutions	57
Table 24 – MRP_TLVHeader.Type	58
Table 25 – MRP_SubTLVHeader.Type	58
Table 26 – MRP_Ed1Type and MRP_Ed1ManufacturerData	59
Table 27 – MRP_Ed1Type and MRP_Ed1ManufacturerData	59
Table 28 – MRP_Version	59
Table 29 – Coding of the field MRP_OtherMRMSA	60
Table 30 – MRP_Prio.....	60
Table 31 – Coding of the field MRP_OtherMRMPrio.....	60
Table 32 – MRP_PortRole.....	60
Table 33 – MRP_RingState	61
Table 34 – MRP_Interval.....	61
Table 35 – MRP_Transition.....	61
Table 36 – MRP_TimeStamp.....	61
Table 37 – MRP_Blocked.....	62
Table 38 – MRP_DomainUUID	62
Table 39 – MRP_InState	62
Table 40 – MRP Local variables of MRM protocol machine	65
Table 41 – MRM State machine	66
Table 42 – MRP Local variables of MRC protocol machine.....	75
Table 43 – MRC state machine	76
Table 44 – MRP local variables of MRA protocol machine.....	82
Table 45 – MRA state machine.....	83

Table 46 – MRP functions and macros	101
Table 47 – MRP FDB clear timer	105
Table 48 – MRP topology change timer	106
Table 49 – MRP Local variables of MIM protocol machine.....	108
Table 50 – MIM State machine for LC-mode	109
Table 51 – MIM State machine for RC-mode	112
Table 52 – MRP Local variables of MIC protocol machine.....	117
Table 53 – MIC State machine for LC-mode	118
Table 54 – MIC State machine for RC-mode.....	121
Table 55 – MRP Interconnection functions.....	124
Table 56 – MRP Interconnection topology change timer.....	127
Table 57 – MRP Interconnection link status poll timer	128
Table 58 – MRP Network/Connection parameters	128
Table 59 – MRP MRM parameters.....	129
Table 60 – MRP MRC parameters	129
Table 61 – MRP MIM parameters	130
Table 62 – MRP MIC parameters	131
Table A.1 – Compatible mode MRP_Option for MRP_Test Substitutions	162
Table A.2 – Compatible mode MRP_Option frames MRP_TestMgrNAck and MRP_TestPropagate Substitutions	162

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
HIGH AVAILABILITY AUTOMATION NETWORKS –****Part 2: Media Redundancy Protocol (MRP)****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.

International Standard IEC 62439-2 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This second edition cancels and replaces the first edition published in 2010. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- adding a protocol extension to select the media redundancy manager automatically;
- adding a protocol to redundantly connect media redundancy protocol rings.

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/834/FDIS	65C/841/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

This International Standard is to be read in conjunction with IEC 62439-1.

A list of all parts of the IEC 62439 series, published under the general title *Industrial communication networks – High availability automation networks*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The IEC 62439 series specifies relevant principles for high availability networks that meet the requirements for industrial automation networks.

In the fault-free state of the network, the protocols of the IEC 62439 series provide ISO/IEC/IEEE 8802-3 (IEEE 802.3) compatible, reliable data communication, and preserve determinism of real-time data communication. In cases of fault, removal, and insertion of a component, they provide deterministic recovery times.

These protocols retain fully the typical Ethernet communication capabilities as used in the office world, so that the software involved remains applicable.

The market is in need of several network solutions, each with different performance characteristics and functional capabilities, matching diverse application requirements. These solutions support different redundancy topologies and mechanisms which are introduced in IEC 62439-1 and specified in the other Parts of the IEC 62439 series. IEC 62439-1 also distinguishes between the different solutions, giving guidance to the user.

The IEC 62439 series follows the general structure and terms of the IEC 61158 series.

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document may involve the use of a patent concerning ring protocol given in Clause 5. Table 1 gives an overview of the relevant patents.

Table 1 – Patent information

No.	Status	Country	Granted Patent Number or Application Number (if pending)	Title
1	granted granted granted granted granted	US CA CN NO EP (AT, BE, CH, DE, DK, ES, FR, GB, IT, NL, SE)	US 6430151 CA 2323429 CN 117195 NO 330908 EP 1062787	Local networking with redundancy properties having a redundancy manager

IEC takes no position concerning the evidence, validity and scope of this patent right.

The holder of this patent right has assured the IEC that he/she is willing to negotiate licences either free of charge or under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of this patent right is registered with IEC. Information may be obtained from:

Siemens Aktiengesellschaft
 Otto-Hahn-Ring 6
 Munich 81739
 Germany
 and
 Hirschmann Automation and Control GmbH
 Stuttgarter Strasse 45-51

Neckartenzlingen 72654
Germany

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. IEC shall not be held responsible for identifying any or all such patent rights.

ISO (www.iso.org/patents) and IEC (<http://patents.iec.ch/>) maintain on-line data bases of patents relevant to their standards. Users are encouraged to consult the data bases for the most up to date information concerning patents.

INDUSTRIAL COMMUNICATION NETWORKS – HIGH AVAILABILITY AUTOMATION NETWORKS –

Part 2: Media Redundancy Protocol (MRP)

1 Scope

The IEC 62439 series is applicable to high-availability automation networks based on the ISO/IEC/IEEE 8802-3 (IEEE 802.3) (Ethernet) technology.

This part of the IEC 62439 series specifies a recovery protocol based on a ring topology, designed to react deterministically on a single failure of an inter-switch link or switch in the network, under the control of a dedicated media redundancy manager node.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-191, *International Electrotechnical Vocabulary – Chapter 191: Dependability and quality of service*

IEC 61158-6-10:2014, *Industrial communication networks – Fieldbus specifications – Part 6-10: Application layer protocol specification – Type 10 elements*

IEC 61784-1, *Industrial communication networks – Profiles – Part 1: Fieldbus profiles*

IEC 61784-2, *Industrial communication networks – Profiles – Part 2: Additional fieldbus profiles for real-time networks based on ISO/IEC 8802-3*

IEC 62439-1:2010, *Industrial communication networks – High availability automation networks – Part 1: General concepts and calculation methods*
IEC 62439-1:2010/AMD1:2012¹

ISO/IEC 10164-1, *Information technology – Open Systems Interconnection – Systems Management: Object Management Function*

ISO/IEC/IEEE 8802-3 *Standard for Ethernet*

IEEE 802.1D:2004, *IEEE Standard for Local and metropolitan area networks – Media Access Control (MAC) Bridges*

IEEE 802.1Q:2011, *IEEE Standard for Local and metropolitan area networks – Media Access Control (MAC) Bridges and Virtual Bridge Local Area Network*

¹ A consolidated version of this publication exists, comprising IEC 62439-1:2010 and IEC 62439-1:2010/AMD1:2012.