

© Copyright SEK. Reproduction in any form without permission is prohibited.

Kopplingsapparater för spänning över 1 kV – Del 102: Frånskiljare och jordningskopplare för växelström

High-voltage switchgear and controlgear –

Part 102: Alternating current disconnectors and earthing switches

Som svensk standard gäller europastandarden EN IEC 62271-102:2018. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 62271-102:2018.

Nationellt förord

Europastandarden EN IEC 62271-102:2018

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 62271-102, Second edition, 2018 - High-voltage switchgear and controlgear - Part 102: Alternating current disconnectors and earthing switches**

utarbetad inom International Electrotechnical Commission, IEC.

EN från CENELEC som är identiska med motsvarande IEC-standarder och som görs tillgängliga för nationalkommittéerna efter den 1 januari 2018 får en beteckning som inleds med EN IEC istället för som tidigare bara EN.

Standarden ska användas tillsammans med SS-EN 62271-1, utgåva 2, 2018.

Tidigare fastställd svensk standard SS-EN 62271-102, utgåva 1, 2003, SS-EN 62271-102/A1, utgåva 1, 2012, SS-EN 62271-102/A2, utgåva 1, 2013 och SS-EN 62271-102 AC1, utgåva 1, 2016, gäller ej fr o m 2021-06-19.

ICS 29.130.10; 29.130.99

Denna standard är fastställd av SEK Svensk Elstandard, som också kan lämna upplysningar om **sakinnehållet** i standarden.
Postadress: Box 1284, 164 29 KISTA
Telefon: 08 - 444 14 00.
E-post: sek@elstandard.se. Internet: www.elstandard.se

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

EUROPEAN STANDARD

EN IEC 62271-102

NORME EUROPÉENNE

EUROPÄISCHE NORM

August 2018

ICS 29.130.10; 29.130.99

Supersedes EN 62271-102:2002

English Version

High-voltage switchgear and controlgear -
Part 102: Alternating current disconnectors and earthing
switches
(IEC 62271-102:2018)

Appareillage à haute tension -
Partie 102: Sectionneurs et sectionneurs de terre à courant
alternatif
(IEC 62271-102:2018)

Hochspannungs-Schaltgeräte und -Schaltanlagen -
Teil 102: Wechselstrom-Trennschalter und -
Erdungsschalter
(IEC 62271-102:2018)

This European Standard was approved by CENELEC on 2018-06-19. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2018 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

SEK Svensk Elstandard

Ref. No. EN IEC 62271-102:2018 E

SS-EN IEC 62271-102, utg 2:2018

European foreword

The text of document 17A/1173/FDIS, future edition 2 of IEC 62271-102, prepared by SC 17A "Switching devices" of IEC/TC 17 "High-voltage switchgear and controlgear" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62271-102:2018.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2019-03-19
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2021-06-19

This document supersedes EN 62271-102:2002.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 62271-102:2018 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60507:2013	NOTE	Harmonized as EN 60507:2014 (not modified).
IEC 60447:2004	NOTE	Harmonized as EN 60447:2004 (not modified).
IEC 60060-1:2010	NOTE	Harmonized as EN 60060-1:2010 (not modified).

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-151	-	International Electrotechnical Vocabulary - - Part 151: Electrical and magnetic devices		-
IEC 60050-441	-	International Electrotechnical Vocabulary - - (IEV) - Chapter 441: Switchgear, controlgear and fuses		-
IEC 60050-471	-	International Electrotechnical Vocabulary - - Part 471: Insulators		-
IEC 60050-614	-	International electrotechnical vocabulary - - Part 614: Generation, transmission and distribution of electricity - Operation		-
IEC 60071-2	-	Insulation co-ordination - Part 2: Application guidelines	EN IEC 60071-2	-
IEC 60137	-	Insulated bushings for alternating voltages above 1000 V	EN 60137	-
IEC 60270	-	High-voltage test techniques - Partial discharge measurements	EN 60270	-
IEC 60529	1989	Degrees of protection provided by enclosures (IP Code)	EN 60529 corr. May	1991 1993
+A1	1999		+A1	2000
+A2	2013		+A2	2013
IEC 60865-1	-	Short-circuit currents - Calculation of effects - Part 1: Definitions and calculation methods	EN 60865-1	-
IEC 62262	2002	Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)	EN 62262	2002
IEC 62271-1	2017	High-voltage switchgear and controlgear - Part 1: Common specifications for alternating current switchgear and controlgear	EN 62271-1	2017

EN IEC 62271-102:2018

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 62271-100 +A1 +A2	2008 2012 2017	High-voltage switchgear and controlgear - Part 100: Alternating current circuit- breakers	EN 62271-100 +A1 +A2	2009 2012 2017
IEC 62271-101 +A1	2012 2017	High-voltage switchgear and controlgear - Part 101: Synthetic testing	EN 62271-101 -	2013 -
IEC 62271-200	2011	High-voltage switchgear and controlgear - Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV	EN 62271-200	2012
IEC 62271-201	2014	High-voltage switchgear and controlgear - Part 201: AC solid-insulation enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV	EN 62271-201	2014
IEC 62271-203	2011	High-voltage switchgear and controlgear - Part 203: Gas-insulated metal-enclosed switchgear for rated voltages above 52 kV	EN 62271-203	2012
IEC/TR 62271-305	-	High-voltage switchgear and controlgear - Part 305: Capacitive current switching capability of air-insulated disconnectors for rated voltages above 52 kV	-	-
ISO 2768-1	-	General tolerances - Part 1: Tolerances for linear and angular dimensions without individual tolerance indications	EN 22768-1	-

6.4	Auxiliary and control equipment and circuits	35
6.5	Dependent power operation	35
6.6	Stored energy operation.....	35
6.7	Independent unlatched operation (independent manual or power operation)	35
6.8	Manually operated actuators	35
6.9	Operation of releases.....	35
6.10	Pressure/level indication	35
6.11	Nameplates.....	35
6.12	Locking devices	38
6.13	Position indication.....	38
6.14	Degree of protection provided by enclosures	38
6.15	Creepage distances for outdoor insulators	38
6.16	Gas and vacuum tightness.....	38
6.17	Tightness for liquid systems.....	38
6.18	Fire hazard (flammability)	38
6.19	Electromagnetic compatibility (EMC).....	38
6.20	X-ray emission	38
6.21	Corrosion	38
6.22	Filling levels for insulation, switching and/or operation	39
6.101	Particular requirements for earthing switches.....	39
6.102	Requirements in respect of the isolating distance of disconnectors	39
6.103	Mechanical strength.....	39
6.104	Operation of disconnectors and earthing switches – Position of the movable contact system and its indicating and signalling devices	40
6.104.1	Securing of position	40
6.104.2	Additional requirements for power-operated mechanisms	40
6.104.3	Indication and signalling of position	40
6.105	Maximum force required for manual (dependent or independent) operation.....	41
6.105.1	General	41
6.105.2	Operation requiring more than one revolution	42
6.105.3	Operation requiring up to one revolution	42
6.106	Dimensional tolerances.....	42
6.107	Earthing switches with short-circuit making current capability	42
7	Type tests	42
7.1	General.....	42
7.1.1	Basics	42
7.1.2	Information for identification of test objects.....	44
7.1.3	Information to be included in type test reports	44
7.2	Dielectric tests	44
7.2.1	General	44
7.2.2	Ambient air conditions during tests	44
7.2.3	Wet test procedure	44
7.2.4	Arrangement of the equipment.....	44
7.2.5	Criteria to pass the test	45
7.2.6	Application of the test voltage and test conditions.....	45
7.2.7	Tests of disconnectors and earthing switches of $U_T \leq 245$ kV.....	45
7.2.8	Test of disconnectors and earthing switches of $U_T > 245$ kV	45
7.2.9	Artificial pollution tests for outdoor insulators.....	45
7.2.10	Partial discharge tests	46

7.2.11	Dielectric tests on auxiliary and control circuits.....	46
7.2.12	Voltage test as condition check	46
7.3	Radio interference voltage (RIV) test	46
7.4	Resistance measurement.....	46
7.5	Continuous current tests	46
7.6	Short-time withstand current and peak withstand current tests	46
7.6.1	General	46
7.6.2	Arrangement of the disconnectors and earthing switches and of the test circuit	46
7.6.3	Test current and duration.....	52
7.6.4	Conditions of disconnectors and earthing switches after test	52
7.7	Verification of the protection	53
7.8	Tightness tests	53
7.9	Electromagnetic compatibility tests (EMC)	53
7.10	Additional tests on auxiliary and control circuits	53
7.11	X-ray radiation test for vacuum interrupters.....	53
7.101	Test to prove the short-circuit making performance of earthing switches	54
7.101.1	General test conditions	54
7.101.2	Arrangement of the earthing switch for tests	54
7.101.3	Test frequency.....	54
7.101.4	Test voltage.....	54
7.101.5	Test short-circuit making current.....	55
7.101.6	Test circuits.....	55
7.101.7	Test procedures.....	55
7.101.8	Behaviour of earthing switches when making short-circuit currents	56
7.101.9	Condition of earthing switch after short-circuit making tests	56
7.101.10	Invalid tests	57
7.101.11	Type test reports	57
7.102	Operating and mechanical endurance tests.....	58
7.102.1	General test conditions	58
7.102.2	Contact zone test.....	58
7.102.3	Mechanical endurance test	61
7.102.4	Operation during the application of rated static mechanical terminal loads	63
7.102.5	Extended mechanical endurance tests.....	64
7.102.6	Testing of mechanical interlocking devices.	65
7.103	Operation under severe ice conditions	65
7.103.1	General	65
7.103.2	Test arrangement	65
7.103.3	Test procedure	66
7.104	Low- and high-temperature tests.....	67
7.104.1	General	67
7.104.2	Measurement of ambient air temperature.....	68
7.104.3	Low-temperature test.....	68
7.104.4	High-temperature test.....	70
7.105	Tests to verify the proper functioning of the position-indicating device	70
7.105.1	General	70
7.105.2	Tests on the power kinematic chain and the position-indicating kinematic chain.....	71
7.106	Bus-transfer current switching tests on disconnectors	71

7.106.1	General	71
7.106.2	Making and breaking tests	71
7.107	Induced current switching tests on earthing switches	75
7.107.1	General	75
7.107.2	Arrangement of the earthing switch for tests	75
7.107.3	Earthing of test circuit and earthing switch	76
7.107.4	Test frequency	76
7.107.5	Test voltage	76
7.107.6	Test currents	76
7.107.7	Test circuits	76
7.108	Bus-charging current switching tests on disconnectors	81
7.108.1	General	81
7.108.2	Test duties	82
7.108.3	Arrangement of the disconnector for tests	82
7.108.4	Test frequency	82
7.108.5	Test voltages for making and breaking tests	83
7.108.6	Test circuits for making and breaking tests	84
7.108.7	Performance of making and breaking tests	86
7.108.8	Behaviour of the disconnector during making and breaking tests	86
7.108.9	Condition after test	87
7.108.10	Type test reports	87
7.108.11	Requirements for U_{TVE} measurements	88
8	Routine tests	88
8.1	General	88
8.2	Dielectric test on the main circuit	88
8.3	Tests on auxiliary and control circuits	89
8.4	Measurement of the resistance of the main circuit	89
8.5	Tightness test	89
8.6	Design and visual checks	89
8.101	Mechanical operating tests	89
8.102	Verification of earthing function	90
9	Guide to the selection of disconnectors and earthing switches (informative)	90
9.1	General	90
9.2	Selection of rated values	91
9.2.101	General	91
9.2.102	Selection of rated voltage and rated insulation level	91
9.2.103	Selection of rated continuous current	91
9.2.104	Selection of rated contact zone	91
9.2.105	Selection of rated static mechanical terminal load	92
9.2.106	Selection of a bus-transfer current switching capability for disconnectors of $U_r > 52$ kV	92
9.2.107	Selection of an induced-current switching capability for earthing switches of $U_r > 52$ kV	92
9.2.108	Selection of rated short-time withstand current and of rated duration of short-circuit	92
9.2.109	Selection of rated peak withstand current and of rated short-circuit making current for earthing switches	93
9.2.110	Selection of short-circuit making capability for earthing switches	93
9.3	Cable-interface considerations	93

9.4	Continuous or temporary overload due to changed service conditions.....	93
9.5	Environmental aspects.....	93
9.5.101	Local environmental conditions.....	93
10	Information to be given with enquiries, tenders and orders (informative).....	94
10.1	General.....	94
10.2	Information with enquiries and orders	94
10.3	Information with tenders.....	95
11	Transport, storage, installation, operating instructions, and maintenance	96
11.1	General.....	96
11.2	Conditions during transport, storage and installation	96
11.3	Installation	96
11.4	Operation.....	97
11.5	Maintenance	97
12	Safety.....	97
12.1	General.....	97
12.2	Precautions by manufacturers.....	97
12.3	Precautions by users	97
13	Influence of the product on the environment	97
	Annex A (informative) Test voltage for the most disadvantageous dielectric position of an earthing switch during operation (minimum temporary clearance)	98
	Annex B (informative) Current-switching capability required of disconnectors and earthing switches.....	99
B.1	Bus-transfer current switching capability of disconnectors.....	99
B.2	Bus-charging current switching capability of disconnectors	99
B.3	Induced current-switching capability of earthing switches.....	100
	Annex C (normative) Tolerances on test quantities for type tests	101
	Annex D (normative) Alternative test methods for short-circuit current making tests.....	103
D.1	General.....	103
D.2	Alternative methods	103
D.2.1	Synthetic test method with both rated voltage and rated short-circuit current.....	103
D.2.2	Test methods with reduced voltage.....	103
	Annex E (informative) Extension of validity of type tests	105
E.1	General.....	105
E.2	Dielectric tests	105
E.3	Short-time withstand current tests.....	105
E.4	Short-circuit making performance of earthing switches.....	105
E.5	Operating and mechanical endurance tests.....	105
E.6	Bus-transfer current switching tests on disconnectors	105
E.7	Induced current switching tests on earthing switches	106
	Bibliography.....	107
	Figure 1 – Position indicating/signalling device(s).....	40
	Figure 2 – Three-phase test arrangement for disconnectors and earthing switches	48
	Figure 3 – Single-phase test arrangement for disconnectors with a horizontal isolating distance and for earthing switches of $U_T > 52$ kV, to be used with flexible or with rigid conductors	49

Figure 4 – Single-phase test arrangement for divided support disconnectors (earthing switches) of $U_T > 52$ kV with a vertical isolating distance, to be used with flexible conductors	50
Figure 5 – Single-phase test arrangement for divided support disconnectors (earthing switches) of $U_T > 52$ kV with a vertical isolating distance, to be used with rigid conductors	51
Figure 6 – Fixed contact parallel to support	59
Figure 7 – Fixed contact perpendicular to support	60
Figure 8 – Example of the application of rated static mechanical terminal loads to a (divided support) pantograph disconnector (or earthing switch)	61
Figure 9 – Example of the application of rated static mechanical terminal loads to a two-column disconnector	62
Figure 10 – Test sequences for low and high temperature tests	68
Figure 11 – Example of test circuit for bus-transfer current switching tests	73
Figure 12 – Test circuit for electromagnetically induced current switching tests	77
Figure 13 – Test circuits for electrostatically induced current-switching tests	79
Figure 14 – Test circuit for test duty 1	83
Figure 15 – Typical voltage waveform (Including VFT and FT components)	85
Figure 16 – Test circuit for test duty 2	85
Figure 17 – Test circuit for test duty 3	86
Figure B.1 – Examples of resistor-fitted disconnectors	100
Table 1 – Classification of earthing switches for short-circuit making	28
Table 2 – Preferred contact zones for "fixed" contacts supported by flexible conductors	29
Table 3 – Preferred contact zones for "fixed" contacts supported by rigid conductors	29
Table 4 – Preferred static mechanical terminal loads	30
Table 5 – Classification of disconnectors for mechanical endurance	31
Table 6 – Classification of earthing switches for mechanical endurance	31
Table 7 – Rated bus-transfer voltages of disconnectors	32
Table 8 – Classification of earthing switches for induced-current switching	32
Table 9 – Rated induced currents and voltages	33
Table 10 – Classification of disconnectors for bus-charging switching	34
Table 11 – Standard rated bus-charging currents	34
Table 12 – Product information	36
Table 13 – List of type tests	43
Table 14 – Power frequency withstand voltages	45
Table 15 – Requirements on the instant of making	56
Table 16 – Invalid tests	57
Table 17 – Standard values of recovery voltages for electromagnetically induced current breaking tests	78
Table 18 – Test circuit capacitances (C_1 values) for electrostatically induced current switching tests	80
Table 19 – Test voltages for making and breaking tests	83
Table 20 – Number of tests	86

Table 21 – Power frequency voltage tests	89
Table B.1 – Average impedances.....	99
Table C.1 – Tolerances on test quantities for type tests	101

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –**Part 102: Alternating current disconnectors and earthing switches**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62271-102 has been prepared by subcommittee 17A: Switching devices, of IEC technical committee 17: High-voltage switchgear and controlgear.

This second edition cancels and replaces the first edition published in 2001, Amendment 1:2011 and Amendment 2:2013. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) new numbering according to IEC 17/1025/RQ to harmonize with ISO/IEC Directives, Part 2, and IEEE Std. C37.100.1;
- b) clause numbering has been aligned with IEC 62271-1:2017;
- c) the Scope has been extended to cover all indoor and outdoor installations. Consideration of switching devices having disconnecting and/or earthing switch functionalities, apart from other functions, are also covered by this document;

- d) ratings have been moved from Annexes B, C and E to Clause 5; the order of the subclauses now corresponds to the order of subclauses in Clause 7;
- e) new rating values for bus-transfer current and bus-transfer voltage have been assigned;
- f) new class of mechanical endurance for earthing switches has been added (M1);
- g) subclause "Rated values of electrical endurance for earthing switches" is now called "Classification of earthing switches for short-circuit making capability";
- h) new subclause with ratings for ice-coating has been added;
- i) new subclause with classification of bus-charging switching capability has been added;
- j) new withstand requirements for interlocking devices have been added;
- k) the way to comply with the requirements of the isolating distance of disconnectors has been modified;
- l) design and construction requirements for position-indicating devices have been modified, aligning the requirements for position indication and signalling;
- m) the value of the operating force has been changed;
- n) the test procedures and validation criteria have been revised and modified where necessary;
- o) requirements for applied voltage during single-phase test on non-simultaneous closing earthing switches have been changed;
- p) non-verifiable requirements have been deleted;
- q) a new subclause has been added for testing mechanical interlocking devices;
- r) the high- and low-temperature test is mandatory if the temperature limits for the service conditions of the apparatus (defined by the manufacturer) are above +40 °C or below –5 °C, and a more detailed testing procedure is given;
- s) the testing procedure to verify the proper functioning of the position-indicating device allows a more practicable testing for every technology used;
- t) a new Annex B has been added with title: "Current-switching capability required of disconnectors and earthing switches";
- u) a new Annex C has been added with title: "Tolerances on test quantities for type tests";
- v) a new Annex E has been added with title: "Extension of validity of type tests".

This standard is to be read in conjunction with IEC 62271-1:2017, to which it refers and which is applicable, unless otherwise specified. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses, except annexes, is used as in IEC 62271-1:2017. Additional subclauses are numbered from 101.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
17A/1173/FDIS	17A/1180/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 102: Alternating current disconnectors and earthing switches

1 Scope

This part of IEC 62271 applies to alternating current disconnectors and earthing switches, designed for indoor and outdoor installations for nominal voltages above 1 000 V and for service frequencies up to and including 60 Hz.

It also applies to the operating devices of these disconnectors and earthing switches and their auxiliary equipment.

Additional requirements for disconnectors and earthing switches in enclosed switchgear and controlgear are given in IEC 62271-200, IEC 62271-201 and IEC 62271-203.

NOTE Disconnectors in which the fuse forms an integral part are not covered by this standard.

This document is also applicable to switching devices having disconnecting and/or earthing functionalities apart from other functions, such as high-speed earthing switch, circuit-breaker and switch-disconnector.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-151, *International Electrotechnical Vocabulary – Part 151: Electrical and magnetic devices*

IEC 60050-441, *International Electrotechnical Vocabulary – Chapter 441: Switchgear controlgear and fuses*

IEC 60050-471, *International Electrotechnical Vocabulary – Part 471: Insulators*

IEC 60050-614, *International Electrotechnical Vocabulary – Part 614: Generation, transmission and distribution of electricity – Operation*

IEC 60071-2, *Insulation co-ordination – Part 2: Application guide*

IEC 60137, *Insulating bushings for alternating voltages above 1 000 V*

IEC 60270, *High-voltage test techniques – Partial discharge measurements*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*

IEC 60529:1989/AMD1:1999

IEC 60529:1989/AMD2:2013

IEC 60865-1, *Short-circuit currents – Calculation of effects – Part 1: Definitions and calculation methods*

IEC 62262:2002, *Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)*

IEC 62271-1:2017, *High-voltage switchgear and controlgear – Part 1: Common specifications for alternating current switchgear and controlgear*

IEC 62271-100:2008, *High-voltage switchgear and controlgear – Part 100: Alternating current circuit-breakers*

IEC 62271-100:2008/AMD1:2012

IEC 62271-100:2008/AMD2:2017

IEC 62271-101:2012, *High-voltage switchgear and controlgear – Part 101: Synthetic testing*

IEC 62271-101:2012/AMD1:2017

IEC 62271-200:2011, *High-voltage switchgear and controlgear – Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV*

IEC 62271-201:2014, *High-voltage switchgear and controlgear – Part 201: AC solid-insulation enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV*

IEC 62271-203:2011, *High-voltage switchgear and controlgear – Part 203: Gas-insulated metal-enclosed switchgear for rated voltages above 52 kV*

IEC/TR 62271-305, *High-voltage switchgear and controlgear – Part 305: Capacitive current switching capability of air-insulated disconnectors for rated voltages above 52 kV*

ISO 2768-1, *General tolerances – Part 1: Tolerances for linear and angular dimensions without individual tolerance indications*