

# SVENSK STANDARD

## SS-EN 81-20:2020

**Säkerhetsregler för konstruktion och installation av hissar –  
Hissar för transport av personer och gods –  
Del 20: Person- och varupersonhissar**

**Safety rules for the construction and installation of lifts – Lifts  
for the transport of persons and goods –  
Part 20: Passenger and goods passenger lifts**



**SIS** Svenska  
Institutet för  
Standarder

Språk: engelska/English  
Utgåva: 2

Denna standard är såld av  
SEK Svensk Elstandard som även lämnar  
allmänna upplysningar om svensk och utländsk standard.  
Postadress: SEK, Box 1284, 164 29 Kista  
Telefon: 08-444 14 00.  
E-post: [sek@elstandard.se](mailto:sek@elstandard.se) Internet: [www.elstandard.se](http://www.elstandard.se)

Den här standarden kan hjälpa dig att effektivisera och kvalitetssäkra ditt arbete. SIS har fler tjänster att erbjuda dig för att underlätta tillämpningen av standarder i din verksamhet.

#### **SIS Abonnemang**

Snabb och enkel åtkomst till gällande standard med SIS Abonnemang, en prenumerationstjänst genom vilken din organisation får tillgång till all världens standarder, senaste uppdateringarna och där hela din organisation kan ta del av innehållet i prenumerationen.

#### **Utbildning, event och publikationer**

Vi erbjuder även utbildningar, rådgivning och event kring våra mest sålda standarder och frågor kopplade till utveckling av standarder. Vi ger också ut handböcker som underlättar ditt arbete med att använda en specifik standard.

#### **Vill du delta i ett standardiseringsprojekt?**

Genom att delta som expert i någon av SIS 300 tekniska kommittéer inom CEN (europeisk standardisering) och/eller ISO (internationell standardisering) har du möjlighet att påverka standardiseringsarbetet i frågor som är viktiga för din organisation. Välkommen att kontakta SIS för att få veta mer!

#### **Kontakt**

Skriv till [kundservice@sis.se](mailto:kundservice@sis.se), besök [sis.se](http://sis.se) eller ring 08 - 555 523 10

---

© Copyright/Upphovsrätten till denna produkt tillhör Svenska institutet för standarder, Stockholm, Sverige. Upphovsrätten och användningen av denna produkt regleras i slutanvändarlicensen som återfinns på [sis.se/slutanvandarlicens](http://sis.se/slutanvandarlicens) och som du automatiskt blir bunden av när du använder produkten. För ordlista och förkortningar se [sis.se/ordlista](http://sis.se/ordlista).

© Copyright Svenska institutet för standarder, Stockholm, Sweden. All rights reserved. The copyright and use of this product is governed by the end-user licence agreement which you automatically will be bound to when using the product. You will find the licence at [sis.se/enduserlicenseagreement](http://sis.se/enduserlicenseagreement).

Upplysningar om sakinnehållet i standarden lämnas av Svenska institutet för standarder, telefon 08 - 555 520 00. Standarder kan beställas hos SIS som även lämnar allmänna upplysningar om svensk och utländsk standard.

Standarden är framtagen av kommittén för Hissar och rulltrappor, SIS/TK 211.

Har du synpunkter på innehållet i den här standarden, vill du delta i ett kommande revideringsarbete eller vara med och ta fram andra standarder inom området? Gå in på [www.sis.se](http://www.sis.se) - där hittar du mer information.

Europastandarden EN 81-20:2020 gäller som svensk standard. Detta dokument innehåller den officiella engelska versionen av EN 81-20:2020.

Denna standard ersätter SS-EN 81-20:2014, utgåva 1 och SS-EN 81-20:2014, utgåva 1.

The European Standard EN 81-20:2020 has the status of a Swedish Standard. This document contains the official version of EN 81-20:2020.

This standard supersedes the SS-EN 81-20:2014, edition 1 and SS-EN 81-20:2014, edition 1.

EUROPEAN STANDARD

**EN 81-20**

NORME EUROPÉENNE

EUROPÄISCHE NORM

February 2020

ICS 91.140.90

Supersedes EN 81-20:2014

English Version

**Safety rules for the construction and installation of lifts -  
Lifts for the transport of persons and goods - Part 20:  
Passenger and goods passenger lifts**

Règles de sécurité pour la construction et l'installation  
des élévateurs - Élévateurs pour le transport de  
personnes et d'objets - Partie 20 : Ascenseurs et  
ascenseurs de charge

Sicherheitsregeln für die Konstruktion und den Einbau  
von Aufzügen - Aufzüge für den Personen- und  
Gütertransport - Teil 20: Personen- und Lastenaufzüge

This European Standard was approved by CEN on 1 December 2019.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

**Contents**

Page

European foreword.....	6
<b>0 Introduction .....</b>	<b>8</b>
<b>0.1 General.....</b>	<b>8</b>
<b>0.2 General remarks.....</b>	<b>8</b>
<b>0.3 Principles .....</b>	<b>9</b>
<b>0.4 Assumptions.....</b>	<b>9</b>
<b>1 Scope .....</b>	<b>13</b>
<b>2 Normative references .....</b>	<b>14</b>
<b>3 Terms and definitions .....</b>	<b>16</b>
<b>4 List of significant hazards .....</b>	<b>23</b>
<b>5 Safety requirements and/or protective measures .....</b>	<b>25</b>
<b>5.1 General.....</b>	<b>25</b>
<b>5.2 Well, machinery spaces and pulley rooms.....</b>	<b>25</b>
<b>5.2.1 General provisions.....</b>	<b>25</b>
<b>5.2.2 Access to well and to machinery spaces and pulley rooms.....</b>	<b>30</b>
<b>5.2.3 Access and emergency doors - Access trap doors - Inspection doors .....</b>	<b>31</b>
<b>5.2.4 Notices.....</b>	<b>32</b>
<b>5.2.5 Well .....</b>	<b>33</b>
<b>5.2.6 Machinery spaces and pulley rooms .....</b>	<b>46</b>
<b>5.3 Landing doors and car doors .....</b>	<b>54</b>
<b>5.3.1 General provisions.....</b>	<b>54</b>
<b>5.3.2 Height and width of entrances .....</b>	<b>54</b>
<b>5.3.3 Sills, guides, door suspension .....</b>	<b>54</b>
<b>5.3.4 Horizontal door clearances .....</b>	<b>55</b>
<b>5.3.5 Strength of landings and car doors.....</b>	<b>56</b>
<b>5.3.6 Protection in relation to door operation .....</b>	<b>60</b>
<b>5.3.7 Local landing lighting and “car here” signal lights.....</b>	<b>62</b>
<b>5.3.8 Locking and closed landing door check .....</b>	<b>63</b>
<b>5.3.9 Locking and emergency unlocking of landing and car doors.....</b>	<b>63</b>
<b>5.3.10 Requirements common to devices for proving the locked condition and the closed condition of the landing door .....</b>	<b>66</b>
<b>5.3.11 Sliding landing doors with multiple, mechanically linked panels .....</b>	<b>66</b>
<b>5.3.12 Closing of automatically operated landing doors.....</b>	<b>67</b>
<b>5.3.13 Electric safety device for proving the car doors closed.....</b>	<b>67</b>
<b>5.3.14 Sliding or folding car doors with multiple, mechanically linked panels.....</b>	<b>67</b>
<b>5.3.15 Opening the car door .....</b>	<b>68</b>
<b>5.4 Car, counterweight and balancing weight.....</b>	<b>68</b>
<b>5.4.1 Height of car .....</b>	<b>68</b>
<b>5.4.2 Available car area, rated load, number of passengers.....</b>	<b>68</b>
<b>5.4.3 Walls, floor and roof of the car .....</b>	<b>74</b>
<b>5.4.4 Car door, floor, wall, ceiling and decorative materials.....</b>	<b>75</b>
<b>5.4.5 Apron.....</b>	<b>76</b>
<b>5.4.6 Emergency trap doors and emergency doors .....</b>	<b>76</b>
<b>5.4.7 Car roof .....</b>	<b>77</b>

5.4.8	Equipment on top of the car.....	81
5.4.9	Ventilation.....	81
5.4.10	Lighting.....	81
5.4.11	Counterweight and balancing weight.....	82
5.5	Suspension means, compensation means and related protection means .....	82
5.5.1	Suspension means .....	82
5.5.2	Sheave, pulley, drum and rope diameter ratios, rope/chain terminations.....	82
5.5.3	Rope traction.....	83
5.5.4	Winding up of ropes for positive drive lifts .....	83
5.5.5	Distribution of load between the ropes or the chains.....	84
5.5.6	Compensation means .....	84
5.5.7	Protection for sheaves, pulleys and sprockets .....	85
5.5.8	Traction sheaves, pulleys and sprockets in the well .....	87
5.6	Precautions against free fall, excessive speed, unintended car movement and creeping of the car.....	87
5.6.1	General provisions .....	87
5.6.2	Safety gear and its tripping means.....	90
5.6.3	Rupture valve.....	96
5.6.4	Restrictors.....	97
5.6.5	Pawl device .....	98
5.6.6	Ascending car overspeed protection means.....	99
5.6.7	Protection against unintended car movement .....	100
5.7	Guide rails .....	103
5.7.1	Guiding of the car, counterweight or balancing weight.....	103
5.7.2	Permissible stresses and deflections .....	103
5.7.3	Combination of loads and forces.....	107
5.7.4	Impact factors .....	107
5.8	Buffers .....	109
5.8.1	Car and counterweight buffers .....	109
5.8.2	Stroke of car and counterweight buffers .....	110
5.9	Lift machinery and associated equipment .....	111
5.9.1	General provision .....	111
5.9.2	Lift machine for traction lifts and positive drive lifts.....	111
5.9.3	Lift machine for hydraulic lifts .....	117
5.10	Electric installations and appliances.....	126
5.10.1	General provisions .....	126
5.10.2	Incoming supply conductor terminations .....	128
5.10.3	Contactors, contactor relays, components of safety circuits .....	128
5.10.4	Protection of electrical equipment .....	129
5.10.5	Main switches.....	130
5.10.6	Electric wiring.....	131
5.10.7	Lighting and socket outlets .....	132
5.10.8	Control of the supply for lighting and socket outlets.....	132
5.10.9	Protective earthing .....	133
5.10.10	Electrical identification.....	133
5.11	Protection against electric faults; failure analysis; electric safety devices .....	133
5.11.1	Protection against electric faults; failure analysis .....	133
5.11.2	Electric safety devices.....	134
5.12	Controls - Final limit switches - Priorities.....	139
5.12.1	Control of lift operations.....	139
5.12.2	Final limit switches .....	146
5.12.3	Emergency alarm device and intercom system .....	147
5.12.4	Priorities and signals .....	148

6	Verification of the safety requirements and/or protective measures.....	148
6.1	Technical compliance documentation.....	148
6.2	Verification of design.....	148
6.3	Examinations and tests before putting into service.....	152
6.3.1	Braking system (5.9.2.2).....	152
6.3.2	Electric installation.....	153
6.3.3	Checking of the traction (5.5.3).....	153
6.3.4	Car safety gear (5.6.2).....	153
6.3.5	Counterweight or balancing weight safety gear (5.6.2).....	154
6.3.6	Pawl device (5.6.5).....	154
6.3.7	Buffers (5.8.1, 5.8.2).....	155
6.3.8	Rupture valve (5.6.3).....	155
6.3.9	Restrictor/one-way restrictor (5.6.4).....	155
6.3.10	Pressure test.....	156
6.3.11	Ascending car overspeed protection means (5.6.6).....	156
6.3.12	Stopping of the car at landings and levelling accuracy (5.12.1.1.4).....	156
6.3.13	Protection against unintended car movement (5.6.7).....	156
6.3.14	Protection against falling/shearing (5.3.9.3.4).....	157
7	Information for use.....	157
7.1	General.....	157
7.2	Instruction manual.....	157
7.2.1	General.....	157
7.2.2	Normal use.....	157
7.2.3	Maintenance.....	157
7.2.4	Examinations and tests.....	158
7.3	Logbook.....	158
Annex A (normative) List of the electric safety devices.....		160
Annex B (informative) Technical compliance documentation.....		163
Annex C (informative) Periodic examinations and tests, examinations and tests after an important modification or after an accident.....		164
C.1	Periodic examinations and tests.....	164
C.2	Examinations and tests after an important modification or after an accident.....	164
Annex D (informative) Machinery spaces – Access.....		166
Annex E (informative) Building interfaces.....		167
E.1	General provisions.....	167
E.2	Support of Guide Rails.....	167
E.3	Ventilation of car, well and machine rooms.....	167
E.3.1	General.....	167
E.3.2	Ventilation of the well and car.....	168
E.3.3	Ventilation of machine rooms.....	169
Annex F (normative) Pit access ladder.....		170
F.1	Types of pit access ladder.....	170
F.2	General provisions.....	170
F.3	Ladder uprights and rungs.....	170

<b>F.3.1</b>	<b>Ladder uprights.....</b>	<b>170</b>
<b>F.3.2</b>	<b>Ladder rungs .....</b>	<b>171</b>
<b>F.4</b>	<b>Specific provisions for non fixed type ladders .....</b>	<b>171</b>
<b>F.5</b>	<b>Location of the ladder in the pit .....</b>	<b>171</b>
	<b>Annex ZA (informative) Relationship between this European Standard and the essential requirements of Directive 2014/33/EU aimed to be covered .....</b>	<b>173</b>
	<b>Bibliography .....</b>	<b>178</b>



## **European foreword**

This document (EN 81-20:2020) has been prepared by Technical Committee CEN/TC 10 “Lifts, escalators and moving walks”, the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by August 2020, and conflicting national standards shall be withdrawn at the latest by February 2022.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 81-20:2014.

This document is a revision of EN 81-20:2014. Significant changes made are as follows:

- All externally referenced standards have now been dated.
- A new Annex ZA has been developed in order to be aligned with the requirements of the EU Commission Standardization Request “M/549 C(2016) 5884 final”.

No technical changes have been made during this revision.

This standard is the culmination of the progressive development of the EN standards for lifts. Previous versions of the EN 81-1 and EN 81-2 standards incorporated into EN 81-20:2020 and EN 81-50:2020 include:

- EN 81-1:1985, Safety rules for electric lifts
- EN 81-1:1998, Safety rules for electric lifts
- EN 81-1:1998, Corrigendum No 1:1999;
- EN 81-1:1998/A1:2005, incorporating programmable electronic system in safety related applications for lifts;
- EN 81-1:1998/A2:2004, incorporating machine-room-less lifts;
- EN 81-1:1998+A3:2009, Incorporating unintended car movement with open doors;
- EN 81-2:1987, Safety rules for hydraulic lifts
- EN 81-2:1998, Safety rules for hydraulic lifts
- EN 81-2:1998, Corrigendum No 1:1999;
- EN 81-2:1998/A1:2005, incorporating programmable electronic system in safety related applications for lifts;
- EN 81-2:1998/A2:2004, incorporating machine-room-less lifts;
- EN 81-2:1998+A3:2009, incorporating unintended car movement with open doors.

This document is part of a series of standards giving safety rules for the construction and installation of lifts which are listed below.

<b>Standard</b>	<b>Use</b>
EN 81-21	Provides alternative technical requirements to those given in EN 81-20 to overcome certain specific problems encountered when installing lifts into existing buildings
EN 81-28	Provides the requirements for the alarm systems to be used on passenger carrying lifts to enable trapped persons to contact a rescue service.
EN 81-50	Used in conjunction with EN 81-20 to provide rules for type testing of safety related components and calculation methodology.
EN 81-58	Provides a unified method of testing the fire resistance of lift landing doors
EN 81-70	Provides additional requirements to EN 81-20 for accessible passenger lifts
EN 81-71	Provides additional requirements to EN 81-20 for vandal resistant lifts
EN 81-72	Provides additional requirements to EN 81-20 for lifts used by fire fighters
EN 81-73	Provides additional requirements to EN 81-20 for lifts used in the evacuation of disabled persons from buildings.
EN 81-77	Provides additional requirements to EN 81-20 for lifts subject to seismic conditions
EN 12015	Provides additional requirements to EN 81-20 for electromagnetic compatibility emissions
EN 12016	Provides additional requirements to EN 81-20 for electromagnetic compatibility immunity
EN 13015	Gives rules for the drafting of maintenance manuals to accompany lifts.

In addition CEN TR 81-10 gives information with regard to the structure of the EN 81 series of standards.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of this document.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## **0 Introduction**

### **0.1 General**

This standard is a type C standard as stated in EN ISO 12100.

The machinery concerned and the extent to which hazards, hazardous situations and hazardous events are covered are indicated in the scope of this standard.

When provisions of this type C standard are different from those which are stated in type A or B standards, the provisions of this type C standard take precedence over the provisions of the other standards, for machines that have been designed and built according to the provisions of this type C standard.

### **0.2 General remarks**

**0.2.1** The object of this standard is to define safety rules related to passenger and goods passenger lifts with a view to safeguarding persons and objects against the risk of accidents associated with the normal use, maintenance and emergency operation of lifts.

**0.2.2** A study has been made of the various possible hazards with lifts, see Clause 4.

**0.2.2.1** Persons to be safeguarded:

- a) users, including passengers and competent and authorized persons, e.g. maintenance and inspection personnel (see EN 13015);
- b) persons in the surrounding area of the well, or any machine room and pulley room, who may be effected by the lift.

**0.2.2.2** Property to be safeguarded:

- a) loads in car;
- b) components of the lift installation;
- c) building in which the lift is installed;
- d) the immediate surrounding area of the lift installation.

NOTE EN 81-71 gives additional requirements covering lifts resistant to acts of vandalism and EN 81-77 gives additional requirements covering lifts in seismic conditions.

**0.2.3** When the weight, size and/or shape of components prevent them from being moved by hand, they are:

- a) either fitted with attachments for lifting gear; or
- b) designed so that they can be fitted with such attachments (e.g. by means of threaded holes); or
- c) shaped in such a way that standard lifting gear can easily be attached.

## 0.3 Principles

### 0.3.1 General

In drawing up this standard the following principles have been used:

**0.3.2** This standard does not repeat all the general technical rules applicable to every electrical, mechanical, or building construction including the protection of building elements against fire.

It has, however, been necessary to establish certain requirements of good construction, either because they are peculiar to lift manufacture or because in the case of lift utilization the requirements may be more stringent than elsewhere.

**0.3.3** This standard states minimum rules for the installation of lifts into buildings/constructions. There may be in some countries regulations for the construction of buildings etc. which cannot be ignored.

Typical clauses affected by this are those defining minimum values for the height of the machine and pulley rooms and for their access doors dimensions.

**0.3.4** As far as possible the standard sets out only the requirements that materials and equipment have to meet in the interests of safe operation of lifts.

**0.3.5** Risk analysis, terminology and technical solutions have been considered taking into account the methods of EN ISO 12100, EN ISO 14798 and the EN 61508 series of standards.

**0.3.6** In order for EN 81-20 to be a widely applicable standard the average weight of a person has been determined to be 75 kg.

This standard defines the maximum car area related to a specified design load in the car (rated load) and the minimum car area to transport a corresponding number of persons, based on 75 kg per person, in order to detect and discourage overloading.

## 0.4 Assumptions

### 0.4.1 General

In drawing up this standard the following assumptions have been made:

**0.4.2** Negotiations have been made between the customer and the supplier and agreement reached about:

- a) the intended use of the lift;
- b) the type and mass of the handling devices intended to be used to load and unload the car in the case of goods passenger lifts;
- c) environmental conditions such as temperature, humidity, exposure to sun or wind, snow, corrosive atmosphere;
- d) civil engineering problems (for example, building regulations);
- e) other aspects related to the place of installation;
- f) the dissipation of heat from the components / equipment of the lift which would require ventilation of the well and/or the machinery space / location of equipment;

g) information concerning the aspects relating to noise and vibrations emitted by the equipment.

**0.4.3** Relevant risks have been considered for each component that may be incorporated in a complete lift installation and rules have been drawn up accordingly:

Components are:

- a) designed in accordance with usual engineering practice (see CEN/TR 81-12) and calculation codes, taking into account all failure modes;
- b) of sound mechanical and electrical construction;
- c) made of materials with adequate strength and of suitable quality;
- d) free of defects;
- e) free from harmful materials, e.g. asbestos.

**0.4.4** Components are kept in good repair and working order, so that the required dimensions remain fulfilled despite wear. All lift components are considered as requiring inspection to ensure safe continued operation during their use.

The operational clearances specified in the standard should be maintained not only during the examination and tests before the lift is put into service, but also throughout the life of the lift.

**NOTE** Components not requiring maintenance (e.g. maintenance free, sealed for life) are still required to be available for inspection.

**0.4.5** Components will be selected and installed so that foreseeable environmental influences and special working conditions do not affect the safe operation of the lift.

**0.4.6** By design of the load bearing elements, safe normal operation of the lift is ensured for loads ranging from 0 % to 100 % of the rated load, plus any designed overload capacity (see 5.12.1.2).

**0.4.7** The requirements of this standard are such that the possibility of a failure of an electric safety device (see 5.11.2) or a type tested safety component complying with all the requirements of this standard and EN 81-50 needs not to be taken into consideration.

**0.4.8** Users have to be safeguarded against their own negligence and unwitting carelessness when using the lift in the intended way.

**0.4.9** A user may, in certain cases, make one imprudent act. The possibility of two simultaneous acts of imprudence and/or the abuse of instructions for use is not considered.

**0.4.10** If in the course of maintenance work a safety device, normally not accessible to the users, is deliberately neutralized, safe operation of the lift is no longer ensured, but compensatory measures will be taken to ensure users safety in conformity with maintenance instructions.

It is assumed that maintenance personnel are instructed and work according to the instructions.

**0.4.11** Horizontal forces and/or energies to consider are indicated in the applicable clauses of the standard. Typically, where not otherwise specified in this standard, the energy exerted by a person results in an equivalent static force of:

- a) 300 N;

b) 1000 N where impact can occur.

**0.4.12** With the exception of the items listed below which have been given special consideration, a mechanical device built according to good practice and the requirements of the standard, including uncontrolled slipping of the ropes on the traction sheave will not deteriorate to a point of creating hazard without the possibility of detection provided that all of the instructions given by the manufacturer have been duly applied:

- a) breakage of the suspension;
- b) breakage and slackening of all linkage by auxiliary ropes, chains and belts;
- c) failure of one of the mechanical components of the electromechanical brake which take part in the application of the braking action on the drum or disk;
- d) failure of a component associated with the main drive elements and the traction sheave;
- e) rupture in the hydraulic system (jack excluded);
- f) small leakage in the hydraulic system (jack included, see 6.3.10).

**0.4.13** The possibility of the safety gear not engaging, should the car free fall from a stationary position at the lowest landing, before the car strikes the buffer(s) is considered acceptable.

**0.4.14** When the speed of the car is linked to the electrical frequency of the mains, the speed is assumed not to exceed 115 % of the rated speed or a corresponding lesser speed where specified in this standard for inspection control, levelling, etc.

**0.4.15** Means of access are provided for the hoisting of heavy equipment (see 0.4.2 e)).

**0.4.16** To ensure the correct functioning of the equipment in the well and machinery space(s), i.e. taking into account the heat dissipated by the equipment, the ambient temperature in the well and the machinery space(s) is assumed to be maintained between + 5 °C and + 40 °C.

NOTE See HD 60364-5-51, Code AA5.

**0.4.17** The well is suitably ventilated, according to national building regulation, taking into consideration the heat output as specified by the manufacturer, the environmental conditions of the lift and the limits given in 0.4.16, e.g. ambient temperature, humidity, direct sunlight, air quality and air tightness of buildings due to energy saving requirements.

NOTE See 0.4.2 and E.3 for further guidance.

**0.4.18** Access ways to the working areas are adequately lit (see 0.4.2).

**0.4.19** Minimum passageways, corridors, fire escapes, etc. are not obstructed by the open door/trap of the lift and/or any protection means for working areas outside of the well, where fitted according to the maintenance instructions (see 0.4.2).

**0.4.20** Where more than one person is working at the same time on a lift, an adequate means of communication between these persons is ensured.

## **SS-EN 81-20:2020 (E)**

**0.4.21** The fixing system of guards, used specifically to provide protection against mechanical, electrical or any other hazards by means of a physical barrier, which have to be removed during regular maintenance and inspection, remains attached to the guard or to the equipment when the guard is removed.

**0.4.22** The fluids used for the operation of hydraulic lifts are according to EN ISO 6743-4.

## 1 Scope

**1.1** This document specifies the safety rules for permanently installed new passenger or goods passenger lifts, with traction, positive or hydraulic drive, serving defined landing levels, having a car designed for the transportation of persons or persons and goods, suspended by ropes, chains or jacks and moving between guide rails inclined not more than 15° to the vertical.

**1.2** In addition to the requirements of this document, supplementary requirements have to be considered in special cases (use of lifts by persons with disabilities, in case of fire, potentially explosive atmosphere, extreme climate conditions, seismic conditions, transporting dangerous goods, etc.).

**1.3** This standard does not cover:

a) lifts with:

- 1) drive systems other than those stated in 1.1;
- 2) rated speed  $\leq 0,15$  m/s;

b) hydraulic lifts:

- 1) with a rated speed exceeding 1 m/s;
- 2) where the setting of the pressure relief valve (5.9.3.5.3) exceeds 50 MPa;

c) new passenger or goods passenger lifts in existing buildings <sup>1)</sup> where in some circumstances due to limitations enforced by building constraints, some requirements of EN 81-20 cannot be met and EN 81-21 should be considered;

d) lifting appliances, such as paternosters, mine lifts, theatrical lifts, appliances with automatic caging, skips, lifts and hoists for building and public works sites, ships' hoists, platforms for exploration or drilling at sea, construction and maintenance appliances or lifts in wind turbines;

e) important modifications (see Annex C) to a lift installed before this standard is brought into application;

f) safety during operations of transport, erection, repairs, and dismantling of lifts.

However, this standard may usefully be taken as a basis.

Noise and vibrations are not dealt with in this standard as they are not found at levels which could be considered as harmful with regard to the safe use and maintenance of the lift (see also 0.4.2).

**1.4** This standard is not applicable to passenger and goods passenger lifts, which are installed before the date of its publication.

---

<sup>1)</sup> Existing building is a building which is used or was already used before the order for the lift was placed. A building whose internal structure is completely renewed is considered as a new building.



## **2 Normative references**

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 81-28:2003, *Safety rules for the construction and installation of lifts — Lifts for the transport of persons and goods — Part 28: Remote alarm on passenger and goods passenger lifts*

EN 81-50:2020, *Safety rules for the construction and installation of lifts — Examinations and tests — Part 50: Design rules, calculations, examinations and tests of lift components*

EN 81-58:2003, *Safety rules for the construction and installation of lifts - Examination and tests - Part 58: Landing doors fire resistance test*

EN 131-2:2010+A1:2017, *Ladders — Requirements, testing, marking*

EN 1993-1-1:2002, *Eurocode 3 — Design of steel structures — Part 1-1: General rules and rules for buildings*

EN 10305-1:2016, *Steel tubes for precision applications - Technical delivery conditions - Part 1: Seamless cold drawn tubes*

EN 10305-2:2016, *Steel tubes for precision applications - Technical delivery conditions - Part 2: Welded cold drawn tubes*

EN 10305-3:2016, *Steel tubes for precision applications - Technical delivery conditions - Part 3: Welded cold sized tubes*

EN 10305-4:2016, *Steel tubes for precision applications - Technical delivery conditions - Part 4: Seamless cold drawn tubes for hydraulic and pneumatic power systems*

EN 10305-5:2016, *Steel tubes for precision applications - Technical delivery conditions - Part 5: Welded cold sized square and rectangular tubes*

EN 10305-6:2016, *Steel tubes for precision applications - Technical delivery conditions - Part 6: Welded cold drawn tubes for hydraulic and pneumatic power systems*

EN 12015:2014, *Electromagnetic compatibility - Product family standard for lifts, escalators and moving walks - Emission*

EN 12016:2013, *Electromagnetic compatibility - Product family standard for lifts, escalators and moving walks - Immunity*

EN 12385-5:2002, *Steel wire ropes - Safety - Part 5: Stranded ropes for lifts*

EN 12600:2002, *Glass in building - Pendulum test - Impact test method and classification for flat glass*

EN 13015:2001+A1:2008, *Maintenance for lifts and escalators - Rules for maintenance instructions*

EN 13501-1:2007+A1:2009, *Fire classification of construction products and building elements — Part 1: Classification using data from reaction to fire tests*

EN 50205:2002, *Relays with forcibly guided (mechanically linked) contacts*

- EN 50214:2006, *Flat polyvinyl chloride sheathed flexible cables*
- EN 50274:2002, *Low-voltage switchgear and controlgear assemblies - Protection against electric shock - Protection against unintentional direct contact with hazardous live parts*
- EN 60204-1:2006, *Safety of machinery - Electrical equipment of machines - Part 1: General requirements*
- EN 60529:1992, *Degrees of protection provided by enclosures (IP Code) (IEC 60529)*
- EN 60664-1:2007, *Insulation coordination for equipment within low-voltage systems - Part 1: Principles, requirements and tests*
- EN 60947-4-1:2010, *Low-voltage switchgear and controlgear - Part 4-1: Contactors and motor-starters - Electromechanical contactors and motor-starters*
- EN 60947-5-1:2004, *Low-voltage switchgear and controlgear - Part 5-1: Control circuit devices and switching elements - Electromechanical control circuit devices*
- EN 60947-5-5:1997, *Low-voltage switchgear and controlgear - Part 5-5: Control circuit devices and switching elements - Electrical emergency stop device with mechanical latching function*
- EN 61310-3:2008, *Safety of machinery - Indication, marking and actuation - Part 3: Requirements for the location and operation of actuators*
- EN 61800-5-2:2007, *Adjustable speed electrical power drive systems - Part 5-2: Safety requirements - Functional*
- EN 61810-1:2008, *Electromechanical elementary relays — Part 1: General requirements (IEC 61810-1:2015)*
- EN ISO 12100:2010, *Safety of machinery - General principles for design - Risk assessment and risk reduction (ISO 12100:2010)*
- EN ISO 13857:2008, *Safety of machinery - Safety distances to prevent hazard zones being reached by upper and lower limbs (ISO 13857:2008)*
- HD 60364-4-41:2007, *Low-voltage electrical installations - Part 4-41: Protection for safety - Protection against electric shock*
- HD 60364-4-42:2011, *Low voltage electrical installations - Part 4-42: Protection for safety - Protection against thermal effects*
- HD 60364-6:2007, *Low voltage electrical installations - Part 6: Verification*
- IEC 60227-6:2001, *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V — Part 6: Lift cables and cables for flexible connections*
- IEC 60245-5:1994, *Rubber insulated cables – Rated voltages up to and including 450/750 V – Part 5: Lift cables*
- IEC 60417:2002, *Database — Graphical symbols for use on equipment*
- IEC 60617:2012, *Graphical symbols for diagrams*

ISO 1219-1:2012, *Fluid power systems and components — Graphical symbols and circuit diagrams — Part 1: Graphical symbols for conventional use and data-processing applications*