



Fastställd 2020-10-21

Utgåva 1 Sida 1 (1+77) Ansvarig kommitté SEK TK 120

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

Elektriska energilagringssystem (EES) – Del 5-2: Säkerhetsfordringar på elektriska energilagringssystem i elnätet – Elektrokemiska system

Electrical energy storage (EES) systems – Part 5-2: Safety requirements for grid-integrated EES systems – Electrochemical-based systems

Som svensk standard gäller europastandarden EN IEC 62933-5-2:2020. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 62933-5-2:2020.

Nationellt förord

Europastandarden EN IEC 62933-5-2:2020

består av:

- europastandardens ikraftsättningsdokument, utarbetat inom CENELEC
- IEC 62933-5-2, First edition, 2020 Electrical energy storage (EES) systems Part 5-2: Safety requirements for grid-integrated EES systems Electrochemical-based systems

utarbetad inom International Electrotechnical Commission, IEC.

Standarden ska användas tillsammans med SEK TS 62933-5-1, utgåva 1, 2018.

ICS 13.020.30

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284 164 29 Kista Tel 08-444 14 00 www.elstandard.se

EUROPEAN STANDARD NORME EUROPÉENNE EUROPÄISCHE NORM

EN IEC 62933-5-2

May 2020

ICS 13.020.30

English Version

Electrical energy storage (EES) systems - Part 5-2: Safety requirements for grid-integrated EES systems - Electrochemical-based systems
(IEC 62933-5-2:2020)

Systèmes de stockage de l'énergie électrique (EES) - Partie 5-2: Exigences de sécurité pour les systèmes EES intégrés dans un réseau - Systèmes électrochimiques (IEC 62933-5-2:2020) Elektrische Energiespeichersysteme (EES-Systeme) - Teil 5-2: Sicherheitsanforderungen an netzintegrierte EES-Systeme elektrochemische Systeme (IEC 62933-5-2:2020)

This European Standard was approved by CENELEC on 2020-05-21. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization Comité Européen de Normalisation Electrotechnique Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2020 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

Ref. No. EN IEC 62933-5-2:2020 E

European foreword

The text of document 120/173/FDIS, future edition 1 of IEC 62933-5-2, prepared by IEC/TC 120 "Electrical Energy Storage (EES) Systems" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62933-5-2:2020.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2021-02-21 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2023-05-21

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 62933-5-2:2020 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

| IEC 60364-4-41 | NOTE | Harmonized as HD 60364-4-41 |
|--------------------|------|--|
| IEC 60364-4-42 | NOTE | Harmonized as HD 60364-4-42 |
| IEC 60364-4-43 | NOTE | Harmonized as HD 60364-4-43 |
| IEC 60721 (series) | NOTE | Harmonized as EN 60721 (series) |
| IEC 60896-21 | NOTE | Harmonized as EN 60896-21 |
| IEC 60896-22 | NOTE | Harmonized as EN 60896-22 |
| IEC 61140 | NOTE | Harmonized as EN 61140 |
| IEC 61427-1 | NOTE | Harmonized as EN 61427-1 |
| IEC 61427-2 | NOTE | Harmonized as EN 61427-2 |
| IEC 61508 (series) | NOTE | Harmonized as EN 61508 (series) |
| IEC 61511-1:2016 | NOTE | Harmonized as EN 61511-1:2017 (not modified) |
| IEC 62040-1 | NOTE | Harmonized as EN IEC 62040-1 |
| IEC 62040-2 | NOTE | Harmonized as EN IEC 62040-2 |
| IEC 62116:2014 | NOTE | Harmonized as EN 62116:2014 (not modified) |
| IEC 62351 (series) | NOTE | Harmonized as EN 62351 (series) |
| IEC 62381:2012 | NOTE | Harmonized as EN 62381:2012 (not modified) |
| IEC 62443-2-4 | NOTE | Harmonized as EN IEC 62443-2-4 |
| IEC 62485-1 | NOTE | Harmonized as EN IEC 62485-1 |
| IEC 62909-1 | NOTE | Harmonized as EN IEC 62909-1 |
| IEC 62932-1:2020 | NOTE | Harmonized as EN IEC 62932-1:2020 (not modified) |
| ISO 1182 | NOTE | Harmonized as EN ISO 1182 |
| ISO 9241 (series) | NOTE | Harmonized as EN ISO 9241 (series) |
| ISO 13732-1:2006 | NOTE | Harmonized as EN ISO 13732-1:2008 (not modified) |
| ISO 13850:2015 | NOTE | Harmonized as EN ISO 13850:2015 (not modified) |
| | | |

Annex ZA

(normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

| Publication | <u>Year</u> | <u>Title</u> | EN/HD | <u>Year</u> |
|----------------|-------------|--|-------------------|-------------|
| IEC 60068-2-52 | - | Environmental testing - Part 2-52: Tests - Test Kb: Salt mist, cyclic (sodium chloride solution) | EN IEC 60068-2-52 | - |
| IEC 60079-7 | 2015 | Explosive atmospheres - Part 7: Equipment protection by increased safety "e" | EN 60079-7 | 2015 |
| + A1 | 2017 | | + A1 | 2018 |
| IEC 60079-13 | - | Explosive atmospheres - Part 13: Equipment protection by pressurized room "p" and artificially ventilated room "v" | EN 60079-13 | - |
| IEC 60079-29 | series | Explosive atmospheres - Gas detectors | EN 60079-29 | series |
| IEC 60364 | series | Low-voltage electrical installations | - | - |
| IEC 60364-4-44 | - | Low-voltage electrical installations - Part 4- 44: Protection for safety - Protection against voltage disturbances and electromagnetic disturbances | HD 60364-4-442 | - |
| IEC 60364-6 | 2016 | Low voltage electrical installations - Part 6: Verification | HD 60364-6 | 2016 |
| | | verilication | + A11 | 2017 |
| | | | + A12 | 2017 |
| IEC 60529 | - | Degrees of protection provided by enclosures (IP Code) | - | - |
| IEC 60664-1 | 2007 | Insulation coordination for equipment within low-voltage systems - Part 1: Principles, requirements and tests | EN 60664-1 | 2007 |
| IEC 60812 | - | Failure modes and effects analysis (FMEA and FMECA) | EN IEC 60812 | - |

| <u>Publication</u> | <u>Year</u> | <u>Title</u> | EN/HD | <u>Year</u> |
|--------------------|-------------|--|----------------|-------------|
| IEC 61000-1-2 | - | Electromagnetic compatibility (EMC) - Part 1-2: General - Methodology for the achievement of functional safety of electrical and electronic systems including equipment with regard to electromagnetic phenomena | EN 61000-1-2 | - |
| IEC 61000-6-7 | - | Electromagnetic compatibility (EMC) - Part 6-7: Generic standards - Immunity requirements for equipment intended to perform functions in a safety-related system (functional safety) in industrial locations | EN 61000-6-7 | - |
| IEC 61025 | - | Fault tree analysis (FTA) | - | - |
| IEC 61660-1 | - | Short-circuit currents in d.c. auxiliary installations in power plants and substations - Part 1: Calculation of short-circuit currents | EN 61660-1 | - |
| IEC 61660-2 | - | Short-circuit currents in d.c. auxiliary installations in power plants and substations - Part 2: Calculation of effects | EN 61660-2 | - |
| IEC 61882 | - | Hazard and operability studies (HAZOP studies) - Application guide | EN 61882 | - |
| IEC 61936-1 (mod) | 2010 | Power installations exceeding 1 kV a.c Part 1: Common rules | EN 61936-1 | 2010 |
| | | | + AC | 2013 |
| + A1 | 2014 | | + A1 | 2014 |
| IEC 62305-2 | - | Protection against lightning - Part 2: Risk management | - | - |
| IEC 62368-1 | - | Audio/video, information and communication technology equipment - Part 1: Safety requirements | EN IEC 62368-1 | - |
| IEC 62477-1 | 2012 | Safety requirements for power electronic converter systems and equipment - Part 1: General | EN 62477-1 | 2012 |
| | | | + A11 | 2014 |
| + A1 | 2016 | | + A1 | 2017 |
| IEC 62485-2 | - | Safety requirements for secondary batteries and battery installations - Part 2: Stationary batteries | EN IEC 62485-2 | - |
| IEC 62619 | 2017 | Secondary cells and batteries containing alkaline or other non-acid electrolytes - Safety requirements for secondary lithium cells and batteries, for use in industrial applications | EN 62619 | 2017 |

EN IEC 62933-5-2:2020 (E)

| <u>Publication</u> | <u>Year</u> | <u>Title</u> | EN/HD | <u>Year</u> |
|--------------------|-------------|--|----------------|-------------|
| IEC 62933-1 | - | Electrical energy storage (EES) systems - Part 1: Vocabulary | EN IEC 62933-1 | - |
| IEC/TS 62933-5-1 | 2017 | Electrical energy storage (EES) systems - Part 5-1: Safety considerations for grid integrated EES systems - General specification | - | - |
| ISO/IEC Guide 51 | 2014 | Safety aspects - Guidelines for their inclusion in standards | - | - |

CONTENTS

| F | DREWOR | RD | 5 |
|----|--------------|---|----|
| IN | TRODUC | CTION | 7 |
| 1 | Scope | | 8 |
| 2 | • | itive references | |
| 3 | | and definitions | |
| 4 | | guidelines for safety of BESS | |
| 4 | | General | |
| | | Approach to BESS safety | |
| | | BESS changes in ownership, control or use | |
| 5 | | d considerations | |
| 6 | | system risk assessment | |
| O | | • | |
| | | BESS structure | |
| | 6.1.1 | General characteristics | |
| | 6.1.2 6.2 | Specific characteristics Description of BESS conditions | |
| | | Risk analysis | |
| | 6.3.1 | General | |
| | 6.3.1 | Hazard identification specific to BESS | _ |
| | 6.3.3 | Risk consideration | |
| | 6.3.4 | System level risk analysis | |
| | | System level risk assessment | |
| 7 | | ements necessary to reduce risks | |
| • | • | General measures to reduce risks | |
| | | Preventive measures against damage to neighbouring inhabitants | |
| | | Preventive measures against damage to heighbouring inhabitants | |
| | 7.0 I | vorkers and residents | 18 |
| | 7.4 | Overcurrent protection design | 18 |
| | 7.5 E | BESS disconnection and shutdown | 18 |
| | 7.6 | Operation and maintenance | 18 |
| | 7.7 | Staff training | 18 |
| | 7.8 | Safety design | 19 |
| | 7.9 | General requirements for BESS safety | 19 |
| | 7.10 I | nherently safe design of BESS | 19 |
| | 7.10.1 | | |
| | 7.10.2 | | |
| | 7.10.3 | • | 21 |
| | 7.10.4 | Protection from hazards arising from electric, magnetic, and electromagnetic fields | 21 |
| | 7.10.5 | - | |
| | 7.10.6 | | |
| | 7.10.7 | | |
| | 7.10.8 | | |
| | 7.10.9 | • | |
| | | Guards and protective measures | |
| | 7.11.1 | General | |
| | 7.11.2 | BESS disconnection and shutdown | 23 |

| | 7.11.3 | Other guards and protective functions of BESS | 24 |
|----|----------------|---|----|
| | 7.12 Info | ormation for end users | 28 |
| | 7.13 Life | cycle safety management | 28 |
| | 7.13.1 | Operation and maintenance | 28 |
| | 7.13.2 | Partial system change | 31 |
| | 7.13.3 | Design revision | 32 |
| | 7.13.4 | End of service life management | 33 |
| | 7.13.5 | Measures for validating life cycle safety management | 33 |
| 8 | System v | alidation and testing | 33 |
| | 8.1 Gei | neral | 33 |
| | 8.2 Val | idation and testing of BESS | 36 |
| | 8.2.1 | Electrical hazards | |
| | 8.2.2 | Mechanical hazards | 38 |
| | 8.2.3 | Explosion | 38 |
| | 8.2.4 | Hazards arising from electric, magnetic, and electromagnetic fields | |
| | 8.2.5 | Fire hazards (propagation) | |
| | 8.2.6 | Temperature hazards | |
| | 8.2.7 | Chemical effects | |
| | 8.2.8 | Hazards arising from auxiliary, control and communication system | |
| | | malfunctions | 42 |
| | 8.2.9 | Hazards arising from environments | 42 |
| | 8.2.10 | IP rating of BESS enclosure and protective guards | 43 |
| 9 | Guideline | es and manuals | 43 |
| Ar | nnex A (info | rmative) Ownership models of BESS | 44 |
| | - | rmative)BESS hazards and risks | |
| | • | neral introduction | |
| | | zard concerns | |
| | B.2.1 | General | |
| | B.2.2 | Fire hazards | |
| | B.2.3 | Chemical hazards | |
| | B.2.4 | Electrical hazards | |
| | B.2.5 | Energy hazards | |
| | B.2.6 | Physical hazards | |
| | B.2.7 | High-pressure hazards | |
| | | zard considerations under normal operating conditions | |
| | B.3.1 | Fire and explosive hazards | |
| | B.3.1 | Chemical hazards | |
| | B.3.3 | Electrical hazards | |
| | B.3.4 | Physical hazards | |
| | | zard considerations under emergency/abnormal conditions | |
| | B.4.1 | Fire hazards | |
| | B.4.2 | Chemical hazards | |
| | B.4.3 | Electrical hazards | |
| | В.4.3 В.4.4 | Physical hazards | |
| | | nmercially available battery technologies | |
| | B.5.1 | Lithium ion (Li-ion) batteries (C-A) | |
| | B.5.1 B.5.2 | Lead-acid batteries (C-B) | |
| | B.5.2 B.5.3 | Nickel batteries (C-B) | |
| | B.5.4 | High-temperature sodium batteries (C-C) | |
| | D.J.¬ | riigii temperatare occidin batterios (O-O) | |

| B.5.5 Flow batteries (C-D) | 61 |
|--|----|
| B.5.6 Lithium metal solid state batteries (C-Z) | 63 |
| B.6 Other technologies | |
| Annex C (informative) Large-scale fire testing on BESS | 64 |
| Annex D (informative) Test methods for protection from hazards arising from | |
| environments | |
| D.1 General | |
| D.2 Outdoor installations subject to moisture exposure | |
| D.3 Outdoor installation near marine environments | 65 |
| Annex E (informative) Information for validation of BESS life cycle safety management | 66 |
| E.1 Overview | |
| E.2 General introduction | |
| E.3 Operation and maintenance process | |
| E.4 Preventive maintenance | |
| E.5 Measuring and monitoring of system soundness | 67 |
| E.6 Staff training | 67 |
| E.7 Partial system change | 67 |
| E.8 Design revision | |
| Annex F (informative) BESS safety signage | 68 |
| Annex G (informative) Example of testing for verification of thermal control operation | 69 |
| Bibliography | 70 |
| | |
| Figure 1 – General description for risk assessment and reduction of BESS | 11 |
| Figure 2 – An example of BESS architecture | 15 |
| Figure 3 – Example of isolated condition (whole isolation of BESS) | 24 |
| Figure 4 – Incompatibility of capacity and/or usage in a BESS | 32 |
| | |
| Table 1 – BESS categories | 13 |
| Table 2 – Examples of BESS use | |
| Table 3 – Examples of components within subsystems of a BESS | |
| Table 4 – Examples of incompatibilities that can arise from system changes | |
| Table 5 – Overview of validation and testing for BESS | |
| Table B.1 – Hazards of BESS in common | |
| Table B.1 – Hazards of BESS in common | |
| | |
| Table B.3 – Hazards of BESS using aqueous electrolyte battery (category "C-B") | |
| Table B.4 – Hazards of BESS using high temperature battery (category "C-C") | |
| Table B.5 – Hazards of BESS using flow battery (category "C-D") | 51 |

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRICAL ENERGY STORAGE (EES) SYSTEMS -

Part 5-2: Safety requirements for grid-integrated EES systems – Electrochemical-based systems

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62933-5-2 has been prepared by IEC technical committee 120: Electrical Energy Storage (EES) Systems.

This International Standard is to be used in conjunction with IEC TS 62933-5-1:2017.

The text of this International Standard is based on the following documents:

| FDIS | Report on voting | | |
|--------------|------------------|--|--|
| 120/173/FDIS | 120/182/RVD | | |

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62933 series, published under the general title *Electrical energy storage (EES) systems*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- · replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

All the electrical energy storage systems (EESS) follow the general safety requirements as described in IEC TS 62933-5-1, which is based on a systems approach. IEC 62933-5-2 follows the same structure as IEC TS 62933-5-1 and provides additional requirements for battery energy storage systems (BESS). The additional requirements are provided for the following reasons:

- a) BESS can be integrated into a significant range of electrical grids.
- b) The level of safety requirements awareness can vary between utilities, system integrators, operators and end-users.
- c) Although the safety of individual subsystems is generally covered by international standards at ISO and IEC levels, the safety matters that arise due to the combination of electrochemical accumulation subsystems and any electrical subsystems are not always considered. BESS are complex at the systems level due to the variety of potential battery options and configurations, including the combination of subsystems (e.g. control systems for electrochemical accumulation subsystems, electrochemical accumulation subsystems, power conversion subsystems and auxiliary subsystems). Compliance with standards and related material produced specifically for the safety of subsystems cannot be sufficient to reach an acceptable level of safety for the overall system.
- d) BESS can have additional safety hazards, due, for example, to the presence of chemicals, the emission of toxic gases, chemicals spilt around the electrochemical accumulation subsystems and to events critical for safety from electrochemical accumulation subsystems that cause safety issues for the entire BESS. They can cause loss of power at any part of the systems and buildings that can result in additional threats to safety. From a systems perspective, these individual hazards can have a system wide impact.

ELECTRICAL ENERGY STORAGE (EES) SYSTEMS -

Part 5-2: Safety requirements for grid-integrated EES systems – Electrochemical-based systems

1 Scope

This part of IEC 62933 primarily describes safety aspects for people and, where appropriate, safety matters related to the surroundings and living beings for grid-connected energy storage systems where an electrochemical storage subsystem is used.

This safety standard is applicable to the entire life cycle of BESS (from design to end of service life management).

This document provides further safety provisions that arise due to the use of an electrochemical storage subsystem (e.g. battery system) in energy storage systems that are beyond the general safety considerations described in IEC TS 62933-5-1.

This document specifies the safety requirements of an "electrochemical" energy storage system as a "system" to reduce the risk of harm or damage caused by the hazards of an electrochemical energy storage system due to interactions between the subsystems as presently understood.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitute requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-52, Environmental testing – Part 2-52: Tests – Test Kb: Salt mist, cyclic (sodium chloride solution)

IEC 60079-7:2015, Explosive atmospheres – Part 7: Equipment protection by increased safety "e"

IEC 60079-7:2015/AMD1:2017

IEC 60079-13, Explosive atmospheres – Part 13: Equipment protection by pressurized room "p" and artificially ventilated room "v"

IEC 60079-29 (all parts), Explosive atmospheres – Gas detectors

IEC 60364 (all parts), Low-voltage electrical installations

IEC 60364-4-44, Low-voltage electrical installations – Part 4-44: Protection for safety – Protection against voltage disturbances and electromagnetic disturbances

IEC 60364-6:2016, Low voltage electrical installations – Part 6: Verification

IEC 60529, Degrees of protection provided by enclosures (IP Code)

IEC 60664-1:2007, Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests

IEC 60812, Failure modes and effects analysis (FMEA and FMECA)

IEC 61000-1-2, Electromagnetic compatibility (EMC) – Part 1-2: General – Methodology for the achievement of functional safety of electrical and electronic systems including equipment with regard to electromagnetic phenomena

IEC 61000-6-7, Electromagnetic compatibility (EMC) – Part 6-7: Generic standards – Immunity requirements for equipment intended to perform functions in a safety-related system (functional safety) in industrial locations

IEC 61025, Fault tree analysis (FTA)

IEC 61660-1, Short-circuit currents in d.c. auxiliary installations in power plants and substations – Part 1: Calculation of short-circuit currents

IEC 61660-2, Short-circuit currents in d.c. auxiliary installations in power plants and substations – Part 2: Calculation of effects

IEC 61882, Hazard and operability studies (HAZOP studies) - Application guide

IEC 61936-1:2010, Power installations exceeding 1 kV a.c. – Part 1: Common rules IEC 61936-1:2010/AMD1:2014

IEC 62305-2, Protection against lightning – Part 2: Risk management

IEC 62368-1, Audio/video, information and communication technology equipment – Part 1: Safety requirements

IEC 62477-1:2012, Safety requirements for power electronic converter systems and equipment – Part 1: General

IEC 62477-1:2012/AMD1:2016

IEC 62485-2, Safety requirements for secondary batteries and battery installations – Part 2: Stationary batteries

IEC 62619:2017, Secondary cells and batteries containing alkaline or other non-acid electrolytes – Safety requirements for secondary lithium cells and batteries, for use in industrial applications

IEC 62933-1, Electrical energy storage (EES) systems – Part 1: Vocabulary

IEC TS 62933-5-1:2017, Electrical energy storage (EES) systems – Part 5-1: Safety considerations for grid integrated EES systems – General specification

ISO/IEC Guide 51:2014, Safety aspects – Guidelines for their inclusion in standards