

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

## **Alarm systems – External perimeter security systems – Part 1: System requirements**

*(CENELEC Technical Specification 50661-1:2017)*

### **Nationellt förord**

En teknisk specifikation, TS, utarbetad inom CENELEC är avsedd att ge beskrivningar som kan stödja den inre marknads utveckling, ge vägledning beträffande specifikationer eller provningsmetoder eller ge specifikationer för teknikområden under snabb utveckling. Ett förslag till europeisk standard, EN, som det inte varit möjligt att nå tillräcklig enighet kring, kan också fastställas som TS, för att användas på försök (som förstandard) och för att efter eventuella justeringar eller bearbetningar senare fastställas som EN. En teknisk specifikation har en giltighetstid som är begränsad till tre år, med möjlighet till förlängning med tre eller högst sex år.

---

ICS 13.320.00

---

Detta dokument är fastställt av SEK Svensk Elstandard, som också kan lämna upplysningar om **sakinnehållet**.  
Postadress: Box 1284, 164 29 KISTA  
Telefon: 08 - 444 14 00.  
E-post: [sek@elstandard.se](mailto:sek@elstandard.se). Internet: [www.elstandard.se](http://www.elstandard.se)

---

### *Standarder underlättar utvecklingen och höjer elsäkerheten*

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

### *SEK är Sveriges röst i standardiseringsarbetet inom elområdet*

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

### *Stora delar av arbetet sker internationellt*

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

### *Var med och påverka!*

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

### **SEK Svensk Elstandard**

Box 1284  
164 29 Kista  
Tel 08-444 14 00  
[www.elstandard.se](http://www.elstandard.se)

ICS 13.320

English Version

## Alarm systems - External perimeter security systems - Part 1: System requirements

Systèmes d'alarme - Systèmes de sécurité de périmètre  
externes - Partie 1: Exigences système

Alarmanlagen Alarmanlagen - Externe Perimeter  
Sicherheitsanlagen - Teil 1: Systemanforderungen

This Technical Specification was approved by CENELEC on 2017-07-31.

CENELEC members are required to announce the existence of this TS in the same way as for an EN and to make the TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

**Contents**

European foreword .....	4
Introduction .....	5
1 Scope .....	6
2 Normative references .....	6
3 Terms, definitions and abbreviations .....	6
3.1 Terms and definitions .....	6
3.2 Abbreviations .....	12
4 System Structure .....	13
4.1 General .....	13
4.2 EPSS central functions .....	13
4.3 Transceiver .....	14
4.4 User interface .....	14
4.5 Power Supply .....	14
4.6 Interconnections .....	14
5 General Requirements, Classifications and Grading .....	14
5.1 General .....	14
5.2 Grading .....	15
5.3 Environmental classification .....	16
5.4 Concepts (Area, Layer, Zone, Detector, Detector Point) .....	17
5.5 Overview of Intrusion Detection, Tamper, Fault Types .....	19
5.6 Documentation and Marking .....	19
6 Component Requirements .....	20
6.4 Reduction of detection capability .....	21
6.5 Fault Detection .....	21
7 Interconnections .....	22
7.1 General .....	22
7.2 Availability of interconnections .....	22
7.3 Monitoring of interconnection .....	22
7.4 Security of communication .....	23
8 System Notification .....	23
8.1 General .....	23
8.2 ATS Notification .....	23
8.3 Audible or other notifications .....	23
8.4 Indications .....	23
9 System Control Interfaces .....	24
10 Power Supply .....	24
10.1 Types of power supply .....	24
10.2 Requirements .....	24
11 Processing .....	25
11.1 Modes .....	25
11.2 Event processing .....	26
11.3 Indications .....	28
11.4 Event Recording .....	29

12	Operation .....	30
12.1	Operation - General .....	30
12.2	User Access and User Administration .....	31
12.3	Basic Operation .....	33
12.4	Advanced Operation .....	35
12.5	Automatic Operation .....	35
Annex A (normative)	Special national conditions .....	36
Bibliography	.....	37

## **European foreword**

This document (CLC/TS 50661-1:2017) has been prepared by CLC/TC 79 "Alarm systems".

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

## Introduction

This Technical Specification applies to External and Perimeter Security Systems.

This Technical Specification is a specification for External and Perimeter Security Systems (EPSS) to provide detection of intruders in external areas outside enclosed buildings installed in the perimeter outside buildings. It includes four self protection grades, four environmental classes and four performance categories.

At the time of writing there is a desire to develop a series of standards for EPSS. This first version of this technical specification is intended to create a framework to enable development of the other parts of the series. In particular this will include the application guidelines and the detector component standards. It is expected that during the development of these other parts enhancements to the system requirements will be identified.

The purpose of an EPSS is to enhance the security of the supervised premises. To maximize its effectiveness an EPSS should be integrated with appropriate physical security devices and procedures. This is particularly important to higher grade EPSS.

This technical specification is intended to assist insurers, intruder alarm companies, customers, the police and other relevant organisations in achieving a complete and accurate specification of the supervision required in particular premises, but it does not specify the type of technology, the extent or degree of detection, nor does it necessarily cover all of the requirements for a particular installation.

All references to the requirements for EPSS refer to basic minimum requirements and the designers of such installed EPSS should take into account the nature of the premises, the value of the contents, the degree of risk of intrusion, the threat to personnel and any other factors which may influence the choice of grade and performance category of an EPSS.

Recommendations for design, planning, operation, installation and maintenance are given in Application Guidelines CLC/prTS 50661-7 (to be developed).

This technical specification makes allowance for the EPSS designer to vary the design of the system according to whether the site is usually staffed when the EPSS is in use or continuously staffed and whether the staff use an internal monitoring station (see definitions) or response is initiated from an alarm receiving centre.

In the context of this technical specification "external" refers to an area, which is not wholly enclosed inside a building, within which it is desired to detect intruders. The perimeter is typically a physical boundary to a site. In some cases the EPSS may include detection devices outside of the physical boundary (e.g. fence) that are used to provide an early warning of possible intrusion or in combination with perimeter detection devices to verify a likely crossing of the perimeter.

This technical specification is not intended to be used for testing individual EPSS components. Requirements for testing individual EPSS components are given in the relevant component standards (to be developed).

## 1 Scope

This Technical Specification specifies the requirements for security systems to provide detection of intruders in external areas outside enclosed buildings.

For enclosed buildings EN 50131-1 should be applied. CLC/TS 50661-1 may be used for unenclosed buildings such as roofed storage areas where an intruder and hold-up alarm system is not suitable.

This Technical Specification specifies performance requirements for installed EPSS but does not include requirements for designing, planning, installation, operation or maintenance.

These requirements also apply to EPSS sharing means of detection, interconnection, control, communication and power supplies with other applications.

This Technical Specification references requirements for system components according to the environment where they are expected to operate as designed. These environmental conditions are classified.

This Technical Specification does not deal with requirements for compliance with EC regulatory Directives, such as the RED Directive, EMC Directive, Low Voltage Directive, etc. except that it specifies the equipment operating conditions for EMC susceptibility testing as required by EN 50130-4.

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50130-5, *Alarm systems - Part 5: Environmental test methods*

EN 50131-6, *Alarm systems - Intrusion and hold-up systems - Part 6: Power supplies*

prEN 50398-1:2016, *Alarm systems - Combined and integrated systems - Part 1: General requirements*

EN 50136-1, *Alarm systems - Alarm transmission systems and equipment - Part 1: General requirements for alarm transmission systems*