

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

Isolatorer –

Isolatorer av keramiskt material eller glas för friledningar med systemspänning över 1000 V växelspanning – Tekniska data för isolatorer av kåp-pinntyp

*Insulators for overhead lines with a nominal voltage above 1000 V –
Ceramic or glass insulator units for AC systems –
Characteristics of insulator units of the cap and pin type*

Som svensk standard gäller europastandarden EN IEC 60305:2021. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 60305:2021.

Nationellt förord

Europastandarden EN IEC 60305:2021

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 60305, Fifth edition, 2021 - Insulators for overhead lines with a nominal voltage above 1000 V - Ceramic or glass insulator units for AC systems - Characteristics of insulator units of the cap and pin type**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 60305, utgåva 1, 1997, gäller ej fr o m 2024-02-15.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English Version

Insulators for overhead lines with a nominal voltage above
1 000 V - Ceramic or glass insulator units for AC systems -
Characteristics of insulator units of the cap and pin type
(IEC 60305:2021)

Isolateurs pour lignes aériennes de tension nominale
supérieure à 1 000 V - Éléments d'isolateurs en céramique
ou en verre pour réseaux à tension alternative -
Caractéristiques des éléments d'isolateurs du type capot et
tige
(IEC 60305:2021)

Isolatoren für Freileitungen mit einer Nennspannung über
1000 V – Keramik- oder Glas-Kettenisolatoren für
Wechselstromsysteme – Kenngrößen von Kettenisolatoren
vom Typ Kappenisolator
(IEC 60305:2021)

This European Standard was approved by CENELEC on 2021-02-15. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 36/499/FDIS, future edition 5 of IEC 60305, prepared by IEC/TC 36 "Insulators" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 60305:2021.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2021-11-15 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2024-02-15 document have to be withdrawn

This document supersedes EN 60305:1996 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 60305:2021 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60120:2020	NOTE	Harmonized as EN IEC 60120:2020 (not modified)
IEC 60471:2020	NOTE	Harmonized as EN IEC 60471:2020 (not modified)

Annex ZA

(normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60383-1	-	Insulators for overhead lines with a nominal voltage above 1000 V - Part 1: Ceramic or glass insulator units for a.c. systems - Definitions, test methods and acceptance criteria	EN 60383-1	-

CONTENTS

FOREWORD	3
1 Scope	5
2 Normative references	5
3 Terms and definitions	5
4 Mechanical characteristics, dimensions and types	6
5 Designation and marking with respect to shed profile	6
6 Tolerances	8
Bibliography	14
Figure 1 – Typical "standard" profile	7
Figure 2 – Typical "anti-fog" profile "P"	7
Figure 3 – Typical "aerodynamic" profile "D"	7
Figure 4 – Typical "two-alternating" profile "V"	7
Figure 5 – Typical "three-alternating" profile "T"	8
Figure 6 – String insulator unit of standard and anti-fog profile with ball and socket coupling	8
Figure 7 – String insulator unit of standard and anti-fog profile with clevis and tongue coupling	10
Figure 8 – String insulator unit of aerodynamic profile with ball and socket coupling	11
Figure 9 – String insulator unit of two-alternating profile with ball and socket coupling	11
Figure 10 – String insulator unit of three-alternating profile with ball and socket coupling	12
Table 1 – Specified values of mechanical and dimensional characteristics for string insulator units of standard and anti-fog profile with ball and socket couplings	9
Table 2 – Specified values of mechanical and dimensional characteristics for string insulator units of standard and anti-fog profile with clevis and tongue couplings	10
Table 3 – Specified values of mechanical and dimensional characteristics for string insulator units of aerodynamic profile with ball and socket couplings	11
Table 4 – Specified values of mechanical and dimensional characteristics for string insulator units of two-alternating profile with ball and socket couplings	12
Table 5 – Specified values of mechanical and dimensional characteristics for string insulator units of three-alternating profile with ball and socket couplings	13

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INSULATORS FOR OVERHEAD LINES WITH
A NOMINAL VOLTAGE ABOVE 1 000 V –
CERAMIC OR GLASS INSULATOR UNITS FOR AC SYSTEMS –
CHARACTERISTICS OF INSULATOR UNITS OF THE CAP AND PIN TYPE****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60305 has been prepared by IEC technical committee 36: Insulators.

This fifth edition cancels and replaces the fourth edition published in 1995. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) wording in Scope changed from "it is recommended" to "it is applicable";
- b) new normative references added;
- c) electromechanical or mechanical failing load in Clause 4 specified;
- d) new figures added showing profiles;
- e) Tables 1, 2, 3, 4 and 5 expanded to include more specified values.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
36/499/FDIS	36/501/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INSULATORS FOR OVERHEAD LINES WITH A NOMINAL VOLTAGE ABOVE 1 000 V – CERAMIC OR GLASS INSULATOR UNITS FOR AC SYSTEMS – CHARACTERISTICS OF INSULATOR UNITS OF THE CAP AND PIN TYPE

1 Scope

This International Standard applies to string insulator units of the cap and pin type with insulating parts of ceramic material or glass, intended for AC overhead lines with a nominal voltage greater than 1 000 V and a frequency not greater than 100 Hz. It also applies to insulators of similar design used in substations.

This document applies to string insulator units of the cap and pin type either with ball and socket couplings or with clevis and tongue couplings.

This document applies to string insulator units for use on overhead lines in clean areas and polluted areas. For use in areas characterized by very heavy pollution levels and for other particular or extreme environmental conditions, it may be necessary for certain dimensions to be changed and insulator units having different creepage distances, spacing and forms may be preferred (for example, flat profile, hemispherical etc.). Insulators for use on DC systems may also need different dimensions. In any case, it is applicable that the standardized mechanical characteristics of this document and coupling sizes are retained.

The object of this document is to prescribe specified values for the mechanical characteristics and for the main dimensions of string insulator units of the cap and pin type.

The power frequency, lightning impulse and puncture withstand voltages of string insulator units are not specified in this document. IEC 60383-1 gives the electrical characteristics which define string insulator units; their values are agreed between purchaser and manufacturer.

Ball and socket couplings are covered by IEC 60120, clevis and tongue couplings by IEC 60471.

NOTE For the definition of site pollution severity see IEC TS 60815-1.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60383-1, *Insulators for overhead lines with a nominal voltage above 1000 V – Part 1: Ceramic or glass insulator units for AC systems – Definitions, test methods and acceptance criteria*