

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

## Datahallsutrymmen och tillhörande system – Del 2-1: Byggnaden

*Information technology –  
Data centre facilities and infrastructures –  
Part 2-1: Building construction*

Som svensk standard gäller europastandarden EN 50600-2-1:2021. Den svenska standarden innehåller den officiella engelska språkversionen av EN 50600-2-1:2021.

### Nationellt förord

Tidigare fastställd svensk standard SS-EN 50600-2-1, utgåva 1, 2014, gäller ej fr o m 2024-03-22.

---

ICS 35.020.00; 35.110.00; 91.140.50

---

Denna standard är fastställd av SEK Svensk Elstandard, som också kan lämna upplysningar om **sakinnehållet** i standarden.  
Postadress: Box 1284, 164 29 KISTA  
Telefon: 08 - 444 14 00.  
E-post: [sek@elstandard.se](mailto:sek@elstandard.se). Internet: [www.elstandard.se](http://www.elstandard.se)

---

### *Standarder underlättar utvecklingen och höjer elsäkerheten*

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

### *SEK är Sveriges röst i standardiseringsarbetet inom elområdet*

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

### *Stora delar av arbetet sker internationellt*

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

### *Var med och påverka!*

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

### **SEK Svensk Elstandard**

Box 1284  
164 29 Kista  
Tel 08-444 14 00  
[www.elstandard.se](http://www.elstandard.se)

EUROPEAN STANDARD

**EN 50600-2-1**

NORME EUROPÉENNE

EUROPÄISCHE NORM

April 2021

ICS 35.020; 35.110; 91.140.50

Supersedes EN 50600-2-1:2014 and all of its  
amendments and corrigenda (if any)

English Version

## Information technology - Data centre facilities and infrastructures - Part 2-1: Building construction

Technologie de l'information - Installation et infrastructures  
de centres de traitement de données - Partie 2-1:  
Construction des bâtiments

Informationstechnik - Einrichtungen und Infrastrukturen von  
Rechenzentren - Teil 2-1: Gebäudekonstruktion

This European Standard was approved by CENELEC on 2021-03-22. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

<b>Contents</b>	<b>Page</b>
<b>European foreword</b> .....	<b>4</b>
<b>Introduction</b> .....	<b>5</b>
<b>1 Scope</b> .....	<b>8</b>
<b>2 Normative references</b> .....	<b>8</b>
<b>3 Terms, definitions and abbreviations</b> .....	<b>9</b>
3.1 Terms and definitions .....	9
3.2 Abbreviations .....	10
<b>4 Conformance</b> .....	<b>10</b>
<b>5 Location</b> .....	<b>10</b>
5.1 Assessment of location .....	10
5.2 Geographical location .....	11
5.3 Environmental risk analysis .....	11
5.4 Utility provision.....	12
<b>6 Site configuration</b> .....	<b>13</b>
6.1 General .....	13
6.2 Site selection .....	13
6.3 Assessment of existing premises .....	14
6.4 Utilities .....	14
<b>7 Outside spaces</b> .....	<b>15</b>
7.1 Access routes .....	15
7.2 Parking.....	15
7.3 Temporary facilities.....	15
7.4 Fuel storage facilities and infrastructure.....	16
7.5 Underground facilities .....	16
7.6 Perimeter design and Protection Class Boundaries .....	16
<b>8 Building construction</b> .....	<b>19</b>
8.1 Load-bearing structure.....	19
8.2 Building materials and finishes .....	19
8.3 Electromagnetic Interference.....	20
8.4 Protection Class Boundaries .....	20
8.5 Foundations .....	21
8.6 Exterior walls .....	22
8.7 Interior walls and barriers .....	22
8.8 Roofs.....	23
8.9 Water drainage .....	23
8.10 Floors .....	24
8.11 Raised access floors.....	25
8.12 Ceilings .....	25
8.13 Corridors and doors .....	26

8.14	Transportation lifts .....	26
<b>9</b>	<b>Design of data centre spaces .....</b>	<b>26</b>
9.1	Accommodation .....	26
9.2	Control room space .....	27
9.3	Computer room space .....	27
9.4	Electrical space .....	28
9.5	Mechanical space .....	28
9.6	Telecommunications space .....	28
9.7	Spaces for firefighting systems .....	28
9.8	Storage space .....	28
9.9	Testing and holding spaces .....	29
9.10	Docking bay .....	29
9.11	General office space .....	29
<b>10</b>	<b>Construction of data centre spaces .....</b>	<b>29</b>
10.1	Protection against flooding .....	29
10.2	Access to data centre spaces .....	30
10.3	Vapour density .....	30
<b>11</b>	<b>Fire compartments and fire barriers .....</b>	<b>30</b>
11.1	Fire compartments .....	30
11.2	Fire barriers .....	31
11.3	Protection Class boundaries .....	32
<b>Annex A (informative) Building materials .....</b>		<b>33</b>
<b>Annex B (informative) Summary of data centre location requirements and recommendations of Clause 5 .....</b>		<b>35</b>
<b>Bibliography .....</b>		<b>38</b>

## Figures

<b>Figure 1 — Schematic relationship between the EN 50600 series standards .....</b>	<b>6</b>
<b>Figure 2 — Examples of free-standing barriers and minimum effective height .....</b>	<b>18</b>

## Tables

<b>Table 1 — Heights and topping requirements for free-standing barriers .....</b>	<b>17</b>
<b>Table 2 — Load capacity guidance for building structures .....</b>	<b>24</b>
<b>Table B.1 — Summary of EN 50600-2-1:2021, Clause 5 location requirements and recommendations .....</b>	<b>35</b>

## European foreword

This document (EN 50600-2-1:2021) has been prepared by CLC/TC 215 "Electrotechnical aspects of telecommunication equipment".

The following dates are fixed:

- latest date by which this document has to be (dop) 2022-03-22  
implemented at national level by publication of an  
identical national standard or by endorsement
- latest date by which the national standards (dow) 2024-03-22  
conflicting with this document have to be withdrawn

This document supersedes EN 50600-2-1:2014 and all of its amendments and corrigenda (if any).

This document includes the following significant technical changes with respect to EN 50600-2-1:2014:

- a) the document has been completely revised and restructured;
- b) the interrelationship between this document and EN 50600-2-5 concerning constructional prerequisites for the implementation of security concepts and desired security systems has been more clearly presented;
- c) Clause 6 "Site configuration" has been split and relevant subclauses have been moved into a new Clause 7 "Outside spaces";
- d) Clause 7 "Building construction" has been completely reworked to present all requirements and recommendations in a single Clause 8;
- e) Clause 8 "Data centre spaces and access routes" has been revised to focus on the design of data centre spaces (now Clause 9);
- f) a new Clause 10 "Construction of data centre spaces" has been added;
- g) Clause 9 "Fire compartments, fire barriers and fire suppression systems" has been revised (now Clause 11);
- h) Annex A on additional requirements and recommendations has been removed;
- i) Annex B on physical protection against external hazards has been revised as Annex A "Building materials";
- j) a new Annex B summarizing the requirements and recommendations of Clause 5 has been added;
- k) Clauses 1 to 4 have been amended accordingly.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

## Introduction

The unrestricted access to internet-based information demanded by the information society has led to an exponential growth of both internet traffic and the volume of stored/retrieved data. Data centres are housing and supporting the information technology and network telecommunications equipment for data processing, data storage and data transport. They are required both by network operators (delivering those services to customer premises) and by enterprises within those customer premises.

Data centres usually provide modular, scalable and flexible facilities and infrastructures to easily accommodate the rapidly changing requirements of the market. In addition, energy consumption of data centres has become critical both from an environmental point of view (reduction of environmental footprint) and with respect to economical considerations (cost of energy) for the data centre operator.

The implementation of data centres varies in terms of:

- a) purpose (enterprise, co-location, co-hosting or network operator facilities);
- b) security level;
- c) physical size;
- d) accommodation (mobile, temporary and permanent constructions).

The needs of data centres also vary in terms of availability of service, the provision of security and the objectives for energy efficiency. These needs and objectives influence the design of data centres in terms of building construction, power distribution, environmental control, telecommunications cabling and physical security as well as the operation of the data centre. Effective management and operational information is important in order to monitor achievement of the defined needs and objectives.

Recognizing the substantial resource consumption, particularly of energy, of larger data centres, it is also important to provide tools for the assessment of that consumption both in terms of overall value and of source mix and to provide Key Performance Indicators (KPIs) to evaluate trends and drive performance improvements.

At the time of publication of this document, the EN 50600 series is designed as a framework of standards, technical specifications and technical reports covering the design, the operation and management, the key performance indicators for energy efficient operation of the data centre as well as a data centre maturity model.

The EN 50600-2 series defines the requirements for the data centre design.

The EN 50600-3 series defines the requirements for the operation and the management of the data centre.

The EN 50600-4 series defines the key performance indicators for the data centre.

The CLC/TS 50600-5 series defines the data centre maturity model requirements and recommendations.

The CLC/TR 50600-99-X Technical Reports cover recommended practices and guidance for specific topics around data centre operation and design.

This series of documents specifies requirements and recommendations to support the various parties involved in the design, planning, procurement, integration, installation, operation and maintenance of facilities and infrastructures within data centres. These parties include:

- 1) owners, operators, facility managers, ICT managers, project managers, main contractors;
- 2) consulting engineers, architects, building designers and builders, system and installation designers, auditors, test and commissioning agents;
- 3) facility and infrastructure integrators, suppliers of equipment;
- 4) installers, maintainers.

At the time of publication of this document, the EN 50600-2 series comprises the following documents:

EN 50600-2-1, *Information technology — Data centre facilities and infrastructures — Part 2-1: Building construction*;

EN 50600-2-2, *Information technology — Data centre facilities and infrastructures — Part 2-2: Power supply and distribution*;


EN 50600-2-3, *Information technology — Data centre facilities and infrastructures — Part 2-3: Environmental control*;

EN 50600-2-4, *Information technology — Data centre facilities and infrastructures — Part 2-4: Telecommunications cabling infrastructure*;

EN 50600-2-5, *Information technology — Data centre facilities and infrastructures — Part 2-5: Security systems*.

CLC/TS 50600-2-10, *Information technology — Data centre facilities and infrastructures — Part 2-10: Earthquake risk and impact analysis*

The inter-relationship of the documents within the EN 50600 series is shown in Figure 1.



**Figure 1 — Schematic relationship between the EN 50600 series standards**

EN 50600-2-X documents specify requirements and recommendations for particular facilities and infrastructures to support the relevant classification for “availability”, “physical security” and “energy efficiency enablement” selected from EN 50600-1.

EN 50600-3-X documents specify requirements and recommendations for data centre operations, processes and management.

EN 50600-4-X documents specify requirements and recommendations for key performance indicators (KPIs) used to assess and improve the resource usage efficiency and effectiveness, respectively, of a data centre.

This document addresses the site selection and the building design of data centres; it addresses security issues from a constructional point of view, whereas EN 50600-2-5 specifies the security system requirements of those facilities and infrastructures (in accordance with the requirements of EN 50600-1).



This document is intended for use by and collaboration between architects, building designers and builders, system and installation designers.

This series of documents does not address the selection of information technology and network telecommunications equipment, software and associated configuration issues.

## 1 Scope

This document gives guidelines for the construction of buildings and other structures which provide accommodation for data centres based upon the criteria and classification for “physical security” within EN 50600-1 in support of availability.

This document specifies requirements and recommendations for the following:

- a) location and site selection (taking in to account natural environment and adjacencies);
- b) protection from environmental risks;
- c) site configuration;
- d) building construction;
- e) building configuration;
- f) provision of access;
- g) intrusion protection;
- h) physical fire protection;
- i) protection against damage from water;
- j) quality construction measures.

Safety and electromagnetic compatibility (EMC) requirements are outside the scope of this document and are covered by other standards and regulations. However, information given in this document can be of assistance in meeting these standards and regulations.

Conformance of data centres to the present document is covered in Clause 4.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 81 (all parts), *Safety rules for the construction and installation of lifts - Special lifts for the transport of persons and goods*

EN 1366-3, *Fire resistance tests for service installations - Part 3: Penetration seals*

EN 1627:2011, *Pedestrian doorsets, windows, curtain walling, grilles and shutters - Burglar resistance - Requirements and classification*

EN 1634 (all parts), *Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware*

EN 1991-1-1, *Eurocode 1: Actions on structures - Part 1-1: General actions - Densities, self-weight, imposed loads for buildings*

EN 12825:2001, *Raised access floors*

EN 50310, *Telecommunications bonding networks for buildings and other structures*

EN 50600-1:2019, *Information technology - Data centre facilities and infrastructures - Part 1: General concepts*

EN 50600-2-2, *Information technology - Data centre facilities and infrastructures - Part 2-2: Power supply and distribution*

EN 50600-2-3, *Information technology - Data centre facilities and infrastructures - Part 2-3: Environmental control*

EN 50600-2-4, *Information technology - Data centre facilities and infrastructures - Part 2-4: Telecommunications cabling infrastructure*

EN 50600-2-5, *Information technology - Data centre facilities and infrastructures - Part 2-5: Security systems*

CLC/TS 50600-2-10, *Information technology - Data centre facilities and infrastructures - Part 2-10: Earthquake risk and impact analysis*

EN 50600-3-1, *Information technology - Data centre facilities and infrastructures - Part 3-1: Management and operational information*