

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

Industriell processtyrning – Profiler – Del 3-13: Fältbussar i system av betydelse för säkerheten – Kompletterande specifikationer för CPF 13 (Ethernet Powerlink)

*Industrial communication networks –
Profiles –
Part 3-13: Functional safety fieldbuses –
Additional specifications for CPF 13*

Som svensk standard gäller europastandarden EN IEC 61784-3-13:2021. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 61784-3-13:2021.

Nationellt förord

Europastandarden EN IEC 61784-3-13:2021

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 61784-3-13, Third edition, 2021 - Industrial communication networks - Profiles - Part 3-13: Functional safety fieldbuses - Additional specifications for CPF 13**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 61784-3-13, utgåva 2, 2018, gäller ej fr o m 2024-06-23.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English Version

**Industrial communication networks - Profiles - Part 3-13:
Functional safety fieldbuses - Additional specifications for
CPF 13
(IEC 61784-3-13:2021)**

Réseaux de communication industriels - Profils - Partie 3-
13: Bus de terrain de sécurité fonctionnelle - Spécifications
supplémentaires pour CPF 13
(IEC 61784-3-13:2021)

Industrielle Kommunikationsnetze - Profile - Teil 3-13:
Funktional sichere Übertragung bei Feldbussen -
Zusätzliche Festlegungen für die
Kommunikationsprofilfamilie 13
(IEC 61784-3-13:2021)

This European Standard was approved by CENELEC on 2021-06-23. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 65C/1083/FDIS, future edition 3 of IEC 61784-3-13, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61784-3-13:2021.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2022-03-23 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2024-06-23 document have to be withdrawn

This document supersedes EN 61784-3-13:2017 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 61784-3-13:2021 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61000-1-2	NOTE	Harmonized as EN 61000-1-2
IEC 61000-6-7	NOTE	Harmonized as EN 61000-6-7
IEC 61010-2-201	NOTE	Harmonized as EN IEC 61010-2-201
IEC 61131-2	NOTE	Harmonized as EN 61131-2
IEC 61131-6	NOTE	Harmonized as EN 61131-6
IEC 61158 (series)	NOTE	Harmonized as EN 61158 (series)
IEC 61158-5 (series)	NOTE	Harmonized as EN 61158-5 (series)
IEC 61326-3-1	NOTE	Harmonized as EN 61326-3-1
IEC 61326-3-2	NOTE	Harmonized as EN IEC 61326-3-2
IEC 61496 (series)	NOTE	Harmonized as EN IEC 61496 (series)
IEC 61508-1:2010	NOTE	Harmonized as EN 61508-1:2010 (not modified)
IEC 61508-4:2010	NOTE	Harmonized as EN 61508-4:2010 (not modified)
IEC 61508-5:2010	NOTE	Harmonized as EN 61508-5:2010 (not modified)
IEC 61511 (series)	NOTE	Harmonized as EN 61511 (series)
IEC 61784-1	NOTE	Harmonized as EN IEC 61784-1
IEC 61784-3 (series)	NOTE	Harmonized as EN 61784-3 (series)
IEC 61784-5 (series)	NOTE	Harmonized as EN IEC 61784-5 (series)
IEC 61800-5-2	NOTE	Harmonized as EN 61800-5-2
IEC 62061	NOTE	Harmonized as EN 62061
IEC 62443 (series)	NOTE	Harmonized as EN IEC 62443 (series)
ISO 10218-1	NOTE	Harmonized as EN ISO 10218-1
ISO 13849 (series)	NOTE	Harmonized as EN ISO 13849 (series)
ISO 13849-1:2015	NOTE	Harmonized as EN ISO 13849-1:2015 (not modified)
ISO 13849-2	NOTE	Harmonized as EN ISO 13849-2

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61131-3	-	Programmable controllers - Part 3: Programming languages	EN 61131-3	-
IEC 61158-3-13	-	Industrial communication networks - Fieldbus specifications - Part 3-13: Data link layer service definition - Type 13 elements	EN 61158-3-13	-
IEC 61158-4-13	-	Industrial communication networks - Fieldbus specifications - Part 4-13: Data-link layer protocol specification - Type 13 elements	EN 61158-4-13	-
IEC 61158-5-13	-	Industrial communication networks - Fieldbus specifications - Part 5-13: Application layer service definition - Type 13 elements	EN 61158-5-13	-
IEC 61158-6-13	-	Industrial communication networks - Fieldbus specifications - Part 6-13: Application layer protocol specification - Type 13 elements	EN 61158-6-13	-
IEC 61508	series	Functional safety of electrical/electronic/programmable electronic safety-related systems	EN 61508	series
IEC 61784-2	-	Industrial communication networks - Profiles - Part 2: Additional fieldbus profiles for real-time networks based on ISO/IEC/IEEE 8802-3	EN IEC 61784-2	-
IEC 61784-3	2021	Industrial communication networks - Profiles - Part 3: Functional safety fieldbuses - General rules and profile definitions	EN IEC 61784-3	2021
IEC 61784-5-13	-	Industrial communication networks - Profiles - Part 5-13: installation of fieldbuses - Installation profiles for CPF 13	EN 61784-5-13	-

EN IEC 61784-3-13:2021 (E)

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61918	-	Industrial communication networks - Installation of communication networks in industrial premises	EN IEC 61918	-
ISO/IEC 19501	-	Information technology - Open Distributed Processing - Unified Modeling Language (UML) Version 1.4.2	-	-

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial communication networks – Profiles –
Part 3-13: Functional safety fieldbuses – Additional specifications for CPF 13**

**Réseaux de communication industriels – Profils –
Partie 3-13: Bus de terrain de sécurité fonctionnelle – Spécifications
supplémentaires pour CPF 13**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 25.040.40; 35.100.05

ISBN 978-2-8322-9759-9

Warning! Make sure that you obtained this publication from an authorized distributor. Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.
--

CONTENTS

FOREWORD	14
0 Introduction	16
0.1 General.....	16
0.2 Patent declaration.....	18
1 Scope	19
2 Normative references	19
3 Terms, definitions, symbols, abbreviated terms and conventions	20
3.1 Terms and definitions.....	20
3.1.1 Common terms and definitions.....	20
3.1.2 CPF 13: Additional terms and definitions	25
3.2 Symbols and abbreviated terms	27
3.2.1 Common symbols and abbreviated terms.....	27
3.2.2 CPF 13: Additional symbols and abbreviated terms	27
3.3 Conventions.....	28
3.3.1 Hexadecimal values.....	28
3.3.2 Binary values.....	28
3.3.3 Wildcard digits	28
3.3.4 Diagrams	29
4 Overview of FSCP 13/1 (openSAFETY™).....	29
4.1 Functional Safety Communication Profile 13/1	29
4.2 Technical overview	29
5 General	30
5.1 External documents providing specifications for the profile	30
5.2 Safety functional requirements.....	30
5.3 Safety measures	31
5.4 Safety communication layer structure.....	32
5.5 Relationships with FAL (and DLL, PhL)	34
5.5.1 General	34
5.5.2 Data types	34
6 Safety communication layer services	34
6.1 Modelling	34
6.1.1 Reference model	34
6.1.2 Communication model	35
6.1.3 Device roles and topology.....	36
6.2 Life cycle model.....	40
6.2.1 General	40
6.2.2 Concept, planning and implementation	40
6.2.3 Commissioning	41
6.2.4 Operation terms.....	43
6.2.5 Maintenance terms	44
6.3 Non safety communication layer	44
6.3.1 General	44
6.3.2 Requirements for data transport	44
6.3.3 Domain protection and separation	48
7 Safety communication layer protocol	48

7.1	Safety PDU format	48
7.1.1	Structure of Safety PDUs	48
7.1.2	Address field (ADR)	53
7.1.3	PDU identification field (ID)	53
7.1.4	Length field (LE)	55
7.1.5	Consecutive Time field (CT)	55
7.1.6	Payload data field (DB0 to DBn)	55
7.1.7	Cyclic Redundancy Check field (CRC-8 / CRC-16)	55
7.1.8	Time Request Address field (TADR)	56
7.1.9	Time Request Distinctive Number field (TR)	56
7.1.10	UDID of SCM coding (UDID of SCM)	56
7.2	Safety Process Data Object (SPDO)	57
7.2.1	General	57
7.2.2	SPDO telegram types	57
7.2.3	Data Only telegram	57
7.2.4	Data with Time Request telegram	58
7.2.5	Data with Time Response telegram	59
7.3	Safety Service Data Object (SSDO)	60
7.3.1	General	60
7.3.2	SSDO telegram types	60
7.3.3	SSDO services and protocols	61
7.3.4	SSDO Download Initiate	62
7.3.5	SSDO Download Segment	64
7.3.6	SSDO Download Initiate with Preload	64
7.3.7	SSDO Download Segment with Preload	66
7.3.8	SSDO Upload Initiate	67
7.3.9	SSDO Upload Segment	68
7.3.10	SSDO Upload Initiate with Preload	69
7.3.11	SSDO Upload Segment with Preload	70
7.3.12	SSDO Abort	71
7.3.13	SSDO Preload	73
7.4	Safety Network Management (SNMT)	74
7.4.1	General	74
7.4.2	SNMT telegram types	74
7.4.3	SNMT services and protocols	75
7.5	Safety Object dictionary (SOD)	89
7.5.1	General	89
7.5.2	Object dictionary entry definition	89
7.5.3	Data type entry specification	94
7.5.4	Object description	96
7.6	Safety related PDO mapping	141
7.6.1	General	141
7.6.2	Transmit SPDOs	142
7.6.3	Receive SPDOs	142
7.6.4	SPDO mapping parameter	142
7.6.5	SPDO mapping example	143
7.6.6	SDPO Feature Set	145
7.6.7	SPDO error handling	146
7.7	State and sequence diagrams	146

7.7.1	Safety Process Data Object (SPDO)	146
7.7.2	Time synchronization and validation	150
7.7.3	Safety Service Data Object (SSDO)	160
7.7.4	SOD access.....	162
7.7.5	Safety Network Management Object (SNMT)	171
7.7.6	SN power up.....	173
7.7.7	SN power down	180
7.7.8	SN recovery after Restart / Error	180
7.7.9	SCM power up.....	180
7.7.10	Address verification	183
7.7.11	Commissioning mode.....	185
7.7.12	Handle single UDID mismatch	185
7.7.13	Activate SN	189
7.7.14	Device exchange	190
8	Safety communication layer management.....	190
8.1	General.....	190
8.2	Configuration of a Safety Domain.....	191
8.3	Parameter check mechanism	191
9	System requirements	191
9.1	Indicators and switches.....	191
9.2	Installation guidelines	192
9.3	Safety function response time	192
9.4	Duration of demands.....	193
9.5	Constraints for calculation of system characteristics	193
9.5.1	General	193
9.5.2	Number of sinks limit	193
9.5.3	Message rate limit	193
9.5.4	Message payload limit	193
9.5.5	Bit error rate considerations.....	194
9.5.6	Residual error rate.....	194
9.6	Maintenance	195
9.6.1	Diagnostic information	195
9.6.2	Replacement of safety related devices.....	195
9.6.3	Modification	196
9.6.4	Machine part changing.....	196
9.6.5	Firmware update of safety related nodes	196
9.6.6	Machine check due to service interval	196
9.7	Safety manual.....	196
10	Assessment.....	196
10.1	General.....	196
10.2	CP 13/1 assessment	197
10.3	FSCP 13/1 conformance test	197
10.4	Approval of functional safety by competent assessment body	197
Annex A (informative) Additional information for functional safety communication profiles of CPF 13.....		198
A.1	Hash function calculation	198
A.2	Void	201
Annex B (informative) Information for assessment of the functional safety communication profiles of CPF 13.....		202

Bibliography.....	203
Figure 1 – Relationships of IEC 61784-3 with other standards (machinery)	16
Figure 2 – Relationships of IEC 61784-3 with other standards (process).....	17
Figure 3 – Producer consumer example	30
Figure 4 – Client server example	30
Figure 5 – Communication layer structure	33
Figure 6 – Safety communication channel.....	34
Figure 7 – Characteristic producer / consumer communication.....	35
Figure 8 – Extended producer / consumer communication	36
Figure 9 – Client Server communication.....	36
Figure 10 – Topology overview	37
Figure 11 – Safety Domain protection (example).....	38
Figure 12 – Safety Domain separation (example).....	39
Figure 13 – Data flow example.....	43
Figure 14 – Communication model.....	45
Figure 15 – SPDO transport.....	46
Figure 16 – SSDO transport.....	47
Figure 17 – Diagnostic data representation	48
Figure 18 – Safety PDUs inside a CP 13/1 PDU.....	49
Figure 19 – Basic Safety PDU for $n = 0 - 8$ octet payload data	49
Figure 20 – Basic Safety PDU from 9 octet payload data	49
Figure 21 – Slim Safety PDU for $n = 0 - 8$ octet payload data	50
Figure 22 – Slim Safety PDU from 9 octet payload data	51
Figure 23 – Safety PDU with 40 bit counter for $n = 0 - 8$ octet payload data	52
Figure 24 – Safety PDU with 40 bit counter from 9 octet payload data	52
Figure 25 – SPDO_Data_Only telegram.....	58
Figure 26 – SPDO_Data_with_Time_Request telegram	58
Figure 27 – SPDO_Data_with_Time_Response telegram.....	59
Figure 28 – SSDO download protocols.....	62
Figure 29 – SSDO upload protocols	62
Figure 30 – SSDO Download Initiate protocol	63
Figure 31 – SSDO Download Segment protocol	64
Figure 32 – SSDO Download Initiate protocol with Preload	65
Figure 33 – SSDO Download Segment protocol with Preload	66
Figure 34 – SSDO Upload Initiate protocol.....	67
Figure 35 – SSDO Upload Segment protocol	68
Figure 36 – SSDO Upload Initiate protocol with Preload	69
Figure 37 – SSDO Upload Segment protocol with Preload	71
Figure 38 – SSDO Abort protocol.....	72
Figure 39 – UDID Request / Response protocol	75
Figure 40 – SADR Assignment protocol	76
Figure 41 – Reset Node Guarding Time protocol.....	77

Figure 42 – SN set to Pre-Operational protocol	79
Figure 43 – SN set to Operational protocol	80
Figure 44 – SN Acknowledge protocol.....	82
Figure 45 – SN set to stop protocol.....	83
Figure 46 – SCM set to Operational protocol.....	83
Figure 47 – Node Guarding protocol	84
Figure 48 – Additional SADR Assignment protocol	85
Figure 49 – UDID of SCM Assignment protocol	87
Figure 50 – Init CT value assignment protocol	88
Figure 51 – SPDO mapping example	143
Figure 52 – State diagram TxSPDO	146
Figure 53 – SPDO communication producer.....	147
Figure 54 – State diagram RxSPDO	148
Figure 55 – SPDO communication consumer	148
Figure 56 – State diagram process data.....	149
Figure 57 – Time synchronization and validation.....	150
Figure 58 – Time synchronization detail	151
Figure 59 – Calculation of propagation delay	153
Figure 60 – Time validation, propagation delay explanation limits	153
Figure 61 – Time synchronization on a nonsafe network	155
Figure 62 – Explanation of time synchronization	155
Figure 63 – Time synchronization failure.....	156
Figure 64 – State diagram time synchronization producer	157
Figure 65 – State diagram time synchronization consumer.....	158
Figure 66 – State diagram SSDO client.....	160
Figure 67 – State diagram SSDO server	161
Figure 68 – Expedited SOD access.....	162
Figure 69 – State diagram segmented SOD download access client	163
Figure 70 – Segmented SOD download access.....	164
Figure 71 – State diagram segmented SOD download access server	165
Figure 72 – State diagram SOD preload download access client.....	167
Figure 73 – SOD preload download access.....	168
Figure 74 – State diagram SOD preload download access server	170
Figure 75 – State diagram SNMT master	172
Figure 76 – State diagram SNMT slave.....	173
Figure 77 – State diagram SN power up.....	174
Figure 78 – State diagram SN Pre-Operational	176
Figure 79 – State diagram SN additional paramters	178
Figure 80 – State diagram SN Operational.....	179
Figure 81 – Life Guarding telegram.....	180
Figure 82 – State diagram SCM power up.....	181
Figure 83 – State diagram SCM Operational	182
Figure 84 – State diagram SCM address verification	184

Figure 85 – State diagram SCM handle single UDID mismatch	186
Figure 86 – State diagram SCM verify parameters	188
Figure 87 – State diagram activate SN	190
Figure 88 – Safety function response time	192
Figure 89 – Assessment flow of devices	197
Table 1 – Communication errors and detection measures (cyclic)	31
Table 2 – Communication errors and detection measures (acyclic)	32
Table 3 – Device roles	37
Table 4 – Basic Safety PDU format	50
Table 5 – Slim Safety PDU format	51
Table 6 – Safety PDU with 40 bit counter	53
Table 7 – PDU identification field (ID)	54
Table 8 – Used ID field combinations	54
Table 9 – Request / response identification	54
Table 10 – Type of CRC depending on LE	55
Table 11 – CRC polynoms for SPDUs	56
Table 12 – SPDO telegram types (ID field, bits 2, 3 and 4)	57
Table 13 – Fields of SPDO_Data_Only telegram	58
Table 14 – Fields of SPDO_Data_with_Time_Request telegram	59
Table 15 – Fields of SPDO_Data_with_Time_Response telegram	59
Table 16 – SSDO telegram types (ID field, bits 2, 3 and 4)	60
Table 17 – SOD Access Command (SACmd) – bit coding	61
Table 18 – Fields of Download Initiate SSDO_Service_Request telegram	63
Table 19 – Fields of Download Initiate SSDO_Service_Response telegram	63
Table 20 – Fields of Download Segment SSDO_Service_Request telegram	64
Table 21 – Fields of Download Segment SSDO_Service_Response telegram	64
Table 22 – Fields of Download Initiate SSDO_Service_Request telegram with Preload	65
Table 23 – Fields of Download Initiate SSDO_Service_Response telegram with Preload	65
Table 24 – Fields of Download Segment SSDO_Service_Request telegram with Preload	66
Table 25 – Fields of Download Segment SSDO_Service_Response telegram with Preload	67
Table 26 – Fields of Upload Initiate SSDO_Service_Request telegram	67
Table 27 – Fields of Upload Initiate SSDO_Service_Response telegram	68
Table 28 – Fields of Upload Segment SSDO_Service_Request telegram	69
Table 29 – Fields of Upload Segment SSDO_Service_Response telegram	69
Table 30 – Fields of Upload Initiate SSDO_Service_Request telegram with Preload	70
Table 31 – Fields of Upload Initiate SSDO_Service_Response telegram with Preload	70
Table 32 – Fields of Upload Segment SSDO_Service_Request telegram with Preload	71
Table 33 – Fields of Upload Segment SSDO_Service_Response telegram with Preload	71
Table 34 – Fields of SSDO Abort telegram	72
Table 35 – SSDO Abort codes	72
Table 36 – TR field usage for SSDO Preload	73
Table 37 – Bit fields inside TR field for SSDO Preload	74

Table 38 – SNMT telegram types (ID field, bits 2, 3 and 4)	74
Table 39 – Fields of SNMT_Request_UDID telegram	75
Table 40 – Fields of SNMT_Response_UDID telegram	76
Table 41 – Fields of SNMT_Assign_SADR telegram	77
Table 42 – Fields of SNMT_SADR_Assigned telegram.....	77
Table 43 – Fields of SNMT_SN_reset_guarding_SCM telegram	78
Table 44 – SNMT request telegram types	78
Table 45 – SNMT response telegram types.....	78
Table 46 – Fields of SNMT_SN_set_to_PRE_OP telegram	79
Table 47 – Fields of SNMT_SN_status_PRE_OP telegram	79
Table 48 – Fields of SNMT_SN_set_to_OP telegram	80
Table 49 – Fields of SNMT_SN_status_OP telegram	80
Table 50 – Fields of SNMT_SN_busy telegram	81
Table 51 – Fields of SNMT_SN_FAIL telegram	81
Table 52 – SNMT_SN_FAIL Error Group values.....	81
Table 53 – SNMT_SN_FAIL Error Code values	81
Table 54 – SNMT_SN_FAIL Error Code values in case of Error Group Code 5	82
Table 55 – Fields of SNMT_SN_ACK telegram	82
Table 56 – Fields of SNMT_SCM_set_to_STOP telegram	83
Table 57 – Fields of SNMT_SCM_set_to_OP telegram	84
Table 58 – Fields of SNMT_SCM_guard_SN telegram	84
Table 59 – Fields of SNMT_SN_status_OP/SNMT_SN_status_OP telegrams	85
Table 60 – Fields of SNMT_assign_additional_SADR telegram.....	86
Table 61 – Fields of SNMT_assigned_additional_SADR telegram	86
Table 62 – Fields of SNMT_assign_UDID_of_SCM telegram.....	87
Table 63 – Fields of SNMT_assigned_UDID_of_SCM telegram.....	87
Table 64 – Fields of SNMT_assign_Init_CT telegram.....	88
Table 65 – Fields of SNMT_assigned_Init_CT telegram	88
Table 66 – Object type definition.....	89
Table 67 – Access attributes for data objects	91
Table 68 – SPDO mapping attributes for data objects	91
Table 69 – Basic data type object definition example	91
Table 70 – Compound data type object definition example.....	92
Table 71 – Sub index interpretation	92
Table 72 – NumberOfEntries sub index specification	93
Table 73 – RECORD type object sub index specification.....	93
Table 74 – ARRAY type object sub index specification.....	94
Table 75 – StructureOfObject encoding	94
Table 76 – Object dictionary data types	95
Table 77 – 0021h Compound data type description example.....	96
Table 78 – 0021h Compound sub index descriptions example	96
Table 79 – Standard objects	97
Table 80 – Common communication objects	97

Table 81 – Receive SPDO communication objects	97
Table 82 – Receive SPDO mapping objects	98
Table 83 – Transmit SPDO communication objects	98
Table 84 – User parameter (writeable at any time)	98
Table 85 – Transmit SPDO mapping objects	98
Table 86 – SADR DVI list	99
Table 87 – Additional SADR list	99
Table 88 – SADR UDID list	99
Table 89 – Additional parameter list	99
Table 90 – Object 1001h Error Register	100
Table 91 – Object 1001h Error Register value interpretation	100
Table 92 – Object 1002h Manufacturer status register	100
Table 93 – Object 1003h Pre defined error field	101
Table 94 – Object 1003h sub index 00h	101
Table 95 – Object 1003h sub index 01h	101
Table 96 – Object 1003h sub index 02h to FEh	102
Table 97 – Object 1003h Error statistics	102
Table 98 – Object 1004h sub index 00h	102
Table 99 – Object 1004h sub index 01h	103
Table 100 – Object 1004h sub index 02h	103
Table 101 – Object 1004h sub index 03h	103
Table 102 – Object 1004h sub index 04h	104
Table 103 – Object 1004h sub index 05h	104
Table 104 – Object 1004h sub index 06h	104
Table 105 – Object 1004h sub index 07h	105
Table 106 – Object 1004h sub index 08h	105
Table 107 – Object 1004h sub index 09h	105
Table 108 – Object 1004h sub index 0Ah	106
Table 109 – Object 1004h sub index 0Bh	106
Table 110 – Object 1004h sub index 0Ch	106
Table 111 – Object 1004h sub index 0Dh	107
Table 112 – Object 1004h sub index 0Eh	107
Table 113 – Object 100Ch Life Guarding	107
Table 114 – Object 100Ch sub index 00h	108
Table 115 – Object 100Ch sub index 01h	108
Table 116 – Object 100Ch sub index 02h	108
Table 117 – Object 100Dh Refresh Interval of Reset Guarding	109
Table 118 – Object 100Eh Number of Retries for Reset Guarding	109
Table 119 – Object 1018h Device Vendor Information	110
Table 120 – Object 1018h sub index 00h	110
Table 121 – Object 1018h sub index 01h	110
Table 122 – Object 1018h sub index 02h	111
Table 123 – Object 1018h sub index 03h	111

Table 124 – Object 1018h sub index 04h	111
Table 125 – Object 1018h sub index 05h	112
Table 126 – Object 1018h sub index 06h	112
Table 127 – Object 1018h sub index 07h	112
Table 128 – Object 1018h sub index 08h	113
Table 129 – Object 1018h sub index 09h	113
Table 130 – Structure of Revision Number	113
Table 131 – Structure of parameter checksum domain	114
Table 132 – CRC polynom for parameter checksum	114
Table 133 – Structure of Stack Version	114
Table 134 – Object 1019h Unique Device ID	115
Table 135 – Object 101Ah Parameter Download	115
Table 136 – Format of Parameter Download	116
Table 137 – Format of additional parameter header	116
Table 138 – Object 101Bh SCM Parameters	116
Table 139 – Object 101Bh sub index 00h	117
Table 140 – Object 101Bh sub index 01h	117
Table 141 – Object 1200h Common Communication Parameter	117
Table 142 – Object 1200h sub index 00h	118
Table 143 – Object 1200h sub index 01h	118
Table 144 – Object 1200h sub index 02h	118
Table 145 – Object 1200h sub index 03h	119
Table 146 – Object 1200h sub index 04h	119
Table 147 – Object 1201h SSDO Communication Parameter	120
Table 148 – Object 1201h sub index 00h	120
Table 149 – Object 1201h sub index 01h	120
Table 150 – Object 1201h sub index 02h	121
Table 151 – Object 1202h SNMT Communication Parameter	121
Table 152 – Object 1202h sub index 00h	121
Table 153 – Object 1202h sub index 01h	122
Table 154 – Object 1202h sub index 02h	122
Table 155 – Object 1400h – 17FEh RxSPDO Communication Parameter	122
Table 156 – Object 1400h – 17FEh sub index 00h	123
Table 157 – Object 1400h – 17FEh sub index 01h	123
Table 158 – Object 1400h – 17FEh sub index 02h	123
Table 159 – Object 1400h – 17FEh sub index 03h	124
Table 160 – Object 1400h – 17FEh sub index 04h	124
Table 161 – Object 1400h – 17FEh sub index 05h	124
Table 162 – Object 1400h – 17FEh sub index 06h	125
Table 163 – Object 1400h – 17FEh sub index 07h	125
Table 164 – Object 1400h – 17FEh sub index 08h	125
Table 165 – Object 1400h – 17FEh sub index 09h	126
Table 166 – Object 1400h – 17FEh sub index 0Ah	126

Table 167 – Object 1400h – 17FEh sub index 0Bh	126
Table 168 – Object 1400h – 17FEh sub index 0Ch	127
Table 169 – Object 1800h – 1BFEh RxSPDO communication parameter	127
Table 170 – Object 1800h – 1BFEh sub index 00h	127
Table 171 – Object 1800h – 1BFEh sub index 01h	128
Table 172 – Object 1800h – 1BFEh sub index 02h – FEh	128
Table 173 – Object C00h – 1FFEh TxSPDO communication parameter	128
Table 174 – Object 1C00h – 1FFEh sub index 00h	129
Table 175 – Object 1C00h – 1FFEh sub index 01h	129
Table 176 – Object 1C00h – 1FFEh sub index 02h	129
Table 177 – Object 1C00h – 1FFEh sub index 03h	130
Table 178 – Object C000h – C3FEh TxSPDO mapping parameter	130
Table 179 – Object C000h – C3FEh sub index 00h	130
Table 180 – Object C000h – C3FEh sub index 01h	131
Table 181 – Object C000h – C3FEh sub index 02h – FEh	131
Table 182 – Object C400h – C7FEh SADR-DVI list	131
Table 183 – Object C400h – C7FEh sub index 00h	132
Table 184 – Object C400h – C7FEh sub index 01h	132
Table 185 – Object C400h – C7FEh sub index 02h	132
Table 186 – Object C400h – C7FEh sub index 03h	133
Table 187 – Object C400h – C7FEh sub index 04h	133
Table 188 – Object C400h – C4FEh sub index 05h	133
Table 189 – Object C400h – C7FEh sub index 06h	134
Table 190 – Object C400h – C7FEh sub index 07h	134
Table 191 – Object C400h – C7FEh sub index 08h	134
Table 192 – Object C400h – C7FEh sub index 09h	135
Table 193 – Object C400h – C7FEh sub index 0Ah	135
Table 194 – Object C400h – C7FEh sub index 0Bh	135
Table 195 – Object C400h – C7FEh sub index 0Ch	136
Table 196 – Bit field of optional features	136
Table 197 – Object C400h – C7FEh sub index 0Dh	136
Table 198 – Object C400h – C7FEh sub index 0Eh	136
Table 199 – Object C400h – C7FEh sub index 0Fh	137
Table 200 – Object C801h – CBFFh Additional SADR list	137
Table 201 – Object C801h – CBFFh sub index 00h	137
Table 202 – Object C801h – CBFFh sub index 01h	138
Table 203 – Object C801h – CBFFh sub index 02h	138
Table 204 – Object Additional SADR List Example	139
Table 205 – Object CC01h – CFFFh SADR-UDID list	139
Table 206 – Object CC01h – CFFFh sub index 00h	139
Table 207 – Object CC01h – CFFFh sub index 01h – FEh	140
Table 208 – SADR-UDID List Example	140
Table 209 – Object E400h – E7FEh SSCM additional parameter list	140

Table 210 – Object E400h – E7FEh sub index 00h	141
Table 211 – Object E400h – E7FEh sub index 01h – 10h.....	141
Table 212 – Structure of SPDO mapping entry.....	142
Table 213 – Mapping example table 1.....	143
Table 214 – Mapping example table 2.....	143
Table 215 – Mapping example table 3.....	144
Table 216 – Mapping example table 4.....	144
Table 217 – Mapping example table 5.....	144
Table 218 – Mapping example table 6.....	144
Table 219 – Mapping example table 7.....	145
Table 220 – SPDO telegram features (TR field, bits 2-7).....	145
Table 221 – SPDO communication producer item description	147
Table 222 – SPDO communication producer state description	147
Table 223 – SPDO communication consumer item description	148
Table 224 – SPDO communication consumer state description	149
Table 225 – SPDO communication consumer telegram validation item description.....	150
Table 226 – SPDO communication consumer telegram validation state description.....	150
Table 227 – Time synchronization item description	152
Table 228 – Time validation item description	154
Table 229 – Extended time synchronization item description.....	156
Table 230 – Time synchronization producer item description	157
Table 231 – Time synchronization producer state description	158
Table 232 – Time synchronization consumer item description	159
Table 233 – Time synchronization consumer state description	159
Table 234 – SSDO client item description	161
Table 235 – SSDO client state description	161
Table 236 – SSDO server state description.....	161
Table 237 – SOD access item description.....	162
Table 238 – Segmented SOD access client item description	164
Table 239 – Segmented SOD download access client state description	164
Table 240 – Segmented SOD access server item description.....	166
Table 241 – Segmented SOD access server state description.....	166
Table 242 – SOD preload download access client item description	168
Table 243 – SOD preload download access client state description	169
Table 244 – SOD preload download access server item description.....	171
Table 245 – SOD preload download access server state description.....	171
Table 246 – SNMT master item description.....	172
Table 247 – SNMT master state description.....	172
Table 248 – SNMT slave state description	173
Table 249 – SN power up state description	174
Table 250 – State and communication object relation	174
Table 251 – SN Pre-Operational state item description	177
Table 252 – SN Pre-Operational state description.....	177

Table 253 – SN additional parameter state description	179
Table 254 – SN Operational state item description.....	180
Table 255 – SN Operational state description	180
Table 256 – SCM power up state description	181
Table 257 – State and communication object relation	181
Table 258 – SCM Operational state item description	183
Table 259 – SCM Operational state description	183
Table 260 – Address verification item description	185
Table 261 – Address verification state description	185
Table 262 – SCM handle single UDID mismatch state description.....	187
Table 263 – SCM verify parameters state description	189
Table 264 – Activate SN state description.....	190
Table 265 – Residual error rate	194

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
PROFILES –****Part 3-13: Functional safety fieldbuses –
Additional specifications for CPF 13****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 61784-3-13 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation. It is an International Standard.

This third edition cancels and replaces the second edition published in 2016. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- removal of block up-/download;
- addition of SSDO with preload;
- addition of SPDO feature sets;

- addition of SPDO with 40 bit counter;
- addition of SPDO dynamic SCT;
- addition of additional parameter sets;
- corrections and editorial improvements.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
65C/1083/FDIS	65C/1087/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

A list of all parts of the IEC 61784-3 series, published under the general title *Industrial communication networks – Profiles – Functional safety fieldbuses*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.


0 Introduction

0.1 General

The IEC 61158 (all parts) fieldbus standard together with its companion standards IEC 61784-1 and IEC 61784-2 defines a set of communication protocols that enable distributed control of automation applications. Fieldbus technology is now considered well accepted and well proven. Thus fieldbus enhancements continue to emerge, addressing applications for areas such as real time and safety-related applications.

IEC 61784-3 (all parts) explains the relevant principles for functional safety communications with reference to IEC 61508 (all parts) and specifies several safety communication layers (profiles and corresponding protocols) based on the communication profiles and protocol layers of IEC 61784-1, IEC 61784-2 and IEC 61158 (all parts). It does not cover electrical safety and intrinsic safety aspects. It also does not cover security aspects nor does it provide any requirements for security.

Figure 1 shows the relationships between IEC 61784-3 (all parts) and relevant safety and fieldbus standards in a machinery environment.




IEC

NOTE IEC 62061 specifies the relationship between PL (Category) and SIL.

Figure 1 – Relationships of IEC 61784-3 with other standards (machinery)

Figure 2 shows the relationships between IEC 61784-3 (all parts) and relevant safety and fieldbus standards in a process environment.



IEC

^a For specified electromagnetic environments; otherwise IEC 61326-3-1 or IEC 61000-6-7.

Figure 2 – Relationships of IEC 61784-3 with other standards (process)

Safety communication layers which are implemented as parts of safety-related systems according to IEC 61508 (all parts) provide the necessary confidence in the transportation of messages (information) between two or more participants on a fieldbus in a safety-related system, or sufficient confidence of safe behaviour in the event of fieldbus errors or failures.

Safety communication layers specified in IEC 61784-3 (all parts) do this in such a way that a fieldbus can be used for applications requiring functional safety up to the Safety Integrity Level (SIL) specified by its corresponding functional safety communication profile.

The resulting SIL claim of a system depends on the implementation of the selected functional safety communication profile (FSCP) within this system – implementation of a functional safety communication profile in a standard device is not sufficient to qualify it as a safety device.

IEC 61784-3 (all parts) describes:

- basic principles for implementing the requirements of IEC 61508 (all parts) for safety-related data communications, including possible transmission faults, remedial measures and considerations affecting data integrity;
- functional safety communication profiles for several communication profile families in IEC 61784-1 and IEC 61784-2, including safety layer extensions to the communication service and protocols sections of IEC 61158 (all parts).

0.2 Patent declaration

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document may involve the use of patents concerning the functional safety communication profiles for family 13. IEC takes no position concerning the evidence, validity, and scope of these patent rights.

The holder of these patent rights has assured IEC that s/he is willing to negotiate licences under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of these patent rights is registered with IEC. Information may be obtained from the patent database available at <http://patents.iec.ch>.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those in the patent database. IEC shall not be held responsible for identifying any or all such patent rights.

INDUSTRIAL COMMUNICATION NETWORKS – PROFILES –

Part 3-13: Functional safety fieldbuses – Additional specifications for CPF 13

1 Scope

This part of IEC 61784-3 (all parts) specifies a safety communication layer (services and protocol) based on CPF 13 of IEC 61784-2 and IEC 61158 Type 13. It identifies the principles for functional safety communications defined in IEC 61784-3 that are relevant for this safety communication layer. This safety communication layer is intended for implementation in safety devices only.

NOTE 1 It does not cover electrical safety and intrinsic safety aspects. Electrical safety relates to hazards such as electrical shock. Intrinsic safety relates to hazards associated with potentially explosive atmospheres.

This document defines mechanisms for the transmission of safety-relevant messages among participants within a distributed network using fieldbus technology in accordance with the requirements of IEC 61508 (all parts)¹ for functional safety. These mechanisms may be used in various industrial applications such as process control, manufacturing automation and machinery.

This document provides guidelines for both developers and assessors of compliant devices and systems.

NOTE 2 The resulting SIL claim of a system depends on the implementation of the selected functional safety communication profile within this system – implementation of a functional safety communication profile according to this document in a standard device is not sufficient to qualify it as a safety device.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61131-3, *Programmable controllers – Part 3: Programming languages*

IEC 61158-3-13, *Industrial communication networks – Fieldbus specifications – Part 3-13: Data-link layer service definition – Type 13 elements*

IEC 61158-4-13, *Industrial communication networks – Fieldbus specifications – Part 4-13: Data-link layer protocol specification – Type 13 elements*

IEC 61158-5-13, *Industrial communication networks – Fieldbus specifications – Part 5-13: Application layer service definition – Type 13 elements*

IEC 61158-6-13, *Industrial communication networks – Fieldbus specifications – Part 6-13: Application layer protocol specification – Type 13 elements*

¹ In the following pages of this document, "IEC 61508" will be used for "IEC 61508 (all parts)".

IEC 61508 (all parts), *Functional safety of electrical/electronic/programmable electronic safety-related systems*

IEC 61784-2, *Industrial communication networks – Profiles – Part 2: Additional fieldbus profiles for real-time networks based on ISO/IEC/IEEE 8802-3*

IEC 61784-3:2021, *Industrial communication networks – Profiles – Part 3: Functional safety fieldbuses – General rules and profile definitions*

IEC 61784-5-13, *Industrial communication networks – Profiles – Part 5-13: Installation of fieldbuses – Installation profiles for CPF 13*

IEC 61918, *Industrial communication networks – Installation of communication networks in industrial premises*

ISO/IEC 19501, *Information technology – Open Distributed Processing – Unified Modeling Language (UML) Version 1.4.2*