

TECHNICAL REPORT



**Communication networks and systems for power utility automation –
Part 90-14: Using IEC 61850 for FACTS (flexible alternate current transmission
systems), HVDC (high voltage direct current) transmission and power
conversion data modelling**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 33.200

ISBN 978-2-8322-1061-2

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	11
INTRODUCTION.....	13
1 Scope.....	14
1.1 Namespace name and version.....	14
1.2 Code Component distribution.....	15
2 Normative references.....	16
3 Terms, definitions, variable symbols and abbreviated terms.....	17
3.1 Terms and definitions.....	17
3.2 Variable symbols.....	17
3.3 Abbreviated terms.....	18
4 FACTS Controllers and power conversion definition and specific requirements – Definitions of FACTS and power conversions.....	20
4.1 Flexible AC transmission system.....	20
4.1.1 General.....	20
4.1.2 Examples of FACTS for shunt compensation.....	20
4.1.3 Examples of series compensation.....	20
4.2 Power conversions systems.....	21
5 Scope clarification and definition.....	21
5.1 General.....	21
5.2 Communication requirements and data flow.....	22
5.2.1 General.....	22
5.2.2 Mapping to interfaces defined in IEC 61850-5.....	23
5.3 SCL modelling requirements.....	24
6 Shared use cases for FACTS controllers and Power Conversion.....	24
6.1 Commonly used actors.....	24
6.2 Use case: Control system redundancy.....	26
6.2.1 Communication redundancy.....	26
6.2.2 Functional application redundancy.....	26
6.3 Use case: Control location and authority.....	27
6.4 Use case: System status and generic sequence processing.....	29
6.4.1 General.....	29
6.4.2 ASEQ Application Overview.....	33
6.4.3 Application example HVDC.....	34
6.4.4 Application example Shunt connected FACTS device.....	37
6.5 Use case: Cooling system.....	40
6.5.1 General.....	40
6.5.2 List of logical nodes for modelling of a Water based cooling system.....	43
6.5.3 Example of modelling a cooling system.....	43
6.6 Use case: Control and supervision of Harmonic filter.....	45
6.7 Use case: Control of external devices as part of automatic reactive power control.....	46
6.7.1 General.....	46
6.7.2 Modelling example for external device control of a FACTS shunt device.....	49
6.8 Use case: Converter status during degraded operation.....	50
6.9 Use case: Power Semiconductor application monitoring.....	51
6.9.1 General.....	51
6.9.2 Equipment Indications and Properties.....	55

6.9.3	Modelling requirements, results, conclusion.....	56
6.10	Use case: Coordinated control between FACTS and other Power Conversion devices	56
6.10.1	General	56
6.10.2	Use case descriptions.....	58
6.10.3	Optimized signal list and process information for modelling	59
6.11	FACTS and Power Conversion Protection	60
6.11.1	General	60
6.11.2	Use case Protective action	60
6.11.3	Modelling summary.....	62
7	FACTS	62
7.1	General.....	62
7.2	Shunt connected FACTS devices	63
7.2.1	General	63
7.2.2	Overview	63
7.2.3	Use cases for Shunt Connected FACTS device	64
7.3	Series connected FACTS devices	81
7.3.1	Overview	81
7.3.2	Use case of Series Compensation	81
7.3.3	Series Capacitors protections	99
8	Power Conversion	104
8.1	Power Converters	104
8.1.1	Overview	104
8.1.2	Power converter use cases with signal and data item descriptions.....	105
8.2	HVDC	122
8.2.1	Overview	122
8.2.2	HVDC use cases with signal and data item descriptions	123
8.3	SFC – Static Frequency Converter.....	147
8.3.1	Overview	147
8.3.2	SFC use cases with signal and data item descriptions	147
9	Data model.....	149
9.1	Abbreviated terms used in data object names	149
9.2	Logical node preliminaries	149
9.2.1	Package LogicalNodes_90_14.....	149
9.3	Data object name semantics and enumerations	222
9.3.1	Data semantics.....	222
9.3.2	Enumerated data attribute types	231
10	SCL Extensions	238
Annex A (informative)	Introduction to FACTS applications	239
A.1	Static Var Compensator overview	239
A.2	Static Synchronous Compensator overview.....	241
A.3	Fixed series compensation.....	243
A.4	Mechanically Switched Series Reactor (MSSR).....	244
A.5	Thyristor Controlled Series Capacitor (TCSC).....	244
Annex B (informative)	Modelling guideline and examples.....	247
B.1	Indication and control of breakers and switches	247
B.2	Power transformer	247
B.3	Metering and measured values	247

B.4	Examples of modelling of FACTS Shunt devices	247
B.5	Example of modelling of Fixed Series Compensation	251
B.6	Examples of modelling of HVDC transmission	252
	Bibliography.....	253
Figure 1	– Conceptual view of communication paths considered in this report.....	21
Figure 2	– Levels and logical interfaces in substation automation systems.....	22
Figure 3	– Data flow of a FACTS / Power Conversion controller.....	23
Figure 4	– Shared use cases for FACTS controllers and Power Conversion.....	24
Figure 5	– Hierarchal view of commonly used actors.....	26
Figure 6	– Typical redundant FACTS/Power Conversion control system setup	27
Figure 7	– Authority for control of devices from different control levels and locations	28
Figure 8	– Typical scheme for implementation of control authority for function groups	29
Figure 9	– System status / generic sequence processing	30
Figure 10	– ASEQ Application Overview (using the most important Data Objects).....	34
Figure 11	– Exemplary sequence diagram, not applicable to all use cases.....	35
Figure 12	– Operating states of a FACTS shunt device	37
Figure 13	– Use case diagrams of State use case.....	39
Figure 14	– Cooling control use cases	41
Figure 15	– Cooling control modelling example	44
Figure 16	– Harmonic filter control and supervision.....	45
Figure 17	– Use case Control of external reactive components	47
Figure 18	– Modelling external banks for reactive power optimization.	49
Figure 19	– Use case Converter status	50
Figure 20	– Example of a hierarchical arrangement of power electronic units.....	51
Figure 21	– Arrangement of 12 thyristor valves in a 12-pulse converter configuration	52
Figure 22	– Use cases for semiconductor application monitoring	53
Figure 23	– Schematic view of two SVC devices connected in parallel.....	56
Figure 24	– Coordination between two FACTS / Power Conversion.....	57
Figure 25	– Use case diagram for coordinated FACTS device operation	57
Figure 26	– Coordination signals between two SVCs	58
Figure 27	– Optimized signal list for IEC 61850	59
Figure 28	– Use cases for Control System Protective Actions	61
Figure 29	– V-I diagram of a generic SVC.....	63
Figure 30	– V-I diagram of a generic STATCOM	64
Figure 31	– Use cases for substation control of a shunt connected FACTS device.....	64
Figure 32	– Example of operating states of a FACTS shunt device	66
Figure 33	– Example of control modes of a shunt connected FACTS device visualized as a state machine.....	66
Figure 34	– Use cases for changing states of FACTS device	67
Figure 35	– Change of control mode use case	68
Figure 36	– Sub-use cases of Configuration use case.....	70
Figure 37	– Automatic Reactive Power Control use case	72
Figure 38	– Non-automatic control mode use case.....	73

Figure 39 – Simplified fixed reactive power regulator block diagram	74
Figure 40 – Simplified voltage regulator block diagram of automatic voltage control mode for an SVC	74
Figure 41 – Shunt connected FACTS device operating characteristic with slow susceptance/reactive power regulator	76
Figure 42 – Example of automatic voltage control system with additional reference signal for POD	77
Figure 43 – Activation of Gain Optimizer Function	78
Figure 44 – Reset Gain Command Interaction Diagram	78
Figure 45 – Series Compensation Use case	82
Figure 46 – Use cases for Fixed Series Capacitors	83
Figure 47 – Use case for Capacitor Discharge function	84
Figure 48 – Use case for By-passing	85
Figure 49 – Sub use cases for Lock-out use case	87
Figure 50 – Sub use cases for auto reinsertion	89
Figure 51 – Interaction of Automatic Reinsertion function with other functions	90
Figure 52 – Example of states in Automatic reinsertion function	91
Figure 53 – SLD of Fast Protective Equipment	93
Figure 54 – Use case for Fast Protective equipment	94
Figure 55 – SLD symbol for Metal Oxide Varistor	95
Figure 56 – Zink Oxide Varistor use case	96
Figure 57 – MSSR Use case diagram	97
Figure 58 – Additional use cases for TCSC	99
Figure 59 – SC Protection function Interface	101
Figure 60 – Varistor Overload Protection use case	104
Figure 61 – Varistor Failure Protection use case	104
Figure 62 – Generic application of Power Conversion	105
Figure 63 – Use Active / reactive power operation mode selection	106
Figure 64 – Active power control use case	108
Figure 65 – P-f characteristic	110
Figure 66 – P-V characteristic	111
Figure 67 – Example: Simple 4-point P-DCVol characteristic	112
Figure 68 – Example: Sophisticated 9-point P-DCVol characteristic	113
Figure 69 – P_Fixed	114
Figure 70 – Reactive power control use case	115
Figure 71 – Q-V characteristic	116
Figure 72 – Q_Fixed	117
Figure 73 – Phi_Fixed	118
Figure 74 – V_Band	119
Figure 75 – Use case	121
Figure 76 – Typical HVDC setup	123
Figure 77 – Use case Power direction change	124
Figure 78 – Use case Run-up/Run-back modules	126
Figure 79 – General AEPC functional characteristic	128

Figure 80 – Use case Automatic Emergency Power Control	129
Figure 81 – DC Line fault recovery sequence.....	133
Figure 82 – Examples for typical HVDC DC-Yard configurations	136
Figure 83 – DC Yard configuration	137
Figure 84 – Coordinated mode switchover	138
Figure 85 – Function mode switchover	140
Figure 86 – Tap changer control and supervision	145
Figure 87 – Typical SFC setup.....	147
Figure 88 – Control by external reference	148
Figure 89 – Class diagram LogicalNodes_90_14::LogicalNodes_90_14	150
Figure 90 – Class diagram AbstractLNs::AbstractLNs	151
Figure 91 – Class diagram LNGroupA::LNGroupANew.....	155
Figure 92 – Class diagram LNGroupA::LNGroupAExt.....	156
Figure 93 – Class diagram LNGroupC::LNGroupCNew	174
Figure 94 – Class diagram LNGroupF::LNGroupFNew	184
Figure 95 – Class diagram LNGroupP::LNGroupPNew.....	186
Figure 96 – Class diagram LNGroupR::LNGroupRNew	194
Figure 97 – Class diagram LNGroupS::LNGroupSNew.....	198
Figure 98 – Class diagram LNGroupT::LNGroupT	204
Figure 99 – Class diagram LNGroupX::LNGroupXNew.....	206
Figure 100 – Class diagram LNGroupZ::LNGroupZNew	210
Figure 101 – Class diagram LNGroupZ::LNGroupZNew2	211
Figure A.1 – Example SVC circuit diagram of an SVC.....	239
Figure A.2 – SLD of example SVC with reference designations.....	240
Figure A.3 – Simplified STATCOM Circuit diagram.....	241
Figure A.4 – Example of SLD for a STATCOM with reference designations.....	242
Figure A.5 – Hybrid solution with two VSC, TSC and TCR branch.....	243
Figure A.6 – Single Line Diagram of a one segment Series Capacitor.....	243
Figure A.7 – Generic SLD of MSSR/OLC FACTS device	244
Figure A.8 – SLD of TCSC and transmitted power vs. transmission angle	245
Figure A.9 – Generic TCSC control system.....	246
Figure B.1 – Logical nodes representing SLD equipment SVC	248
Figure B.2 – Modelling example of SVC functionality	249
Figure B.3 – Logical nodes representing SLD equipment, STATCOM.....	250
Figure B.4 – Logical nodes representing SLD equipment, Control and Protection, Fixed SC	251
Figure B.5 – Logical Nodes representing HVDC specific equipment and functionality.....	252
Table 1 – Attributes of (Tr)IEC 61850-90-14:2020A namespace	15
Table 2 – Tracking information of (Tr)IEC 61850-90-14:2020A namespace building-up.....	15
Table 3 – Actors used in use cases.....	25
Table 4 – Use case: System status and generic sequence processing	31
Table 5 – Use case: State.....	40

Table 6 – Use case: Cooling system	41
Table 7 – Logical nodes for modelling a water-based cooling system.....	43
Table 8 – Use case: Control and supervision of Harmonic filter.....	46
Table 9 – Use case: Control of external banks mode	48
Table 10 – Process data for Control of external banks mode.....	49
Table 11 – Use case: Get Converter Status	51
Table 12 – Use case: Semiconductor application monitoring	53
Table 13 – Thyristor controlled reactive components.....	55
Table 14 – Process information for Thyristor controlled reactive component	55
Table 15 – Coordinated FACTS device operation use case	58
Table 16 – Process information for coordinated control mode	60
Table 17 – Use cases for Control System Protective Actions	61
Table 18 – Classification of FACTS Controllers.....	63
Table 19 – Main use cases of FACTS Shunt device	65
Table 20 – Changing states of FACTS device use cases.....	68
Table 21 – Main control functions	69
Table 22 – Supplementary control functions.....	69
Table 23 – Additional control mode functions	69
Table 24 – Use case: Control Mode selection	69
Table 25 – Change Control mode process data.....	70
Table 26 – Use case: Configuration of control mode	71
Table 27 – Automatic Reactive Power Control process data.....	72
Table 28 – Non-automatic control mode use case	73
Table 29 – Non-automatic control mode setpoints.....	73
Table 30 – Reactive power control mode process data	74
Table 31 – Additional functions in Automatic Voltage Control mode	75
Table 32 – Voltage Control mode process data	75
Table 33 – Process data for slow susceptance regulator mode or reactive power regulator	76
Table 34 – POD mode settings and controls	77
Table 35 – Use case: Gain.....	79
Table 36 – Gain Supervision mode data objects.....	79
Table 37 – Gain Optimizer mode data objects.....	79
Table 38 – Protective Control Functions of SVC use cases	80
Table 39 – Protective Control Functions of a VSC use cases	81
Table 40 – Use case: Series Compensation.....	82
Table 41 – Use case: Fixed Series compensation	84
Table 42 – Use case: Capacitor Discharge Function	85
Table 43 – Bypassing of series capacitor	86
Table 44 – Use case: Lock-out and temporary block insertion.....	87
Table 45 – Use case: Auto reinsertion	90
Table 46 – Transition description for Figure 55	92
Table 47 – Use case: Fast Protective Equipment	95

Table 48 – Use case: Zink Oxide Varistor	97
Table 49 – Use case: MSSR	98
Table 50 – Indications and measurements	98
Table 51 – Use case: TCSC.....	99
Table 52 – Overview of typical series capacitor bank protections, based on IEC 60143-2 ...	100
Table 53 – Use case: SC protection functions.....	102
Table 54 – Series protections modelling guideline	103
Table 55 – Use case: Active / reactive power operation mode selection.....	106
Table 56 – Use case: Active power control	109
Table 57 – New data items for P-f-characteristics	111
Table 58 – New data items for P-V.....	112
Table 59 – New data items for P-DCVol.....	113
Table 60 – New data items for fixed active power	114
Table 61 – New data items for fixed DC current	114
Table 62 – New data items for Active power (general)	114
Table 63 – Reactive Power control use case (Power Conversion)	116
Table 64 – New data items for Q-V	117
Table 65 – New data items for Q_fixed	117
Table 66 – New data items for Q_Band.....	118
Table 67 – New data items for Phi_Fixed.....	118
Table 68 – New data items for V_Band	119
Table 69 – New data items for Reactive power (general),	119
Table 70 – Use case Reactive power (Power Conversion)	120
Table 71 – Intermediate DC circuit use case	122
Table 72 – Use case Power direction change.....	125
Table 73 – Use case Run-up/Run-back modules	127
Table 74 – Use case Automatic Emergency Power Control	129
Table 75 – AEPC data modelling example	131
Table 76 – Use case: DC Line fault recovery sequence	134
Table 77 – Use case: DC Yard configuration.....	137
Table 78 – Use case: Coordinated mode switchover	139
Table 79 – Use case: Function mode switchover.....	141
Table 80 – Use case: Tap changer control and supervision.....	145
Table 81 – Use case: Control by external reference	148
Table 82 – Normative abbreviations for data object names	149
Table 83 – Data objects of FACTSandPowerConversionLN.....	152
Table 84 – Data objects of ReactiveComponentInterfaceLN	153
Table 85 – Data objects of EmergencyPowerControl_PowerRunUpRunBackLN	154
Table 86 – Data objects of ARCOExt	157
Table 87 – Data objects of AFLK.....	159
Table 88 – Data objects of AMSR	160
Table 89 – Data objects of APOD	162
Table 90 – Data objects of AEPC	163

Table 91 – Data objects of ARUB.....	165
Table 92 – Data objects of ASEQ.....	166
Table 93 – Data objects of ATCCExt.....	168
Table 94 – Data objects of ARPC.....	171
Table 95 – Data objects of AVCOExt.....	172
Table 96 – Data objects of CCGRExt.....	175
Table 97 – Data objects of CCAP.....	177
Table 98 – Data objects of CJCL.....	178
Table 99 – Data objects of CFPC.....	180
Table 100 – Data objects of CREL.....	183
Table 101 – Data objects of FFUN.....	184
Table 102 – Data objects of PLFR.....	187
Table 103 – Data objects of PMHE.....	189
Table 104 – Data objects of PMHT.....	190
Table 105 – Data objects of PMOV.....	192
Table 106 – Data objects of PFPE.....	193
Table 107 – Data objects of RBPF.....	195
Table 108 – Data objects of RRIN.....	196
Table 109 – Data objects of SCND.....	199
Table 110 – Data objects of SFLW.....	200
Table 111 – Data objects of SFPE.....	201
Table 112 – Data objects of SPES.....	203
Table 113 – Data objects of TCND.....	205
Table 114 – Data objects of XFPE.....	207
Table 115 – Data objects of XDCC.....	209
Table 116 – Data objects of ZCONExt.....	211
Table 117 – Data objects of ZHAF.....	213
Table 118 – Data objects of ZLINEt.....	215
Table 119 – Data objects of ZMOV.....	217
Table 120 – Data objects of ZTCREt.....	218
Table 121 – Data objects of ZCAPEt.....	220
Table 122 – Data objects of ZREAExt.....	221
Table 123 – Attributes defined on classes of LogicalNodes_90_14 package.....	222
Table 124 – Literals of ActivePowerModKind.....	232
Table 125 – Literals of AutoReinsertionKind.....	232
Table 126 – Literals of ChargingDCCircuitStateKind.....	233
Table 127 – Literals of ConfigurationDCCircuitStateKind.....	233
Table 128 – Literals of ConnectionDCStateKind.....	233
Table 129 – Literals of ConverterTypKind.....	234
Table 130 – Literals of EPCModKind.....	234
Table 131 – Literals of EPCTypKind.....	234
Table 132 – Literals of ForcedOperationControlModKind.....	235
Table 133 – Literals of GenerationDCStateKind.....	235

Table 134 – Literals of HarmonicFilterTypKind	235
Table 135 – Literals of OperationCommandKind	236
Table 136 – Literals of OperationModKind	236
Table 137 – Literals of OperationStateKind	236
Table 138 – Literals of PowerDirectionalModKind	237
Table 139 – Literals of ReactivePowerModKind	237
Table 140 – Literals of RubModKind	237
Table 141 – Literals of RubTypKind	238
Table 142 – Literals of SequenceStateKind.....	238
Table 143 – Literals of ThyristorBranchFunctionKind	238
Table B.1 – Suggested modelling of measured and meter values.....	247

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**COMMUNICATION NETWORKS AND SYSTEMS
FOR POWER UTILITY AUTOMATION –**
**Part 90-14: Using IEC 61850 for FACTS (flexible alternate current
transmission systems), HVDC (high voltage direct current)
transmission and power conversion data modelling**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TR 61850-90-14 has been prepared by working group 10: Power system IED communication and associated data models, of IEC technical committee 57: Power systems management and associated information exchange. It is a Technical Report.

The text of this Technical Report is based on the following documents:

Draft	Report on voting
57/2232/DTR	57/2273/RVDTR

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

The language used for the development of this Technical Report is English.

A list of all parts in the IEC 61850 series, published under the general title *Communication networks and systems for power utility automation*, can be found on the IEC website.

This IEC standard includes Code Components i.e. components that are intended to be directly processed by a computer.

Such content is any text found between the markers and, or otherwise is clearly labelled in this standard as a Code Component.

The purchase of this IEC standard carries a copyright license for the purchaser to sell software containing Code Components from this standard to end users either directly or via distributors, subject to IEC software licensing conditions, which can be found at: <http://www.iec.ch/CCv1>

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The IEC 61850 series was established to focus on the main primary equipment and functionality of conventional AC substations. By now it has been widely deployed and has become state of the art in that area.

Soon after, ambitions emerged to make IEC 61850 applicable to a largely widened range of equipment and functionality. Even completely new domains, like wind or hydro power generation, have created extensions to the series in order to match their applications.

Thanks to the very generic basic information and communication structures of IEC 61850 and the integrated services provided, most domain requirements can be easily adopted and fulfilled with IEC 61850 core functionality. Most of the extension work thus just needs to focus on creating a domain specific data modelling, which allows the semantic description of domain specific signals.

Due to the latest boom in deploying an exponentially increasing number of power electronics and semiconductor based equipment directly in the area of medium, high and ultra-high voltage transmission networks, the call for integrating those direct current related processes and control systems into IEC 61850 is only logical and consecutive.

Two main groups of DC based types of applications exist: FACTS devices (shunt and series connected) that mainly influence the network at a definite point of connection and Power Converters (e.g. HVDC, SFC) that additionally allow the transmission of active power between two different points of connection.

The benefits of those technologies are clear: as methods to influence conventional AC networks are limited, DC based technologies provide the possibility to actively adjust power flow and network parameters like frequency and voltage within just milliseconds. They help to support network stability, performance and quality, increase transmission capacity. They enable transmission tasks that would otherwise be technically borderline or impossible, moreover doing so mostly with unprecedented efficiency respectively low losses.

FACTS and Power Conversion are thus indispensable to secure power supply and represent a vital component within the backbone of efficient, reliable and resilient future smart grids. This technical report finally enables those technologies to also become an integral part of the IEC 61850 world.

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 90-14: Using IEC 61850 for FACTS (flexible alternate current transmission systems), HVDC (high voltage direct current) transmission and power conversion data modelling

1 Scope

This part of IEC 61850, which is a technical report, specifies the information model of devices and functions related to systems of power utility automation, specifically related to FACTS (Flexible AC Transmission Systems) and Power Conversion applications.

The IEC 61850-90-14 information model standard utilizes existing IEC 61850-7-4 logical nodes where possible, but also defines specific logical nodes where needed.

Specifically, the scope of this document:

- Covers communication between control system of FACTS, HVDC and Power Conversion and SCADA and HMI systems
- Includes the data model for FACTS, HVDC and Power conversion devices
- Does not cover Protection relays
- Does not cover process bus
- Does not cover valve communication

1.1 Namespace name and version

This new subclause is mandatory for any IEC 61850 namespace (as defined by IEC 61850-7-1:2011).

Table 1 shows all attributes of (Tr)IEC 61850-90-14:2020A namespace.

Table 1 – Attributes of (Tr)IEC 61850-90-14:2020A namespace

Attribute	Content
Namespace nameplate	
Namespace Identifier	(Tr)IEC 61850-90-14
Version	2020
Revision	A
Release	3
Full Namespace Name	(Tr)IEC 61850-90-14:2020A
Namespace Type	transitional
Namespace dependencies	
extends	IEC 61850-7-4:2007B version:2007 revision:B
Namespace transitional status	
Future handling of namespace content	The name space (Tr)IEC 61850-90-14:2020A is considered as "transitional" since the models are expected to be included in further editions of IEC 61850-7-4xx. Potential extensions/modifications may happen if/when the models are moved to the International Standard status

The table below provides an overview of all published versions of this namespace.

Edition	Publication date	Webstore	Namespace
Edition 1.0	2020-xx	IEC TR 61850-90-14:2020	(Tr)IEC 61850-90-14:2020

Table 2 shows all tracking information of (Tr)IEC 61850-90-14:2020A namespace building-up.

Table 2 – Tracking information of (Tr)IEC 61850-90-14:2020A namespace building-up

Attribute	Content
Namespace IEC specific information	
Version of the UML model used for generating the document (informative)	wg10built7-wg18built5-wg17built6-jwg25built2-tc17built1-tc38built1_20210122.eap
Date of the UML model used for generating the document (informative)	2021-01-22
Autogeneration software name and version(informative)	j61850DocBuilder 01v12 based on jCleanCim 02v02-NS beta5

1.2 Code Component distribution

The Code Components are in light and full version:

- The full version is named: *IEC_TR_61850-90-14.NSD.2020A.Full*. It contains definition of the whole data model defined in this standard with the documentation associated and access is restricted to purchaser of this part

- The light version is named: *IEC_TR_61850-90-14.NSD.2020A3.Light*. It does not contain any documentations but contains the whole data model as per full version, and this light version is freely accessible on the IEC website for download at: <http://www.iec.ch/tc57/supportdocuments>, but the usage remains under the licensing conditions.

The Code Components for IEC 61850 data models are formatted in compliance with the NSD format defined by the standard IEC 61850-7-7. Each Code Component is a ZIP package containing:

- the electronic representation of the Code Component itself (possibly multiple files),
- the grammar files (XSD) enabling to check the consistency of the associated files against the defined version of NSD, but as well against the IEC 61850 flexibility rules in case of private extensions
- a file describing the content of the package (IECManifest.xml)

The IECManifest file contains different sections giving information on:

- The copyright notice
- The identification of the code component
- The publication related to the code component
- The list of the electronic files which compose the code component
- An optional list of history files to track changes during the evolution process of the code component

The life cycle of a code component is not restricted to the life cycle of the related publication. The publication life cycle goes through two stages, Version (corresponding to an edition) and Revision (corresponding to an amendment). A third publication stage (Release) allows publication of Code Component in case of urgent fixes of InterOp Tissues, thus without need to publish an amendment.

Consequently new release(s) of the Code Component may be released, which supersede(s) the previous release, and will be distributed through the IEC TC57 web site at: <http://www.iec.ch/tc57/supportdocuments>.

The latest version/release of the document will be found by selecting the file named *IEC_TR_61850-90-14.NSD.{VersionStateInfo}.Light* with the filed VersionStateInfo of the highest value.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC TS 61850-2, *Communication networks and systems for power utility automation – Part 2: Glossary*

IEC 61850-5:2013, *Communication networks and systems for power utility automation – Part 5: Communication requirements for functions and device models*
IEC 61850-5:2013/AMD1:2021

IEC 61850-6:2009, *Communication networks and systems for power utility automation – Part 6: Configuration description language for communication in electrical substations related to IEDs*
IEC 61850-6:2009/AMD1:2018

IEC 61850-7-2:2010, *Communication networks and systems for power utility automation – Part 7-2: Basic information and communication structure – Abstract communication service interface (ACSI)*

IEC 61850-7-2:2010/AMD1:2020

IEC 61850-7-3:2010, *Communication networks and systems for power utility automation – Part 7-3: Basic communication structure – Common data classes*

IEC 61850-7-3:2010/AMD1:2020

IEC 61850-7-4:2010, *Communication networks and systems for power utility automation – Part 7-4: Basic communication structure – Compatible logical node classes and data object classes*

IEC 61850-7-4:2010/AMD1:2020

IEC 60633:2019, *High-voltage direct current (HVDC) transmission – Vocabulary*

IEC TR 61850-7-500:2017, *Communication networks and systems for power utility automation – Part 7-500: Basic information and communication structure – Use of logical nodes for modeling application functions and related concepts and guidelines for substations*