

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

Elsäkerhet i elektriska starkströmsanläggningar för lågspänning – Utrustning för provning, mätning och övervakning av skyddsåtgärder – Del 1: Allmänt

*Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC –
Equipment for testing, measuring or monitoring of protective measures –
Part 1: General requirements*

Som svensk standard gäller europastandarden EN IEC 61557-1:2021. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 61557-1:2021.

Nationellt förord

Europastandarden EN IEC 61557-1:2021

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 61557-1, Third edition, 2019 - Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC - Equipment for testing, measuring or monitoring of protective measures - Part 1: General requirements**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 61557-1, utgåva 2, 2007, gäller ej fr o m 2024-11-10.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English Version

Electrical safety in low voltage distribution systems up to 1 000 V
AC and 1 500 V DC - Equipment for testing, measuring or
monitoring of protective measures - Part 1: General
requirements
(IEC 61557-1:2019)

Sécurité électrique dans les réseaux de distribution basse
tension au plus égale à 1 000 V c.a. et 1 500 V c.c. -
Dispositifs de contrôle, de mesure ou de surveillance de
mesures de protection - Partie 1: Exigences générales
(IEC 61557-1:2019)

Elektrische Sicherheit in Niederspannungsnetzen bis AC 1
000 V und DC 1 500 V - Geräte zum Prüfen, Messen oder
Überwachen von Schutzmaßnahmen - Teil 1: Allgemeine
Anforderungen
(IEC 61557-1:2019)

This European Standard was approved by CENELEC on 2021-11-10. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 85/689/FDIS, future edition 3 of IEC 61557-1, prepared by IEC/TC 85 "Measuring equipment for electrical and electromagnetic quantities" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61557-1:2021.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2022-08-10
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2024-11-10

This document supersedes EN 61557-1:2007 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a Standardization Request given to CENELEC by the European Commission and the European Free Trade Association.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 61557-1:2019 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60359	NOTE	Harmonized as EN 60359
IEC 60364-1	NOTE	Harmonized as HD 60364-1
IEC 60364-6	NOTE	Harmonized as HD 60364-6
IEC 60664-1	NOTE	Harmonized as EN IEC 60664-1
IEC 61326 (series)	NOTE	Harmonized as EN IEC 61326 (series)
IEC 61326-2-4	NOTE	Harmonized as EN IEC 61326-2-4
IEC 62430	NOTE	Harmonized as EN IEC 62430
IEC 62474	NOTE	Harmonized as EN IEC 62474

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60038 (mod)	2009	IEC standard voltages	EN 60038	2011
IEC 60529	1989	Degrees of protection provided by enclosures (IP Code)	EN 60529	1991
-	-		+ corrigendum May	1993
+ A1	1999		+ A1	2000
+ A2	2013		+ A2	2013
IEC 61010-1	2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements	EN 61010-1	2010
+ A1 (mod)	2016		+ A1	2019
IEC 61010-031	-	Safety requirements for electrical equipment for measurement, control and laboratory use - Part 031: Safety requirements for hand-held probe assemblies for electrical measurement and test	EN 61010-031	-
IEC 61010-2-030	2017	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 2-030: Particular requirements for equipment having testing or measuring circuits	EN IEC 61010-2-030	2021
-	-		+ A11	2021
IEC 61010-2-032	-	Safety requirements for electrical equipment for measurement, control and laboratory use - Part 2-032: Particular requirements for hand-held and hand-manipulated current sensors for electrical test and measurement	EN IEC 61010-2-032	-

EN IEC 61557-1:2021 (E)

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61010-2-034	2017	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 2-034: Particular requirements for measurement equipment for insulation resistance and test equipment for electric strength	EN IEC 61010-2-034	2021
-	-		+ A11	2021
IEC 61326-1	2012	Electrical equipment for measurement, control and laboratory use - EMC requirements - Part 1: General requirements	EN 61326-1	2013
IEC 61557-8	2014	Electrical safety in low voltage distribution systems up to 1 000 V a.c. and 1 500 V d.c. - Equipment for testing, measuring or monitoring of protective measures - Part 8: Insulation monitoring devices for IT systems	EN 61557-8	2015
IEC 61557-9	2014	Electrical safety in low voltage distribution systems up to 1 000 V a.c. and 1 500 V d.c. - Equipment for testing, measuring or monitoring of protective measures - Part 9: Equipment for insulation fault location in IT systems	EN 61557-9	2015

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Electrical safety in low voltage distribution systems up to 1 000 V a.c. and
1 500 V d.c. – Equipment for testing, measuring or monitoring of protective
measures**

Part 1: General requirements

**Sécurité électrique dans les réseaux de distribution basse tension au plus égale
à 1 000 V c.a. et 1 500 V c.c. – Dispositifs de contrôle, de mesure ou de
surveillance de mesures de protection**

Partie 1: Exigences générales

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 17.220.20; 29.080.01; 29.240.01

ISBN 978-2-8322-7141-4

Warning! Make sure that you obtained this publication from an authorized distributor. Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.
--

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	8
4 Requirements	12
4.1 General requirements	12
4.2 Influence quantities – Operating uncertainty (<i>B</i>), percentage operating uncertainty (<i>B</i> [%])	12
4.3 Rated operating conditions	13
4.4 Battery test facility	14
4.5 Safety	14
4.6 Electromagnetic compatibility.....	14
4.6.1 Immunity.....	14
4.6.2 Emission.....	14
4.7 Mechanical strength against vibration	14
5 Marking and operating instructions	15
5.1 General.....	15
5.2 Marking.....	15
5.3 Operating instructions.....	15
5.3.1 Performance requirements.....	15
5.3.2 Other information.....	15
6 Tests	16
6.1 General.....	16
6.2 Operating uncertainty.....	16
6.2.1 General	16
6.2.2 Influence of changing position	16
6.2.3 Influence of temperature	16
6.2.4 Influence of the supply voltage	16
6.3 Battery test facility	16
6.4 Safety tests.....	16
6.5 EMC tests	16
6.6 Mechanical requirements	17
6.7 Marking and operating instructions.....	17
6.8 Records	17
Annex A (informative) Explanation of the application of GUM in series IEC 61557	18
A.1 Overview.....	18
A.2 Basic model of evaluation of results under operational conditions	18
A.2.1 General	18
A.2.2 Standard uncertainty of a result	18
A.2.3 Expanded uncertainty	19
A.2.4 Relative operating uncertainty	19
A.2.5 Calibration uncertainty.....	19
A.3 Operating uncertainty calculations as basis for 4.1	20
A.3.1 Standard uncertainty	20
A.3.2 Operating uncertainty in accordance with 4.1.....	20

Annex B (informative) Environmental aspects	21
B.1 Overview.....	21
B.2 Guidelines to establish a material declaration and end-of-life information	21
B.2.1 General	21
B.2.2 Guidelines for material declaration	22
B.2.3 Guidelines for end-of-life (EoL)	22
B.2.4 Example of a material declaration and end-of-life information	22
Bibliography.....	25
 Figure B.1 – Components listed for EoL of a product	 24
 Table B.1 – Material content according to IEC 62474 material classes.....	 23

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRICAL SAFETY IN LOW VOLTAGE DISTRIBUTION SYSTEMS
UP TO 1 000 V AC AND 1 500 V DC –
EQUIPMENT FOR TESTING, MEASURING OR MONITORING
OF PROTECTIVE MEASURES****Part 1: General requirements****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61557-1 has been prepared by technical committee 85: Measuring equipment for electrical and electromagnetic quantities.

This third edition cancels and replaces the second edition published in 2007. This edition constitutes a technical revision.

This third edition includes the following significant technical changes with respect to the previous edition:

- a) terms aligned with IEC 60050;
- b) measurement of uncertainty revised according to the equations in 4.2 of ISO/IEC Guide 98-3:2008 (GUM);
- c) updated references for safety and EMC requirements;

- d) updated references for marking and operating instructions;
- e) updated references for testing safety and EMC;
- f) Annex A contains an explanation of GUM;
- g) Annex B addresses environmental aspects.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
85/689/FDIS	85/692/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61557 series, published under the general title *Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

IEC 60364-6 stipulates standardized conditions for the initial test of power installations in TN, TT or IT systems for continuous monitoring and for testing these installations after modifications. In addition to general references for the performance of the tests, IEC 60364-6 contains requirements that have to be verified by measurements. Only in a few instances, for example when measuring the insulation resistance, does IEC 60364-6 contain details of the characteristics of the measuring device to be used. Circuits which are given as examples in IEC 60364-6, and referred to within the text of that document, are generally not suitable for practical use.

The tests are carried out in installations where hazardous voltages can occur and where careless use or a defect in the equipment can easily cause an accident. Therefore, the technician has to rely on measuring devices which ensure safe test methods, in addition to simplifying the measurements.

The application of the general safety regulations for electrical and electronic measuring devices (IEC 61010-1) for testing the protective measures is not sufficient in itself. The performance of measurements in the installation can cause hazards not only to the technician, but also to third persons, depending on the measuring method used.

Likewise, reliable and comparable results of measurement with measuring devices from different manufacturers are an important precondition in order to obtain an objective assessment about the installation, for example when the installation is handed over for periodic tests, for continuous insulation monitoring or in the case of performance warranty.

The IEC 61557 series has been established with the aim of stipulating common principles for measuring and monitoring equipment for testing electrical safety and measuring performances in systems with nominal voltages up to 1 000 V AC and 1 500 V DC which correspond to the above-mentioned characteristics.

For that reason, the following common requirements have been stipulated in IEC 61557-1 (other parts of IEC 61557 can specify additional requirements or deviations):

- protection against extraneous voltages;
- class II protection (except insulation monitoring devices and insulation fault location systems);
- requirements and safety precautions against hazardous touch voltages at the measuring device;
- requirements for the assessment of connection configurations with respect to wiring errors in the tested equipment;
- special mechanical requirements;
- measuring methods;
- measured quantity;
- specification of the maximum operating uncertainty;
- requirements for testing the influencing quantity and the calculation of the operating uncertainty;
- uncertainties of the measuring device at the thresholds specified in the respective standards;
- specification of the nature of type and routine tests and the required conditions for testing.

Contrary to the usual convention, terms and definitions that occur more than once in another part of the series are listed in IEC 61557-1:2019, Clause 3. Only terms and definitions specific to the respective part of IEC 61557 are listed in Clause 3 of that part.

ELECTRICAL SAFETY IN LOW VOLTAGE DISTRIBUTION SYSTEMS UP TO 1 000 V AC AND 1 500 V DC – EQUIPMENT FOR TESTING, MEASURING OR MONITORING OF PROTECTIVE MEASURES

Part 1: General requirements

1 Scope

This part of IEC 61557 specifies the general requirements applicable to measuring and monitoring equipment for testing the electrical safety in low-voltage distribution systems with nominal voltages up to 1 000 V AC and 1 500 V DC.

When measuring equipment or measuring installations involve measurement tasks of various measuring equipment covered by this series of standards, then the part of this series relevant to each of the measurement tasks is applicable.

NOTE The term "measuring equipment" will hereafter be used to designate "testing, measuring and monitoring equipment".

Other parts of IEC 61557 can specify additional requirements or deviations.

This document does not cover functional safety or cybersecurity.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:2009, *IEC standard voltages*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP code)*

IEC 60529:1989/AMD1:1999

IEC 60529:1989/AMD2:2013¹

IEC 61010-1:2010, *Safety requirements for electrical equipment for measurement, control and laboratory use – Part 1: General requirements*

IEC 61010-1:2010/AMD1:2016²

IEC 61010-031, *Safety requirements for electrical equipment for measurement, control and laboratory use – Part 031: Safety requirements for hand-held and hand-manipulated assemblies for electrical test and measurement*

¹ A consolidated version of this publication exists, comprising IEC 60529:1989, IEC 60529:1989/AMD1:1999 and IEC 60529:1989/AMD2:2013.

² A consolidated version of this publication exists, comprising IEC 61010-1:2010 and IEC 61010-1:2010/AMD 1:2016.

IEC 61010-2-030:2017, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 2-030: Particular requirements for equipment having testing or measuring circuits*

IEC 61010-2-032, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 2-032: Particular requirements for hand-held and hand-manipulated current sensors for electrical test and measurement*

IEC 61010-2-034:2017, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 2-034: Particular requirements for measurement equipment for insulation resistance and test equipment for electric strength*

IEC 61326-1:2012, *Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 1: General requirements*

IEC 61557-8:2014, *Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures – Part 8: Insulation monitoring devices for IT systems*

IEC 61557-9:2014, *Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures – Part 9: Equipment for insulation fault location in IT systems*