

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

## Gränssnitt för EMS (EMS-API) – Del 452: CIM-profiler för statisk modellering av transmissionsnät

*Energy management system application program interface (EMS-API) –  
Part 452: CIM static transmission network model profiles*

Som svensk standard gäller europastandarden EN IEC 61970-452:2021. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 61970-452:2021.

### Nationellt förord

Europastandarden EN IEC 61970-452:2021

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 61970-452, Fourth edition, 2021 - Energy management system application program interface (EMS-API) - Part 452: CIM static transmission network model profiles**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 61970-452, utgåva 3, 2018, gäller ej fr o m 2024-12-01.

---

ICS 33.200.00

---

Denna standard är fastställd av SEK Svensk Elstandard, som också kan lämna upplysningar om **sakinnehållet** i standarden.  
Postadress: Box 1284, 164 29 KISTA  
Telefon: 08 - 444 14 00.  
E-post: sek@elstandard.se. Internet: www.elstandard.se

---

### *Standarder underlättar utvecklingen och höjer elsäkerheten*

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

### *SEK är Sveriges röst i standardiseringsarbetet inom elområdet*

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

### *Stora delar av arbetet sker internationellt*

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

### *Var med och påverka!*

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

### **SEK Svensk Elstandard**

Box 1284  
164 29 Kista  
Tel 08-444 14 00  
[www.elstandard.se](http://www.elstandard.se)

EUROPEAN STANDARD

NORME EUROPÉENNE

EUROPÄISCHE NORM

**EN IEC 61970-452**

December 2021

ICS 33.200

Supersedes EN 61970-452:2017 and all of its  
amendments and corrigenda (if any)

English Version

**Energy management system application program interface  
(EMS-API) - Part 452: CIM static transmission network model  
profiles  
(IEC 61970-452:2021)**

Interface de programmation d'application pour système de  
gestion d'énergie (EMS-API) - Partie 452: Profils du modèle  
de réseau de transport statique CIM  
(IEC 61970-452:2021)

Schnittstelle für Anwendungsprogramme für  
Netzführungssysteme (EMS-API) - Teil 452: CIM-Statistische-  
Übertragungsnetzwerk-Modell-Profil  
(IEC 61970-452:2021)

This European Standard was approved by CENELEC on 2021-12-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

© 2021 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

Ref. No. EN IEC 61970-452:2021 E

SEK Svensk Elstandard

SS-EN IEC 61970-452, utg 4:2022

## **European foreword**

The text of document 57/2400/FDIS, future edition 4 of IEC 61970-452, prepared by IEC/TC 57 "Power systems management and associated information exchange" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61970-452:2021.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2022-09-01
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2024-12-01

This document supersedes EN 61970-452:2017 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

## **Endorsement notice**

The text of the International Standard IEC 61970-452:2021 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61968-13 NOTE Harmonized as EN IEC 61968-13

IEC 61970-1 NOTE Harmonized as EN 61970-1

IEC/TS 61970-2 NOTE Harmonized as CLC/TS 61970-2

IEC 61970-456 NOTE Harmonized as EN IEC 61970-456

IEC 61970-501 NOTE Harmonized as EN 61970-501

IEC 61970-552 NOTE Harmonized as EN 61970-552

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: [www.cenelec.eu](http://www.cenelec.eu).

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61970-301	2020	Energy management system application program interface (EMS-API) - Part 301: Common information model (CIM) base	EN IEC 61970-301	2020

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



---

**Energy management system application program interface (EMS-API) –  
Part 452: CIM static transmission network model profiles**

**Interface de programmation d'application pour système de gestion d'énergie  
(EMS-API) –  
Partie 452: Profils du modèle de réseau de transport statique CIM**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

---

ICS 33.200

ISBN 978-2-8322-1032-8

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD.....	23
INTRODUCTION.....	25
1 Scope.....	26
2 Normative references .....	26
3 Terms and definitions .....	26
4 Application profile specification.....	27
4.1 General.....	27
4.2 Version information .....	27
4.2.1 Core equipment profile .....	27
4.2.2 Operation profile.....	27
4.2.3 Short-Circuit profile.....	28
4.3 Requirements and constraints.....	28
4.4 Transformer modelling .....	40
4.5 Modelling authorities.....	41
4.6 Use of measurement classes .....	41
4.6.1 General .....	41
4.6.2 ICCP data exchange.....	42
4.7 Voltage or active power regulation .....	42
4.8 Use of curves.....	42
4.8.1 General .....	42
4.8.2 Generating unit reactive power limits .....	42
4.9 Definition of schedules.....	42
5 Detailed profile specification.....	43
5.1 General.....	43
5.2 Core Equipment Profile .....	43
5.2.1 General .....	43
5.2.2 (abstract) EarthFaultCompensator .....	66
5.2.3 (abstract) EnergyArea.....	67
5.2.4 (abstract) EnergyConnection .....	67
5.2.5 EnergyConsumer .....	68
5.2.6 EnergySchedulingType .....	69
5.2.7 TapSchedule .....	69
5.2.8 EnergySource.....	70
5.2.9 (abstract) Equipment .....	71
5.2.10 (abstract) EquipmentContainer .....	72
5.2.11 (abstract) ACDCConverter .....	72
5.2.12 ACDCConverterDCTerminal .....	73
5.2.13 (abstract) ACDCTerminal.....	74
5.2.14 ACLineSegment.....	75
5.2.15 ActivePowerLimit.....	76
5.2.16 ApparentPowerLimit .....	76
5.2.17 AsynchronousMachine.....	77
5.2.18 (abstract) AuxiliaryEquipment .....	78
5.2.19 BaseVoltage .....	78
5.2.20 (abstract) BasicIntervalSchedule .....	78
5.2.21 BatteryUnit .....	79

5.2.22	Bay	79
5.2.23	Breaker	80
5.2.24	BusbarSection	81
5.2.25	BusNameMarker	81
5.2.26	CAESPlant	82
5.2.27	Clamp	82
5.2.28	ConformLoadSchedule	83
5.2.29	CogenerationPlant	84
5.2.30	CombinedCyclePlant	84
5.2.31	(abstract) ConductingEquipment	84
5.2.32	(abstract) Conductor	85
5.2.33	ConformLoad	86
5.2.34	ConformLoadGroup	86
5.2.35	ConnectivityNode	87
5.2.36	(abstract) ConnectivityNodeContainer	87
5.2.37	(abstract) Connector	88
5.2.38	ControlArea	88
5.2.39	ControlAreaGeneratingUnit	89
5.2.40	CsConverter	90
5.2.41	CurrentLimit	92
5.2.42	CurrentTransformer	92
5.2.43	(abstract) Curve	93
5.2.44	CurveData root class	93
5.2.45	Cut	94
5.2.46	DayType	95
5.2.47	(abstract) DCBaseTerminal	95
5.2.48	DCBreaker	96
5.2.49	DCBusbar	97
5.2.50	DCChopper	97
5.2.51	(abstract) DCConductingEquipment	98
5.2.52	DCConverterUnit	98
5.2.53	DCDisconnecter	99
5.2.54	(abstract) DCEquipmentContainer	99
5.2.55	DCGround	100
5.2.56	DCLine	100
5.2.57	DCLineSegment	101
5.2.58	DCNode	102
5.2.59	RegulationSchedule	102
5.2.60	DCSeriesDevice	103
5.2.61	DCShunt	104
5.2.62	DCSwitch	104
5.2.63	DCTerminal	105
5.2.64	Disconnecter	105
5.2.65	DisconnectingCircuitBreaker	106
5.2.66	EquivalentBranch	107
5.2.67	(abstract) EquivalentEquipment	108
5.2.68	EquivalentInjection	108
5.2.69	EquivalentNetwork	109
5.2.70	EquivalentShunt	110

5.2.71	ExternalNetworkInjection .....	110
5.2.72	FaultIndicator .....	111
5.2.73	FossilFuel.....	112
5.2.74	Fuse .....	112
5.2.75	GeneratingUnit .....	113
5.2.76	GeographicalRegion .....	115
5.2.77	GrossToNetActivePowerCurve.....	115
5.2.78	Ground .....	116
5.2.79	GroundDisconnecter .....	116
5.2.80	GroundingImpedance .....	117
5.2.81	HydroGeneratingUnit .....	118
5.2.82	HydroPowerPlant.....	119
5.2.83	HydroPump.....	119
5.2.84	(abstract) IdentifiedObject root class .....	120
5.2.85	Jumper .....	120
5.2.86	Junction.....	121
5.2.87	Line .....	121
5.2.88	LinearShuntCompensator .....	122
5.2.89	LoadArea.....	122
5.2.90	LoadBreakSwitch.....	123
5.2.91	(abstract) LoadGroup.....	123
5.2.92	LoadResponseCharacteristic .....	124
5.2.93	NonConformLoad.....	125
5.2.94	NonConformLoadGroup .....	126
5.2.95	NonConformLoadSchedule .....	127
5.2.96	NonlinearShuntCompensator .....	127
5.2.97	NonlinearShuntCompensatorPoint root class .....	128
5.2.98	NuclearGeneratingUnit .....	129
5.2.99	(abstract) OperationalLimit .....	130
5.2.100	OperationalLimitSet .....	130
5.2.101	OperationalLimitType.....	131
5.2.102	PetersenCoil.....	131
5.2.103	(abstract) PhaseTapChanger .....	132
5.2.104	PhaseTapChangerAsymmetrical .....	133
5.2.105	PhaseTapChangerLinear .....	134
5.2.106	(abstract) PhaseTapChangerNonLinear .....	135
5.2.107	PhaseTapChangerSymmetrical.....	136
5.2.108	PhaseTapChangerTable .....	137
5.2.109	PhaseTapChangerTablePoint .....	137
5.2.110	PhaseTapChangerTabular .....	137
5.2.111	PhotoVoltaicUnit.....	138
5.2.112	PostLineSensor .....	139
5.2.113	PotentialTransformer .....	139
5.2.114	PowerElectronicsConnection .....	140
5.2.115	(abstract) PowerElectronicsUnit.....	141
5.2.116	PowerElectronicsWindUnit.....	141
5.2.117	(abstract) PowerSystemResource .....	142
5.2.118	PowerTransformer .....	142
5.2.119	PowerTransformerEnd .....	143

5.2.120	(abstract) ProtectedSwitch.....	144
5.2.121	RatioTapChanger .....	145
5.2.122	RatioTapChangerTable.....	146
5.2.123	RatioTapChangerTablePoint.....	146
5.2.124	ReactiveCapabilityCurve.....	147
5.2.125	(abstract) RegulatingCondEq.....	147
5.2.126	RegulatingControl.....	148
5.2.127	RegularTimePoint root class.....	149
5.2.128	(abstract) RegularIntervalSchedule.....	150
5.2.129	ReportingGroup.....	150
5.2.130	(abstract) RotatingMachine.....	150
5.2.131	Season.....	151
5.2.132	(abstract) Sensor.....	152
5.2.133	(abstract) SeasonDayTypeSchedule.....	152
5.2.134	SeriesCompensator.....	153
5.2.135	(abstract) ShuntCompensator.....	153
5.2.136	SolarGeneratingUnit.....	154
5.2.137	StaticVarCompensator.....	155
5.2.138	StationSupply.....	156
5.2.139	SubGeographicalRegion.....	157
5.2.140	SubLoadArea.....	158
5.2.141	Substation.....	158
5.2.142	SurgeArrester.....	159
5.2.143	Switch.....	159
5.2.144	SwitchSchedule.....	160
5.2.145	SynchronousMachine.....	161
5.2.146	(abstract) TapChanger.....	161
5.2.147	TapChangerControl.....	162
5.2.148	(abstract) TapChangerTablePoint root class.....	163
5.2.149	Terminal.....	164
5.2.150	ThermalGeneratingUnit.....	165
5.2.151	TieFlow.....	166
5.2.152	(abstract) TransformerEnd.....	166
5.2.153	VoltageLevel.....	167
5.2.154	VoltageLimit.....	168
5.2.155	VsCapabilityCurve.....	168
5.2.156	VsConverter.....	169
5.2.157	WaveTrap.....	170
5.2.158	WindGeneratingUnit.....	170
5.2.159	ControlAreaTypeKind enumeration.....	171
5.2.160	Currency enumeration.....	172
5.2.161	CurveStyle enumeration.....	175
5.2.162	DCCConverterOperatingModeKind enumeration.....	176
5.2.163	DCPolarityKind enumeration.....	176
5.2.164	FuelType enumeration.....	176
5.2.165	GeneratorControlSource enumeration.....	177
5.2.166	HydroEnergyConversionKind enumeration.....	177
5.2.167	HydroPlantStorageKind enumeration.....	177
5.2.168	HydroTurbineKind enumeration.....	178

5.2.169	OperationalLimitDirectionKind enumeration .....	178
5.2.170	PhaseCode enumeration .....	178
5.2.171	RegulatingControlModeKind enumeration .....	179
5.2.172	SynchronousMachineKind enumeration .....	180
5.2.173	(deprecated) SVCControlMode enumeration .....	180
5.2.174	UnitMultiplier enumeration .....	181
5.2.175	UnitSymbol enumeration.....	182
5.2.176	WindGenUnitKind enumeration .....	187
5.2.177	WindingConnection enumeration .....	187
5.2.178	ActivePower datatype .....	187
5.2.179	ActivePowerPerCurrentFlow datatype .....	188
5.2.180	ActivePowerPerFrequency datatype .....	188
5.2.181	AngleDegrees datatype .....	188
5.2.182	ApparentPower datatype.....	188
5.2.183	Capacitance datatype .....	189
5.2.184	Conductance datatype .....	189
5.2.185	CurrentFlow datatype .....	189
5.2.186	Frequency datatype .....	190
5.2.187	Inductance datatype .....	190
5.2.188	Length datatype.....	190
5.2.189	Money datatype .....	190
5.2.190	PerCent datatype.....	191
5.2.191	Reactance datatype .....	191
5.2.192	ReactivePower datatype .....	191
5.2.193	RealEnergy datatype .....	191
5.2.194	Resistance datatype .....	192
5.2.195	RotationSpeed datatype .....	192
5.2.196	Seconds datatype .....	192
5.2.197	Susceptance datatype .....	192
5.2.198	Voltage datatype.....	193
5.2.199	VoltagePerReactivePower datatype .....	193
5.2.200	Boolean primitive .....	193
5.2.201	Date primitive .....	193
5.2.202	DateTime primitive.....	193
5.2.203	Decimal primitive .....	193
5.2.204	Float primitive.....	194
5.2.205	Integer primitive.....	194
5.2.206	MonthDay primitive .....	194
5.2.207	String primitive .....	194
5.3	Operation Profile.....	194
5.3.1	General .....	194
5.3.2	Accumulator .....	198
5.3.3	AccumulatorLimit .....	198
5.3.4	AccumulatorLimitSet.....	199
5.3.5	AccumulatorReset .....	199
5.3.6	AccumulatorValue.....	200
5.3.7	(abstract) ACDCTerminal.....	201
5.3.8	Analog .....	201
5.3.9	(abstract) AnalogControl.....	201

5.3.10	AnalogLimit .....	202
5.3.11	AnalogLimitSet .....	203
5.3.12	AnalogValue .....	203
5.3.13	Command .....	204
5.3.14	(abstract) Control .....	204
5.3.15	Discrete .....	205
5.3.16	DiscreteValue .....	206
5.3.17	(abstract) IdentifiedObject root class .....	206
5.3.18	(abstract) IOPoint .....	207
5.3.19	(abstract) Limit .....	207
5.3.20	(abstract) LimitSet .....	208
5.3.21	(abstract) Measurement .....	208
5.3.22	(abstract) MeasurementValue .....	209
5.3.23	MeasurementValueQuality .....	210
5.3.24	MeasurementValueSource .....	211
5.3.25	(abstract) PowerSystemResource .....	211
5.3.26	(abstract) Quality61850 root class .....	211
5.3.27	RaiseLowerCommand .....	212
5.3.28	SetPoint .....	213
5.3.29	StringMeasurement .....	214
5.3.30	StringMeasurementValue .....	214
5.3.31	(abstract) Terminal .....	215
5.3.32	ValueAliasSet .....	215
5.3.33	ValueToAlias .....	216
5.3.34	PhaseCode enumeration .....	216
5.3.35	Source enumeration .....	217
5.3.36	UnitMultiplier enumeration .....	218
5.3.37	UnitSymbol enumeration .....	219
5.3.38	Validity enumeration .....	224
5.3.39	PerCent datatype .....	224
5.3.40	Boolean primitive .....	225
5.3.41	Date primitive .....	225
5.3.42	DateTime primitive .....	225
5.3.43	Float primitive .....	225
5.3.44	Integer primitive .....	225
5.3.45	String primitive .....	225
5.4	Short Circuit Profile .....	225
5.4.1	General .....	225
5.4.2	(abstract) ACDCTerminal .....	227
5.4.3	(Description) ACLineSegment .....	227
5.4.4	(Description) AsynchronousMachine .....	228
5.4.5	(Description) BusbarSection .....	228
5.4.6	(abstract) ConductingEquipment .....	229
5.4.7	(abstract) Conductor .....	229
5.4.8	(abstract) Connector .....	229
5.4.9	(abstract) EarthFaultCompensator .....	230
5.4.10	(abstract) EnergyConnection .....	230
5.4.11	(Description) EnergySource .....	230
5.4.12	(abstract) Equipment .....	231

5.4.13	(Description) EquivalentBranch.....	231
5.4.14	(abstract) EquivalentEquipment .....	233
5.4.15	(Description) EquivalentInjection .....	233
5.4.16	(Description) ExternalNetworkInjection .....	234
5.4.17	(Description) GroundingImpedance.....	234
5.4.18	(abstract) IdentifiedObject root class .....	235
5.4.19	(Description) LinearShuntCompensator .....	235
5.4.20	MutualCoupling.....	235
5.4.21	(Description) NonlinearShuntCompensatorPoint root class .....	236
5.4.22	(Description) PetersenCoil.....	237
5.4.23	(abstract) PowerSystemResource .....	237
5.4.24	(Description) PowerTransformer .....	238
5.4.25	(Description) PowerTransformerEnd .....	239
5.4.26	(abstract) RegulatingCondEq.....	240
5.4.27	(abstract) RotatingMachine.....	240
5.4.28	(Description) SeriesCompensator .....	241
5.4.29	(abstract) ShuntCompensator .....	241
5.4.30	(Description) SynchronousMachine.....	241
5.4.31	(abstract) Terminal .....	243
5.4.32	(abstract) TransformerEnd.....	243
5.4.33	PetersenCoilModeKind enumeration .....	243
5.4.34	ShortCircuitRotorKind enumeration.....	243
5.4.35	UnitMultiplier enumeration .....	244
5.4.36	UnitSymbol enumeration.....	245
5.4.37	ActivePower datatype .....	250
5.4.38	AngleDegrees datatype .....	250
5.4.39	Conductance datatype .....	251
5.4.40	CurrentFlow datatype .....	251
5.4.41	Length datatype.....	251
5.4.42	PerCent datatype.....	251
5.4.43	PU datatype.....	252
5.4.44	Reactance datatype .....	252
5.4.45	Resistance datatype .....	252
5.4.46	Susceptance datatype .....	252
5.4.47	Temperature datatype.....	253
5.4.48	Voltage datatype.....	253
5.4.49	Boolean primitive.....	253
5.4.50	Date primitive .....	253
5.4.51	Float primitive.....	253
5.4.52	Integer primitive.....	253
5.4.53	String primitive .....	254
6	Amplifications and conventions.....	254
6.1	Overview.....	254
6.2	XML file validity .....	254
6.3	Normative string tables .....	254
6.4	Roles and multiplicity .....	256
Annex A	(informative) Model exchange use cases .....	257
A.1	General.....	257
A.2	Regional security coordinators operating as peers .....	257

A.3	Hierarchical modeling .....	259
Annex B (informative)	Modeling authorities .....	261
B.1	General.....	261
B.2	The ModelingAuthority Class and ModelingAuthoritySets .....	261
B.3	Full Model Exchange.....	261
B.4	Benefits of this approach .....	262
B.4.1	Generality .....	262
B.4.2	Naming & MRIDs .....	262
B.4.3	Processing efficiency .....	262
B.4.4	Verification of authority .....	262
Annex C (informative)	Boundary definition .....	263
Annex D (informative)	Multiple Profile Processing .....	264
Annex E (informative)	Reactive Capability Curve Styles.....	265
E.1	General.....	265
E.2	Reactive capability curve styles .....	265
Annex F (informative)	Common power system model (CPSM) minimum data requirements.....	268
F.1	Overview.....	268
F.2	Scope .....	268
F.3	Glossary .....	270
F.4	Recommended data model exchange attributes .....	270
Bibliography.....		274
Figure 1 – Two winding transformer impedance .....		40
Figure 2 – Three winding transformer impedance.....		40
Figure 3 – Class diagram CoreEquipmentProfile::Main.....		44
Figure 4 – Class diagram CoreEquipmentProfile::ACDCConverter .....		45
Figure 5 – Class diagram CoreEquipmentProfile::ACDCTerminal .....		46
Figure 6 – Class diagram CoreEquipmentProfile::ACDCConnectivityModel .....		47
Figure 7 – Class diagram CoreEquipmentProfile::AuxiliaryEquipment .....		48
Figure 8 – Class diagram CoreEquipmentProfile::Containment .....		49
Figure 9 – Class diagram CoreEquipmentProfile::ControlArea .....		50
Figure 10 – Class diagram CoreEquipmentProfile::CutsAndJumpers.....		51
Figure 11 – Class diagram CoreEquipmentProfile::DCContainment.....		52
Figure 12 – Class diagram CoreEquipmentProfile::DCLineModel .....		53
Figure 13 – Class diagram CoreEquipmentProfile::DCEquipment.....		53
Figure 14 – Class diagram CoreEquipmentProfile::EquivalentS .....		54
Figure 15 – Class diagram CoreEquipmentProfile::LoadModel .....		55
Figure 16 – Class diagram CoreEquipmentProfile::PowerElectronics .....		56
Figure 17 – Class diagram CoreEquipmentProfile::PowerPlant .....		56
Figure 18 – Class diagram CoreEquipmentProfile::Production .....		57
Figure 19 – Class diagram CoreEquipmentProfile::Schedules .....		58
Figure 20 – Class diagram CoreEquipmentProfile::ShuntCompensator .....		59
Figure 21 – Class diagram CoreEquipmentProfile::TapChanger .....		60
Figure 22 – Class diagram CoreEquipmentProfile::Transformer .....		61

Figure 23 – Class diagram CoreEquipmentProfile::OperationalLimits .....	62
Figure 24 – Class diagram CoreEquipmentProfile::Wires .....	63
Figure 25 – Class diagram CoreEquipmentProfile::Datatypes .....	64
Figure 26 – Class diagram CoreEquipmentProfile::Primitives .....	65
Figure 27 – Class diagram CoreEquipmentProfile::Enumerations .....	66
Figure 28 – Class diagram OperationProfile::Control .....	195
Figure 29 – Class diagram OperationProfile::Meas .....	196
Figure 30 – Class diagram OperationProfile::Datatypes .....	197
Figure 31 – Class diagram ShortCircuitProfile::ShortCircuitProfile .....	226
Figure 32 – Class diagram ShortCircuitProfile::Datatypes .....	226
Figure A.1 – Security coordinators .....	257
Figure A.2 – CIM model exchange .....	258
Figure A.3 – Revised CIM model exchange .....	259
Figure A.4 – Hierarchical modeling .....	260
Figure E.1 – ReactiveCapabilityCurve and associated classes .....	265
Figure E.2 – straightLineYValues style of of ReactiveCapabilityCurve (RCC) .....	266
Figure E.3 – constantYValues style of of ReactiveCapabilityCurve .....	266
Figure F.1 – Example model configuration .....	273
Table 1 – Attributes of CoreEquipmentProfile::EarthFaultCompensator .....	67
Table 2 – Association ends of CoreEquipmentProfile:: EarthFaultCompensator with other classes .....	67
Table 3 – Attributes of CoreEquipmentProfile::EnergyArea .....	67
Table 4 – Attributes of CoreEquipmentProfile::EnergyConnection .....	68
Table 5 – Association ends of CoreEquipmentProfile:: EnergyConnection with other classes .....	68
Table 6 – Attributes of CoreEquipmentProfile::EnergyConsumer .....	68
Table 7 – Association ends of CoreEquipmentProfile:: EnergyConsumer with other classes .....	69
Table 8 – Attributes of CoreEquipmentProfile::EnergySchedulingType .....	69
Table 9 – Attributes of CoreEquipmentProfile::TapSchedule .....	70
Table 10 – Association ends of CoreEquipmentProfile::TapSchedule with other classes .....	70
Table 11 – Attributes of CoreEquipmentProfile::EnergySource .....	70
Table 12 – Association ends of CoreEquipmentProfile::EnergySource with other classes .....	71
Table 13 – Attributes of CoreEquipmentProfile::Equipment .....	71
Table 14 – Association ends of CoreEquipmentProfile::Equipment with other classes .....	71
Table 15 – Attributes of CoreEquipmentProfile::EquipmentContainer .....	72
Table 16 – Attributes of CoreEquipmentProfile::ACDCConverter .....	72
Table 17 – Association ends of CoreEquipmentProfile:: ACDCConverter with other classes .....	73
Table 18 – Attributes of CoreEquipmentProfile::ACDCConverterDCTerminal .....	74
Table 19 – Association ends of CoreEquipmentProfile:: ACDCConverterDCTerminal with other classes .....	74
Table 20 – Attributes of CoreEquipmentProfile::ACDCTerminal .....	74

Table 21 – Association ends of CoreEquipmentProfile:: ACDCTerminal with other classes .....	75
Table 22 – Attributes of CoreEquipmentProfile::ACLLineSegment.....	75
Table 23 – Association ends of CoreEquipmentProfile:: ACLLineSegment with other classes .....	76
Table 24 – Attributes of CoreEquipmentProfile::ActivePowerLimit .....	76
Table 25 – Association ends of CoreEquipmentProfile:: ActivePowerLimit with other classes .....	76
Table 26 – Attributes of CoreEquipmentProfile::ApparentPowerLimit .....	76
Table 27 – Association ends of CoreEquipmentProfile:: ApparentPowerLimit with other classes .....	77
Table 28 – Attributes of CoreEquipmentProfile::AsynchronousMachine.....	77
Table 29 – Association ends of CoreEquipmentProfile:: AsynchronousMachine with other classes .....	77
Table 30 – Attributes of CoreEquipmentProfile::AuxiliaryEquipment .....	78
Table 31 – Association ends of CoreEquipmentProfile:: AuxiliaryEquipment with other classes .....	78
Table 32 – Attributes of CoreEquipmentProfile::BaseVoltage .....	78
Table 33 – Attributes of CoreEquipmentProfile::BasicIntervalSchedule .....	79
Table 34 – Attributes of CoreEquipmentProfile::BatteryUnit .....	79
Table 35 – Association ends of CoreEquipmentProfile::BatteryUnit with other classes .....	79
Table 36 – Attributes of CoreEquipmentProfile::Bay.....	80
Table 37 – Association ends of CoreEquipmentProfile::Bay with other classes .....	80
Table 38 – Attributes of CoreEquipmentProfile::Breaker.....	80
Table 39 – Association ends of CoreEquipmentProfile::Breaker with other classes .....	81
Table 40 – Attributes of CoreEquipmentProfile::BusbarSection .....	81
Table 41 – Association ends of CoreEquipmentProfile:: BusbarSection with other classes .....	81
Table 42 – Attributes of CoreEquipmentProfile::BusNameMarker .....	82
Table 43 – Association ends of CoreEquipmentProfile:: BusNameMarker with other classes .....	82
Table 44 – Attributes of CoreEquipmentProfile::CAESPlant .....	82
Table 45 – Attributes of CoreEquipmentProfile::Clamp.....	83
Table 46 – Association ends of CoreEquipmentProfile::Clamp with other classes .....	83
Table 47 – Attributes of CoreEquipmentProfile::ConformLoadSchedule .....	83
Table 48 – Association ends of CoreEquipmentProfile:: ConformLoadSchedule with other classes .....	84
Table 49 – Attributes of CoreEquipmentProfile::CogenerationPlant .....	84
Table 50 – Attributes of CoreEquipmentProfile::CombinedCyclePlant .....	84
Table 51 – Attributes of CoreEquipmentProfile::ConductingEquipment.....	85
Table 52 – Association ends of CoreEquipmentProfile:: ConductingEquipment with other classes .....	85
Table 53 – Attributes of CoreEquipmentProfile::Conductor.....	85
Table 54 – Association ends of CoreEquipmentProfile::Conductor with other classes .....	85
Table 55 – Attributes of CoreEquipmentProfile::ConformLoad.....	86
Table 56 – Association ends of CoreEquipmentProfile::ConformLoad with other classes.....	86

Table 57 – Attributes of CoreEquipmentProfile::ConformLoadGroup .....	86
Table 58 – Association ends of CoreEquipmentProfile:: ConformLoadGroup with other classes .....	87
Table 59 – Attributes of CoreEquipmentProfile::ConnectivityNode .....	87
Table 60 – Association ends of CoreEquipmentProfile:: ConnectivityNode with other classes .....	87
Table 61 – Attributes of CoreEquipmentProfile::ConnectivityNodeContainer .....	87
Table 62 – Attributes of CoreEquipmentProfile::Connector.....	88
Table 63 – Association ends of CoreEquipmentProfile::Connector with other classes .....	88
Table 64 – Attributes of CoreEquipmentProfile::ControlArea .....	89
Table 65 – Association ends of CoreEquipmentProfile::ControlArea with other classes.....	89
Table 66 – Attributes of CoreEquipmentProfile::ControlAreaGeneratingUnit.....	89
Table 67 – Association ends of CoreEquipmentProfile:: ControlAreaGeneratingUnit with other classes .....	90
Table 68 – Attributes of CoreEquipmentProfile::CsConverter .....	91
Table 69 – Association ends of CoreEquipmentProfile::CsConverter with other classes .....	92
Table 70 – Attributes of CoreEquipmentProfile::CurrentLimit.....	92
Table 71 – Association ends of CoreEquipmentProfile::CurrentLimit with other classes .....	92
Table 72 – Attributes of CoreEquipmentProfile::CurrentTransformer .....	93
Table 73 – Association ends of CoreEquipmentProfile:: CurrentTransformer with other classes .....	93
Table 74 – Attributes of CoreEquipmentProfile::Curve .....	93
Table 75 – Attributes of CoreEquipmentProfile::CurveData .....	94
Table 76 – Association ends of CoreEquipmentProfile::CurveData with other classes .....	94
Table 77 – Attributes of CoreEquipmentProfile::Cut .....	95
Table 78 – Association ends of CoreEquipmentProfile::Cut with other classes .....	95
Table 79 – Attributes of CoreEquipmentProfile::DayType .....	95
Table 80 – Attributes of CoreEquipmentProfile::DCBaseTerminal .....	96
Table 81 – Association ends of CoreEquipmentProfile:: DCBaseTerminal with other classes .....	96
Table 82 – Attributes of CoreEquipmentProfile::DCBreaker.....	96
Table 83 – Association ends of CoreEquipmentProfile::DCBreaker with other classes .....	96
Table 84 – Attributes of CoreEquipmentProfile::DCBusbar.....	97
Table 85 – Association ends of CoreEquipmentProfile::DCBusbar with other classes.....	97
Table 86 – Attributes of CoreEquipmentProfile::DCChopper.....	97
Table 87 – Association ends of CoreEquipmentProfile::DCChopper with other classes .....	98
Table 88 – Attributes of CoreEquipmentProfile::DCConductingEquipment.....	98
Table 89 – Association ends of CoreEquipmentProfile:: DCConductingEquipment with other classes .....	98
Table 90 – Attributes of CoreEquipmentProfile::DCConverterUnit .....	99
Table 91 – Association ends of CoreEquipmentProfile:: DCConverterUnit with other classes .....	99
Table 92 – Attributes of CoreEquipmentProfile::DCDisconnecter.....	99
Table 93 – Association ends of CoreEquipmentProfile:: DCDisconnecter with other classes .....	99
Table 94 – Attributes of CoreEquipmentProfile::DCEquipmentContainer .....	100

Table 95 – Attributes of CoreEquipmentProfile::DCGround .....	100
Table 96 – Association ends of CoreEquipmentProfile::DCGround with other classes .....	100
Table 97 – Attributes of CoreEquipmentProfile::DCLine .....	101
Table 98 – Association ends of CoreEquipmentProfile::DCLine with other classes .....	101
Table 99 – Attributes of CoreEquipmentProfile::DCLineSegment .....	101
Table 100 – Association ends of CoreEquipmentProfile:: DCLineSegment with other classes .....	102
Table 101 – Attributes of CoreEquipmentProfile::DCNode.....	102
Table 102 – Association ends of CoreEquipmentProfile::DCNode with other classes .....	102
Table 103 – Attributes of CoreEquipmentProfile::RegulationSchedule.....	103
Table 104 – Association ends of CoreEquipmentProfile:: RegulationSchedule with other classes .....	103
Table 105 – Attributes of CoreEquipmentProfile::DCSeriesDevice .....	103
Table 106 – Association ends of CoreEquipmentProfile:: DCSeriesDevice with other classes .....	104
Table 107 – Attributes of CoreEquipmentProfile::DCShunt.....	104
Table 108 – Association ends of CoreEquipmentProfile::DCShunt with other classes.....	104
Table 109 – Attributes of CoreEquipmentProfile::DCSwitch.....	105
Table 110 – Association ends of CoreEquipmentProfile::DCSwitch with other classes .....	105
Table 111 – Attributes of CoreEquipmentProfile::DCTerminal .....	105
Table 112 – Association ends of CoreEquipmentProfile::DCTerminal with other classes .....	105
Table 113 – Attributes of CoreEquipmentProfile::Disconnecter .....	106
Table 114 – Association ends of CoreEquipmentProfile:: Disconnecter with other classes .....	106
Table 115 – Attributes of CoreEquipmentProfile::DisconnectingCircuitBreaker.....	106
Table 116 – Association ends of CoreEquipmentProfile:: DisconnectingCircuitBreaker with other classes .....	107
Table 117 – Attributes of CoreEquipmentProfile::EquivalentBranch.....	107
Table 118 – Association ends of CoreEquipmentProfile:: EquivalentBranch with other classes .....	108
Table 119 – Attributes of CoreEquipmentProfile::EquivalentEquipment .....	108
Table 120 – Association ends of CoreEquipmentProfile:: EquivalentEquipment with other classes .....	108
Table 121 – Attributes of CoreEquipmentProfile::EquivalentInjection .....	109
Table 122 – Association ends of CoreEquipmentProfile:: EquivalentInjection with other classes .....	109
Table 123 – Attributes of CoreEquipmentProfile::EquivalentNetwork.....	110
Table 124 – Attributes of CoreEquipmentProfile::EquivalentShunt .....	110
Table 125 – Association ends of CoreEquipmentProfile:: EquivalentShunt with other classes .....	110
Table 126 – Attributes of CoreEquipmentProfile::ExternalNetworkInjection .....	111
Table 127 – Association ends of CoreEquipmentProfile:: ExternalNetworkInjection with other classes .....	111
Table 128 – Attributes of CoreEquipmentProfile::FaultIndicator.....	112
Table 129 – Association ends of CoreEquipmentProfile:: FaultIndicator with other classes .....	112

Table 130 – Attributes of CoreEquipmentProfile::FossilFuel .....	112
Table 131 – Association ends of CoreEquipmentProfile::FossilFuel with other classes.....	112
Table 132 – Attributes of CoreEquipmentProfile::Fuse .....	113
Table 133 – Association ends of CoreEquipmentProfile::Fuse with other classes .....	113
Table 134 – Attributes of CoreEquipmentProfile::GeneratingUnit .....	114
Table 135 – Association ends of CoreEquipmentProfile:: GeneratingUnit with other classes .....	115
Table 136 – Attributes of CoreEquipmentProfile::GeographicalRegion .....	115
Table 137 – Attributes of CoreEquipmentProfile::GrossToNetActivePowerCurve.....	115
Table 138 – Association ends of CoreEquipmentProfile::GrossToNetActivePowerCurve with other classes .....	116
Table 139 – Attributes of CoreEquipmentProfile::Ground .....	116
Table 140 – Association ends of CoreEquipmentProfile::Ground with other classes .....	116
Table 141 – Attributes of CoreEquipmentProfile::GroundDisconnecter .....	117
Table 142 – Association ends of CoreEquipmentProfile:: GroundDisconnecter with other classes .....	117
Table 143 – Attributes of CoreEquipmentProfile::GroundingImpedance.....	117
Table 144 – Association ends of CoreEquipmentProfile:: GroundingImpedance with other classes .....	117
Table 145 – Attributes of CoreEquipmentProfile::HydroGeneratingUnit .....	118
Table 146 – Association ends of CoreEquipmentProfile:: HydroGeneratingUnit with other classes .....	118
Table 147 – Attributes of CoreEquipmentProfile::HydroPowerPlant.....	119
Table 148 – Attributes of CoreEquipmentProfile::HydroPump.....	119
Table 149 – Association ends of CoreEquipmentProfile::HydroPump with other classes .....	119
Table 150 – Attributes of CoreEquipmentProfile::IdentifiedObject .....	120
Table 151 – Attributes of CoreEquipmentProfile::Jumper .....	120
Table 152 – Association ends of CoreEquipmentProfile::Jumper with other classes .....	121
Table 153 – Attributes of CoreEquipmentProfile::Junction.....	121
Table 154 – Association ends of CoreEquipmentProfile::Junction with other classes .....	121
Table 155 – Attributes of CoreEquipmentProfile::Line .....	121
Table 156 – Association ends of CoreEquipmentProfile::Line with other classes.....	122
Table 157 – Attributes of CoreEquipmentProfile::LinearShuntCompensator .....	122
Table 158 – Association ends of CoreEquipmentProfile:: LinearShuntCompensator with other classes .....	122
Table 159 – Attributes of CoreEquipmentProfile::LoadArea.....	123
Table 160 – Attributes of CoreEquipmentProfile::LoadBreakSwitch.....	123
Table 161 – Association ends of CoreEquipmentProfile:: LoadBreakSwitch with other classes .....	123
Table 162 – Attributes of CoreEquipmentProfile::LoadGroup.....	124
Table 163 – Association ends of CoreEquipmentProfile::LoadGroup with other classes .....	124
Table 164 – Attributes of CoreEquipmentProfile::LoadResponseCharacteristic .....	125
Table 165 – Attributes of CoreEquipmentProfile::NonConformLoad.....	126
Table 166 – Association ends of CoreEquipmentProfile:: NonConformLoad with other classes .....	126
Table 167 – Attributes of CoreEquipmentProfile::NonConformLoadGroup .....	126

Table 168 – Association ends of CoreEquipmentProfile:: NonConformLoadGroup with other classes .....	127
Table 169 – Attributes of CoreEquipmentProfile::NonConformLoadSchedule .....	127
Table 170 – Association ends of CoreEquipmentProfile:: NonConformLoadSchedule with other classes .....	127
Table 171 – Attributes of CoreEquipmentProfile::NonlinearShuntCompensator .....	128
Table 172 – Association ends of CoreEquipmentProfile:: NonlinearShuntCompensator with other classes .....	128
Table 173 – Attributes of CoreEquipmentProfile::NonlinearShuntCompensatorPoint .....	128
Table 174 – Association ends of CoreEquipmentProfile:: NonlinearShuntCompensatorPoint with other classes.....	129
Table 175 – Attributes of CoreEquipmentProfile::NuclearGeneratingUnit .....	129
Table 176 – Association ends of CoreEquipmentProfile:: NuclearGeneratingUnit with other classes .....	129
Table 177 – Attributes of CoreEquipmentProfile::OperationalLimit .....	130
Table 178 – Association ends of CoreEquipmentProfile:: OperationalLimit with other classes .....	130
Table 179 – Attributes of CoreEquipmentProfile::OperationalLimitSet .....	131
Table 180 – Association ends of CoreEquipmentProfile:: OperationalLimitSet with other classes .....	131
Table 181 – Attributes of CoreEquipmentProfile::OperationalLimitType.....	131
Table 182 – Attributes of CoreEquipmentProfile::PetersenCoil.....	132
Table 183 – Association ends of CoreEquipmentProfile::PetersenCoil with other classes .....	132
Table 184 – Attributes of CoreEquipmentProfile::PhaseTapChanger.....	132
Table 185 – Association ends of CoreEquipmentProfile:: PhaseTapChanger with other classes .....	133
Table 186 – Attributes of CoreEquipmentProfile::PhaseTapChangerAsymmetrical .....	133
Table 187 – Association ends of CoreEquipmentProfile:: PhaseTapChangerAsymmetrical with other classes .....	134
Table 188 – Attributes of CoreEquipmentProfile::PhaseTapChangerLinear .....	134
Table 189 – Association ends of CoreEquipmentProfile:: PhaseTapChangerLinear with other classes .....	135
Table 190 – Attributes of CoreEquipmentProfile::PhaseTapChangerNonLinear .....	135
Table 191 – Association ends of CoreEquipmentProfile:: PhaseTapChangerNonLinear with other classes .....	136
Table 192 – Attributes of CoreEquipmentProfile::PhaseTapChangerSymmetrical.....	136
Table 193 – Association ends of CoreEquipmentProfile:: PhaseTapChangerSymmetrical with other classes .....	136
Table 194 – Attributes of CoreEquipmentProfile::PhaseTapChangerTable .....	137
Table 195 – Attributes of CoreEquipmentProfile::PhaseTapChangerTablePoint .....	137
Table 196 – Association ends of CoreEquipmentProfile:: PhaseTapChangerTablePoint with other classes .....	137
Table 197 – Attributes of CoreEquipmentProfile::PhaseTapChangerTabular .....	138
Table 198 – Association ends of CoreEquipmentProfile:: PhaseTapChangerTabular with other classes .....	138
Table 199 – Attributes of CoreEquipmentProfile::PhotoVoltaicUnit.....	138

Table 200 – Association ends of CoreEquipmentProfile:: PhotoVoltaicUnit with other classes .....	139
Table 201 – Attributes of CoreEquipmentProfile::PostLineSensor .....	139
Table 202 – Association ends of CoreEquipmentProfile:: PostLineSensor with other classes .....	139
Table 203 – Attributes of CoreEquipmentProfile::PotentialTransformer .....	140
Table 204 – Association ends of CoreEquipmentProfile:: PotentialTransformer with other classes .....	140
Table 205 – Attributes of CoreEquipmentProfile::PowerElectronicsConnection .....	140
Table 206 – Association ends of CoreEquipmentProfile:: PowerElectronicsConnection with other classes .....	141
Table 207 – Attributes of CoreEquipmentProfile::PowerElectronicsUnit.....	141
Table 208 – Association ends of CoreEquipmentProfile:: PowerElectronicsUnit with other classes .....	141
Table 209 – Attributes of CoreEquipmentProfile::PowerElectronicsWindUnit.....	142
Table 210 – Association ends of CoreEquipmentProfile:: PowerElectronicsWindUnit with other classes .....	142
Table 211 – Attributes of CoreEquipmentProfile::PowerSystemResource.....	142
Table 212 – Attributes of CoreEquipmentProfile::PowerTransformer .....	143
Table 213 – Association ends of CoreEquipmentProfile:: PowerTransformer with other classes .....	143
Table 214 – Attributes of CoreEquipmentProfile::PowerTransformerEnd.....	144
Table 215 – Association ends of CoreEquipmentProfile:: PowerTransformerEnd with other classes .....	144
Table 216 – Attributes of CoreEquipmentProfile::ProtectedSwitch.....	145
Table 217 – Association ends of CoreEquipmentProfile:: ProtectedSwitch with other classes .....	145
Table 218 – Attributes of CoreEquipmentProfile::RatioTapChanger.....	145
Table 219 – Association ends of CoreEquipmentProfile:: RatioTapChanger with other classes .....	146
Table 220 – Attributes of CoreEquipmentProfile::RatioTapChangerTable.....	146
Table 221 – Attributes of CoreEquipmentProfile::RatioTapChangerTablePoint.....	146
Table 222 – Association ends of CoreEquipmentProfile:: RatioTapChangerTablePoint with other classes .....	147
Table 223 – Attributes of CoreEquipmentProfile::ReactiveCapabilityCurve.....	147
Table 224 – Attributes of CoreEquipmentProfile::RegulatingCondEq.....	147
Table 225 – Association ends of CoreEquipmentProfile:: RegulatingCondEq with other classes .....	148
Table 226 – Attributes of CoreEquipmentProfile::RegulatingControl.....	149
Table 227 – Association ends of CoreEquipmentProfile:: RegulatingControl with other classes .....	149
Table 228 – Attributes of CoreEquipmentProfile::RegularTimePoint.....	149
Table 229 – Association ends of CoreEquipmentProfile:: RegularTimePoint with other classes .....	150
Table 230 – Attributes of CoreEquipmentProfile::RegularIntervalSchedule.....	150
Table 231 – Attributes of CoreEquipmentProfile::ReportingGroup .....	150
Table 232 – Attributes of CoreEquipmentProfile::RotatingMachine.....	151

Table 233 – Association ends of CoreEquipmentProfile:: RotatingMachine with other classes .....	151
Table 234 – Attributes of CoreEquipmentProfile::Season .....	151
Table 235 – Attributes of CoreEquipmentProfile::Sensor .....	152
Table 236 – Association ends of CoreEquipmentProfile::Sensor with other classes.....	152
Table 237 – Attributes of CoreEquipmentProfile::SeasonDayTypeSchedule .....	152
Table 238 – Association ends of CoreEquipmentProfile:: SeasonDayTypeSchedule with other classes .....	153
Table 239 – Attributes of CoreEquipmentProfile::SeriesCompensator .....	153
Table 240 – Association ends of CoreEquipmentProfile:: SeriesCompensator with other classes .....	153
Table 241 – Attributes of CoreEquipmentProfile::ShuntCompensator .....	154
Table 242 – Association ends of CoreEquipmentProfile:: ShuntCompensator with other classes .....	154
Table 243 – Attributes of CoreEquipmentProfile::SolarGeneratingUnit .....	155
Table 244 – Association ends of CoreEquipmentProfile:: SolarGeneratingUnit with other classes .....	155
Table 245 – Attributes of CoreEquipmentProfile::StaticVarCompensator .....	156
Table 246 – Association ends of CoreEquipmentProfile:: StaticVarCompensator with other classes .....	156
Table 247 – Attributes of CoreEquipmentProfile::StationSupply .....	157
Table 248 – Association ends of CoreEquipmentProfile:: StationSupply with other classes .....	157
Table 249 – Attributes of CoreEquipmentProfile::SubGeographicalRegion .....	157
Table 250 – Association ends of CoreEquipmentProfile:: SubGeographicalRegion with other classes .....	157
Table 251 – Attributes of CoreEquipmentProfile::SubLoadArea.....	158
Table 252 – Association ends of CoreEquipmentProfile:: SubLoadArea with other classes .....	158
Table 253 – Attributes of CoreEquipmentProfile::Substation .....	158
Table 254 – Association ends of CoreEquipmentProfile::Substation with other classes .....	158
Table 255 – Attributes of CoreEquipmentProfile::SurgeArrester .....	159
Table 256 – Association ends of CoreEquipmentProfile:: SurgeArrester with other classes .....	159
Table 257 – Attributes of CoreEquipmentProfile::Switch .....	159
Table 258 – Association ends of CoreEquipmentProfile::Switch with other classes .....	160
Table 259 – Attributes of CoreEquipmentProfile::SwitchSchedule .....	160
Table 260 – Association ends of CoreEquipmentProfile:: SwitchSchedule with other classes .....	160
Table 261 – Attributes of CoreEquipmentProfile::SynchronousMachine.....	161
Table 262 – Association ends of CoreEquipmentProfile:: SynchronousMachine with other classes .....	161
Table 263 – Attributes of CoreEquipmentProfile::TapChanger.....	162
Table 264 – Association ends of CoreEquipmentProfile::TapChanger with other classes ....	162
Table 265 – Attributes of CoreEquipmentProfile::TapChangerControl .....	163
Table 266 – Association ends of CoreEquipmentProfile:: TapChangerControl with other classes .....	163

Table 267 – Attributes of CoreEquipmentProfile::TapChangerTablePoint .....	163
Table 268 – Attributes of CoreEquipmentProfile::Terminal .....	164
Table 269 – Association ends of CoreEquipmentProfile::Terminal with other classes .....	165
Table 270 – Attributes of CoreEquipmentProfile::ThermalGeneratingUnit.....	165
Table 271 – Association ends of CoreEquipmentProfile:: ThermalGeneratingUnit with other classes .....	166
Table 272 – Attributes of CoreEquipmentProfile::TieFlow.....	166
Table 273 – Association ends of CoreEquipmentProfile::TieFlow with other classes .....	166
Table 274 – Attributes of CoreEquipmentProfile::TransformerEnd.....	167
Table 275 – Association ends of CoreEquipmentProfile:: TransformerEnd with other classes .....	167
Table 276 – Attributes of CoreEquipmentProfile::VoltageLevel.....	167
Table 277 – Association ends of CoreEquipmentProfile::VoltageLevel with other classes .....	168
Table 278 – Attributes of CoreEquipmentProfile::VoltageLimit.....	168
Table 279 – Association ends of CoreEquipmentProfile::VoltageLimit with other classes .....	168
Table 280 – Attributes of CoreEquipmentProfile::VsCapabilityCurve .....	169
Table 281 – Attributes of CoreEquipmentProfile::VsConverter .....	169
Table 282 – Association ends of CoreEquipmentProfile::VsConverter with other classes .....	170
Table 283 – Attributes of CoreEquipmentProfile::WaveTrap .....	170
Table 284 – Association ends of CoreEquipmentProfile::WaveTrap with other classes.....	170
Table 285 – Attributes of CoreEquipmentProfile::WindGeneratingUnit.....	171
Table 286 – Association ends of CoreEquipmentProfile:: WindGeneratingUnit with other classes .....	171
Table 287 – Literals of CoreEquipmentProfile::ControlAreaTypeKind .....	171
Table 288 – Literals of CoreEquipmentProfile::Currency .....	172
Table 289 – Literals of CoreEquipmentProfile::CurveStyle .....	176
Table 290 – Literals of CoreEquipmentProfile::DCConverterOperatingModeKind .....	176
Table 291 – Literals of CoreEquipmentProfile::DCPolarityKind.....	176
Table 292 – Literals of CoreEquipmentProfile::FuelType.....	177
Table 293 – Literals of CoreEquipmentProfile::GeneratorControlSource .....	177
Table 294 – Literals of CoreEquipmentProfile::HydroEnergyConversionKind.....	177
Table 295 – Literals of CoreEquipmentProfile::HydroPlantStorageKind .....	178
Table 296 – Literals of CoreEquipmentProfile::HydroTurbineKind .....	178
Table 297 – Literals of CoreEquipmentProfile::OperationalLimitDirectionKind .....	178
Table 298 – Literals of CoreEquipmentProfile::PhaseCode .....	179
Table 299 – Literals of CoreEquipmentProfile::RegulatingControlModeKind.....	180
Table 300 – Literals of CoreEquipmentProfile::SynchronousMachineKind .....	180
Table 301 – Literals of CoreEquipmentProfile::SVCControlMode .....	180
Table 302 – Literals of CoreEquipmentProfile::UnitMultiplier .....	181
Table 303 – Literals of CoreEquipmentProfile::UnitSymbol.....	182
Table 304 – Literals of CoreEquipmentProfile::WindGenUnitKind.....	187
Table 305 – Literals of CoreEquipmentProfile::WindingConnection .....	187

Table 306 – Attributes of CoreEquipmentProfile::ActivePower .....	188
Table 307 – Attributes of CoreEquipmentProfile::ActivePowerPerCurrentFlow .....	188
Table 308 – Attributes of CoreEquipmentProfile::ActivePowerPerFrequency .....	188
Table 309 – Attributes of CoreEquipmentProfile::AngleDegrees .....	188
Table 310 – Attributes of CoreEquipmentProfile::ApparentPower .....	189
Table 311 – Attributes of CoreEquipmentProfile::Capacitance .....	189
Table 312 – Attributes of CoreEquipmentProfile::Conductance .....	189
Table 313 – Attributes of CoreEquipmentProfile::CurrentFlow .....	189
Table 314 – Attributes of CoreEquipmentProfile::Frequency .....	190
Table 315 – Attributes of CoreEquipmentProfile::Inductance .....	190
Table 316 – Attributes of CoreEquipmentProfile::Length .....	190
Table 317 – Attributes of CoreEquipmentProfile::Money .....	190
Table 318 – Attributes of CoreEquipmentProfile::PerCent .....	191
Table 319 – Attributes of CoreEquipmentProfile::Reactance .....	191
Table 320 – Attributes of CoreEquipmentProfile::ReactivePower .....	191
Table 321 – Attributes of CoreEquipmentProfile::RealEnergy .....	191
Table 322 – Attributes of CoreEquipmentProfile::Resistance .....	192
Table 323 – Attributes of CoreEquipmentProfile::RotationSpeed .....	192
Table 324 – Attributes of CoreEquipmentProfile::Seconds .....	192
Table 325 – Attributes of CoreEquipmentProfile::Susceptance .....	193
Table 326 – Attributes of CoreEquipmentProfile::Voltage .....	193
Table 327 – Attributes of CoreEquipmentProfile::VoltagePerReactivePower .....	193
Table 328 – Attributes of OperationProfile::Accumulator .....	198
Table 329 – Association ends of OperationProfile::Accumulator with other classes .....	198
Table 330 – Attributes of OperationProfile::AccumulatorLimit .....	199
Table 331 – Association ends of OperationProfile::AccumulatorLimit with other classes .....	199
Table 332 – Attributes of OperationProfile::AccumulatorLimitSet .....	199
Table 333 – Association ends of OperationProfile:: AccumulatorLimitSet with other classes .....	199
Table 334 – Attributes of OperationProfile::AccumulatorReset .....	200
Table 335 – Association ends of OperationProfile::AccumulatorReset with other classes .....	200
Table 336 – Attributes of OperationProfile::AccumulatorValue .....	200
Table 337 – Association ends of OperationProfile::AccumulatorValue with other classes .....	200
Table 338 – Attributes of OperationProfile::ACDCTerminal .....	201
Table 339 – Attributes of OperationProfile::Analog .....	201
Table 340 – Association ends of OperationProfile::Analog with other classes .....	201
Table 341 – Attributes of OperationProfile::AnalogControl .....	202
Table 342 – Association ends of OperationProfile::AnalogControl with other classes .....	202
Table 343 – Attributes of OperationProfile::AnalogLimit .....	202
Table 344 – Association ends of OperationProfile::AnalogLimit with other classes .....	203
Table 345 – Attributes of OperationProfile::AnalogLimitSet .....	203
Table 346 – Association ends of OperationProfile::AnalogLimitSet with other classes .....	203

Table 347 – Attributes of OperationProfile::AnalogValue .....	203
Table 348 – Association ends of OperationProfile::AnalogValue with other classes .....	204
Table 349 – Attributes of OperationProfile::Command .....	204
Table 350 – Association ends of OperationProfile::Command with other classes .....	204
Table 351 – Attributes of OperationProfile::Control .....	205
Table 352 – Association ends of OperationProfile::Control with other classes .....	205
Table 353 – Attributes of OperationProfile::Discrete .....	205
Table 354 – Association ends of OperationProfile::Discrete with other classes .....	206
Table 355 – Attributes of OperationProfile::DiscreteValue .....	206
Table 356 – Association ends of OperationProfile::DiscreteValue with other classes .....	206
Table 357 – Attributes of OperationProfile::IdentifiedObject .....	207
Table 358 – Attributes of OperationProfile::IOPoint .....	207
Table 359 – Attributes of OperationProfile::Limit .....	207
Table 360 – Attributes of OperationProfile::LimitSet .....	208
Table 361 – Attributes of OperationProfile::Measurement .....	209
Table 362 – Association ends of OperationProfile::Measurement with other classes .....	209
Table 363 – Attributes of OperationProfile::MeasurementValue .....	210
Table 364 – Association ends of OperationProfile:: MeasurementValue with other classes .....	210
Table 365 – Attributes of OperationProfile::MeasurementValueQuality .....	210
Table 366 – Association ends of OperationProfile:: MeasurementValueQuality with other classes .....	211
Table 367 – Attributes of OperationProfile::MeasurementValueSource .....	211
Table 368 – Attributes of OperationProfile::PowerSystemResource .....	211
Table 369 – Attributes of OperationProfile::Quality61850 .....	212
Table 370 – Attributes of OperationProfile::RaiseLowerCommand .....	213
Table 371 – Association ends of OperationProfile:: RaiseLowerCommand with other classes .....	213
Table 372 – Attributes of OperationProfile::SetPoint .....	213
Table 373 – Association ends of OperationProfile::SetPoint with other classes .....	214
Table 374 – Attributes of OperationProfile::StringMeasurement .....	214
Table 375 – Association ends of OperationProfile:: StringMeasurement with other classes .....	214
Table 376 – Attributes of OperationProfile::StringMeasurementValue .....	215
Table 377 – Association ends of OperationProfile:: StringMeasurementValue with other classes .....	215
Table 378 – Attributes of OperationProfile::Terminal .....	215
Table 379 – Attributes of OperationProfile::ValueAliasSet .....	216
Table 380 – Attributes of OperationProfile::ValueToAlias .....	216
Table 381 – Association ends of OperationProfile::ValueToAlias with other classes .....	216
Table 382 – Literals of OperationProfile::PhaseCode .....	217
Table 383 – Literals of OperationProfile::Source .....	217
Table 384 – Literals of OperationProfile::UnitMultiplier .....	218
Table 385 – Literals of OperationProfile::UnitSymbol .....	219
Table 386 – Literals of OperationProfile::Validity .....	224

Table 387 – Attributes of OperationProfile::PerCent.....	224
Table 388 – Attributes of ShortCircuitProfile::ACDCTerminal .....	227
Table 389 – Attributes of ShortCircuitProfile::ACLineSegment .....	228
Table 390 – Attributes of ShortCircuitProfile::AsynchronousMachine.....	228
Table 391 – Attributes of ShortCircuitProfile::BusbarSection .....	229
Table 392 – Attributes of ShortCircuitProfile::ConductingEquipment .....	229
Table 393 – Attributes of ShortCircuitProfile::Conductor .....	229
Table 394 – Attributes of ShortCircuitProfile::Connector .....	230
Table 395 – Attributes of ShortCircuitProfile::EarthFaultCompensator.....	230
Table 396 – Attributes of ShortCircuitProfile::EnergyConnection .....	230
Table 397 – Attributes of ShortCircuitProfile::EnergySource.....	231
Table 398 – Attributes of ShortCircuitProfile::Equipment.....	231
Table 399 – Attributes of ShortCircuitProfile::EquivalentBranch .....	231
Table 400 – Attributes of ShortCircuitProfile::EquivalentEquipment.....	233
Table 401 – Attributes of ShortCircuitProfile::EquivalentInjection .....	233
Table 402 – Attributes of ShortCircuitProfile::ExternalNetworkInjection.....	234
Table 403 – Attributes of ShortCircuitProfile::GroundingImpedance .....	235
Table 404 – Attributes of ShortCircuitProfile::IdentifiedObject .....	235
Table 405 – Attributes of ShortCircuitProfile::LinearShuntCompensator .....	235
Table 406 – Attributes of ShortCircuitProfile::MutualCoupling .....	236
Table 407 – Association ends of ShortCircuitProfile::MutualCoupling with other classes .....	236
Table 408 – Attributes of ShortCircuitProfile::NonlinearShuntCompensatorPoint.....	237
Table 409 – Attributes of ShortCircuitProfile::PetersenCoil .....	237
Table 410 – Attributes of ShortCircuitProfile::PowerSystemResource .....	238
Table 411 – Attributes of ShortCircuitProfile::PowerTransformer .....	238
Table 412 – Attributes of ShortCircuitProfile::PowerTransformerEnd.....	240
Table 413 – Attributes of ShortCircuitProfile::RegulatingCondEq .....	240
Table 414 – Attributes of ShortCircuitProfile::RotatingMachine .....	240
Table 415 – Attributes of ShortCircuitProfile::SeriesCompensator .....	241
Table 416 – Attributes of ShortCircuitProfile::ShuntCompensator .....	241
Table 417 – Attributes of ShortCircuitProfile::SynchronousMachine .....	242
Table 418 – Attributes of ShortCircuitProfile::Terminal .....	243
Table 419 – Attributes of ShortCircuitProfile::TransformerEnd .....	243
Table 420 – Literals of ShortCircuitProfile::PetersenCoilModeKind .....	243
Table 421 – Literals of ShortCircuitProfile::ShortCircuitRotorKind .....	244
Table 422 – Literals of ShortCircuitProfile::UnitMultiplier.....	244
Table 423 – Literals of ShortCircuitProfile::UnitSymbol .....	245
Table 424 – Attributes of ShortCircuitProfile::ActivePower .....	250
Table 425 – Attributes of ShortCircuitProfile::AngleDegrees.....	250
Table 426 – Attributes of ShortCircuitProfile::Conductance .....	251
Table 427 – Attributes of ShortCircuitProfile::CurrentFlow.....	251
Table 428 – Attributes of ShortCircuitProfile::Length.....	251
Table 429 – Attributes of ShortCircuitProfile::PerCent.....	252

Table 430 – Attributes of ShortCircuitProfile::PU.....	252
Table 431 – Attributes of ShortCircuitProfile::Reactance.....	252
Table 432 – Attributes of ShortCircuitProfile::Resistance.....	252
Table 433 – Attributes of ShortCircuitProfile::Susceptance.....	253
Table 434 – Attributes of ShortCircuitProfile::Temperature.....	253
Table 435 – Attributes of ShortCircuitProfile::Voltage.....	253
Table 436 – Valid attribute values.....	255

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ENERGY MANAGEMENT SYSTEM APPLICATION  
PROGRAM INTERFACE (EMS-API) –****Part 452: CIM static transmission network model profiles**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61970 has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

This fourth edition cancels and replaces the third edition published in 2017. This edition constitutes a technical revision. It is based on the IEC 61970 UML version 'IEC61970CIM17v40', dated 2020-08-24.

This edition includes the following significant technical changes with respect to the previous edition:

- a) The classes `PowerElectronicsConnection`, `PowerElectronicsUnit` and `PowerElectronicsWindUnit` are added to the Core Equipment profile.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
57/2400/FDIS	57/2407/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/standardsdev/publications](http://www.iec.ch/standardsdev/publications).

A list of all parts in the IEC 61970 series, published under the general title *Energy management system application program interface (EMS-API)*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION

This part of IEC 61970 is part of the IEC 61970 series that define an application program interface (API) for an energy management system (EMS).

The IEC 61970-300 series specifies a Common Information Model (CIM). The CIM is an abstract model that represents all of the major objects in an electric utility enterprise typically needed to model the operational aspects of a utility. It provides the semantics for the IEC 61970 APIs specified in the IEC 61970-400 series of Component Interface Standards (CIS). The IEC 61970-300 series includes IEC 61970-301, *Common Information Model (CIM) base* and draft standard IEC 61970-302, *Common Information Model (CIM) for Dynamics*.

This document is one of the IEC 61970-400 series of Component Interface Standards that specify the functional requirements for interfaces that a component (or application) shall implement to exchange information with other components (or applications) and/or to access publicly available data in a standard way. The component interfaces describe the specific message contents and services that can be used by applications for this purpose. The implementation of these messages in a particular technology is described in the IEC 61970-500 series.

This document specifies the specific profiles (or subsets) of the CIM for exchange of static power system data between utilities, security coordinators and other entities participating in an interconnected power system, such that all parties have access to the modelling of their neighbour's systems that is necessary to execute state estimation or power flow applications. Currently three profiles, the CoreEquipment Profile, the Operation Profile and the Short Circuit Profile, have been defined. A companion standard, IEC 61970-552, defines the CIM XML Model Exchange Format based on the Resource Description Framework (RDF) Schema specification language. IEC 61970-552 is the common industry approach and is recommended to be used to transfer power system model data for the IEC 61970-452 profile.

# ENERGY MANAGEMENT SYSTEM APPLICATION PROGRAM INTERFACE (EMS-API) –

## Part 452: CIM static transmission network model profiles

### 1 Scope

This document is one of the IEC 61970-450 to 499 series that, taken as a whole, defines at an abstract level the content and exchange mechanisms used for data transmitted between control centres and/or control centre components, such as power systems applications.

The purpose of this document is to define the subset of classes, class attributes, and associations from the CIM necessary to execute state estimation and power flow applications. The North American Electric Reliability Council (NERC) Data Exchange Working Group (DEWG) Common Power System Modelling group (CPSM) produced the original data requirements, which are shown in Annex F. These requirements are based on prior industry practices for exchanging power system model data for use primarily in planning studies. However, the list of required data has been extended starting with the first edition of this standard to facilitate a model exchange that includes parameters common to breaker-oriented applications. Where necessary this document establishes conventions, shown in Clause 6, with which an XML data file must comply in order to be considered valid for exchange of models.

The data exchange use cases which this standard is meant to support are described in Annex A. The idea of a modelling authority as the source responsible for the modeling of a given region is described in Annex B. The concept of a boundary between regions is explained in Annex C. Annex D explains the processing of multiple profiles such as the three profiles described in this standard. The use of different curve styles to define ReactiveCapabilityCurve-s is explained in Annex E.

This document is intended for two distinct audiences, data producers and data recipients, and may be read from two perspectives.

From the standpoint of model export software used by a data producer, this document describes a minimum subset of CIM classes, attributes, and associations which must be present in an XML formatted data file for model exchange. This document does not dictate how the network is modelled, however. It only dictates what classes, attributes, and associations are to be used to describe the source model as it exists.

### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE For general glossary definitions, see IEC 60059, International Electrotechnical Vocabulary.

IEC 61970-301:2020, *Energy management system application program interface (EMS-API) – Part 301: Common information model (CIM) base*