

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

Industriell processtyrning – Nät med hög driftsäkerhet – Del 3: Parallel Redundancy Protocol (PRP) och High-availability Seamless Redundancy (HSR)

*Industrial communication networks –
High availability automation networks –
Part 3: Parallel Redundancy Protocol (PRP) and High-availability Seamless Redundancy (HSR)*

Som svensk standard gäller europastandarden EN IEC 62439-3:2022. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 62439-3:2022.

Nationellt förord

Europastandarden EN IEC 62439-3:2022

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 62439-3, Fourth edition, 2021 - Industrial communication networks - High availability automation networks - Part 3: Parallel Redundancy Protocol (PRP) and High-availability Seamless Redundancy (HSR)**

utarbetad inom International Electrotechnical Commission, IEC.

Standarden ska användas tillsammans med SS-EN 62439-1.

Tidigare fastställd svensk standard SS-EN IEC 62439-3, utgåva 3, 2018, gäller ej fr o m 2025-01-19.

ICS 25.040.40; 35.100.05

Denna standard är fastställd av SEK Svensk Elstandard, som också kan lämna upplysningar om **sakinnehållet** i standarden.
Postadress: Box 1284, 164 29 KISTA
Telefon: 08 - 444 14 00.
E-post: sek@elstandard.se. Internet: www.elstandard.se

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English Version

Industrial communication networks - High availability automation networks - Part 3: Parallel Redundancy Protocol (PRP) and High-availability Seamless Redundancy (HSR) (IEC 62439-3:2021)

Réseaux de communication industriels - Réseaux de haute disponibilité pour l'automatisation - Partie 3: Protocole de redondance en parallèle (PRP) et redondance transparente de haute disponibilité (HSR) (IEC 62439-3:2021)

Industrielle Kommunikationsnetze - Hochverfügbare Automatisierungsnetze - Teil 3: Parallelredundanz-Protokoll (PRP) und nahtloser Hochverfügbarkeits-Ring (HSR) (IEC 62439-3:2021)

This European Standard was approved by CENELEC on 2022-01-19. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 65C/1120/FDIS, future edition 4 of IEC 62439-3, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62439-3:2022.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2022-10-19
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2025-01-19

This document supersedes EN IEC 62439-3:2018 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 62439-3:2021 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61784-1	NOTE	Harmonized as EN IEC 61784-1
IEC 61784-2	NOTE	Harmonized as EN IEC 61784-2
IEC 61850 (series)	NOTE	Harmonized as EN 61850 (series)
IEC 61850-8-1	NOTE	Harmonized as EN 61850-8-1
IEC 61850-9-2	NOTE	Harmonized as EN 61850-9-2
IEC 62439-2	NOTE	Harmonized as EN 62439-2
IEC 62439-3:2016	NOTE	Harmonized as EN IEC 62439-3:2018 (not modified)
IEC 62439-4	NOTE	Harmonized as EN 62439-4
IEC 62439-6	NOTE	Harmonized as EN 62439-6
IEC 62439-7	NOTE	Harmonized as EN 62439-7

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-192	-	International Electrotechnical Vocabulary (IEV) - Part 192: Dependability	-	-
IEC 61588	2021	Precision Clock Synchronization Protocol for Networked Measurement and Control Systems	-	-
IEC/TR 61850-90-4	2020	Communication networks and systems for power utility automation - Part 90-4: Network engineering guidelines	-	-
IEC 62439-1	-	Industrial communication networks - High availability automation networks - Part 1: General concepts and calculation methods	EN 62439-1	-
ISO/IEC/IEEE 8802-3	2021	Telecommunications and exchange between information technology systems - Requirements for local and metropolitan area networks - Part 3: Standard for Ethernet	-	-
IEC/IEEE 61850-9-3	2016	Communication networks and systems for power utility automation - Part 9-3: Precision time protocol profile for power utility automation	-	-
IEEE 802.1Q	2018	IEEE Standard for Local and metropolitan area networks – Bridges and Bridged Network	-	-
IETF RFC 768	-	User Datagram Protocol (UDP) [online]. August 1980.	-	-
IETF RFC 791	-	Internet Protocol (IP) [online]. September 1981.	-	-
IETF RFC 792	-	Internet Control Message Protocol [online]. September 1981.	-	-

EN IEC 62439-3:2022 (E)

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IETF RFC 793	-	Transmission Control Protocol [online]. September 1981.	-	-
IETF RFC 826	-	Ethernet Address Resolution Protocol [online]. November 1982.	-	-
IETF RFC 2578	-	Structure of Management Information Version 2 (SMIv2) [online]. April 1999.	-	-
IETF RFC 3418	-	Structure of Management Information Version 2 (SMIv2) [online]. December 2002.	-	-

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial communication networks – High availability automation networks –
Part 3: Parallel Redundancy Protocol (PRP) and High-availability Seamless
Redundancy (HSR)**

**Réseaux de communication industriels – Réseaux de haute disponibilité pour
l'automatisation –
Partie 3: Protocole de redondance en parallèle (PRP) et redondance
transparente de haute disponibilité (HSR)**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 25.040.40; 35.100.05

ISBN 978-2-8322-1059-5

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	10
INTRODUCTION.....	13
0.1 General.....	13
0.2 Patent declaration.....	13
1 Scope.....	15
1.1 General.....	15
1.2 Code component distribution.....	15
2 Normative references	16
3 Terms, definitions, abbreviated terms, and conventions.....	17
3.1 Terms and definitions.....	17
3.2 Abbreviated terms.....	19
3.3 Conventions.....	20
4 Parallel Redundancy Protocol (PRP)	20
4.1 PRP principle of operation	20
4.1.1 PRP network topology	20
4.1.2 PRP LANs with linear or bus topology.....	22
4.1.3 PRP LANs with ring topology	22
4.1.4 DANP node structure	23
4.1.5 PRP attachment of singly attached nodes.....	24
4.1.6 Compatibility between singly and doubly attached nodes.....	25
4.1.7 Network management	25
4.1.8 Implication on application	25
4.1.9 Transition to a single-thread network.....	26
4.1.10 Duplicate handling	26
4.1.11 Network supervision	31
4.1.12 Redundancy management interface.....	31
4.2 PRP protocol specifications	32
4.2.1 Installation, configuration and repair guidelines	32
4.2.2 Unicast MAC addresses.....	32
4.2.3 Multicast MAC addresses	32
4.2.4 IP addresses	33
4.2.5 Node specifications	33
4.2.6 Duplicate Accept mode (testing only).....	33
4.2.7 Duplicate Discard mode.....	34
4.3 PRP_Supervision frame	38
4.3.1 PRP_Supervision frame format.....	38
4.3.2 PRP_Supervision frame contents.....	40
4.3.3 PRP_Supervision frame for RedBox	41
4.3.4 Bridging node (deprecated)	41
4.4 Constants	42
4.5 PRP layer management entity (LME)	42
5 High-availability Seamless Redundancy (HSR)	42
5.1 HSR objectives	42
5.2 HSR principle of operation	43
5.2.1 Basic operation with a ring topology	43
5.2.2 HSR connection to other networks.....	45

5.2.3	DANH node structure	57
5.2.4	RedBox structure	58
5.3	HSR protocol specifications	59
5.3.1	HSR layout	59
5.3.2	HSR operation	59
5.3.3	DANH sending from its link layer interface	61
5.3.4	DANH receiving from an HSR port	62
5.3.5	DANH forwarding rules	62
5.3.6	HSR Class of Service	64
5.3.7	HSR clock synchronization	64
5.3.8	Deterministic transmission delay and jitter	64
5.4	HSR RedBox specifications	64
5.4.1	RedBox properties	64
5.4.2	RedBox receiving from port C (interlink)	65
5.4.3	RedBox receiving from port A or port B (HSR ring)	67
5.4.4	RedBox receiving from its link layer interface (local)	69
5.4.5	Redbox ProxyNodeTable handling	69
5.4.6	RedBox CoS	69
5.4.7	RedBox clock synchronization	69
5.4.8	RedBox medium access	69
5.5	QuadBox specification	70
5.6	Duplicate Discard method	70
5.7	Frame format for HSR	70
5.7.1	Frame format for all frames	70
5.7.2	HSR_Supervision frame	71
5.8	HSR constants	74
5.9	HSR layer management entity (LME)	75
6	Protocol Implementation Conformance Statement (PICS)	77
7	PRP/HSR Management Information Base (MIB)	79
Annex A (normative)	Synchronization of clocks over redundant paths	94
A.1	Overview	94
A.2	PRP mapping to PTP	94
A.2.1	Particular operation of PRP for PTP messages	94
A.2.2	Scenarios and device roles	96
A.2.3	Attachment to redundant LANs by a BC	98
A.2.4	Attachment to redundant LANs by doubly attached clocks	98
A.2.5	Specifications of DANP as DAC	102
A.2.6	PRP-SAN RedBoxes for PTP	103
A.3	HSR Mapping to PTP	123
A.3.1	HSR messages and other messages	123
A.3.2	HSR operation with PTP messages	123
A.3.3	HSR with redundant master clocks	125
A.3.4	HSR timing diagram for PTP messages	126
A.3.5	HSR nodes specifications	127
A.4	HSR RedBoxes for PTP	129
A.4.1	HSR-SAN RedBox	129
A.4.2	HSR-PRP RedBox connection by BC	130
A.4.3	HSR-PRP RedBox connection by TC	132
A.4.4	HSR to HSR connection by QuadBoxes	134

A.5	Doubly attached clock specification.....	135
A.5.1	State machine	135
A.5.2	Supervision of the port.....	138
A.5.3	BMCA for paired ports	139
A.5.4	Selection of the port state.....	140
A.6	PTP datasets for high availability	140
A.6.1	General	140
A.6.2	Data types	140
A.6.3	Datasets for OC or BC.....	141
A.6.4	Datasets for TCs.....	149
Annex B (normative) PTP profile for Power Utility Automation (PUP) – Redundant clock attachment.....		150
B.1	Application domain.....	150
B.2	PTP profile specification	150
B.3	Specifications	150
B.4	Redundant clock attachment	150
Annex C (normative) PTP industry profiles for high-availability automation networks		151
C.1	Application domain.....	151
C.2	PTP profile specification	151
C.3	Clock types	152
C.4	Protocol specification common.....	152
C.4.1	Base protocol	152
C.4.2	Version control	152
C.4.3	Time scale.....	153
C.4.4	BMCA.....	153
C.4.5	Time correction mechanism	153
C.4.6	Management.....	153
C.4.7	1 PPS support	153
C.4.8	Leap second transition.....	153
C.4.9	Use of port number	153
C.4.10	Time distribution security	154
C.5	Protocol specification for L3E2E industry profile	154
C.5.1	Base protocol	154
C.5.2	Multicast address.....	154
C.5.3	Delay calculation mechanism.....	154
C.5.4	Sync message padding.....	154
C.6	Protocol specification for L2P2P industry profile	155
C.6.1	Base protocol	155
C.6.2	Delay measurement mechanism	155
C.6.3	Consideration of media converters.....	155
C.7	Common timing requirements for L2P2P and L3E2E	155
C.7.1	Measurement conditions	155
C.7.2	Network time inaccuracy.....	155
C.7.3	Response to time step changes	156
C.7.4	Requirements for GCs	156
C.7.5	Requirements for TCs.....	158
C.7.6	Requirements for BCs.....	158
C.8	Requirements for media converters.....	161
C.9	Requirements for links	161

C.10	Network engineering	161
C.11	Default settings	162
C.12	Handling of doubly attached clocks	163
C.13	Protocol Implementation Conformance Statement (PICS) for PTP	164
C.13.1	PICS conventions	164
C.13.2	PICS for PTP	164
C.14	Recommendations for time representation	166
C.14.1	Usage of flags in TimePropertyDS	166
C.14.2	UTC leap second transition	167
C.14.3	ALTERNATE_TIME_OFFSET_INDICATOR_TLV	168
Annex D	(informative) Precision Time Protocol tutorial for the PTP Industrial profile	172
D.1	Objective	172
D.2	Precision and accuracy	172
D.3	PTP clock types	173
D.4	PTP main options	175
D.5	Layer 2 and layer 3 communication	176
D.6	1-step and 2-step correction	176
D.6.1	Time correction in TCs	176
D.6.2	2-step to 1-step translation	177
D.7	End-to-End link delay measurement	179
D.7.1	General method	179
D.7.2	End-to-end link delay measurement with 1-step clock correction	179
D.7.3	End-to-end link delay measurement with 2-step clock correction	180
D.7.4	End-to-end link delay calculation by Delay_Req – Delay_Resp	181
D.7.5	Consideration of media converters in end-to-end delay calculation	181
D.8	Peer-to-peer link delay calculation	182
D.8.1	Peer-to-peer link delay calculation with 1-step correction	182
D.8.2	Peer-to-peer link delay calculation with 2-step correction	183
D.8.3	Consideration of media converters in peer delay calculation	184
Annex E	(normative) Management Information base for singly and doubly attached clocks	186
Annex F	(normative) Conformance testing for PRP and HSR and handling of redundancy in PIP and PUP	214
F.1	General	214
F.2	PRP conformance test	214
F.2.1	PRP test set-up	214
F.2.2	PRP test components	215
F.2.3	Test for documentation and labelling	215
F.2.4	Test for (unicast) IP addresses	216
F.2.5	Test for configuration	216
F.2.6	Test of DANP	217
F.2.7	Test of PRP Redboxes	221
F.2.8	Test for Management	223
F.2.9	Test of DANP or RedBox for processing of PTP frames	225
F.3	HSR conformance test	230
F.3.1	HSR test set-up	230
F.3.2	HSR test components	231
F.3.3	Test for HSR documentation and labelling	231
F.3.4	Test of DANH or RedBox for IP addresses	232

F.3.5	Test of DANH for configuration	232
F.3.6	Test of DANH	233
F.3.7	Test of HSR RedBoxes	237
F.3.8	Test of DANH or RedBox for receive/transmit counters	239
F.3.9	Test of DANH or RedBox for processing of PTP frames in L2P2P	240
Bibliography.....		244
Figure 1	– PRP example of general duplicated network	21
Figure 2	– PRP example of duplicated network in bus topology.....	22
Figure 3	– PRP example of redundant ring with SANs and DANPs.....	23
Figure 4	– PRP with two DANPs communicating	24
Figure 5	– PRP RedBox, transition from single to double LAN.....	26
Figure 6	– PRP frame closed by an RCT	27
Figure 7	– PRP VLAN-tagged frame closed by an RCT	28
Figure 8	– PRP padded frame closed by an RCT	28
Figure 9	– Duplicate Discard algorithm boundaries	30
Figure 10	– HSR example of ring traffic for multicast frames	43
Figure 11	– HSR example of ring traffic for unicast frames.....	44
Figure 12	– HSR example of coupling two redundant PRP LANs to a ring (unicast).....	47
Figure 13	– HSR example of coupling from a ring node to PRP LANs (multicast)	49
Figure 14	– HSR example of coupling from a ring to two PRP LANs (multicast)	50
Figure 15	– HSR example of coupling three rings to one PRP LAN	51
Figure 16	– HSR example of peer coupling of two rings	52
Figure 17	– HSR example of connected rings	53
Figure 18	– HSR example of meshed topology.....	54
Figure 19	– HSR example of topology using two independent networks	55
Figure 20	– HSR example of coupling an RSTP LAN to HSR by two bridges	56
Figure 21	– HSR structure of a DANH.....	57
Figure 22	– HSR structure of a RedBox	58
Figure 23	– HSR frame without a VLAN tag	70
Figure 24	– HSR frame with VLAN tag	71
Figure 25	– HSR node with management counters.....	76
Figure 26	– HSR RedBox with management counters	77
Figure A.1	– Connection of a DAC master to a DAC slave over PRP.....	95
Figure A.2	– Elements of PRP time distribution networks	97
Figure A.3	– Doubly Attached Clock as BC (OC3A is best master).....	98
Figure A.4	– Doubly Attached Clocks OC1 and OC2	100
Figure A.5	– Doubly attached clocks when OC1 has the same identity on both LANs	102
Figure A.6	– PRP RedBox as TWBCs	104
Figure A.7	– RedBox DABC clock model.....	105
Figure A.8	– PRP RedBoxes as DABC with E2E – message flow	107
Figure A.9	– PRP RedBoxes as DABC with E2E – timing	108
Figure A.10	– PRP RedBoxes as DABC with P2P on PRP – message flow	109
Figure A.11	– PRP RedBoxes as DABC with P2P on PRP – timing	110

Figure A.12 – PRP-SAN RedBox as SLTC with E2E – message flow	112
Figure A.13 – PRP RedBox as SLTC with E2E – timing	114
Figure A.14 – PRP RedBox as SLTC with P2P – message flow.....	115
Figure A.15 – PRP RedBox as SLTC with P2P – timing diagram.....	116
Figure A.16 – PRP RedBox as DATC with E2E – message flow	119
Figure A.17 – PRP RedBox as DATC with E2E – timing.....	120
Figure A.18 – PRP RedBox as DATC with P2P – message flow	121
Figure A.19 – PRP RedBox as DATC with P2P – timing.....	122
Figure A.20 – HSR with two GCs (GC1 is grandmaster, GC2 is back-up).....	125
Figure A.21 – PTP messages sent and received by an HSR node (1-step).....	126
Figure A.22 – PTP messages sent and received by an HSR node (2-step).....	127
Figure A.23 – Attachment of a GC to an HSR ring through a RedBox as TC and BC.....	129
Figure A.24 – PRP to HSR coupling by BCs.....	131
Figure A.25 – PRP to HSR coupling by DATC and SLTC	133
Figure A.26 – HSR coupling to two PRP and one HSR network.....	134
Figure A.27 – Port states including transitions for redundant operation	136
Figure A.28 – BMCA for redundant masters	139
Figure C.1 – Response to a time step	156
Figure C.2 – States of a BC	159
Figure D.1 – Time error as a probability distribution function.....	172
Figure D.2 – PTP principle with GC, TC and OC	174
Figure D.3 – PTP elements	175
Figure D.4 – Delays and time-stamping logic in TCs	176
Figure D.5 – 1-step and 2-step correction of a Sync message (peer-to-peer)	177
Figure D.6 – Translation from 2-step to 1-step correction in TCs.....	178
Figure D.7 – Translation from 2-step to 1-step correction – message view	179
Figure D.8 – End-to-end link delay measurement with 1-step correction	180
Figure D.9 – End-to-end delay measurement with 2-step correction.....	181
Figure D.10 – Peer-to-peer link delay measurement with 1-step correction	182
Figure D.11 – Peer-to-peer link delay measurement with 2-step correction	183
Figure D.12 – Peer delay measurement and Sync message delay with media converter	185
Figure F.1 – Test set-up for PRP	215
Figure F.2 – Test set-up for PRP and PTP with L2P2P	225
Figure F.3 – Test set-up for HSR (without PTP)	231
Figure F.4 – Test set-up for HSR with L2P2P.....	240
Table 1 – Duplicate discard cases	30
Table 2 – Monitoring data set.....	34
Table 3 – NodesTable attributes	35
Table 4 – PRP_Supervision frame with no VLAN tag.....	39
Table 5 – PRP_Supervision frame with (optional) VLAN tag.....	40
Table 6 – PRP_Supervision frame contents	41
Table 7 – PRP_Supervision TLV for Redbox	41

Table 8 – PRP constants	42
Table 9 – HSR_Supervision frame with no VLAN tag	72
Table 10 – HSR_Supervision frame with optional VLAN tag	73
Table 11 – HSR Constants.....	75
Table 12 – PICS	78
Table A.1 – States	137
Table A.2 – Transitions	138
Table A.3 – Variables	138
Table C.1 – ClockClass.....	157
Table C.2 – PTP attributes.....	163
Table C.3 – PICS for clocks	164
Table C.4 – Transitions with an inserted leap second (UTC binary and C37.118).....	168
Table C.5 – Transitions with a removed leap second (UTC binary and C37.118).....	168
Table C.6 – ATOI transition to Pacific Summer Time (spring).....	170
Table C.7 – ATOI transitions to Pacific Standard Time (autumn)	170
Table C.8 – Transitions with an inserted leap second in Pacific Standard Time.....	171
Table C.9 – Transitions with a removed leap second in Pacific Standard Time.....	171
Table F.1 – Test for PRP documentation and labelling	216
Table F.2 – Test for (unicast) IP addresses.....	216
Table F.3 – Test for PRP configuration (Table 8)	217
Table F.4 – Test for PRP supervision frames (Table 4 and Table 5).....	217
Table F.5 – Test for PRP tagging (4.1.10.2, 4.2.7.3)	219
Table F.6 – Test of a DANP without a NodesTable.....	220
Table F.7 – Test of a DANP with a NodesTable	220
Table F.8 – Test for discard over different ports.....	221
Table F.9 – Test for PRP supervision frames (Table 4 and Table 5).....	222
Table F.10 – Test of RedBox for ProxyNodeTable.....	222
Table F.11 – Test of RedBox for forwarding	223
Table F.12 – Test for DANP receive/transmit counters	224
Table F.13 – Test procedure for processing of PTP frames	227
Table F.14 – Test for processing of PTP frames	228
Table F.15 – Test for processing of PTP frames	229
Table F.16 – Test procedure for processing of PTP frames.....	230
Table F.17 – Test for HSR documentation.....	232
Table F.18 – Test for IP addresses	232
Table F.19 – Test procedure for HSR configuration (Table 11).....	233
Table F.20 – Test for HSR supervision frames (Table 9 and Table 10).....	234
Table F.21 – Test for HSR tagging	235
Table F.22 – Test of DANH for HSR Mode H multicast.....	236
Table F.23 – Test of DANH for HSR Mode H unicast.....	236
Table F.24 – Test of DANH for other modes than Mode H.....	237
Table F.25 – Test of RedBox for HSR supervision frames (Table 9 and Table 10).....	237
Table F.26 – Test of RedBox for ProxyNodeTable.....	238

Table F.27 – Test of RedBox for Mode H Unicast.....	238
Table F.28 – Test of DANH or RedBox for receive/transmit counters	239
Table F.29 – Test for processing of PTP frames (slave).....	241
Table F.30 – Test for processing of PTP frames (master)	242

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
HIGH AVAILABILITY AUTOMATION NETWORKS –****Part 3: Parallel Redundancy Protocol (PRP) and
High-availability Seamless Redundancy (HSR)**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62439-3 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2016. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) References to Precision Time Protocol (PTP) IEC 61588:2021 replace references to IEC 61588:2009, unless the previous version is explicitly referenced (Clause 2);
- b) References to IEC 61850-90-4:2020 replace references to IEC 61850-90-4:2013 with corresponding changes in the Logical Nodes (Clause 2);

- c) Terms and abbreviations are aligned with the next edition of IEC/IEEE 61850-9-3 (currently under preparation) (Clause 3);
- d) RSTP support in HSR is specified (5.2.2.10);
- e) RedBoxes and QuadBoxes specifications are extended to TCs (5.5);
- f) Network management (MIB) for PRP and HSR is available as a "Code Component", machine-readable separate document (Clause 7);
- g) PTP over PRP specifies a unified operation of DATC and SLTC RedBoxes (A.2.6.4);
- h) PTP over HSR specifies the operation of RedBoxes for TCs (A.4.3);
- i) PTP datasets are aligned with IEC 61588:2021 (Clause A.6);
- j) PTP industry profile is extended:
 - Sync messages padding to support media converters (C.5.4);
 - ClockClass definition aligned with IEC 61588:2021 option a) (C.7.4.3);
 - TC operation over different domains (C.7.5.3);
 - BCs behaviour in holdover and recovery (C.7.6.2);
 - PICS entries renamed and extended (C.13.2);
 - Flags semantics in TimePropertyDS actualized (C.14.1);
 - UTC events handling during a leap second specified (C.14.2);
 - UTC leap second time representation aligned with IEEE C37.118.2 (C.14.2.2);
 - Daylight saving time and leap second events recommended in the ALTERNATE_TIME_OFFSET_INDICATOR TLV (C.14.3.2);
- k) Tutorial extended to explain the media converter issue (D.8.3);
- l) PTP network management MIB (Annex E) is available as a "Code Component", machine-readable separate document and considers IEC 61588:2021 objects;
- m) Conformance testing for PRP, HSR and the doubly attached PTP clocks (Annex F) has been added.
- n) Interoperability issues with previous editions of this International Standard are mentioned in a note at the end of the corresponding clause.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
65C/1120/FDIS	65C/1139/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

This International Standard is to be read in conjunction with IEC 62439-1.

A list of all parts in the IEC 62439 series, published under the general title *Industrial communication networks – High availability automation networks*, can be found on the IEC website.

This IEC standard includes Code Components, i.e., components that are intended to be directly processed by a computer. Such content is any text found between the markers <CODE BEGINS> and <CODE ENDS>, or otherwise is clearly labeled in this standard as a Code Component.

The purchase of this IEC standard carries a copyright license for the purchaser to sell software containing Code Components from this standard directly to end users and to end users via distributors, subject to IEC software licensing conditions, which can be found at: <http://www.iec.ch/CCv1>.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

INTRODUCTION

0.1 General

This document belongs to the IEC 62439 series “*Industrial communication networks – High availability automation networks*”. It was developed jointly with IEC TC57 WG10 as the redundancy method for demanding substation automation networks operating on layer 2 networks, in accordance with IEC 61850-8-1 and IEC 61850-9-2, and extended to encompass the needs of CPF 2 of IEC 61784-1 and IEC 61784-2 for layer 3 networks.

This document specifies two related redundancy protocols that, in the event of failure of any network element, provide seamless switchover with zero recovery time:

- PRP (Parallel Redundancy Protocol), which allows attaching nodes to two separate networks while allowing attachment of nodes to one network only; and
- HSR (High-availability Seamless Redundancy), which allows threading two-port nodes in a ring or multi-port nodes in a meshed network.

This document applies the seamless redundancy principle to clocks compliant with the Precision Time Protocol (PTP).

This document specifies a PTP Industry profile (PIP) that offers the performance needed to achieve sub-microsecond time accuracy. This profile can be applied to any industrial communication network based on Ethernet. Two variants of PIP are specified:

- L3E2E (Layer 3, end-to-end) for clocks operating on layer 3 networks with end-to-end path delay measurement such as CP 2/2 of IEC 61784-1 and IEC 61784-2; and
- L2P2P (Layer 2, peer-to-peer) for clocks operating on layer 2 with peer-to-peer link delay measurement (P2P).

Based on L2P2P, IEC TC57 WG10 and the IEEE PSRC jointly specified the Power Utility Profile (PUP) and copied it to IEC/IEEE 61850-9-3. IEC and IEEE agreed to keep the contents of this document and IEC/IEEE 61850-9-3 aligned, under the umbrella of the Dual Logo Maintenance Team (DLMT) hosted by IEEE PSCC P20.

The specifications of PRP and HSR present no backward compatibility issues as the changes are compatible extensions of the protocol. The minor version of these protocols is kept at value “1”.

The specifications of the clock profile PIP are based on IEC 61588:2021, which presents some differences compared with IEC 61588:2009. The minorVersionPTP has been increased to 1.

This document includes guidelines for conformance testing, applicable to PRP, HSR and to the PIP and PUP clock synchronization profiles.

0.2 Patent declaration

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this standard may involve the use of a patent. IEC takes no position concerning the evidence, validity, and scope of this patent right.

The holder of this patent right has assured IEC that s/he is willing to negotiate licences under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of this patent right is registered with IEC. Information may be obtained from the patent database available at <http://patents.iec.ch>.

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights other than those in the patent database. IEC shall not be held responsible for identifying any or all such patent rights.

INDUSTRIAL COMMUNICATION NETWORKS – HIGH AVAILABILITY AUTOMATION NETWORKS –

Part 3: Parallel Redundancy Protocol (PRP) and High-availability Seamless Redundancy (HSR)

1 Scope

1.1 General

The IEC 62439 series is applicable to high-availability automation networks based on the Ethernet technology.

This document:

- specifies PRP and HSR as two related redundancy protocols designed to provide seamless recovery in case of single failure of an inter-bridge link or bridge in the network, which are based on the same scheme: parallel transmission of duplicated information;
- specifies the operation of the precision time protocol (PTP) in networks that implement the two redundancy protocols (Annex A);
- specifies PTP profiles with performance suitable for power utility automation (Annex B) and industrial automation (Annex C);
- includes for better understanding a tutorial (Annex D) on the PTP features effectively used in high-availability automation networks;
- includes a management information base for PTP (Annex E);
- defines a conformance test suite for the above protocols (Annex F).

1.2 Code component distribution

This document is associated with Code components. Each Code Component is a ZIP package containing at least the electronic representation of the Code Component itself and a file describing the content of the package (IECManifest.xml).

The IECManifest contains different sections giving information on:

- the copyright notice;
- the identification of the code component;
- the publication related to the code component;
- the list of the electronic files which compose the code component;
- an optional list of history files to track changes during the evolution process of the code component.

The Code Components associated with this IEC standard are a set of SNMP MIBs. The Code Component IEC-62439-3-MIB.mib is a file containing the MIBs for PRP/HSR and PTP_SNMP. It is available in a full version, which contains the MIBs defined in this document with the documentation associated and access is restricted to purchaser of this document.

The Code Components are freely accessible on the IEC website for download at: https://www.iec.ch/sc65c/supportingdocuments/IEC_62439-3.MIB.{VersionStateInfo}.full.zip but the usage remains under the licensing conditions.

The life cycle of a code component is not restricted to the life cycle of the related publication. The publication life cycle goes through two stages, "Version" (corresponding to an edition) and "Revision" (corresponding to an amendment). Consequently, new release(s) of the Code Component(s) may be released, which supersede(s) the previous release, and will be distributed through the IEC web site at: <https://www.iec.ch/sc65c/supportingdocuments>.

The latest version/release of the document will be found by selecting the file IEC_62439-3.MIB.{VersionStateInfo}.full.zip for the code component with the highest value for VersionStateInfo.

In case of any differences between the downloadable code and the IEC pdf published content, the downloadable code(s) is(are) the valid one; it may be subject to updates. See history files.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-192, *International Electrotechnical Vocabulary – Part 192: Dependability*

IEC 61588:2021, *Precision Clock Synchronization Protocol for Networked Measurement and Control Systems*

IEC TR 61850-90-4:2020, *Communication networks and systems for power utility automation – Part 90-4: Network engineering guidelines*

IEC 62439-1, *Industrial communication networks – High availability automation networks – Part 1: General concepts and calculation method*

ISO/IEC/IEEE 8802-3:2021, *Standard for Ethernet*

IEC/IEEE 61850-9-3:2016, *Communication networks and systems for power utility automation – Part 9-3: Precision time protocol profile for power utility automation*

IEEE 802.1Q-2018, *IEEE Standard for Local and metropolitan area networks – Bridges and Bridged Network*

NOTE IETF references are dated with the original Request for Comment (RFC). Subsequent versions receive a new RFC number. Since IETF amends or extends documents and publishes errata on-line, the valid version can be found on the internet at <https://tools.ietf.org/>.

IETF RFC 768, *User Datagram Protocol (UDP)* [online]. August 1980 [viewed 2020-05-07]. Available at <https://tools.ietf.org/html/rfc768>

IETF RFC 791, *Internet Protocol (IP)* [online]. September 1981 [viewed 2020-05-07]. Available at <https://tools.ietf.org/html/rfc791>

IETF RFC 792, *Internet Control Message Protocol* [online]. September 1981 [viewed 2020-05-07]. Available at <https://tools.ietf.org/html/rfc792>

IETF RFC 793, *Transmission Control Protocol* [online]. September 1981 [viewed 2020-05-07]. Available at <https://tools.ietf.org/html/rfc793>

IETF RFC 826, *Ethernet Address Resolution Protocol* [online]. November 1982 [viewed 2020-05-07]. Available at <https://tools.ietf.org/html/rfc826>

IETF RFC 2578, *Structure of Management Information Version 2 (SMIv2)* [online]. April 1999 [viewed 2020-05-07]. Available at <https://tools.ietf.org/html/rfc2578>

IETF RFC 3418, *Structure of Management Information Version 2 (SMIv2)* [online]. December 2002 [viewed 2020-05-07]. Available at <https://tools.ietf.org/html/rfc3418>