

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

Kopplingsapparater för spänning över 1 kV – Del 203: Gasisolerade metallkapslade ställverk med märkspänning högre än 52 kV

High-voltage switchgear and controlgear –

Part 203: AC gas-insulated metal-enclosed switchgear for rated voltages above 52 kV

Som svensk standard gäller europastandarden EN IEC 62271-203:2022. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 62271-203:2022.

Nationellt förord

Europastandarden EN IEC 62271-203:2022

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 62271-203, Third edition, 2022 - High-voltage switchgear and controlgear - Part 203: AC gas-insulated metal-enclosed switchgear for rated voltages above 52 kV**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 62271-203, utgåva 2, 2012, gäller ej fr o m 2025-07-04.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English Version

High-voltage switchgear and controlgear - Part 203: AC gas-insulated metal-enclosed switchgear for rated voltages above
52 kV
(IEC 62271-203:2022)

Appareillage à haute tension - Partie 203: Appareillage sous enveloppe métallique à isolation gazeuse et à courant alternatif de tensions assignées supérieures à 52 kV
(IEC 62271-203:2022)

Hochspannungs-Schaltgeräte und -Schaltanlagen - Teil 203: Gasisolierte metallgekapelte Schaltanlagen für Bemessungsspannungen über 52 kV
(IEC 62271-203:2022)

This European Standard was approved by CENELEC on 2022-07-04. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 17C/835/FDIS, future edition 3 of IEC 62271-203, prepared by SC 17C "Assemblies" of IEC/TC 17 "High-voltage switchgear and controlgear" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62271-203:2022.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2023-04-04
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2025-07-04

This document supersedes EN 62271-203:2012 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 62271-203:2022 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60060-1 NOTE Harmonized as EN 60060-1

IEC 60071-1:2019 NOTE Harmonized as EN IEC 60071-1:2019 (not modified)

IEC 61462 NOTE Harmonized as EN 61462

IEC 61672-1 NOTE Harmonized as EN 61672-1

IEC 61672-2 NOTE Harmonized as EN 61672-2

IEC 62155 NOTE Harmonized as EN 62155

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60068-2-11	-	Environmental testing - Part 2-11: Tests - Test Ka: Salt mist	EN IEC 60068-2-11	-
IEC 60068-2-17	-	Basic environmental testing procedures - Part 2-17: Tests - Test Q: Sealing	EN 60068-2-17	-
IEC 60085	2007	Electrical insulation - Thermal evaluation and designation	EN 60085	2008
IEC 60099-4	2014	Surge arresters - Part 4: Metal-oxide surge arresters without gaps for a.c. systems	EN 60099-4	2014
IEC 60137	2017	Insulated bushings for alternating voltages above 1000 V	EN 60137	2017
IEC 60141-1	-	Tests on oil-filled and gas-pressure cables - and their accessories - Part 1: Oil-filled, paper or polypropylene paper laminate insulated, metal-sheathed cables and accessories for alternating voltages up to and including 500 kV		-
IEC 60270	-	High-voltage test techniques - Partial discharge measurements	EN 60270	-
IEC 60376	-	Specifications of technical grade sulphur hexafluoride (SF ₆) and complementary gases to be used in its mixtures for use in electrical equipment	EN IEC 60376	-
IEC 60480	-	Specifications for the re-use of sulphur hexafluoride (SF ₆) and its mixtures in electrical equipment	EN IEC 60480	-
IEC 60840	-	Power cables with extruded insulation and their accessories for rated voltages above 30 kV (U _m = 36 kV) up to 150 kV (U _m = 170 kV) - Test methods and requirements		-
IEC 61869-1	-	Instrument transformers - Part 1: General requirements	EN 61869-1	-

EN IEC 62271-203:2022 (E)

IEC 61869-2	-	Instrument transformers - Part 2: Additional requirements for current transformers	EN 61869-2	-
IEC 61869-3	-	Instrument transformers - Part 3: Additional requirements for inductive voltage transformers	EN 61869-3	-
IEC 62067	-	Power cables with extruded insulation and their accessories for rated voltages above 150 kV ($U_m = 170$ kV) up to 500 kV ($U_m = 550$ kV) - Test methods and requirements		-
IEC 62271-1	2017	High-voltage switchgear and controlgear - Part 1: Common specifications for alternating current switchgear and controlgear	EN 62271-1	2017
IEC 62271-4	-	High-voltage switchgear and controlgear - Part 4: Handling procedures for sulphur hexafluoride (SF ₆) and its mixtures	EN 62271-4	-
IEC 62271-100	2021	High-voltage switchgear and controlgear - Part 100: Alternating-current circuit-breakers	EN IEC 62271-100	2021
IEC 62271-102	2018	High-voltage switchgear and controlgear - Part 102: Alternating current disconnectors and earthing switches	EN IEC 62271-102	2018
IEC 62271-209	2019	High-voltage switchgear and controlgear - Part 209: Cable connections for gas-insulated metal-enclosed switchgear for rated voltages above 52 kV - Fluid-filled and extruded insulation cables - Fluid-filled and dry-type cable-terminations	EN IEC 62271-209	2019
IEC 62271-211	2014	High-voltage switchgear and controlgear - Part 211: Direct connection between power transformers and gas-insulated metal-enclosed switchgear for rated voltages above 52 kV	EN 62271-211	2014
ISO 22479	-	Corrosion of metals and alloys – Sulfur dioxide test in a humid atmosphere (fixed gas method)		-



IEC 62271-203

Edition 3.0 2022-05

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**High-voltage switchgear and controlgear –
Part 203: AC gas-insulated metal-enclosed switchgear for rated voltages above
52 kV**

**Appareillage à haute tension –
Partie 203: Appareillage sous enveloppe métallique à isolation gazeuse et à
courant alternatif de tensions assignées supérieures à 52 kV**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.130.10

ISBN 978-2-8322-3799-1

Warning! Make sure that you obtained this publication from an authorized distributor. Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.
--

CONTENTS

FOREWORD	4
1 Scope	6
2 Normative references	6
3 Terms and definitions	7
4 Normal and special service conditions	10
5 Ratings	11
6 Design and construction	14
7 Type tests	27
8 Routine tests	41
9 Guide to the selection of switchgear and controlgear (informative)	44
10 Information to be given with enquiries, tenders and orders (informative)	44
11 Transport, storage, installation, operating instructions and maintenance	44
12 Safety	50
13 Influence of the product on the environment	51
Annex A (normative) Test procedure for dielectric test on three-phase encapsulated GIS, range II (above 245 kV)	52
Annex B (normative) Methods for testing gas-insulated metal-enclosed switchgear under conditions of arcing due to an internal fault	53
Annex C (informative) Technical and practical considerations of site testing	56
Annex D (informative) Calculation of pressure rise due to an internal fault	61
Annex E (informative) Information to be given with enquiries, tenders and orders	62
Annex F (informative) Service continuity	68
Annex G (informative) List of notes concerning certain countries	76
Bibliography	77
Figure 1 – Pressure coordination	19
Figure 2 – Example of arrangement of enclosures and gas compartments	24
Figure F.1 – MRE1X (e.g. repair of disconnector to busbar)	71
Figure F.2 – MRE00 (e.g. during visual inspection)	71
Figure F.3 – MRE01 (e.g. repair of circuit-breaker)	72
Figure F.4 – MRE11 (e.g. repair of disconnector)	72
Figure F.5 – MRE11 (e.g. extension of switchgear with a feeder bay)	73
Figure F.6 – MRE13 (e.g. repair of disconnector)	73
Figure F.7 – MRE2X (e.g. on-site dielectric test of busbar section A)	74
Figure F.8 – MRE2X (e.g. on-site dielectric test of busbar section 1)	74
Figure F.9 – MRE00 (e.g. repair of circuit-breaker)	75
Table 1 – Reference table of service conditions relevant to GIS	11
Table 2 – Rated insulation levels for rated voltages for equipment of range I (245 kV and below)	12
Table 3 – Rated insulation levels for rated voltages for equipment of range II (above 245 kV)	13

Table 4 – Performance criteria	20
Table 5 – Type tests	28
Table 6 – Test voltage for measuring PD intensity	31
Table 7 – On-site test voltages	48
Table A.1 – Switching impulse test conditions above 245 kV.....	52
Table E.1 – Normal and special service conditions	62
Table E.2 – Ratings	63
Table E.3 – Design and construction.....	64
Table E.4 – Bus ducts	65
Table E.5 – Bushing.....	65
Table E.6 – Cable connection	66
Table E.7 – Transformer connection	66
Table E.8 – Current transformer.....	66
Table E.9 – Inductive voltage transformer	66
Table E.10 – Documentation for enquiries and tenders	67

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

**Part 203: AC gas-insulated metal-enclosed switchgear
for rated voltages above 52 kV**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62271-203 has been prepared by subcommittee 17C: Assemblies, of IEC technical committee 17: High-voltage switchgear and controlgear. It is an International Standard.

This third edition cancels and replaces the second edition published in 2011. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) the document has been aligned with IEC 62271-1:2017;
- b) beside SF₆ also alternative gases have been implemented where needed;
- c) the terms and definitions have been updated and terms not used have been removed;
- d) Subclause 6.16 “Gas and vacuum tightness” has been updated;

- e) Subclause 6.16.3 “Closed pressure systems”: Two classes of gas has been introduced:
- 1) $GWP \leq 1\,000$
 - 2) $GWP > 1\,000$
- and the tightness requirements for type tests for gasses with $GWP > 1\,000$ has been reduced from 0,5 % to 0,1 % per year per gas compartment;
- f) Subclause 6.108 “Interfaces”: Typical maximum pressures in service for interfaces connected to GIS have been defined;
- g) Subclauses 7.2 through 7.8 have been restructured;
- h) Subclause 7.107 “Corrosion test on earthing connections” has been updated;
- i) Subclause 7.108 “Corrosion tests on sealing systems of enclosures and auxiliary equipment” has been updated;
- j) Annex F ‘Service Continuity’ has been modified and aligned with the recommendations of CIGRE WG B3.51.

The text of this International Standard is based on the following documents:

Draft	Report on voting
17C/835/FDIS	17C/844/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 203: AC gas-insulated metal-enclosed switchgear for rated voltages above 52 kV

1 Scope

This part of IEC 62271 specifies requirements for gas-insulated metal-enclosed switchgear in which the insulation is obtained, at least partly, by an insulating gas or gas mixture other than air at atmospheric pressure, for alternating current of rated voltages above 52 kV, for indoor and outdoor installation, and for service frequencies up to and including 60 Hz.

For the purpose of this document, the terms “GIS” and “switchgear” are used for “gas-insulated metal-enclosed switchgear”.

The gas-insulated metal-enclosed switchgear covered by this document consists of individual components intended to be directly connected together and able to operate only in this manner.

This document completes and amends, if applicable, the various relevant standards applying to the individual components constituting GIS.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-11, *Environmental testing – Part 2-11: Tests – Test Ka: Salt mist*

IEC 60068-2-17, *Basic environmental testing procedures – Part 2-17: Tests – Test Q: Sealing*

IEC 60085:2007, *Electrical insulation – Thermal evaluation and designation*

IEC 60099-4:2014, *Surge arresters – Part 4: Metal-oxide surge arresters without gaps for a.c. systems*

IEC 60137:2017, *Insulated bushings for alternating voltages above 1 000 V*

IEC 60141-1, *Tests on oil-filled and gas-pressure cables and their accessories – Part 1: Oil-filled, paper or polypropylene paper laminate insulated, metal-sheathed cables and accessories for alternating voltages up to and including 500 kV*

IEC 60270, *High-voltage test techniques – Partial discharge measurements*

IEC 60376, *Specification of technical grade sulphur hexafluoride (SF₆) and complementary gases to be used in its mixtures for use in electrical equipment*

IEC 60480, *Specifications for the re-use of sulphur hexafluoride (SF₆) and its mixtures in electrical equipment*

IEC 60840, *Power cables with extruded insulation and their accessories for rated voltages above 30 kV ($U_m = 36$ kV) up to 150 kV ($U_m = 170$ kV) – Test methods and requirements*

IEC 61869-1, *Instrument transformers – Part 1: General requirements*

IEC 61869-2, *Instrument transformers – Part 2: Additional requirements for current transformers*

IEC 61869-3, *Instrument transformers – Part 3: Additional requirements for inductive voltage transformers*

IEC 62067, *Power cables with extruded insulation and their accessories for rated voltages above 150 kV ($U_m = 170$ kV) up to 500 kV ($U_m = 550$ kV) – Test methods and requirements*

IEC 62271-1:2017, *High-voltage switchgear and controlgear – Part 1: Common specifications for alternating current switchgear and controlgear*

IEC 62271-4, *High-voltage switchgear and controlgear – Part 4: Handling procedures for sulphur hexafluoride (SF_6) and its mixtures*

IEC 62271-100:2021, *High-voltage switchgear and controlgear – Part 100: Alternating current circuit-breakers*

IEC 62271-102:2018, *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches*

IEC 62271-209:2019, *High-voltage switchgear and controlgear – Part 209: Cable connections for gas-insulated metal-enclosed switchgear for rated voltages above 52 kV – Fluid-filled and extruded insulation cables – Fluid-filled and dry-type cable-terminations*

IEC 62271-211:2014, *High-voltage switchgear and controlgear – Part 211: Direct connection between power transformers and gas-insulated metal-enclosed switchgear for rated voltages above 52 kV*

ISO 22479, *Corrosion of metals and alloys – Sulfur dioxide test in a humid atmosphere (fixed gas method)*