

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

## Kopplingsapparater för spänning över 1 kV – Del 4: Hantering av gaser för isolering och/eller koppling

*High-voltage switchgear and controlgear –*

*Part 4: Handling procedures for gases for insulation and/or switching*

Som svensk standard gäller europastandarden EN IEC 62271-4:2022. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 62271-4:2022.

### Nationellt förord

Europastandarden EN IEC 62271-4:2022

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 62271-4, Second edition, 2022 - High-voltage switchgear and controlgear - Part 4: Handling procedures for gases for insulation and/or switching**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 62271-4, utg 1:2014, gäller ej fr o m 2025-08-26.

### *Standarder underlättar utvecklingen och höjer elsäkerheten*

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

### *SEK är Sveriges röst i standardiseringsarbetet inom elområdet*

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

### *Stora delar av arbetet sker internationellt*

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

### *Var med och påverka!*

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

### **SEK Svensk Elstandard**

Box 1284  
164 29 Kista  
Tel 08-444 14 00  
[www.elstandard.se](http://www.elstandard.se)

English Version

**High-voltage switchgear and controlgear - Part 4: Handling  
procedures for gases for insulation and/or switching  
(IEC 62271-4:2022)**

Appareillage à haute tension - Partie 4: Procédures de  
manipulation des gaz pour l'isolation et/ou la commutation  
(IEC 62271-4:2022)

Hochspannungs-Schaltgeräte und -Schaltanlagen - Teil 4:  
Handhabungsmethoden für Gase zur Isolation und/oder  
Unterbrechung  
(IEC 62271-4:2022)

This European Standard was approved by CENELEC on 2022-08-26. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

## **European foreword**

The text of document 17/1124/FDIS, future edition 2 of IEC 62271-4, prepared by IEC/TC 17 "High-voltage switchgear and controlgear" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62271-4:2022.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2023-05-26
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2025-08-26

This document supersedes EN 62271-4:2013 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

### **Endorsement notice**

The text of the International Standard IEC 62271-4:2022 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC/IEEE 82079-1:2019    NOTE    Harmonized as EN IEC/IEEE 82079-1:2020 (not modified)

IEC 62474:2018            NOTE    Harmonized as EN IEC 62474:2019 (not modified)

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: [www.cenelec.eu](http://www.cenelec.eu).

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-212	2010	International Electrotechnical Vocabulary - Part 212: Electrical insulating solids, liquids and gases	-	-
+ AMD1	2015			
+ AMD2	2015		-	-
+ AMD3	2020		-	-
IEC 60050-426	2020	International Electrotechnical Vocabulary (IEV) - Part 426: Explosive atmospheres	-	-
IEC 60050-441	1984	International Electrotechnical Vocabulary. Switchgear, controlgear and fuses	-	-
+ AMD1	2000		-	-
IEC 60335-2-69	2021	Household and similar electrical appliances - Safety - Part 2-69: Particular requirements for wet and dry vacuum cleaners, including power brush, for commercial use	-	-
IEC 60376	2018	Specification of technical grade sulphur hexafluoride (SF <sub>6</sub> ) and complementary gases to be used in its mixtures for use in electrical equipment	EN IEC 60376	2018
IEC 60480	2019	Specifications for the re-use of sulphur hexafluoride (SF <sub>6</sub> ) and its mixtures in electrical equipment	EN IEC 60480	2019
IEC 62271-1	2017	High-voltage switchgear and controlgear - Part 1: Common specifications for alternating current switchgear and controlgear	EN 62271-1	2017
+ AMD1	2021		+ A1	2021
ISO 8573-1	2010	Compressed air - Part 1: Contaminants and purity classes	-	-

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



---

**High-voltage switchgear and controlgear –  
Part 4: Handling procedures for gases for insulation and/or switching**

**Appareillage à haute tension –  
Partie 4: Procédures de manipulation des gaz pour l'isolation et/ou la  
commutation**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

---

ICS 29.130.10; 29.130.99

ISBN 978-2-8322-4025-0

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD.....	15
INTRODUCTION.....	17
1 Scope.....	18
2 Normative references .....	18
3 Terms and definitions .....	19
3.1 General terms and definitions .....	19
3.2 Terms and definitions for SF <sub>6</sub> .....	24
3.3 Terms and definitions for SF <sub>6</sub> mixtures .....	24
3.4 Terms and definitions for compressed air.....	25
3.5 Terms and definitions for natural-origin gases.....	26
3.6 Terms and definitions for C <sub>5</sub> F <sub>10</sub> O (C5-FK) in mixtures with N <sub>2</sub> , CO <sub>2</sub> , O <sub>2</sub> (C5-FK mixtures) .....	27
3.7 Terms and definitions for C <sub>4</sub> F <sub>7</sub> N (C4-FN) in mixtures with N <sub>2</sub> , CO <sub>2</sub> , O <sub>2</sub> (C4-FN mixtures) .....	28
4 Gas handling during installation, commissioning and after repair or overhaul on site.....	29
4.1 General.....	29
4.2 Evacuation, filling and quality checking.....	30
4.3 Topping-up of pre-filled gas compartments to the filling pressure/density for insulation and/or switching.....	33
4.4 Filling sealed pressure systems .....	35
5 Gas handling during normal service life .....	35
5.1 Topping-up of gas to the filling pressure/density for insulation and/or switching.....	35
5.2 Checking the quality of the gas .....	37
5.2.1 General .....	37
5.2.2 On-site measurement of the quality of gases with portable measurement equipment.....	37
5.2.3 Sampling and shipment of gases for off-site analysis.....	38
5.3 Rectifying the composition of a gas mixture .....	38
6 Recovery and reclaiming of gases during maintenance, repair, overhaul or dismantling on-site .....	39
6.1 General.....	39
6.2 Recovery and reclaiming of non-arced or normally arced gases from any gas compartment.....	39
6.3 Recovery and reclaiming from any gas compartment containing heavily arced gas.....	41
7 End-of-life of electric power equipment.....	43
7.1 General.....	43
7.2 End-of-life of controlled or closed pressure systems .....	44
7.3 End-of-life of sealed pressure systems.....	44
7.4 Gas recovery and reclaiming at the end-of-life of sealed pressure systems.....	45
7.5 Dismantling of electric power equipment (informative).....	49
Annex A (informative) Sulphur hexafluoride (SF <sub>6</sub> ).....	50
A.1 Gas properties .....	50
A.2 Safety and first aid.....	50
A.2.1 General .....	50

A.2.2	Protection of personnel.....	51
A.2.3	Handling of contaminated safety equipment and tools.....	53
A.2.4	Pressurised equipment and tools or measuring devices.....	53
A.2.5	Personal safety and protective equipment.....	53
A.2.6	Facilities and services .....	54
A.2.7	Additional safety measures in case of sudden release of SF <sub>6</sub> .....	54
A.2.8	First aid equipment and treatment .....	54
A.3	Environmental impact.....	55
A.4	Training and certification.....	55
A.4.1	General .....	55
A.4.2	Training .....	56
A.4.3	Certification .....	57
A.5	Storage and transportation.....	57
A.5.1	General .....	57
A.5.2	Storage of containers filled with SF <sub>6</sub> .....	57
A.5.3	Transportation of containers filled with SF <sub>6</sub> .....	58
A.5.4	Storage and transportation of electric power equipment containing SF <sub>6</sub> .....	59
A.5.5	Responsibilities .....	60
A.6	Description of handling equipment .....	60
A.6.1	General .....	60
A.6.2	Filters .....	61
A.6.3	Vacuum pump.....	62
A.6.4	Main and vacuum compressors.....	63
A.6.5	Outlet compressor .....	63
A.6.6	External and internal gas storage containers .....	63
A.6.7	Evaporator and gas storage container heater.....	63
A.6.8	Gas piping and pipe junctions.....	64
A.6.9	Control instruments .....	64
A.6.10	Safety valves .....	64
A.6.11	Flexible hose connections.....	64
A.6.12	Portable devices for gas measurement .....	64
A.6.13	Gas leakage tester .....	66
A.6.14	Gas concentration alarm systems .....	66
A.6.15	Gas sampling cylinders.....	67
A.7	Reclaiming procedures .....	67
A.8	By-products .....	67
A.9	Procedure to evaluate the potential effects on health of by-products.....	67
A.10	Handling of SF <sub>6</sub> .....	67
A.10.1	General .....	67
A.10.2	Filling gas compartments with SF <sub>6</sub> .....	67
A.10.3	Topping-up gas compartments with SF <sub>6</sub> to the filling pressure for insulation and/or switching.....	67
A.10.4	Checking the quality of SF <sub>6</sub> .....	67
A.10.5	Recovery and reclaim of SF <sub>6</sub> .....	67
A.11	Specifications for SF <sub>6</sub> needed for filling or topping-up electric power equipment.....	67
Annex B (informative)	SF <sub>6</sub> mixtures .....	68

B.1	Gas properties .....	68
B.1.1	General .....	68
B.1.2	Chemical properties .....	68
B.1.3	Physical properties .....	68
B.1.4	Insulating and switching behaviour .....	69
B.2	Safety and first aid.....	70
B.2.1	General .....	70
B.2.2	Protection of personnel.....	70
B.2.3	Handling of contaminated safety equipment and tools.....	70
B.2.4	Pressurised equipment and tools or measuring devices .....	70
B.2.5	Personal safety and protective equipment.....	70
B.2.6	Facilities and services .....	70
B.2.7	Additional safety measures in case of sudden release of SF <sub>6</sub> mixtures.....	70
B.2.8	First aid equipment and treatment .....	70
B.3	Environmental impact.....	70
B.4	Training and certification.....	70
B.4.1	General .....	70
B.4.2	Training .....	71
B.4.3	Certification .....	71
B.5	Storage and transportation.....	71
B.5.1	General .....	71
B.5.2	Storage of containers filled with SF <sub>6</sub> mixture .....	71
B.5.3	Transportation of containers filled with SF <sub>6</sub> mixture .....	73
B.5.4	Storage and transportation of electric power equipment containing SF <sub>6</sub> mixture .....	74
B.5.5	Responsibilities .....	75
B.6	Description of handling equipment .....	75
B.6.1	General .....	75
B.6.2	Filters .....	77
B.6.3	Vacuum pump.....	77
B.6.4	Main and vacuum compressors.....	77
B.6.5	Outlet compressor .....	77
B.6.6	External and internal gas storage containers .....	77
B.6.7	Evaporator and gas storage container heater.....	77
B.6.8	Gas piping and pipe junctions .....	77
B.6.9	Control instruments .....	77
B.6.10	Safety valves.....	77
B.6.11	Flexible hose connections.....	77
B.6.12	Portable devices for gas measurement .....	77
B.6.13	Gas leakage tester .....	78
B.6.14	Gas concentration alarm systems .....	78
B.6.15	Gas sampling cylinders.....	79
B.6.16	Gas mixing unit.....	79
B.7	Reclaiming procedures .....	79
B.8	By-products .....	79
B.9	Procedure to evaluate the potential effects on health of by-products.....	79
B.10	Handling of SF <sub>6</sub> mixtures .....	79
B.10.1	General .....	79

B.10.2	Filling gas compartments with SF <sub>6</sub> mixtures .....	80
B.10.3	Topping-up gas compartments with SF <sub>6</sub> mixtures to the filling pressure for insulation and/or switching .....	80
B.10.4	Checking the quality of SF <sub>6</sub> mixtures .....	81
B.10.5	Recovery and reclaim of SF <sub>6</sub> mixtures .....	81
B.10.6	Rectifying the composition of SF <sub>6</sub> mixtures .....	82
B.11	Specifications for SF <sub>6</sub> mixtures needed for filling or topping-up electric power equipment .....	82
Annex C (informative)	Compressed air .....	83
C.1	Gas properties .....	83
C.1.1	General .....	83
C.1.2	Chemical properties .....	83
C.1.3	Physical properties .....	83
C.1.4	Insulating and switching behaviour .....	84
C.2	Safety and first aid .....	84
C.2.1	General .....	84
C.2.2	Protection of personnel .....	85
C.2.3	Handling of contaminated safety equipment and tools .....	86
C.2.4	Pressurised equipment and tools or measuring devices .....	86
C.2.5	Personal safety and protective equipment .....	87
C.2.6	Facilities and services .....	88
C.2.7	Additional safety measures in case of sudden release of compressed air .....	88
C.2.8	First aid equipment and treatment .....	88
C.3	Environmental impact .....	89
C.3.1	General .....	89
C.3.2	Ecotoxicology .....	89
C.3.3	Ozone depletion .....	90
C.3.4	Global warming/climate change (greenhouse effect) .....	90
C.3.5	Environmental impact of by-products .....	90
C.4	Training and certification .....	90
C.4.1	General .....	90
C.4.2	Training .....	90
C.4.3	Certification .....	91
C.5	Storage and transportation .....	92
C.5.1	General .....	92
C.5.2	Storage of containers filled with compressed air .....	92
C.5.3	Transportation of containers filled with compressed air .....	92
C.5.4	Storage and transportation of electrical power equipment containing compressed air .....	93
C.5.5	Responsibilities .....	93
C.6	Description of handling equipment .....	93
C.6.1	General .....	93
C.6.2	Filters .....	94
C.6.3	Vacuum pump .....	95
C.6.4	Main and vacuum compressors .....	96
C.6.5	Outlet compressor .....	96
C.6.6	External and internal gas storage containers .....	96
C.6.7	Evaporator and gas storage container heater .....	96

C.6.8	Gas piping and pipe junctions .....	96
C.6.9	Control instruments .....	96
C.6.10	Safety valves .....	97
C.6.11	Flexible hose connections.....	97
C.6.12	Portable devices for gas measurement .....	97
C.6.13	Gas leakage tester .....	98
C.6.14	Gas concentration alarm systems .....	98
C.6.15	Gas sampling cylinders.....	99
C.6.16	Gas purifying and filling device .....	99
C.7	Reclaiming procedures .....	100
C.7.1	General .....	100
C.7.2	Filtering recommendations.....	100
C.7.3	Transport of used compressed air in gas cylinders and containers by road.....	100
C.8	By-products .....	101
C.8.1	General .....	101
C.8.2	Decomposition of compressed air .....	101
C.8.3	Corrosion behaviour of compressed air and its by-products .....	102
C.8.4	Measures for the removal of by-products .....	102
C.8.5	Physiological characteristics of by-products.....	102
C.9	Procedure to evaluate the potential effects on health of by-products .....	103
C.9.1	General .....	103
C.9.2	Formation of by-products and health effects .....	104
C.10	Handling of compressed air.....	114
C.10.1	General .....	114
C.10.2	Filling gas compartments with compressed air .....	114
C.10.3	Topping-up gas compartments with compressed air to the filling pressure for insulation and/or switching .....	114
C.10.4	Checking the quality of compressed air.....	114
C.10.5	Recovery and reclaim of compressed air .....	115
C.11	Specifications for compressed air needed for filling or topping-up electric power equipment .....	115
Annex D (informative)	Natural-origin gases.....	116
D.1	Gas properties .....	116
D.1.1	General .....	116
D.1.2	Chemical properties.....	116
D.1.3	Physical properties .....	116
D.1.4	Insulating and switching behaviour .....	117
D.2	Safety and first aid.....	117
D.2.1	General .....	117
D.2.2	Protection of personnel.....	119
D.2.3	Handling of contaminated safety equipment and tools.....	120
D.2.4	Pressurised equipment and tools or measuring devices .....	120
D.2.5	Personal safety and protective equipment.....	120
D.2.6	Facilities and services .....	121
D.2.7	Additional safety measures in case of sudden release of natural-origin gases .....	122
D.2.8	First aid equipment and treatment .....	122
D.3	Environmental impact.....	123
D.3.1	General .....	123

D.3.2	Ecotoxicology .....	123
D.3.3	Ozone depletion .....	124
D.3.4	Global warming/climate change (greenhouse effect) .....	124
D.3.5	Environmental impact of by-products .....	124
D.4	Training and certification .....	124
D.4.1	General .....	124
D.4.2	Training .....	125
D.4.3	Certification .....	126
D.5	Storage and transportation .....	126
D.5.1	General .....	126
D.5.2	Storage of containers filled with natural-origin gases .....	126
D.5.3	Transportation of containers filled with natural-origin gases .....	127
D.5.4	Storage and transportation of electrical power equipment containing natural-origin gases .....	128
D.5.5	Responsibilities .....	129
D.6	Description of handling equipment .....	129
D.6.1	General .....	129
D.6.2	Filters .....	132
D.6.3	Vacuum pump .....	133
D.6.4	Main and vacuum compressors .....	133
D.6.5	Outlet compressor .....	133
D.6.6	External and internal gas storage container .....	134
D.6.7	Evaporator and gas storage container heater .....	134
D.6.8	Gas piping and pipe junctions .....	134
D.6.9	Control instruments .....	134
D.6.10	Safety valves .....	134
D.6.11	Flexible hose connections .....	134
D.6.12	Portable devices for gas measurement .....	135
D.6.13	Gas leakage tester .....	137
D.6.14	Gas concentration alarm systems .....	137
D.6.15	Gas sampling cylinders .....	137
D.6.16	Gas mixing unit .....	137
D.6.17	Gas filling unit .....	138
D.6.18	Gas recovery unit .....	138
D.6.19	Used gas storage and transportation devices .....	138
D.7	Reclaiming procedures .....	138
D.7.1	General .....	138
D.7.2	Filtering recommendations .....	139
D.7.3	Transport of used natural-origin gases in gas cylinders and containers by road .....	139
D.8	By-products .....	140
D.8.1	General .....	140
D.8.2	Decomposition of natural-origin gases .....	140
D.8.3	Corrosion behaviour of natural-origin gases and their by-products .....	140
D.8.4	Measures for the removal of by-products .....	141
D.8.5	Physiological characteristics of by-products .....	141
D.9	Procedure to evaluate the potential effects on health of gas components and by-products .....	142
D.9.1	General .....	142
D.9.2	Formation of by-products and health effects .....	142

D.10	Handling of natural-origin gases.....	152
D.10.1	General .....	152
D.10.2	Filling gas compartments with natural-origin gases .....	152
D.10.3	Topping-up gas compartments with natural-origin gases.....	153
D.10.4	Checking the quality of natural-origin gases.....	153
D.10.5	Recovery and reclaim of natural-origin gases .....	154
D.10.6	Rectifying the composition of natural-origin gas mixtures.....	154
D.11	Specifications for natural-origin gases needed for filling or topping-up electric power equipment .....	155
Annex E (informative)	C <sub>5</sub> F <sub>10</sub> O (C5-FK) in mixtures with N <sub>2</sub> , CO <sub>2</sub> , O <sub>2</sub> (C5-FK mixtures) .....	156
E.1	Gas properties .....	156
E.1.1	General .....	156
E.1.2	Chemical properties.....	156
E.1.3	Physical properties .....	157
E.1.4	Insulating and switching behaviour .....	158
E.2	Safety and first aid.....	158
E.2.1	General .....	158
E.2.2	Protection of personnel.....	159
E.2.3	Handling of contaminated safety equipment and tools.....	161
E.2.4	Pressurised equipment and tools or measuring devices .....	161
E.2.5	Personal safety and protective equipment.....	162
E.2.6	Facilities and services .....	163
E.2.7	Additional safety measures in case of sudden release of C5-FK mixtures .....	163
E.2.8	First aid equipment and treatment .....	163
E.3	Environmental impact.....	164
E.3.1	General .....	164
E.3.2	Ecotoxicology .....	164
E.3.3	Ozone depletion .....	165
E.3.4	Global warming/climate change (greenhouse effect).....	165
E.3.5	Environmental impact of by-products .....	165
E.3.6	Decomposition by UV-light in the upper atmosphere .....	165
E.4	Training and certification.....	165
E.4.1	General .....	165
E.4.2	Training .....	166
E.4.3	Certification .....	167
E.5	Storage and transportation.....	167
E.5.1	General .....	167
E.5.2	Storage of containers filled with C5-FK or C5-FK mixtures.....	167
E.5.3	Transportation of containers filled with C5-FK or C5-FK mixtures .....	169
E.5.4	Storage and transportation of electrical power equipment containing C5-FK mixtures .....	171
E.5.5	Responsibilities .....	172
E.6	Description of handling equipment .....	172
E.6.1	General .....	172
E.6.2	Filters .....	174
E.6.3	Vacuum pump.....	175
E.6.4	Main and vacuum compressors.....	176

E.6.5	Outlet compressor .....	176
E.6.6	External and internal gas storage containers .....	176
E.6.7	Evaporator and gas storage container heater.....	176
E.6.8	Gas piping and pipe junctions.....	177
E.6.9	Control instruments .....	177
E.6.10	Safety valves .....	177
E.6.11	Flexible hose connections.....	177
E.6.12	Portable devices for gas measurement .....	177
E.6.13	Gas leakage tester .....	179
E.6.14	Gas concentration alarm systems .....	179
E.6.15	Gas sampling cylinders.....	179
E.6.16	Gas mixing unit.....	180
E.6.17	Gas filling unit .....	180
E.6.18	Gas recovery unit .....	180
E.6.19	Used gas storage and transportation devices.....	181
E.7	Reclaiming procedures .....	181
E.8	By-products .....	181
E.8.1	General .....	181
E.8.2	Decomposition of C5-FK mixtures.....	181
E.8.3	Corrosion behaviour of C5-FK mixtures and their by-products.....	183
E.8.4	Measures for the removal of by-products .....	183
E.8.5	Physiological characteristics of by-products.....	184
E.9	Procedure to evaluate the potential effects on health of gas components and by-products.....	184
E.9.1	General .....	184
E.9.2	Formation of by-products and health effects .....	185
E.10	Handling of C5-FK mixtures .....	194
E.10.1	General .....	194
E.10.2	Filling gas compartments with C5-FK mixtures.....	194
E.10.3	Topping-up gas compartments with C5-FK mixtures to the filling pressure for insulation and/or switching.....	195
E.10.4	Checking the quality of C5-FK mixtures .....	195
E.10.5	Recovery and reclaim of C5-FK mixtures .....	196
E.10.6	Rectifying the composition of C5-FK mixtures.....	196
E.11	Specifications for C5-FK mixtures needed for filling or topping-up electric power equipment .....	196
Annex F (informative)	C <sub>4</sub> F <sub>7</sub> N (C4-FN) in mixtures with N <sub>2</sub> , CO <sub>2</sub> , O <sub>2</sub> (C4-FN mixtures) .....	197
F.1	Gas properties .....	197
F.1.1	General .....	197
F.1.2	Chemical properties.....	197
F.1.3	Physical properties .....	198
F.1.4	Insulating and switching behaviour .....	199
F.2	Safety and first aid.....	199
F.2.1	General .....	199
F.2.2	Protection of personnel.....	200
F.2.3	Handling of contaminated safety equipment and tools.....	202
F.2.4	Pressurised equipment and tools or measuring devices .....	202
F.2.5	Personal safety and protective equipment.....	202
F.2.6	Facilities and services .....	203

F.2.7	Additional safety measures in case of sudden release of C4-FN mixtures .....	203
F.2.8	First aid equipment and treatment .....	204
F.3	Environmental impact.....	204
F.3.1	General .....	204
F.3.2	Ecotoxicology .....	204
F.3.3	Ozone depletion .....	205
F.3.4	Global warming/climate change (greenhouse effect) .....	205
F.3.5	Environmental impact of by-products .....	205
F.3.6	Decomposition by UV-light in the upper atmosphere .....	206
F.4	Training and certification.....	206
F.4.1	General .....	206
F.4.2	Training .....	206
F.4.3	Certification .....	207
F.5	Storage and transportation.....	208
F.5.1	General .....	208
F.5.2	Storage of containers filled with C4-FN or C4-FN mixtures .....	208
F.5.3	Transportation of containers filled with C4-FN or C4-FN mixtures .....	210
F.5.4	Storage and transportation of electrical power equipment containing C4-FN mixtures .....	212
F.5.5	Responsibilities .....	213
F.6	Description of handling equipment .....	213
F.6.1	General .....	213
F.6.2	Filters .....	215
F.6.3	Vacuum pump.....	216
F.6.4	Main and vacuum compressors.....	217
F.6.5	Outlet compressor .....	217
F.6.6	External and internal gas storage containers .....	217
F.6.7	Evaporator and gas storage container heater.....	217
F.6.8	Gas piping and pipe junctions .....	218
F.6.9	Control instruments .....	218
F.6.10	Safety valves .....	218
F.6.11	Flexible hose connections.....	218
F.6.12	Portable devices for gas measurement .....	218
F.6.13	Gas leakage tester .....	220
F.6.14	Gas concentration alarm systems .....	220
F.6.15	Gas sampling cylinder .....	220
F.6.16	Gas mixing unit.....	221
F.6.17	Gas filling unit .....	221
F.6.18	Gas recovery unit .....	221
F.6.19	Used gas storage and transportation devices.....	222
F.7	Reclaiming procedures .....	222
F.8	By-products .....	222
F.8.1	General .....	222
F.8.2	Decomposition of C4-FN mixtures.....	222
F.8.3	Corrosion behaviour of C4-FN mixtures and their by-products .....	224
F.8.4	Measures for the removal of by-products .....	224
F.8.5	Physiological characteristics of by-products.....	225
F.9	Procedure to evaluate the potential effects on health of gas components and by-products.....	225

F.9.1	General .....	225
F.9.2	Formation of by-products and health effects .....	226
F.10	Handling of C4-FN mixtures .....	234
F.10.1	General .....	234
F.10.2	Filling gas compartments with C4-FN mixtures .....	234
F.10.3	Topping-up gas compartments with C4-FN mixtures to the filling pressure for insulation and/or switching .....	235
F.10.4	Checking the quality of C4-FN mixtures .....	236
F.10.5	Recovery and reclaim of C4-FN mixtures .....	236
F.10.6	Rectifying the composition of C4-FN mixtures .....	236
F.11	Specifications for C4-FN mixtures needed for filling or topping-up electric power equipment .....	236
	Bibliography .....	237
	Figure 1 – Evacuation, filling and checking of the quality of the gas after filling .....	31
	Figure 2 – Topping-up of pre-filled gas compartments to the filling pressure/density for insulation and/or switching .....	34
	Figure 3 – Topping-up of a gas to the filling pressure/density for insulation and/or switching .....	36
	Figure 4 – Example of recovery and reclaiming of non-arced or normally arc'd gas from any gas compartment .....	40
	Figure 5 – Example of recovery and reclaiming of heavily arc'd gas from any gas compartment .....	42
	Figure 6 – End-of-life of controlled or closed pressure systems .....	44
	Figure 7 – End-of-life of sealed pressure systems .....	45
	Figure 8 – Gas recovery and reclaiming at the end-of-life of sealed pressure systems .....	46
	Figure 9 – Dilution method .....	48
	Figure 10 – Dismantling of electric power equipment .....	49
	Figure A.1 – Pressure-temperature-density diagram for SF <sub>6</sub> .....	50
	Figure A.2 – Schematic view of an example of a handling equipment for SF <sub>6</sub> .....	61
	Figure B.1 – Schematic view of an example of a handling equipment for SF <sub>6</sub> mixture .....	76
	Figure C.1 – Controlled release of compressed air .....	94
	Figure C.2 – Example of a gas filling and purifying device .....	99
	Figure D.1 – Schematic view of an example of a handling equipment for natural origin gases .....	131
	Figure E.1 – Structure of the C5-FK molecule .....	156
	Figure E.2 – Vapour pressure curve of C5-FK .....	157
	Figure E.3 – Schematic view of an example of a handling equipment for C5-FK mixture .....	173
	Figure F.1 – Structure of the C4-FN molecule .....	197
	Figure F.2 – Vapour pressure curve of C4-FN .....	198
	Figure F.3 – Schematic view of an example of a handling equipment for C4-FN mixture .....	214

Table 1 – Evacuation, filling and checking of the quality of the gas after filling .....	32
Table 2 – Topping-up of pre-filled gas compartments to the filling pressure/density for insulation and/or switching .....	35
Table 3 – Topping-up of a gas to the filling pressure/density for insulation and/or switching .....	37
Table 4 – Sampling and shipment of gases .....	38
Table 5 – Example of recovery and reclaiming of non-arced or normally arced gas from any gas compartment.....	41
Table 6 – Example of recovery and reclaiming of heavily arced gas from any gas compartment.....	43
Table 7 – Gas recovery at the end-of-life of sealed pressure systems .....	47
Table A.1 – Measures when working with SF <sub>6</sub> electric power equipment.....	51
Table A.2 – Safety measures when opening or accessing gas compartments.....	52
Table A.3 – Examples of container types required for storage and transportation of SF <sub>6</sub> .....	58
Table A.4 – International regulations for shipment of SF <sub>6</sub> .....	59
Table A.5 – Gas measuring devices .....	64
Table B.1 – Main chemical characteristics of CF <sub>4</sub> and N <sub>2</sub> .....	68
Table B.2 – Main physical characteristics of CF <sub>4</sub> and N <sub>2</sub> .....	69
Table B.3 – Examples of container types required for storage and transportation of SF <sub>6</sub> mixtures and their complementary gases .....	73
Table B.4 – International regulations for shipment of SF <sub>6</sub> mixtures .....	74
Table B.5 – Gas measuring devices .....	78
Table C.1 – Main chemical characteristics of N <sub>2</sub> and O <sub>2</sub> .....	83
Table C.2 – Typical physical characteristics of N <sub>2</sub> and O <sub>2</sub> .....	84
Table C.3 – Measures when working with electric power equipment containing compressed air .....	85
Table C.4 – Safety measures when opening or accessing gas compartments .....	86
Table C.5 – Examples of container types required for storage and transportation of compressed air .....	92
Table C.6 – International regulations for shipment of compressed air.....	93
Table C.7 – Typical filter types used during release of compressed air to the atmosphere.....	95
Table C.8 – Gas measuring devices .....	97
Table C.9 – Exemplary filtering methods .....	100
Table C.10 – Typical adsorbents for various compressed air contaminants .....	100
Table C.11 – OELs for NO <sub>2</sub> , NO, O <sub>3</sub> and HNO <sub>3</sub> .....	106
Table C.12 – Example calculation of a normal leakage .....	109
Table C.13 – Example calculation of an abnormal leakage.....	111
Table C.14 – Example calculation for maintenance .....	112
Table D.1 – Main chemical characteristics of N <sub>2</sub> , O <sub>2</sub> and CO <sub>2</sub> .....	116
Table D.2 – Typical physical characteristics of N <sub>2</sub> , O <sub>2</sub> and CO <sub>2</sub> .....	117
Table D.3 – Measures when working with electric power equipment containing natural-origin gases .....	118
Table D.4 – Safety measures when opening or accessing gas compartments .....	119

Table D.5 – Examples of container types required for storage and transportation of natural-origin gases .....	127
Table D.6 – International regulations for shipment of natural-origin gases.....	128
Table D.7 – Typical filter types used during release of natural-origin gases to the atmosphere.....	132
Table D.8 – Gas measuring devices.....	135
Table D.9 – Exemplary filtering operations.....	139
Table D.10 – Typical adsorbents for various contaminants of natural-origin gases .....	139
Table D.11 – OELs for NO <sub>2</sub> , NO, O <sub>3</sub> , CO and HNO <sub>3</sub> .....	144
Table D.12 – Example calculation of a normal leakage .....	147
Table D.13 – Example calculation of an abnormal leakage.....	149
Table D.14 – Example calculation for maintenance .....	150
Table E.1 – Main chemical characteristics C5-FK .....	157
Table E.2 – Main physical characteristics of C5-FK.....	158
Table E.3 – Measures when working with electric power equipment containing C5-FK mixtures.....	159
Table E.4 – Safety measures when opening or accessing gas compartments.....	160
Table E.5 – Methods for storage of C5-FK .....	168
Table E.6 – Examples of container types required for storage / transportation of C5-FK .....	168
Table E.7 – Methods for storage of C5-FK mixtures .....	169
Table E.8 – Examples of container types required for storage / transportation of C5-FK mixtures.....	169
Table E.9 – International regulations for shipment of C5-FK.....	170
Table E.10 – International regulations for shipment of C5-FK mixtures .....	171
Table E.11 – Typical filter types .....	175
Table E.12 – Gas measuring devices .....	177
Table E.13 – OELs and LC50 values for C5-FK mixtures by-products .....	182
Table E.14 – Example calculation of a normal leakage.....	189
Table E.15 – Example calculation of an abnormal leakage.....	191
Table E.16 – Example calculation for maintenance .....	192
Table E.17 – TWA values of gas components .....	193
Table F.1 – Main chemical characteristics C4-FN.....	198
Table F.2 – Main physical characteristics of C4-FN.....	199
Table F.3 – Measures when working with electric power equipment containing C4-FN mixtures.....	200
Table F.4 – Safety measures when opening or accessing gas compartments.....	201
Table F.5 – Methods for storage of C4-FN .....	208
Table F.6 – Examples of container types required for storage / transportation of C4-FN .....	208
Table F.7 – Methods for storage of C4-FN mixtures .....	209
Table F.8 – Examples of container types required for storage and transportation of C4-FN mixtures .....	210
Table F.9 – International regulations for shipment of C4-FN.....	210
Table F.10 – International regulations for shipment of C4-FN mixtures .....	212
Table F.11 – Typical filter types .....	216
Table F.12 – Gas measuring devices .....	218

Table F.13 – OELs and LC50 values for C4-FN mixtures by-products .....	223
Table F.14 – Example calculation of a normal leakage.....	230
Table F.15 – Example calculation of an abnormal leakage .....	231
Table F.16 – Example calculation for maintenance .....	232
Table F.17 – TWA values of gas components .....	233

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –****Part 4: Handling procedures for gases for insulation and/or switching****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62271-4 has been prepared by IEC technical committee 17: High-voltage switchgear and controlgear. It is an International Standard.

This second edition cancels and replaces the first edition of IEC 62271-4 published in 2013. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) title has been modified;
- b) handling procedures of alternatives to SF<sub>6</sub>, which are used for insulation and/or switching, are added;
- c) the main clauses are independent from the type of gas;
- d) for each gas a separate annex describes gas specific information, handling procedures, safety measure, etc.;

- e) information about SF<sub>6</sub> (former Annex E) and about environmental effects of SF<sub>6</sub> and its mixtures (former Annex F) has been moved to IEC 60376;
- f) information about by-products of SF<sub>6</sub> and its mixtures (former Annex G), the procedure for evaluating the potential effects on health of by-products of SF<sub>6</sub> and its mixtures (former Annex H) and the cryogenic reclaim of SF<sub>6</sub> (former Annex I) have been moved to IEC 60480.

The text of this International Standard is based on the following documents:

Draft	Report on voting
17/1124/FDIS	17/1125/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

A list of all parts in the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/standardsdev/publications](http://www.iec.ch/standardsdev/publications).

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document can involve the use of a patent. IEC takes no position concerning the evidence, validity, and scope of this patent right.

The holder of this patent right has assured IEC that s/he is willing to negotiate licences under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of this patent right is registered with IEC. Information can be obtained from the patent database available at <http://patents.iec.ch>.

Attention is drawn to the possibility that some of the elements of this document can be the subject of patent rights other than those in the patent database. IEC shall not be held responsible for identifying any or all such patent rights.

This document does not purport to address all the safety problems associated with its use. It is the responsibility of the user of this document to establish appropriate health and safety practices and determine the applicability of regulatory limitations prior to use.

The gases for insulation and/or switching which are the subjects of this document should be handled in compliance with local regulations, suppliers safety data-sheets, the operating instruction manual of the manufacturer and the safety guidance of the user of the electric power equipment.

Considering the limited information for some of the data which appear in the informative Annex E and Annex F, the reader should be aware that the information related with possible by-products and their possible toxicological effects on health and on the environment is still a matter of study.

Within IEC TC 10 new standards about specifications of technical grade (IEC 63360) and re-use (IEC 63359) for alternatives to SF<sub>6</sub> are being prepared. Therefore, in a later revision of this standard, some of the information will be moved to these new standards, similarly as it has been done for SF<sub>6</sub> and SF<sub>6</sub> mixtures.

# HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

## Part 4: Handling procedures for gases for insulation and/or switching

### 1 Scope

This part of IEC 62271 applies to the procedures for handling of gases for insulation and/or switching during installation, commissioning, repair, overhaul, normal and abnormal operations and disposal at the end-of-life of electric power equipment.

These procedures are regarded as minimum requirements to ensure the reliability of electric power equipment, the safety of personnel working with these gases and to minimize the impact on the environment. Additional requirements could be given or specified in the operating instruction manual of the manufacturer.

For each gas, which is known to be used in electric power equipment at the date of the publication of this document, a separate annex describes specifications, handling procedures, safety measures, etc. For gases not covered by these annexes the electric power equipment manufacturer should provide the information needed, following the structure of these annexes. Such gases should also be described in a next edition or in amendments to this edition.

NOTE 1 For the use of this document, high-voltage (HV) is defined as the rated voltage above 1 000 V. However, the term medium-voltage (MV) is commonly used for distribution systems with voltages above 1 kV and generally applied up to and including 52 kV.

NOTE 2 Throughout this document, the term “pressure” stands for “absolute pressure”.

NOTE 3 In this document, percentages of gaseous components, contaminants and by-products, are always percentages per volume, measured at 20 °C, if not otherwise indicated.

NOTE 4 Reference is also made to CIGRE Brochure 802 [1] <sup>1</sup>.

NOTE 5 For further details on gases, e.g. ecotoxicology, also refer to the chemical database of the European Chemicals Agency, ECHA ([www.echa.europa.eu](http://www.echa.europa.eu)), which takes the actual tonnage band into consideration.

NOTE 6 If gases for insulation and/or switching are regulated, their designation and regulation origin can be found in the IEC 62474 database (available at <https://std.iec.ch/iec62474> [26]).

NOTE 7 When reference to circuit-breakers is made, only gas circuit-breakers are of interest. When vacuum circuit-breakers are of interest, they are explicitly mentioned.

### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-212:2010, *International Electrotechnical Vocabulary (IEV) – Part 212: Electrical insulating solids, liquids and gases* (available at [www.electropedia.org](http://www.electropedia.org))

IEC 60050-212:2010/AMD1:2015

IEC 60050-212:2010/AMD2:2015

IEC 60050-212:2010/AMD3:2020

---

<sup>1</sup> Numbers in square brackets refer to the Bibliography.

IEC 60050-426:2020, *International Electrotechnical Vocabulary (IEV) – Part 426: Explosive atmospheres* (available at [www.electropedia.org](http://www.electropedia.org))

IEC 60050-441:1984, *International Electrotechnical Vocabulary (IEV) – Part 441: Switchgear, controlgear and fuses* (available at [www.electropedia.org](http://www.electropedia.org))

IEC 60050-441:1984/AMD1:2000

IEC 60335-2-69:2021, *Household and similar electrical appliances – Safety – Part 2-69: Particular requirements for wet and dry vacuum cleaners, including power brush, for commercial use*

IEC 60376:2018, *Specification of technical grade sulphur hexafluoride (SF<sub>6</sub>) and complementary gases to be used in its mixtures for use in electrical equipment*

IEC 60480:2019, *Specifications for the re-use of sulphur hexafluoride (SF<sub>6</sub>) and its mixtures in electrical equipment*

IEC 62271-1:2017, *High-voltage switchgear and controlgear – Part 1: Common specifications for alternating current switchgear and controlgear*

IEC 62271-1:2017/AMD1:2021

ISO 8573-1:2010, *Compressed air – Part 1: Contaminants and purity classes*