

# INTERNATIONAL STANDARD

**IEC**  
**61850-7-2**

First edition  
2003-05

---

---

## **Communication networks and systems in substations –**

### **Part 7-2:**

### **Basic communication structure for substation and feeder equipment – Abstract communication service interface (ACSI)**

© IEC 2003 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland  
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: [inmail@iec.ch](mailto:inmail@iec.ch) Web: [www.iec.ch](http://www.iec.ch)



Commission Electrotechnique Internationale  
International Electrotechnical Commission  
Международная Электротехническая Комиссия

PRICE CODE

**XH**

*For price, see current catalogue*

## CONTENTS

FOREWORD .....	8
INTRODUCTION .....	10
1 Scope .....	11
2 Normative references .....	11
3 Terms and definitions .....	12
4 Abbreviated terms .....	13
5 ACSI overview and basic concepts .....	14
5.1 General .....	14
5.2 Overview of basic information models .....	15
5.3 Overview of the other service models .....	16
5.4 Overview of ACSI services .....	19
5.5 Type definitions .....	20
5.5.1 Data attribute types .....	20
5.5.2 BasicTypes .....	21
5.5.3 Common ACSI types .....	22
6 SERVER class model .....	26
6.1 SERVER class definition .....	26
6.1.1 SERVER class syntax .....	26
6.1.2 SERVER class attributes .....	27
6.2 Server class services .....	27
6.2.1 Overview of directory and GetDefinition services .....	27
6.2.2 GetServerDirectory .....	28
7 Application association model .....	29
7.1 Introduction .....	29
7.2 Concept of application associations .....	29
7.3 Access control .....	29
7.4 TWO-PARTY-APPLICATION-ASSOCIATION (TPAA) class model .....	30
7.4.1 TWO-PARTY-APPLICATION-ASSOCIATION (TPAA) class definition .....	30
7.4.2 Two-party application association services .....	32
7.5 MULTICAST-APPLICATION-ASSOCIATION (MCAA) class .....	34
7.5.1 MULTICAST-APPLICATION-ASSOCIATION (MCAA) class definition .....	34
8 LOGICAL-DEVICE class model .....	36
8.1 LOGICAL-DEVICE class definition .....	36
8.1.1 LOGICAL-DEVICE class syntax .....	36
8.1.2 LOGICAL-DEVICE class attributes .....	36
8.2 LOGICAL-DEVICE class services .....	37
8.2.1 GetLogicalDeviceDirectory .....	37
9 LOGICAL-NODE class model .....	38
9.1 LOGICAL-NODE class definition .....	38
9.1.1 LOGICAL-NODE class syntax .....	38
9.1.2 LOGICAL-NODE class attributes .....	38
9.2 LOGICAL-NODE class services .....	40
9.2.1 Overview .....	40
9.2.2 GetLogicalNodeDirectory .....	40
9.2.3 GetAllDataValues .....	41

10	DATA class model.....	42
10.1	General .....	42
10.2	DATA class definition .....	42
10.2.1	DATA class syntax .....	42
10.2.2	DATA class attributes.....	45
10.3	Relation of DATA, common DATA, and compatible DATA classes .....	52
10.4	DATA class services .....	52
10.4.1	General definitions and overview .....	52
10.4.2	GetDataValues.....	53
10.4.3	SetDataValues .....	54
10.4.4	GetDataDirectory .....	55
10.4.5	GetDataDefinition.....	56
11	DATA-SET class model.....	56
11.1	General .....	56
11.2	DATA-SET class definition .....	58
11.2.1	DATA-SET class syntax .....	58
11.2.2	DATA-SET class attributes .....	58
11.3	DATA-SET class services .....	59
11.3.1	Overview.....	59
11.3.2	GetDataSetValues.....	59
11.3.3	SetDataSetValues .....	60
11.3.4	CreateDataSet .....	61
11.3.5	DeleteDataSet.....	61
11.3.6	GetDataSetDirectory .....	62
12	Substitution model .....	63
13	SETTING-GROUP-CONTROL-BLOCK class model .....	65
13.1	General .....	65
13.2	SGCB class definition .....	66
13.2.1	SGCB class syntax.....	66
13.2.2	SGCB class attributes .....	67
13.3	SGCB class services.....	68
13.3.1	Overview.....	68
13.3.2	SelectActiveSG .....	68
13.3.3	SelectEditSG.....	69
13.3.4	SetSGValues .....	70
13.3.5	ConfirmEditSGValues.....	71
13.3.6	GetSGValues .....	71
13.3.7	GetSGCBValues .....	72
14	REPORT-CONTROL-BLOCK and LOG-CONTROL-BLOCK class models .....	74
14.1	Overview .....	74
14.2	REPORT-CONTROL-BLOCK class model .....	76
14.2.1	Basic concepts.....	76
14.2.2	BUFFERED-REPORT-CONTROL-BLOCK (BRCB) class definition.....	76
14.2.3	BRCB class services .....	82
14.2.4	UNBUFFERED-REPORT-CONTROL-BLOCK (URCB) class definition.....	94
14.2.5	URCB class services .....	95
14.3	LOG-CONTROL-BLOCK class model .....	96
14.3.1	General.....	96
14.3.2	LCB class definition.....	97

14.3.3	LOG class definition .....	101
14.3.4	Procedures to generate the log entries .....	104
14.3.5	LOG services .....	104
15	Generic substation event class model (GSE) .....	107
15.1	Overview .....	107
15.2	GOOSE-CONTROL-BLOCK (GoCB) class.....	109
15.2.1	GoCB definition .....	109
15.2.2	GOOSE service Definitions .....	111
15.2.3	Generic object oriented substation event (GOOSE) message.....	116
15.3	Generic substation state event (GSSE) control block (GsCB).....	117
15.3.1	GsCB class definition .....	117
15.3.2	Generic substation state event (GSSE) control block class attributes .....	119
15.3.3	GSSE service definitions .....	120
15.3.4	Generic substation state event (GSSE) message.....	124
16	Transmission of sampled value class model .....	126
16.1	Overview .....	126
16.2	Transmission of sampled values using multicast.....	127
16.2.1	MSVCB class definition .....	127
16.2.2	Multicast sampled value class services.....	129
16.3	Transmission of sampled values using unicast .....	132
16.3.1	USVCB class definition.....	132
16.3.2	Unicast sampled value services.....	134
16.4	Sampled value format .....	137
16.4.1	MsvID or UsvID .....	138
16.4.2	OptFlds.....	138
16.4.3	DatSet .....	138
16.4.4	Sample [1..n].....	138
16.4.5	SmpCnt.....	138
16.4.6	RefrTm .....	139
16.4.7	ConfRev.....	139
16.4.8	SmpSynch.....	139
16.4.9	SmpRate.....	139
17	CONTROL class model .....	139
17.1	Introduction.....	139
17.2	Control with normal security .....	140
17.2.1	Direct control with normal security .....	140
17.2.2	SBO control with normal security .....	141
17.3	Control with enhanced security.....	143
17.3.1	Introduction.....	143
17.3.2	Direct control with enhanced security.....	143
17.3.3	SBO control with enhanced security.....	144
17.4	Time-activated operate .....	146
17.5	CONTROL class service definitions.....	147
17.5.1	Overview.....	147
17.5.2	Service parameter definition .....	148
17.5.3	Service specification .....	150
18	Time and time-synchronization model.....	154
18.1	General .....	154
18.2	External information .....	154

19	Naming conventions .....	155
19.1	Class naming and class specializations .....	155
19.2	Referencing an instance of a class .....	156
19.3	Scope .....	158
20	File transfer .....	159
20.1	File transfer model .....	159
20.1.1	FileName .....	159
20.1.2	FileSize [0..1] .....	159
20.1.3	LastModified .....	159
20.2	File services .....	160
20.2.1	GetFile .....	160
20.2.2	SetFile .....	160
20.2.3	DeleteFile .....	161
20.2.4	GetFileAttributeValues .....	162
	Annex A (normative) ACSI conformance statement .....	163
A.1	General .....	163
A.2	ACSI models conformance statement .....	164
A.3	ACSI service conformance statement .....	165
	Bibliography .....	169
	Index .....	170
	Figure 1 – Excerpt of conceptual model .....	15
	Figure 2 – Basic conceptual class model of the ACSI .....	16
	Figure 3 – Conceptual service model of the ACSI .....	17
	Figure 4 – Data attribute type concept .....	20
	Figure 5 – Overview about GetDirectory and GetDefinition services .....	27
	Figure 6 – Access views of a server .....	30
	Figure 7 – Normal operation .....	31
	Figure 8 – Aborting association .....	31
	Figure 9 – Principle of multicast application association .....	35
	Figure 10 – Class diagram of DATA and DataAttributeType .....	43
	Figure 11 – Example of DATA .....	44
	Figure 12 – Relation of TrgOp and Reporting .....	50
	Figure 13 – Relation of DATA classes .....	52
	Figure 14 – Excerpt of data class services .....	53
	Figure 15 – Dynamic creation of data set instances .....	57
	Figure 16 – Principles of substitution .....	64
	Figure 17 – Basic model of the settings model .....	65
	Figure 18 – Setting group state machine .....	67
	Figure 19 – Basic building blocks for reporting and logging .....	75
	Figure 20 – BRCB state machine .....	78

Figure 21 – Buffer time .....	80
Figure 22 – Report example on the use of sequence number .....	84
Figure 23 – Data set members and reporting .....	86
Figure 24 – Report example.....	87
Figure 25 – Log model overview .....	96
Figure 26 – GoCB model .....	108
Figure 27 – Specifics for GsCB model.....	118
Figure 28 – Model for transmission of sampled values .....	126
Figure 29 – Principle of the control model .....	140
Figure 30 – State machine of direct control with normal security.....	141
Figure 31 – Direct control with normal security .....	141
Figure 32 – State machine of SBO control with normal security .....	142
Figure 33 – State machine of direct control with enhanced security .....	143
Figure 34 – State machine SBO control with enhanced security .....	144
Figure 35 – Select before operate with enhanced security – positive case .....	145
Figure 36 – Select before operate with enhanced security – negative case (no status change).....	145
Figure 37 – Time-activated operate .....	147
Figure 38 – Time model and time synchronization (principle).....	154
Figure 39 – Specializations .....	155
Figure 40 – Object names and object reference .....	158
Table 1 – ACSI classes .....	19
Table 2 – BasicTypes .....	21
Table 3 – ObjectName type .....	22
Table 4 – ObjectReference type.....	22
Table 5 – ServiceError type .....	23
Table 6 – PACKED-LIST type .....	23
Table 7 – TimeStamp type.....	24
Table 8 – TimeQuality definition.....	24
Table 9 – TimeAccuracy .....	25
Table 10 – TriggerConditions type .....	26
Table 11 – SERVER class definition .....	26
Table 12 – TWO-PARTY-APPLICATION-ASSOCIATION (TPAA) class definition.....	31
Table 13 – MULTICAST-APPLICATION-ASSOCIATION (MCAA) class definition .....	35
Table 14 – LOGICAL-DEVICE (LD) class definition .....	36
Table 15 – LOGICAL-NODE (LN) class definition .....	38
Table 16 – DATA class definition .....	45
Table 17 – DAType definition .....	46
Table 18 – Functional constraints .....	48
Table 19 – Trigger option.....	49
Table 20 – COMMON-DATA class definition .....	51
Table 21 – DATA-SET (DS) class definition .....	58

Table 22 – SGCB class definition.....	66
Table 23 – BRCB class definition.....	77
Table 24 – Report format specification.....	83
Table 25 – URCB class definition.....	94
Table 26 – LCB class definition.....	97
Table 27 – LOG class definition .....	102
Table 28 – GOOSE control block class definition .....	109
Table 29 – GOOSE message definition.....	116
Table 30 – GSSE control block class definition .....	118
Table 31 – GSSE message definition.....	125
Table 32 – MSVCB class definition .....	127
Table 33 – USVCB class definition.....	132
Table 34 – Sampled value (SV) format definition.....	138
Table 35 – Control services .....	147
Table 36 – Control time-stamp definition.....	148
Table 37 – Test status definition .....	148
Table 38 – Check condition definition.....	148
Table 39 – Additional cause diagnosis definition .....	149
Table 40 – AddCause semantic .....	149
Table 41 – TimeActivatedOperate response definition.....	150
Table 42 – List of ObjectReferences .....	156
Table 43 – FILE class definition.....	159
Table A.1 – Basic conformance statement .....	163
Table A.2 – ACSI models conformance statement.....	164
Table A.3 – ACSI service conformance statement.....	165

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**COMMUNICATION NETWORKS AND SYSTEMS IN SUBSTATIONS –****Part 7-2: Basic communication structure  
for substation and feeder equipment –  
Abstract communication service interface (ACSI)**

## FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organisation for standardisation comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardisation in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organisations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organisation for Standardisation (ISO) in accordance with conditions determined by agreement between the two organisations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61850-7-2 has been prepared by IEC technical committee 57: Power system control and associated communications.

The text of this standard is based on the following documents:

FDIS	Report on voting
57/612/FDIS	57/629/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

IEC 61850 consists of the following parts, under the general title *Communication networks and systems in substations*:

- Part 1: Introduction and overview <sup>1</sup>
- Part 2: Glossary <sup>1</sup>
- Part 3: General requirements
- Part 4: System and project management

---

<sup>1</sup> To be published.



- Part 5: Communication requirements for functions and device models <sup>2</sup>
- Part 6: Configuration description language for communication in electrical substations related to IEDs <sup>2</sup>
- Part 7-1: Basic communication structure for substation and feeder equipment – Principles and models
- Part 7-2: Basic communication structure for substation and feeder equipment – Abstract communication service interface (ACSI)
- Part 7-3: Basic communication structure for substation and feeder equipment – Common data classes
- Part 7-4: Basic communication structure for substation and feeder equipment – Compatible logical node classes and data classes
- Part 8-1: Specific communication service mapping (SCSM) – Mappings to MMS (ISO/IEC 9506-1 and ISO/IEC 9506-2) and to ISO/IEC 8802-3 <sup>2</sup>
- Part 9-1: Specific communication service mapping (SCSM) – Sampled values over serial unidirectional multidrop point to point link
- Part 9-2: Specific communication service mapping (SCSM) – Sampled values over ISO/IEC 8802-3 <sup>2</sup>
- Part 10: Conformance testing <sup>2</sup>

The committee has decided that the contents of this publication will remain unchanged until 2005. At this date the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition; or
- amended.

A bilingual version of this publication may be issued at a later date.

---

<sup>2</sup> To be published.

## INTRODUCTION

This document is part of a set of specifications which details a layered substation communication architecture. This architecture has been chosen to provide abstract definitions of classes and services such that the specifications are independent of specific protocol stacks, implementations, and operating systems.

The IEC 61850 series is intended to provide interoperability between a variety of substation and feeder devices. Communication between these devices is achieved by the definition of a hierarchical class model (for example, logical device, logical node, data, data set, report control, or log) and services provided by these classes (for example, get, set, report, define, delete) in parts IEC 61850-7-x.

This part of IEC 61850 defines the abstract communication service interface (ACSI) for use in the utility substation domain that require real-time cooperation of intelligent electronic devices. The ACSI has been defined so as to be independent of the underlying communication systems. Specific communication service mappings<sup>3</sup> (SCSM) are specified in part 8-x and part 9-x of this standard.

This part of IEC 61850 defines the abstract communication service interface in terms of

- a hierarchical class model of all information that can be accessed via a communication network,
- services that operate on these classes, and
- parameters associated with each service.

The ACSI description technique abstracts away from all the different approaches to implement the cooperation of the various devices.

NOTE 1 Abstraction in ACSI has two meanings. First, only those aspects of a real device (for example, a breaker) or a real function that are visible and accessible over a communication network are modelled. This abstraction leads to the hierarchical class models and their behaviour defined in IEC 61850-7-2, IEC 61850-7-3, and IEC 61850-7-4. Second, the ACSI abstracts from the aspect of concrete definitions on how the devices exchange information; only a conceptual cooperation is defined. The concrete information exchange is defined in the SCSMs.

NOTE 2 This part of IEC 61850 does not provide comprehensive tutorial material. It is recommended that IEC 61850-5 and IEC 61850-7-1 be read first in conjunction with IEC 61850-7-2 and IEC 61850-7-3.

NOTE 3 Examples use names of classes (e.g. XCBR for a class of a logical node) defined in IEC 61850-7-4 and IEC 61850-7-3. The normative names are defined in IEC 61850-7-4 and IEC 61850-7-3 only.

---

<sup>3</sup> The ACSI is independent of the specific mapping. Mappings to standard application layers or middle ware technologies are possible.

## **COMMUNICATION NETWORKS AND SYSTEMS IN SUBSTATIONS –**

### **Part 7-2: Basic communication structure for substation and feeder equipment – Abstract communication service interface (ACSI)**

#### **1 Scope**

This part of IEC 61850 applies to the ACSI communication in substations and feeder applications. The ACSI provides the following abstract interfaces.

- a) Abstract interface describing communications between a client and a remote server for
  - real-time data access and retrieval,
  - device control,
  - event reporting and logging,
  - publisher/subscriber,
  - self-description of devices (device data dictionary),
  - data typing and discovery of data types, and
  - file transfer.
- b) Abstract interface for fast and reliable system-wide event distribution between an application in one device and many remote applications in different devices (publisher/subscriber) and for transmission of sampled measured values (publisher/subscriber).

This part of IEC 61850 may also be applied to describe device models and functions for additional activities, such as:

- substation to substation information exchange,
- substation to control centre information exchange,
- power plant to control centre information exchange,
- information exchange for distributed generation, or
- information exchange for metering.

#### **2 Normative references**

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61850-2, *Communication networks and systems in substations – Part 2: Glossary*

IEC 61850-5, *Communication networks and systems in substations – Part 5: Communication requirements for functions and devices models*

IEC 61850-7-1, *Communication networks and systems in substations – Part 7-1: Basic communication structure for substation and feeder equipment – Principles and models*

IEC 61850-7-3, *Communication networks and systems in substations – Part 7-3: Basic communication structure for substation and feeder equipment – Common data classes*

IEC 61850-7-4, *Communication networks and systems in substations – Part 7-4: Basic communication structure for substation and feeder equipment – Compatible logical node classes and data classes*

IEC 61850-8-1: *Communication networks and systems in substations – Part 8-1: Specific communication service mapping (SCSM) – Mappings to MMS (ISO/IEC 9506-1 and ISO/IEC 9506-2) and to ISO/IEC 8802-3*