

INTERNATIONAL STANDARD

IEC
61850-9-1

First edition
2003-05

Communication networks and systems in substations –

Part 9-1: Specific Communication Service Mapping (SCSM) – Sampled values over serial unidirectional multidrop point to point link

© IEC 2003 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE

U

For price, see current catalogue

CONTENTS

FOREWORD	4
INTRODUCTION	6
1 Scope	7
2 Normative references	8
3 Terms and definitions	8
4 Abbreviations	8
5 Principle of mapping to the serial unidirectional multidrop point to point link	9
5.1 Communication stack	9
5.1.1 Physical layer	10
5.1.2 Link layer	11
5.1.3 Network layer	12
5.1.4 Transport layer	12
5.1.5 Session layer	12
5.1.6 Presentation layer	12
5.1.7 Application layer	12
5.2 Restrictions	12
6 Mapping of common types	12
6.1 Object name	12
6.2 Object reference	12
7 Mapping of the model for transmission of sampled values using multicast	13
7.1 Mapping of the multicast sampled values services	13
7.2 Mapping of the update of the sampled value buffer	14
7.3 Additional definitions for the transmission of sampled analogue values	14
7.3.1 Application layer functionality	14
7.3.2 Presentation layer functionality	15
7.3.3 Transport layer functionality	15
8 Mapping of the common data classes	16
8.1 Overview	16
8.2 Additional definitions for the mapping of the common data classes	16
Annex A (normative) Definition of data set instances and related multicast sampled value control instances	19
Annex B (informative) Calculation of required bandwidth	22
Annex C (informative) Definitions of logical node instance names and data names related to the data sets	24
Annex D (informative) Electronic transformers block diagram and configuration example	28

Figure 1 – Example for the use of the serial unidirectional multidrop point to point link	7
Figure 2 – Communication stack.....	10
Figure 3 – Concatenation of several ASDU's into one APDU	14
Figure A.1 – Data set for status indication.....	20
Figure B.1 – Ethernet Frame Format.....	23
Figure C.1 – Contents of the universal data set based on the specification in IEC 60044-8	27
Figure D.1 – Example for general block diagram of a single-phase electronic transformer	28
Figure D.2 – Example for electronic transformers configuration.....	29
Table 1 – Mapping of the object reference	13
Table 2 – Mapping of the multicast sampled value services.....	13
Table 3 – Encoding for the transmission of sampled value buffer	15
Table 4 – Extended common data class single point status information	16
Table 5 – Encoding of the common data class SPS used for the universal data set	16
Table 6 – Encoding of the common data class MV	17
Table 7 – Encoding of common data class SPS used for the status indication group.....	18
Table A.1 – Predefined multicast sampled value control block instances relating to the transmission of the Universal Data Set according to IEC 60044-8	19
Table A.2 – Predefined multicast sampled value control block instances relating to the transmission of status indications	21
Table B.1 – Selection guide for Ethernet physical layer (receiving node).....	22
Table B.2 – Selection guide for Ethernet physical layer (sending node)	22
Table C.1 – Definitions of logical instance name and data names related to the universal data set	24
Table C.2 – Definitions of logical instance name and data names related to the status indication data set	26

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMUNICATION NETWORKS AND SYSTEMS IN SUBSTATIONS –**Part 9-1: Specific Communication Service Mapping (SCSM) –
Sampled values over serial unidirectional multidrop
point to point link**

FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organisation for standardisation comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardisation in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organisations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organisation for Standardisation (ISO) in accordance with conditions determined by agreement between the two organisations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61850-9-1 has been prepared by IEC technical committee 57: Power system control and associated communications.

The text of this standard is based on the following documents:

FDIS	Report on voting
57/619/FDIS	57/636/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

IEC 61850 consists of the following parts, under the general title *Communication networks and systems in substations*.

- Part 1: Introduction and overview
- Part 2: Glossary ¹
- Part 3: General requirements
- Part 4: System and project management
- Part 5: Communication requirements for functions and devices models ²
- Part 6: Configuration description language for communication in electrical substations related to IEDs ¹
- Part 7-1: Basic communication structure for substation and feeder equipment – Principles and models
- Part 7-2: Basic communication structure for substation and feeder equipment – Abstract communication service interface (ACSI)
- Part 7-3: Basic communication structure for substation and feeder equipment – Common data classes
- Part 7-4: Basic communication structure for substation and feeder equipment – Compatible logical node classes and data classes
- Part 8-1: Specific communication service mapping (SCSM) – Mappings to MMS (ISO/IEC 9506-1 and ISO/IEC 9506-2) and to ISO/IEC 8802-3 ¹
- Part 9-1: Specific communication service mapping (SCSM) – Sampled values over serial unidirectional multidrop point to point link
- Part 9-2: Specific communication service mapping (SCSM) – Sampled values over ISO/IEC 8802-3 ¹
- Part 10: Conformance testing ¹

The relationship between IEC 60044-8 and this standard is as follows:

IEC 60044-8 defines a merging unit as interface to electronic current and voltage transformers. Data objects provided by that merging unit are specified in IEC 60044-8. This standard specifies a serial communication interface between the merging unit and equipment using the digital output of the merging unit like protection or metering equipment. For the specification of that serial interface, a subset of the abstract communication services defined in IEC 61850-7-2 are mapped on an ISO/IEC 8802-3 based communication link.

The committee has decided that the contents of this publication will remain unchanged until 2005. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

A bilingual version of this standard may be issued at a later date.

¹ Under consideration.

² To be published.

INTRODUCTION

This part of IEC 61850 applies to electronic current and voltage transformers (ECT and EVT) with a digital output via a merging unit, for use with electronic measuring instruments and electronic protective devices.

The transformer technology can be based on optical arrangements equipped with electronic components, on air core coils (with or without a built-in integrator) or, on iron core coils with integrated burden and used as a current to voltage converter, alone or equipped with electronic components.

For digital output, this standard takes into account a point to point connection from the merging unit to electronic measuring instruments and electronic devices.

This mapping allows interoperability between devices from different manufacturers.

This standard does not specify individual implementations or products, nor does it constrain the implementation of entities and interfaces within a computer system. This standard specifies the externally visible functionality of implementations.

Reading Guide


- The point to point transformer interface as defined here is based on the concepts described in IEC 60044-8. This standard extends this concept and proposes an alternative link layer to provide a solution for transmitting sampled measured values via Ethernet based interfaces. For the definition and measurement of the accuracy, synchronisation methods, data rates etc. of the transformers, refer to IEC 60044-8.
- This document can best be understood if the reader is thoroughly familiar with Parts 7-1, 7-2, 7-3 and 7-4 of this Standard.
- No explanations to the ACSI services are given in this part of the standard. For detailed information about the use of the ACSI services, refer to IEC 61850-7-2.

COMMUNICATION NETWORKS AND SYSTEMS IN SUBSTATIONS –

Part 9-1: Specific Communication Service Mapping (SCSM) – Sampled values over serial unidirectional multidrop point to point link

1 Scope

This part of IEC 61850 specifies the specific communication service mappings for the communication between bay and process level and it specifies a mapping on a serial unidirectional multidrop point to point link in accordance with IEC 60044-8. This part of IEC 61850 specifies a mapping of the abstract service for the transmission of sampled values (as defined in IEC 61850-7-2) on a serial unidirectional multidrop point to point link in accordance with IEC 60044-8. It applies to the communication between merging units of electronic current (ECT) or voltage-transformers (EVT) and bay devices such as protection relays. If higher requirements on sampling rate, further sampled measured value data sets in addition to the universal data set, inter-bay communication and synchronisation apply, these will be covered by IEC 61850-9-2³. Figure 1 shows the schematics of this interface.



IEC 812/03

Figure 1 – Example for the use of the serial unidirectional multidrop point to point link

³ Under consideration.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60044-7: *Instrument Transformers – Part 7: Electronic voltage transformers*

IEC 60044-8: *Instrument Transformers – Part 8: Electronic current transformers*

IEC 60874-10-1:1997, *Connectors for optical fibres and cables – Part 10-1: Detail specification for fibre optic connector type BFOC/2,5 terminated to multimode fibre type A1*

IEC 61850-7-2: *Communication networks and systems in substations – Part 7-2: Basic communication structure for substation and feeder equipment – Abstract communication service interface (ACSI)*

IEC 61850-7-3: *Communication networks and systems in substations – Part 7-3: Basic communication structure for substation and feeder equipment – Common data classes*

ISO/IEC 8802-3: *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications*

ISO/IEC 8825-1: *Information technology – ASN.1 encoding rules: Specification of Basic Encoding Rules (BER), Canonical Encoding Rules (CER) and Distinguished Encoding Rules (DER)*

IEEE 802.1Q-1998: *IEEE Standards for Local and Metropolitan Area Networks: Virtual Bridged Local Area Networks*

IEEE 802.3: *Information Technology – Telecommunication and Information Exchange Between Systems – LAN/MAN – Specific Requirements – Part 3: Carrier Sense Multiple Access with Collision Detection (CSMA/CD) Access Method and Physical Layer Specifications*