

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

Industriell processtyrning – Profiler – Del 1-3: Fältbussprofiler – Kommunikationsprofilfamilj 3

*Industrial networks –
Profiles –
Part 1-3: Fieldbus profiles –
Communication Profile Family 3*

Som svensk standard gäller europastandarden EN IEC 61784-1-3:2023. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 61784-1-3:2023.

Nationellt förord

Europastandarden EN IEC 61784-1-3:2023

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 61784-1-3, First edition, 2023 - Industrial networks - Profiles - Part 1-3: Fieldbus profiles - Communication Profile Family 3**

utarbetad inom International Electrotechnical Commission, IEC.

Standarden ersätter tillsammans med de andra delarna i samma serie tidigare fastställd svensk standard SS-EN IEC 61784-1, utg 4:2019 med eventuella tillägg, ändringar och rättelser, som ej gäller fr o m 2026-04-26.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English Version

Industrial networks - Profiles - Part 1-3: Fieldbus profiles -
Communication Profile Family 3
(IEC 61784-1-3:2023)

Réseaux industriels - Profils - Part 1-3: Profils de bus de
terrain - Famille de profils de communication 3
(IEC 61784-1-3:2023)

Industrielle Kommunikationsnetze - Profile - Teil 1-3:
Feldbusprofile - Kommunikationsprofilfamilie (CPF) 3
(IEC 61784-1-3:2023)

This European Standard was approved by CENELEC on 2023-04-26. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 65C/1207/FDIS, future edition 1 of IEC 61784-1-3, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61784-1-3:2023.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2024-01-26
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2026-04-26

This document, together with other parts of the same series, partially supersedes EN IEC 61784-1:2019 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 61784-1-3:2023 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

IEC 60079-14	NOTE Approved as EN 60079-14
IEC 60793 (series)	NOTE Approved as EN IEC 60793 (series)
IEC 61131-3	NOTE Approved as EN 61131-3
IEC 61158-1	NOTE Approved as EN IEC 61158-1
IEC 61158-3 (series)	NOTE Approved as EN 61158-3 (series)
IEC 61158-4 (series)	NOTE Approved as EN 61158-4 (series)
IEC 61158-5 (series)	NOTE Approved as EN 61158-5 (series)
IEC 61158-5-10	NOTE Approved as EN IEC 61158-5-10
IEC 61158-6 (series)	NOTE Approved as EN 61158-6 (series)
IEC 61158-6-10	NOTE Approved as EN IEC 61158-6-10
IEC 61784-1 (series)	NOTE Approved as EN IEC 61784-1 (series)
IEC 61784-2 (series)	NOTE Approved as EN IEC 61784-2 (series)

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60079-11	-	Electrical apparatus for explosive gas atmospheres - Part 11: Intrinsic safety "i"	EN 60079-11	-
IEC 60079-25	-	Explosive atmospheres - Part 25: Intrinsically safe electrical systems	EN IEC 60079-25	-
IEC 61010	series	Safety requirements for electrical equipment for measurement, control, and laboratory use	EN IEC 61010	series
IEC 61131-2	-	Industrial-process measurement and control - Programmable controllers - Part 2: Equipment requirements and tests	EN 61131-2	-
IEC 61158	series	Industrial communication networks - Fieldbus specifications	EN IEC 61158	series
IEC 61158-2	2023	Industrial communication networks - Fieldbus specifications - Part 2: Physical layer specification and service definition	EN IEC 61158-2	2023
IEC 61158-3-3	2014	Industrial communication networks - Fieldbus specifications - Part 3-3: Data-link layer service definition - Type 3 elements	EN 61158-3-3	2014
IEC 61158-4-3	2019	Industrial communication networks - Fieldbus specifications - Part 4-3: Data-link layer protocol specification - Type 3 elements	EN IEC 61158-4-3	2019
IEC 61158-5-3	2014	Industrial communication networks - Fieldbus specifications - Part 5-3: Application layer service definition - Type 3 elements	EN 61158-5-3	2014
IEC 61158-6-3	2019	Industrial communication networks - Fieldbus specifications - Part 6-3: Application layer protocol specification - Type 3 elements	EN IEC 61158-6-3	2019

EN IEC 61784-1-3:2023 (E)

IEC 61784-1-0	2023	Industrial networks - Profiles - Part 1-0: Fieldbus profiles - General concepts and terminology	EN IEC 61784-1-0	2023
IEC 61784-2-3	2023	Industrial networks - Profiles - Part 2-3: Additional real-time fieldbus profiles based on ISO/IEC/IEEE 8802-3 - CPF 3	EN IEC 61784-2-3	2023
ISO 15745-3	2003	Industrial automation systems and integration - Open systems application integration framework - Part 3: Reference description for IEC 61158 based control systems	-	-
TIA-485-A	1998	Electrical Characteristics of Generators and Receivers for Use in Balanced Digital Multipoint Systems	-	-

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Industrial networks – Profiles –
Part 1-3: Fieldbus profiles – Communication Profile Family 3**

**Réseaux industriels – Profils –
Partie 1-3: Profils de bus de terrain – Famille de profils de communication 3**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 35.100.20; 35.240.50

ISBN 978-2-8322-6587-1

Warning! Make sure that you obtained this publication from an authorized distributor. Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.
--

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references	9
3 Terms, definitions, abbreviated terms, symbols, and conventions	10
3.1 Terms and definitions.....	10
3.2 Abbreviations and symbols	10
3.2.1 Common abbreviations and symbols.....	10
3.2.2 Other abbreviations and symbols.....	10
3.3 Conventions.....	10
4 CPF 3 (PROFIBUS & PROFINET)	11
4.1 General overview.....	11
4.2 CP 3/1 (PROFIBUS DP).....	12
4.2.1 Physical layer	12
4.2.2 Data-link layer	14
4.2.3 Application layer.....	39
4.3 CP 3/2 (PROFIBUS PA).....	95
4.3.1 Physical layer	95
4.3.2 Data-link layer	99
4.3.3 Application layer.....	111
Annex A (informative) CPF 3 (PROFIBUS & PROFINET) communication concepts	112
A.1 Basic characteristics	112
A.1.1 General	112
A.1.2 PROFIBUS DP	112
A.2 Physical layer profiles	113
A.3 Communication feature list (GSD).....	113
Bibliography.....	115
Figure 1 – CP 3/2 Slave devices usable in applications.....	12
Table 1 – CPF 3: overview of profile sets.....	11
Table 2 – CP 3/1: PhL selection.....	12
Table 3 – CP 3/1: PhL selection of Clause 3	14
Table 4 – CP 3/1: PhL selection of Clause 4	14
Table 5 – CP 3/1: General DLL service selection	15
Table 6 – CP 3/1: DLL service selection for DP-V0 master (class 1)	16
Table 7 – CP 3/1: DLM service selection for DP-V0 master (class 1).....	17
Table 8 – CP 3/1: DLL service selection for DP-V1 master (class 1)	18
Table 9 – CP 3/1: DLM service selection for DP-V1 master (class 1).....	19
Table 10 – CP 3/1: DLL service selection for DP-V0 master (class 2).....	19
Table 11 – CP 3/1: DLL service selection for DP-V1 master (class 2).....	20
Table 12 – CP 3/1: DLL service selection for DP-V0 slave	22
Table 13 – CP 3/1: DLM service selection for DP-V0 slave	23
Table 14 – CP 3/1: DLL service selection for DP-V1 slave	24

Table 15 – CP 3/1: DLM service selection for DP-V1 slave	25
Table 16 – CP 3/1: General DLL protocol selection	26
Table 17 – CP 3/1: DLL protocol selection of Clause 5.....	26
Table 18 – CP 3/1: DLL protocol selection of Clause 6.....	27
Table 19 – CP 3/1: DLL protocol selection of Clause 7.....	27
Table 20 – CP 3/1: Time variable selection for DP-V0 master (class 1).....	28
Table 21 – CP 3/1: Timer and counter selection for DP-V0 master (class 1).....	29
Table 22 – CP 3/1: DLPDU selection for DP-V0 master (class 1)	29
Table 23 – CP 3/1: MAC state selection for DP-V0 master (class 1).....	30
Table 24 – CP 3/1: Time selection for DP-V1 master (class 1)	31
Table 25 – CP 3/1: Timer and counter selection for DP-V1 master (class 1).....	32
Table 26 – CP 3/1: DLPDU selection for DP-V1 master (class 1)	32
Table 27 – CP 3/1: MAC state selection for DP-V1 master (class 1).....	33
Table 28 – CP 3/1: CS protocol selection for DP-V1 master (class 1).....	33
Table 29 – CP 3/1: Time selection for DP-V1 master (class 2)	34
Table 30 – CP 3/1: Timer and counter selection for DP-V1 master (class 2).....	34
Table 31 – CP 3/1: DLPDU selection for DP-V1 master (class 2)	35
Table 32 – CP 3/1: Time selection for DP-V0 slave	35
Table 33 – CP 3/1: Timer and counter selection for DP-V0 slave	36
Table 34 – CP 3/1: DLPDU selection for DP-V0 slave	36
Table 35 – CP 3/1: MAC state selection for DP-V0 slave	37
Table 36 – CP 3/1: Time selection for DP-V1 slave	37
Table 37 – CP 3/1: Timer and counter selection for DP-V1 slave	38
Table 38 – CP 3/1: DLPDU selection for DP-V1 slave	38
Table 39 – CP 3/1: CS protocol selection for DP-V1 slave	39
Table 40 – CP 3/1, 3/2: AL service selection.....	39
Table 41 – CP 3/1, 3/2: AL service selection of Clause 6	40
Table 42 – CP 3/1, 3/2: AL service selection of I/O data ASE.....	40
Table 43 – CP 3/1, 3/2: AL service selection of Diagnosis ASE.....	41
Table 44 – CP 3/1, 3/2: AL service selection of Context ASE	41
Table 45 – CP 3/1, 3/2: AL service selection of Management ASE	42
Table 46 – CP 3/1, 3/2: AL service selection of AR ASE	43
Table 47 – CP 3/1, 3/2: AL service selection of Clause 6	44
Table 48 – CP 3/1, 3/2: AL service selection of Process data ASE.....	44
Table 49 – CP 3/1, 3/2: AL service selection of I/O data ASE.....	45
Table 50 – CP 3/1, 3/2: AL service selection of Alarm ASE	45
Table 51 – CP 3/1, 3/2: AL service selection of Context ASE	45
Table 52 – CP 3/1, 3/2: AL service selection of Load region ASE.....	46
Table 53 – CP 3/1, 3/2: AL service selection of Function invocation ASE.....	46
Table 54 – CP 3/1, 3/2: AL service selection of Time ASE	46
Table 55 – CP 3/1, 3/2: AL service selection of AR ASE	47
Table 56 – CP 3/1, 3/2: AL service selection of Clause 6	48
Table 57 – CP 3/1, 3/2: AL service selection of I/O data ASE.....	48

Table 58 – CP 3/1, 3/2: AL service selection of Diagnosis ASE	49
Table 59 – CP 3/1, 3/2: AL service selection of Context ASE	49
Table 60 – CP 3/1, 3/2: AL service selection of Management ASE	49
Table 61 – CP 3/1, 3/2: AL service selection of AR ASE	50
Table 62 – CP 3/1, 3/2: AL service selection of Clause 6	51
Table 63 – CP 3/1, 3/2: AL service selection of Process data ASE	51
Table 64 – CP 3/1, 3/2: AL service selection of Context ASE	52
Table 65 – CP 3/1, 3/2: AL service selection of Load region ASE	52
Table 66 – CP 3/1, 3/2: AL service selection of Function invocation ASE	53
Table 67 – CP 3/1, 3/2: AL service selection of Time ASE	53
Table 68 – CP 3/1, 3/2: AL service selection of AR ASE	54
Table 69 – CP 3/1, 3/2: AL service selection of Clause 6	55
Table 70 – CP 3/1, 3/2: AL service selection of I/O data ASE	56
Table 71 – CP 3/1, 3/2: AL service selection of Diagnosis ASE	57
Table 72 – CP 3/1, 3/2: AL service selection of Context ASE	58
Table 73 – CP 3/1, 3/2: AL service selection of AR ASE	59
Table 74 – CP 3/1, 3/2: AL service selection of Clause 6	60
Table 75 – CP 3/1, 3/2: AL service selection of Process data ASE	60
Table 76 – CP 3/1, 3/2: AL service selection of I/O data ASE	61
Table 77 – CP 3/1, 3/2: AL service selection of diagnosis ASE	61
Table 78 – CP 3/1, 3/2: AL service selection of Alarm ASE	62
Table 79 – CP 3/1, 3/2: AL service selection of Context ASE	62
Table 80 – CP 3/1, 3/2: AL service selection of Load region ASE	63
Table 81 – CP 3/1, 3/2: AL service selection of Function invocation ASE	63
Table 82 – CP 3/1, 3/2: AL service selection of Time ASE	63
Table 83 – CP 3/1, 3/2: AL service selection of AR ASE	64
Table 84 – CP 3/1, 3/2: AL protocol selection	65
Table 85 – CP 3/1, 3/2: AL protocol selection of Clause 4 to 11	65
Table 86 – CP 3/1, 3/2: AL protocol selection of APDUs	67
Table 87 – CP 3/1, 3/2: AL protocol selection of FSPM services primitives	68
Table 88 – CP 3/1, 3/2: AL protocol selection of DMPM services primitives	69
Table 89 – CP 3/1, 3/2: AL protocol selection of Clause 4 to 11	69
Table 90 – CP 3/1, 3/2: AL protocol selection of APDUs	71
Table 91 – CP 3/1, 3/2: AL protocol selection of FSPM services primitives	72
Table 92 – CP 3/1, 3/2: AL protocol selection of DMPM services primitives	74
Table 93 – CP 3/1, 3/2: AL protocol selection of Clause 4 to 6	74
Table 94 – CP 3/1, 3/2: AL protocol selection of APDUs	76
Table 95 – CP 3/1, 3/2: AL protocol selection of FSPM services primitives	77
Table 96 – CP 3/1, 3/2: AL protocol selection of DMPM services primitives	77
Table 97 – CP 3/1, 3/2: AL protocol selection of Clause 4 to 11	78
Table 98 – CP 3/1, 3/2: AL protocol selection of APDUs	80
Table 99 – CP 3/1, 3/2: AL protocol selection of FSPM services primitives	82
Table 100 – CP 3/1, 3/2: AL protocol selection of DMPM services primitives	83

Table 101 – CP 3/1, 3/2: AL protocol selection of Clause 4 to 11	83
Table 102 – CP 3/1, 3/2: AL protocol selection of APDU selection	85
Table 103 – CP 3/1, 3/2: AL protocol selection of FSPM services primitives.....	86
Table 104 – CP 3/1, 3/2: AL protocol selection of DMPM services primitives.....	87
Table 105 – CP 3/1, 3/2: AL protocol selection of Clause 4 to 11	87
Table 106 – CP 3/1, 3/2: AL protocol selection of APDUs	89
Table 107 – CP 3/1, 3/2: AL protocol selection of FSPM services primitives.....	91
Table 108 – CP 3/1, 3/2: AL protocol selection of DMPM services primitives.....	93
Table 109 – CP 3/2: PhL selection	95
Table 110 – CP 3/2: PhL selection of Clause 12 for devices and their MAUs.....	97
Table 111 – CP 3/2: PhL selection of recommended IS parameters	98
Table 112 – CP 3/2: PhL selection of Clause 21 for devices and their MAUs.....	98
Table 113 – CP 3/2: General DLL protocol selection	100
Table 114 – CP 3/2: DLL protocol selection of Clause 4.....	100
Table 115 – CP 3/2: DLL protocol selection of Clause 5.....	101
Table 116 – CP 3/2: DLL protocol selection of Clause 6.....	101
Table 117 – CP 3/2: DLL protocol selection of Clause 7	102
Table 118 – CP 3/2: Time variable selection for DP-V0 master (class 1).....	103
Table 119 – CP 3/2: Timer and counter selection for DP-V0 master (class 1).....	103
Table 120 – CP 3/2: DLPDU selection for DP-V0 master (class 1)	104
Table 121 – CP 3/2: Time variable selection for DP-V1 master (class 1).....	105
Table 122 – CP 3/2: Timer and counter selection for DP-V1 master (class 1).....	106
Table 123 – CP 3/2: DLPDU selection for DP-V1 master (class 1)	106
Table 124 – CP 3/2: Time variable selection for DP-V1 master (class 2).....	107
Table 125 – CP 3/2: Timer and counter selection for DP-V1 master (class 2).....	108
Table 126 – CP 3/2: DLPDU selection for DP-V1 master (class 2)	108
Table 127 – CP 3/2: Time variable selection for DP-V0 slave.....	109
Table 128 – CP 3/2: Timer and counter selection for DP-V0 slave	109
Table 129 – CP 3/2: DLPDU selection for DP-V0 slave	110
Table 130 – CP 3/2: Time variable selection for DP-V1 slave.....	110
Table 131 – CP 3/2: Timer and counter selection for DP-V1 slave	111
Table 132 – CP 3/2: DLPDU selection for DP-V1 slave	111

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL NETWORKS –
PROFILES –****Part 1-3: Fieldbus profiles –
Communication Profile Family 3****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of some of the associated protocol types is restricted by their intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by their respective intellectual property right holders.

NOTE Combinations of protocol types are specified in the IEC 61784-1 series and the IEC 61784-2 series.

IEC 61784-1-3 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation. It is an International Standard.

This first edition, together with the other parts of the same series, cancels and replaces the fifth edition of IEC 61784-1 published in 2019. This first edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to IEC 61784-1:2019:

- a) split of the original IEC 61784-1 into several subparts, one subpart for the material of a generic nature, and one subpart for each Communication Profile Family specified in the original document.

The text of this International Standard is based on the following documents:

Draft	Report on voting
65C/1207/FDIS	65C/1236/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 61784-1 series, published under the general title *Industrial networks – Profiles – Part 1: Fieldbus profiles*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

The IEC 61784-1 series provides a set of Communication Profiles (CP) in the sense of ISO/IEC TR 10000-1. These answer the need of identifying the protocol families co-existing within the IEC 61158 series, as a result of the international harmonization of fieldbus technologies available on the market. More specifically, these profiles help to correctly state the compliance with the IEC 61158 series, and to avoid the spreading of divergent implementations, which would limit its use, clearness and understanding. Additional profiles to address specific market concerns, such as functional safety or information security, can be addressed by future parts of the IEC 61784-1 series.

The IEC 61784-1 series contains several Communication Profile Families (CPF), which specify one or more communication profiles. Such profiles identify, in a strict sense, protocol subsets of the IEC 61158 series via protocol specific communication profiles. They do not define device profiles that specify communication profiles together with application functions needed to answer the need of a specific application ("application profiles").

It is agreed that these latter classes of profiles would facilitate the use of the IEC 61158 series of standards; the profiles defined in the IEC 61784-1 series are a necessary step to achieve that task.

It is also important to clarify that interoperability – defined as the ability of two or more network systems to exchange information and to make mutual use of the information that has been exchanged (see ISO/IEC TR 10000-1) – can be directly achieved on the same link only for those devices complying with the same communication profile.

Profiles contained in the IEC 61784-1 series are constructed of references to IEC 61158-2 and the IEC 61158-3, IEC 61158-4, IEC 61158-5 and IEC 61158-6 series, and other IS, TS or worldwide-accepted standards, as appropriate¹. Each profile is required to reference at least one part of the IEC 61158 series in addition to IEC 61158-1.

Two or more Profiles, which are related to a common family, are specified within a "Communication Profile Family" (CPF).

¹ International Standardised Profiles may contain normative references to specifications other than International Standards; see ISO/IEC JTC 1 N 4047: *The Normative Referencing of Specifications other than International Standards in JTC 1 International Standardized Profiles – Guidelines for ISP Submitters*.

INDUSTRIAL NETWORKS – PROFILES –

Part 1-3: Fieldbus profiles – Communication Profile Family 3

1 Scope

This part of IEC 61784-1 defines Communication Profile Family 3 (CPF 3). CPF 3 specifies a set of protocol specific communication profiles (CPs) based on the IEC 61158 series (Type 3 and Type 10) and other standards, to be used in the design of devices involved in communications in factory manufacturing and process control.

NOTE 1 All CPs are based on standards or draft standards or International Standards published by the IEC or on standards or International Standards established by other standards bodies or open standards processes.

NOTE 2 Some CPs of CPF 3 are specified in IEC 61784-2-3.

Each CP selects an appropriate consistent and compatible subset of services and protocols from the relevant set that is defined and modelled in the IEC 61158 series. For the selected subset of services and protocols, the profile also describes any possible or necessary constraints in parameter values.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE All parts of the IEC 61158 series, as well as the IEC 61784-1 series and the IEC 61784-2 series are maintained simultaneously. Cross-references to these documents within the text therefore refer to the editions as dated in this list of normative references.

IEC 60079-11, *Explosive atmospheres – Part 11: Equipment protection by intrinsic safety "i"*

IEC 60079-25, *Explosive atmospheres – Part 25: Intrinsically safe electrical systems*

IEC 61010 (all parts), *Safety requirements for electrical equipment for measurement, control and laboratory use*

IEC 61131-2, *Industrial-process measurement and control – Programmable controllers – Part 2: Equipment requirements and tests*

IEC 61158 (all parts), *Industrial communication networks – Fieldbus specifications*

IEC 61158-2:2023, *Industrial communication networks – Fieldbus specifications – Part 2: Physical layer specification and service definition*

IEC 61158-3-3:2014, *Industrial communication networks – Fieldbus specifications – Part 3-3: Data-link layer service definition – Type 3 elements*

IEC 61158-4-3:2019, *Industrial communication networks – Fieldbus specifications – Part 4-3: Data-link layer protocol specification – Type 3 elements*

IEC 61158-5-3:2014, *Industrial communication networks – Fieldbus specifications – Part 5-3: Application layer service definition – Type 3 elements*

IEC 61158-6-3:2019, *Industrial communication networks – Fieldbus specifications – Part 6-3: Application layer protocol specification – Type 3 elements*

IEC 61784-1-0:2023, *Industrial networks – Profiles – Part 1-0: Fieldbus profiles – General concepts and terminology*

IEC 61784-2-3:2023, *Industrial networks – Profiles – Part 2-3: Additional real-time fieldbus profiles based on ISO/IEC/IEEE 8802-3 – CPF 3*

ISO 15745-3:2003, *Industrial automation systems and integration – Open systems application integration framework – Part 3: Reference description for IEC 61158-based control systems*

TIA-485-A:1998, *Electrical Characteristics of Generators and Receivers for Use in Balanced Digital Multipoint Systems*