

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

## Kopplingsapparater för spänning över 1 kV – Del 103: Lastbrytare och lastfrånskiljare för växelström, med märkspänning över 1 kV men högst 52 kV

*High-voltage switchgear and controlgear –*

*Part 103: Switches for rated voltages above 1 kV up to and including 52 kV*

Som svensk standard gäller europastandarden EN IEC 62271-103:2023. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 62271-103:2023.

### Nationellt förord

Europastandarden EN IEC 62271-103:2023

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 62271-103, Second edition, 2021 - High-voltage switchgear and controlgear –  
Part 103: Switches for rated voltages above 1 kV up to  
and including 52 kV**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 62271-103, utg 1:2012 med eventuella tillägg, ändringar och rättelser gäller ej fr o m 2026-11-10.

---

ICS 29.130.10

---

Denna standard är fastställd av SEK Svensk Elstandard,  
som också kan lämna upplysningar om **sakinnehållet** i standarden.  
Postadress: Box 1284, 164 29 KISTA  
Telefon: 08 - 444 14 00.  
E-post: [sek@elstandard.se](mailto:sek@elstandard.se). Internet: [www.elstandard.se](http://www.elstandard.se)

---

### *Standarder underlättar utvecklingen och höjer elsäkerheten*

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

### *SEK är Sveriges röst i standardiseringsarbetet inom elområdet*

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

### *Stora delar av arbetet sker internationellt*

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

### *Var med och påverka!*

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

### **SEK Svensk Elstandard**

Box 1284  
164 29 Kista  
Tel 08-444 14 00  
[www.elstandard.se](http://www.elstandard.se)

English Version

High-voltage switchgear and controlgear - Part 103: Alternating  
current switches for rated voltages above 1 kV up to and  
including 52 kV  
(IEC 62271-103:2021)

Appareillage à haute tension - Partie 103: Interrupteurs à  
courant alternatif pour tensions assignées supérieures à  
1 kV et inférieures ou égales à 52 kV  
(IEC 62271-103:2021)

Hochspannungs-Schaltgeräte und -Schaltanlagen -  
Teil 103: Lastschalter für Bemessungsspannungen über 1  
kV bis einschließlich 52 kV  
(IEC 62271-103:2021)

This European Standard was approved by CENELEC on 2021-06-15. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

## **European foreword**

The text of document 17A/1297/FDIS, future edition 2 of IEC 62271-103, prepared by SC 17A "Switching devices" of IEC/TC 17 "High-voltage switchgear and controlgear" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62271-103:2023.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2024-05-10 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2026-11-10 document have to be withdrawn

This document supersedes EN 62271-103:2011 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

## **Endorsement notice**

The text of the International Standard IEC 62271-103:2021 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60059	NOTE	Harmonized as EN 60059
IEC 62271-105	NOTE	Harmonized as EN 62271-105
IEC 62271-200	NOTE	Harmonized as EN 62271-200
IEC 62271-201	NOTE	Harmonized as EN 62271-201
IEC 60507	NOTE	Harmonized as EN 60507
IEC 62271-100	NOTE	Harmonized as EN 62271-100
IEC 60071-1	NOTE	Harmonized as EN IEC 60071-1

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: [www.cenelec.eu](http://www.cenelec.eu).

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-441	-	International Electrotechnical Vocabulary. Switchgear, controlgear and fuses	-	-
IEC 60529	1989	Degrees of protection provided by enclosures (IP Code)	EN 60529	1991
-	-		+ corrigendum May	1993
+ A1	1999		+ A1	2000
+ A2	2013		+ A2	2013
IEC 62262	2002	Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)	EN 62262	2002
IEC 62271-1	2017	High-voltage switchgear and controlgear - Part 1: Common specifications for alternating current switchgear and controlgear	EN 62271-1	2017
IEC 62271-102	2018	High-voltage switchgear and controlgear - Part 102: Alternating current disconnectors and earthing switches	EN IEC 62271-102	2018
IEC 62271-110	2017	High-voltage switchgear and controlgear - Part 110: Inductive load switching	EN IEC 62271-110	2018

## **Annex ZB** (informative)

### **A-deviations**

**A-deviation:** National deviation due to regulations, the alteration of which is for the time being outside the competence of the CEN and/or CENELEC member.

This European Standard does not fall under any Directive/Regulation of the EU.

In the relevant CEN and/or CENELEC countries, these A-deviations are valid instead of the respective provisions of the European Standard until the national situation causing the A-deviation has changed

<u>Clause</u>	<u>Deviation</u>
---------------	------------------

General	<b>Italy</b>
---------	--------------

CAPITOLO VSR 8.B D.M. 1 DICEMBRE 1980 e succ. Modifiche

Disciplina dei contenitori a pressione di gas con membrane miste di materiale isolante e di materiale metallico, contenenti parti attive di apparecchiature elettriche.

Gas filled compartments having a design pressure exceeding 0,5 bar (gauge) or a volume exceeding 2 m<sup>3</sup> shall be designed according to the Italian pressure vessel code for electrical switchgear.

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE



---

**High-voltage switchgear and controlgear –  
Part 103: Alternating current switches for rated voltages above 1 kV up to and  
including 52 kV**

**Appareillage à haute tension –  
Partie 103: Interrupteurs à courant alternatif pour tensions assignées  
supérieures à 1 kV et inférieures ou égales à 52 kV**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

---

ICS 29.130.10

ISBN 978-2-8322-9770-4

<p><b>Warning! Make sure that you obtained this publication from an authorized distributor.</b></p> <p><b>Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.</b></p>
--

## CONTENTS

FOREWORD .....	8
1 Scope .....	10
2 Normative references .....	10
3 Terms and definitions .....	11
3.1 General terms and definitions .....	11
3.2 Assemblies of switchgear and controlgear .....	11
3.3 Parts of assemblies .....	11
3.4 Switching devices .....	12
3.5 Parts of switchgear and controlgear .....	12
3.6 Operational characteristics of switchgear and controlgear .....	13
3.7 Characteristic quantities .....	13
3.8 Index of definitions .....	17
4 Normal and special service conditions .....	18
5 Ratings .....	18
5.1 General .....	18
5.2 Rated voltage ( $U_r$ ) .....	18
5.3 Rated insulation level ( $U_d$ , $U_p$ , $U_s$ ) .....	18
5.4 Rated frequency ( $f_r$ ) .....	18
5.5 Rated continuous current ( $I_r$ ) .....	18
5.6 Rated short-time withstand current ( $I_k$ ) .....	19
5.7 Rated peak withstand current ( $I_p$ ) .....	19
5.8 Rated duration of short-circuit ( $t_k$ ) .....	19
5.9 Rated supply voltage of auxiliary circuits and control circuits ( $U_a$ ) .....	19
5.10 Rated supply frequency of auxiliary and control circuits .....	19
5.11 Rated pressure of compressed gas supply for controlled pressure systems .....	19
5.101 Rated mainly active load-breaking current ( $I_{load}$ ) .....	19
5.102 Rated closed-loop breaking current ( $I_{loop}$ ) .....	19
5.103 Rated parallel power transformer breaking current for special purpose switches ( $I_{pptr}$ ) .....	19
5.104 Rated cable-charging breaking current ( $I_{cc}$ ) .....	19
5.105 Rated line-charging breaking current ( $I_{lc}$ ) .....	19
5.106 Rated single capacitor bank breaking current for special purpose switches ( $I_{sb}$ ) .....	20
5.107 Rated back-to-back capacitor bank breaking current for special purpose switches ( $I_{bb}$ ) .....	20
5.108 Rated back-to-back capacitor bank inrush making current for special purpose switches ( $I_{in}$ ) .....	20
5.109 Rated earth fault breaking current ( $I_{ef1}$ ) .....	20
5.110 Rated cable- and line-charging breaking current under earth fault conditions ( $I_{ef2}$ ) .....	20
5.111 Rated motor breaking current for special purpose switches ( $I_{mot}$ ) .....	20
5.112 Rated short-circuit making current ( $I_{ma}$ ) .....	21
5.113 Types of switches and their associated ratings .....	21

5.113.1	Types of switches .....	21
5.113.2	Rated making and breaking currents for general purpose switches .....	21
5.113.3	Rated making and breaking currents for limited purpose switches .....	22
5.113.4	Rated making and breaking currents for special purpose switches .....	22
5.113.5	Ratings for switches backed by fuses .....	22
5.114	Mechanical endurance class of switches .....	23
5.114.1	Class M1 switch .....	23
5.114.2	Class M2 switch .....	23
5.115	Electrical endurance class of general purpose switches .....	23
5.115.1	Class E1 general purpose switch .....	23
5.115.2	Class E2 general purpose switch .....	23
5.115.3	Class E3 general purpose switch .....	23
5.116	Capacitive breaking capability class of switches .....	23
5.116.1	General .....	23
5.116.2	Class C1 switch .....	23
5.116.3	Class C2 switch .....	24
6	Design and construction .....	24
6.1	Requirements for liquids in switchgear and controlgear .....	24
6.2	Requirements for gases in switchgear and controlgear .....	24
6.3	Earthing of switchgear and controlgear .....	24
6.4	Auxiliary and control equipment and circuits .....	24
6.5	Dependent power operation .....	24
6.6	Stored energy operation .....	24
6.7	Independent unlatched operation (independent manual or power operation) .....	24
6.8	Manually operated actuators .....	24
6.9	Operation of releases .....	24
6.10	Pressure/level indication .....	24
6.11	Nameplates .....	25
6.11.1	General .....	25
6.11.2	Application .....	25
6.12	Locking devices .....	27
6.13	Position indication .....	27
6.14	Degrees of protection provided by enclosures .....	27
6.15	Creepage distances for outdoor insulators .....	27
6.16	Gas and vacuum tightness .....	27
6.17	Tightness for liquid systems .....	27
6.18	Fire hazard (flammability) .....	27
6.19	Electromagnetic compatibility (EMC) .....	28
6.20	X-ray emission .....	28
6.21	Corrosion .....	28
6.22	Filling levels for insulation, switching and/or operation .....	28
6.101	Making and breaking operations .....	28
6.102	Requirements for switch-disconnectors .....	28
6.103	Mechanical strength .....	28
6.104	Securing the position .....	28
6.105	Indication and signalling of position .....	28
6.105.1	General requirements .....	28
6.105.2	Indication of position .....	29
6.105.3	Signalling of position by auxiliary contacts .....	30

6.106	No-load transformer breaking.....	30
7	Type tests .....	30
7.1	General.....	30
7.1.1	Basics .....	30
7.1.2	Information for identification of test objects.....	31
7.1.3	Information to be included in the type-test reports .....	31
7.2	Dielectric tests .....	31
7.2.9	Artificial pollution tests for outdoor insulators.....	31
7.2.10	Partial discharge tests .....	31
7.3	Radio interference voltage (RIV) test .....	31
7.4	Resistance measurement.....	32
7.5	Continuous current tests .....	32
7.6	Short-time withstand current and peak withstand current tests.....	32
7.6.1	General .....	32
7.6.2	Arrangement of the equipment and of the test circuit .....	32
7.6.3	Test current and duration.....	32
7.6.4	Conditions of the test object after test.....	32
7.7	Verification of the protection .....	32
7.8	Tightness tests .....	32
7.9	Electromagnetic compatibility (EMC) tests .....	32
7.10	Additional tests on auxiliary and control circuits .....	32
7.10.1	General .....	32
7.10.2	Functional tests .....	32
7.10.3	Verification of the operational characteristics of auxiliary contacts .....	33
7.10.4	Environmental tests .....	33
7.10.5	Dielectric test .....	33
7.11	X-radiation test for vacuum interrupters .....	33
7.101	Making and breaking tests .....	33
7.101.1	Test duties for general purpose switches .....	33
7.101.2	Test duties for limited purpose switches .....	36
7.101.3	Test duties for special purpose switches.....	36
7.101.4	Arrangement of the switch for tests.....	37
7.101.5	Earthing of test circuit and switch .....	38
7.101.6	Test parameters .....	38
7.101.7	Test circuits.....	41
7.101.8	Behaviour of switch during breaking tests .....	56
7.101.9	Condition of switch after breaking tests and short-circuit making tests .....	57
7.101.10	Type-test reports .....	57
7.102	Mechanical and environmental tests .....	59
7.102.1	Miscellaneous provisions for mechanical and environmental tests .....	59
7.102.2	Mechanical operation test at ambient air temperature .....	60
7.102.3	Low and high temperature tests .....	61
7.102.4	Humidity test on auxiliary and control circuits .....	65
7.102.5	Operation under severe ice conditions .....	67
7.102.6	Tests to verify the proper functioning of the position-indicating device .....	67
7.103	Common checks after tests .....	68
7.103.1	Checking the capability of the switch to carry its rated continuous current.....	68

7.103.2	Checking the integrity of vacuum in case of a switch using a vacuum interrupter.....	69
8	Routine tests .....	70
8.101	General.....	70
8.102	Mechanical operating tests .....	70
9	Guide to the selection of switchgear and controlgear (informative) .....	70
9.101	General.....	70
9.102	Conditions affecting application .....	70
9.103	Insulation coordination.....	71
9.104	Selection of class of switch .....	71
9.104.1	General purpose switch .....	71
9.104.2	Limited purpose switch .....	71
9.104.3	Special purpose switch .....	71
9.105	Tests for special applications .....	71
10	Information to be given with inquiries, tenders and orders (informative) .....	71
10.1	General.....	71
10.2	Information with inquiries and orders.....	72
10.3	Information with tenders.....	72
11	Transport, storage, installation, operating instructions and maintenance.....	73
12	Safety .....	73
13	Influence of the product on the environment .....	73
Annex A (normative)	Tolerances on test quantities for type tests .....	74
Annex B (informative)	Explanation of the determination for the value of $I_{ef1}$ and $I_{ef2}$ .....	76
B.1	Usage of rating $I_{ef1}$ and $I_{ef2}$ .....	76
B.1.1	General .....	76
B.1.2	Isolated neutral system.....	76
B.1.3	High impedance earthed neutral systems .....	78
B.1.4	Resonant earthed neutral systems (Petersen coil) .....	79
B.1.5	Synthesis.....	80
B.2	Calculation of $I_{ef1}$ and $I_{ef2}$ .....	81
B.2.1	General .....	81
B.2.2	Calculation of $I_{ef1}$ .....	84
B.2.3	Calculation of $I_{ef2}$ .....	84
Annex C (informative)	List of notes concerning certain countries .....	86
Bibliography	.....	87
Figure 1	– Position-indicating/signalling device(s).....	29
Figure 2	– Three-phase test circuit for mainly active load current switching for test duty $TD_{load}$ .....	42
Figure 3	– Single-phase test circuit for mainly active load current switching for test duty $TD_{load}$ .....	43
Figure 4	– Three-phase test circuit for distribution line closed-loop and parallel transformer current switching test for test duties $TD_{loop}$ and $TD_{ptr}$ .....	45

Figure 5 – Single-phase test circuit for distribution line closed-loop and parallel transformer current switching test, for test duties $TD_{loop}$ and $TD_{pptr}$ .....	45
Figure 6 – General test circuit for three- and single-phase capacitive switching tests.....	51
Figure 7 – Prospective recovery voltage and related specified parameter values for capacitive current breaking tests.....	53
Figure 8 – Three-phase test circuit for earth fault breaking current tests, for test duty $TD_{ef1}$ .....	54
Figure 9 – Three-phase test circuit for cable-charging breaking current tests under earth fault conditions, for test duty $TD_{ef2}$ .....	55
Figure 10 – Three-phase test circuit for short-circuit making current test for test duty $TD_{ma}$ .....	55
Figure 11 – Single-phase test circuit for short-circuit making current test for test duty $TD_{ma}$ .....	56
Figure 12 – Test sequences for low and high temperature tests .....	62
Figure 13 – Humidity test .....	66
Figure B.1 – Earth fault in isolated neutral system .....	76
Figure B.2 – Capacitive current in non-faulty phases of isolated neutral system.....	78
Figure B.3 – Earth fault in high impedance earthed neutral system .....	79
Figure B.4 – Earth fault in resonant or compensate earthed neutral system .....	80
Figure B.5 – Example of sequence to find and isolate a faulty branch in an overhead network.....	82
Figure B.6 – Example of sequence to find and isolate a faulty branch in a cable network.....	83
Table 1 – Preferred values of rated line- and cable-charging breaking currents for general purpose switches .....	22
Table 2 – Nameplate information .....	25
Table 3 – Test duties for general purpose switches – Test duties for three-phase tests on three-pole operated, general purpose switches .....	34
Table 4 – Test duties for general purpose switches – Single-phase tests on three-pole general purpose switches operated pole-after-pole and single-pole general purpose switches applied on three-phase systems .....	34
Table 5 – Test duties for special purpose switches – Three-phase tests on three-pole operated switches.....	36
Table 6 – Test duties for special purpose switches – Single-phase tests on three-pole switches operated pole-after-pole and single-pole switches applied on three-phase systems .....	37
Table 7 – Summary of the conditions for combining tests and alternative procedures .....	39
Table 8 – Supply circuit TRV parameters for mainly active load current breaking tests <sup>a</sup> .....	43
Table 9 – TRV parameters for distribution line closed loop breaking tests.....	46
Table 10 – TRV parameters for parallel power transformer breaking current tests.....	47
Table 11 – Prospective recovery voltage parameter limits for capacitive current breaking tests .....	53
Table A.1 – Tolerances on test quantities for type tests .....	74
Table B.1 – Need of ratings $I_{ef1}$ and $I_{ef2}$ in non-effectively earthed neutral systems .....	80
Table B.2 – Values relating to the examples in Figure B.5 and Figure B.6 for capacitance and capacitive current for cables and overhead lines [6], [10], [11].....	85

Table B.3 – Values for $I_{ef2}$ .....	85
--	----

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

## HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

**Part 103: Alternating current switches for rated voltages  
above 1 kV up to and including 52 kV**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62271-103 has been prepared by subcommittee 17A: Switching devices, of IEC technical committee 17: High-voltage switchgear and controlgear. It is an International Standard.

This second edition cancels and replaces the first edition published in 2011. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) this document has been aligned with IEC 62271-1:2017 and IEC 62271-102:2018;
- b) clarifications regarding the behaviour of the switch during breaking tests regarding current interruption and restrikes have been added;
- c) conditions of the switch after making and breaking tests have been clarified;
- d) a new informative Annex B intended to provide guidance for the calculation of  $I_{ef1}$  and  $I_{ef2}$  has been added;

- e) new rules for the combination of 50 Hz and 60 Hz switching tests have been defined and a new table (Table 7) has been added;
- f) tests with specified TRV have been modified to be in accordance with the practice described in IEC 62271-100;
- g) the behaviour of the switch during breaking tests has been clarified and boundaries for restrike allowance have been defined;
- h) explanations for short-circuit making tests have been added;
- i) vacuum integrity check after mechanical operations has been defined;
- j) all test voltages for single-phase capacitive testing have been grouped under 7.101.7.3.2 and have been confirmed by simulation and calculation.

The text of this International Standard is based on the following documents:

Draft	Report on voting
17A/1297/FDIS	17A/1303/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/standardsdev/publications](http://www.iec.ch/standardsdev/publications).

This document is to be read in conjunction with IEC 62271-1:2017, to which it refers and which is applicable unless otherwise specified. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC 62271-1:2017. Amendments to these clauses and subclauses are given under the same numbering whilst additional subclauses are numbered from 101.

A list of all parts in the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The reader's attention is drawn to the fact that Annex C lists all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

### Part 103: Alternating current switches for rated voltages above 1 kV up to and including 52 kV

#### 1 Scope

This part of IEC 62271 is applicable to three-phase, alternating current switches and switch-disconnectors for their switching function, having making and breaking current ratings, for indoor and outdoor installations, for rated voltages above 1 kV up to and including 52 kV and for rated frequencies from 16 2/3 Hz up to and including 60 Hz. This document is also applicable to single-pole switches used on three-phase systems.

This document is also applicable to the operating devices of these switches and to their auxiliary equipment.

For switch-disconnectors, refer also to IEC 62271-102 for their disconnecting function.

Devices not covered by this document are:

- devices that require a dependent manual operation;
- earthing switches. Earthing switches forming an integral part of a switch are covered by IEC 62271-102;
- switching devices attached as an element of a high-voltage fuse assembly or its mounting and operated by opening and closing the fuse assembly.

General principles and provisions of this document can also be applicable to single pole switches intended for application in single-phase systems, the requirements for dielectric tests and making and breaking tests being in accordance with the requirements of the specific application.

This document establishes requirements for general, limited and special purpose switches used in distribution systems.

NOTE Except where special clarification is required, the term "switch" is used to refer to all kinds of switches and switch-disconnectors within the scope of this document.

#### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-441, *International Electrotechnical Vocabulary (IEV) – Part 441: Switchgear, controlgear and fuses* (available at <http://www.electropedia.org>)

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*

IEC 60529:1989/AMD1:1999

IEC 60529:1989/AMD1:2013

IEC 62262:2002, *Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)*

IEC 62271-1:2017, *High-voltage switchgear and controlgear – Part 1: Common specifications for alternating current switchgear and controlgear*

IEC 62271-102:2018, *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches*

IEC 62271-110:2017, *High-voltage switchgear and controlgear – Part 110: Inductive load switching*