

SVENSK STANDARD SS-EN IEC 60335-2-40+A11, utg 5:2025

Fastställd 2025-02-05

Sida 1 (178) Ansvarig kommitté

SEK TK 61

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

Elektriska hushållsapparater och liknande bruksföremål – Säkerhet –

Del 2-40: Särskilda fordringar på elektriska värmepumpar, luftkonditioneringsaggregat och luftavfuktare

Household and similar electrical appliances – Safetv –

Part 2-40: Particular requirements for electrical heat pumps, air-conditioners and dehumidifiers

Som svensk standard gäller europastandarden EN IEC 60335-2-40:2024. Den svenska standarden innehåller de officiella engelska språkversionerna av EN IEC 60335-2-40:2024 och EN IEC 60335-2-40:2024/A11:2024

Nationellt förord

Europastandarden EN IEC 60335-2-40:2024

består av:

- europastandardens ikraftsättningsdokument, utarbetat inom CENELEC

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN IEC 60335-2-40+A11, utg 4:2024 med eventuella tillägg, ändringar och rättelser gäller ej fr o m 2027-08-12.

ICS 23.120.00

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1042 172 21 Sundbyberg Tel 08-444 14 00 elstandard.se

EUROPEAN STANDARD NORME EUROPÉENNE FUROPÄISCHE NORM

EN IEC 60335-2-40

November 2024

ICS 23.120

Supersedes EN IEC 60335-2-40:2023; EN IEC 60335-2-40:2023/A11:2023

English Version

Household and similar electrical appliances - Safety - Part 2-40: Particular requirements for electrical heat pumps, airconditioners and dehumidifiers (IEC 60335-2-40:2022 + COR1:2024)

Appareils électrodomestiques et analogues - Sécurité -Partie 2-40: Exigences particulières pour les pompes à chaleur électriques, les climatiseurs et les déshumidificateurs (IEC 60335-2-40:2022 + COR1:2024) Sicherheit elektrischer Geräte für den Hausgebrauch und ähnliche Zwecke - Teil 2-40: Besondere Anforderungen für elektrisch betriebene Wärmepumpen, Klimageräte und Raumluft-Entfeuchter

(IEC 60335-2-40:2022 + COR1:2024)

This European Standard was approved by CENELEC on 2024-08-12. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization Comité Européen de Normalisation Electrotechnique Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2024 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

Ref. No. EN IEC 60335-2-40:2024 E

European foreword

This document (EN IEC 60335-2-40:2024) consists of the text of IEC 60335-2-40:2022 + COR1:2024 prepared by IEC/TC 61 "Safety of household and similar electrical appliances".

The following dates are fixed:

- latest date by which this document has to be (dop) 2025-08-12 implemented at national level by publication of an identical national standard or by endorsement
- latest date by which the national standards (dow) 2027-08-12 conflicting with this document have to be withdrawn

This document supersedes EN IEC 60335-2-40:2023 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN-CENELEC shall not be held responsible for identifying any or all such patent rights.

This document is read in conjunction with EN IEC 60335-2-40:2024/A11:2024.

This document has been prepared under a standardization request addressed to CENELEC by the European Commission. The Standing Committee of the EFTA States subsequently approves these requests for its Member States.

For the relationship with EU Legislation, see informative Annexes ZZA and ZZB, which are an integral part of EN IEC 60335-2-40:2024/A11:2024.

Any feedback and questions on this document should be directed to the users' national standards body/national committee. A complete listing of these bodies can be found on the CEN and CENELEC websites.

Endorsement notice

The text of the International Standard IEC 60335-2-40:2022 + COR1:2024 was approved by CEN-CENELEC as a European Standard without any modification.



Edition 7.0 2022-05

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Household and similar electrical appliances – Safety – Part 2-40: Particular requirements for electrical heat pumps, air-conditioners and dehumidifiers

Appareils électrodomestiques et analogues – Sécurité – Partie 2-40: Exigences particulières pour les pompes à chaleur électriques, les climatiseurs et les déshumidificateurs

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMISSION ELECTROTECHNIQUE INTERNATIONALE

ICS 23.120 ISBN 978-2-8322-3437-2

Warning! Make sure that you obtained this publication from an authorized distributor. Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

CONTENTS

FOF	REWORD	5
INTI	RODUCTION	8
1	Scope	9
2	Normative references	10
3	Terms and definitions	11
4	General requirement	19
5	General conditions for the tests	19
6	Classification	20
7	Marking and instructions	20
8	Protection against access to live parts	26
9	Starting of motor-operated appliances	26
10	Power input and current	26
11	Heating	26
12	Void	29
13	Leakage current and electric strength at operating temperature	29
14	Transient overvoltages	29
15	Moisture resistance	
16	Leakage current and electric strength	31
17	Overload protection of transformers and associated circuits	31
18	Endurance	31
19	Abnormal operation	31
20	Stability and mechanical hazards	38
21	Mechanical strength	38
22	Construction	39
23	Internal wiring	51
24	Components	51
25	Supply connection and external flexible cords	52
26	Terminals for external conductors	53
27	Provision for earthing	53
28	Screws and connections	53
29	Clearances, creepage distances and solid insulation	53
30	Resistance to heat and fire	53
31	Resistance to rusting	55
32	Radiation, toxicity and similar hazards	55
Ann	exes	62
Ann	ex D (normative) Thermal motor protectors	62
Ann volta	ex I (normative) Motors having basic insulation that is inadequate for the rated age of the appliance	62
	ex AA (informative) Examples for operating temperatures of the appliance	
	ex BB (normative) Selected information about refrigerants	
	ex CC (informative) Transportation, marking and storage for units that employ	٠.
	mable refrigerants	68

Annex DD (normative) Requirements for installation, service, maintenance and repair, and decommissioning manuals of appliances using flammable refrigerants	69
Annex EE (normative) Pressure tests	78
Annex FF (normative) Leak simulation tests	80
Annex GG (normative) Charge limits, ventilation requirements and requirements for secondary circuits	
Annex HH (informative) Competence of service personnel	115
Annex II (Void)	117
Annex JJ (normative) Allowable openings of relays and similar components to prevent ignition of A2L refrigerants	118
Annex KK (normative) Test method for hot surface ignition temperature for A2L	120
Annex LL (normative) Refrigerant detection systems for flammable refrigerants	124
Annex MM (normative) Refrigerant sensor location confirmation test	135
Annex NN (normative) Flame arrest enclosure verification test for A2L refrigerants	138
Annex OO (Void)	140
Annex PP (normative) Leak detection system confirmation test for flammable refrigerants	141
Annex QQ (normative) Methods for determining releasable charge	147
Bibliography	155
Figure 101 – Example of label for field charged units	57
Figure 102 – Arrangement for heating test of appliances with supplementary air heater	59
Figure 103 – Supply circuit for locked-rotor test of a motor of the single-phase type – Revise as needed for three-phase test	60
Figure 104 – Power spectral density profile for vibration test in 21.101	60
Figure 105 – Dimensional details for the weight in the area of the pressure ball	60
Figure 106 – Measurement before and after the test	61
Figure GG.1 – Unventilated area	112
Figure GG.2 – Mechanical ventilation	112
Figure GG.3 – Relevant heights $h_{\rm inst}$, h_0 and $h_{\rm rel}$ for calculation of $A_{\rm min}$ and $m_{\rm max}$	113
Figure GG.4 – Airflow direction	114
Figure KK.1 – Front view of test apparatus labels	120
Figure KK.2 – Test apparatus with dimensions	121
Figure KK.3 – Top view of test apparatus	122
Figure LL.1 – Example of test chamber design	130
Table 101 – Power spectral density profile for vibration test	38
Table 102 – UVC spectral irradiance measurement location	56
Table AA.1 – Examples for operating temperatures of the appliance	63
Table BB.1 – Selected information about refrigerants	64
Table DD.1 – Mandatory clauses in each manual	69
Table GG.1 – Outline of Annex GG (informative)	83
Table GG.2 – Circulation airflow	88
Table GG.3 – Appliance with packaging	95

Table GG.4 – Appliance without packaging	95
Table GG.5 – Minimum air velocity	. 107
Table GG.6 – Refrigerant leak rate (ṁ _{leak})	. 110
Table LL.1 – Relationship among alarm set point, tolerance and test gas (informative)	. 126
Table LL.2 – Gas and vapour concentrations	. 128
Table LL.3 – Example of the test chamber design	. 131

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HOUSEHOLD AND SIMILAR ELECTRICAL APPLIANCES - SAFETY -

Part 2-40: Particular requirements for electrical heat pumps, air-conditioners and dehumidifiers

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60335 has been prepared by subcommittee 61D: Appliances for air-conditioning for household and similar purposes, of IEC technical committee 61: Safety of household and similar electrical appliances. It is an International Standard.

This seventh edition cancels and replaces the sixth edition published in 2018. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- Clause 1 added thermoelectric heat pumps to the scope and increased maximum rated voltage to 300 V for single phase appliances;
- Clause 7 revised requirements for marking on the appliance and packaging, including a symbol for minimum floor area and modifying the symbol for **flammable refrigerants** to include the safety group per ISO 817;
- Clause 11 and Clause 19 restructured for alignment with Part 1 and added requirements for supplementary air heaters;

- Clause 13 and Clause 16 revised requirement for leakage current for stationary class I motor-operated appliances;
- Clause 21 added requirements for particle foam material and revised requirements for transport testing;
- Clause 22 removed limit on the sum of refrigerant charges for appliances with multiple refrigerating systems, and revised requirements for avoiding ignition sources, leak detection systems, safety shut-off valves, and particle foam material;
- Clause 23 added requirements to avoid contact between wires and refrigerant piping;
- Clause 24 revised requirements for motor-compressors;
- Clause 30 added requirements for resistance to heat of particle foam material;
- Annex BB revised Table BB.1 with refrigerant information and added a link to ISO 817 refrigerant data;
- Annex DD revised requirements for information in the manual for appliances with flammable refrigerants;
- Annex EE revised requirements for pressure testing;
- Annex FF revised requirements for leak simulation tests;
- Annex GG added requirements for applying releasable charge, added additional coverage for A2 and A3 refrigerants, including new charge limits for appliances with circulation airflow and for enhanced tightness refrigerating systems, and revised requirements for enhanced tightness refrigerating systems using A2L refrigerant;
- Annex LL revised requirements for refrigerant detection systems;
- Annex MM revised simulated leak rate;
- Annex OO deleted annex for conditioning internal wiring using UV light.
- Annex PP new coverage of **leak detection system** confirmation test;
- Annex QQ new coverage of method for determining releasable charge.

The text of this International Standard is based on the following documents:

Draft	Report on voting
61D/491/FDIS	61D/493/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

This part 2-40 is to be used in conjunction with IEC 60335-1:2010, its Amendment 1:2013 and its Amendment 2:2016.

NOTE 1 $\,$ When "Part 1" is mentioned in this standard, it refers to IEC 60335-1.

This part 2-40 supplements or modifies the corresponding clauses in IEC 60335-1, so as to convert that publication into the IEC standard: Safety requirements for electrical heat pumps, air-conditioners and dehumidifiers.

When a particular subclause of Part 1 is not mentioned in this part 2, that subclause applies as far as is reasonable. When this standard states "addition", "modification" or "replacement", the relevant text in Part 1 is to be adapted accordingly.

NOTE 2 The following numbering system is used:

- subclauses, tables and figures that are numbered starting from 101 are additional to those in Part 1;
- unless notes are in a new subclause or involve notes in Part 1, they are numbered starting from 101, including those in a replaced clause or subclause;
- additional annexes are lettered AA, BB, etc.

NOTE 3 The following print types are used:

- requirements: in roman type;
- test specifications: in italic type;
- notes: in small roman type.

Words in **bold** in the text are defined in Clause 3. When a definition concerns an adjective, the adjective and associated noun are also in bold.

The following differences exist in the countries indicated below:

- 6.1: Class 0I appliances are allowed (Japan).
- 11.8: The temperature of the wooden walls in the test casing is limited to 85 °C (Sweden).

A list of all parts of the IEC 60335 series, under the general title: *Household and similar electrical appliances – Safety,* can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- · reconfirmed,
- withdrawn,
- · replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

It has been assumed in the drafting of this International Standard that the execution of its provisions is entrusted to appropriately qualified and experienced persons.

Guidance documents concerning the application of the safety requirements for appliances can be accessed via TC 61 supporting documents on the IEC website

https://www.iec.ch/tc61/supportingdocuments

This information is given for the convenience of users of this International Standard and does not constitute a replacement for the normative text in this standard.

This standard recognizes the internationally accepted level of protection against hazards such as electrical, mechanical, thermal, fire and radiation of appliances when operated as in normal use taking into account the instructions. It also covers abnormal situations that can be expected in practice.

This standard takes into account the requirements of IEC 60364 as far as possible so that there is compatibility with the wiring rules when the appliance is connected to the supply mains. However, national wiring rules can differ.

If an appliance within the scope of this standard also incorporates functions that are covered by another part 2 of IEC 60335, the relevant part 2 is applied to each function separately, as far as is reasonable. If applicable, the influence of one function on the other is taken into account.

When a part 2 standard does not include additional requirements to cover hazards dealt with in Part 1, Part 1 applies.

NOTE 1 This means that the technical committees responsible for the part 2 standards have determined that it is not necessary to specify particular requirements for the appliance in question over and above the general requirements.

This standard is a product family standard dealing with the safety of appliances and takes precedence over horizontal and generic standards covering the same subject.

NOTE 2 Horizontal publications, basic safety publications and group safety publications covering a hazard are not applicable since they have been taken into consideration when developing the general and particular requirements for the IEC 60335 series of standards.

An appliance that complies with the text of this standard will not necessarily be considered to comply with the safety principles of the standard if, when examined and tested, it is found to have other features that impair the level of safety covered by these requirements.

An appliance employing materials or having forms of construction differing from those detailed in the requirements of this standard may be examined and tested according to the intent of the requirements and, if found to be substantially equivalent, may be considered to comply with the standard.

HOUSEHOLD AND SIMILAR ELECTRICAL APPLIANCES - SAFETY -

Part 2-40: Particular requirements for electrical heat pumps, air-conditioners and dehumidifiers

1 Scope

This clause of Part 1 is replaced by the following.

This part of IEC 60335 deals with the safety of electric heat pumps, sanitary hot water heat pumps and air conditioners, incorporating motor-compressors as well as hydronic fan coils units, dehumidifiers (with or without motor-compressors), thermoelectric heat pumps and partial units. Their maximum rated voltage being not more than 300 V for single phase appliances and 600 V for multi-phase appliances.

Appliances not intended for normal household use but which nevertheless can be a source of danger to the public, such as appliances intended to be used by laymen in shops, in light industry and on farms, are within the scope of this standard.

The appliances referenced above can consist of one or more factory-made assemblies. If provided in more than one assembly, the separate assemblies are used together, and the requirements are based on the use of matched assemblies.

NOTE 101 A definition of 'motor-compressor' is given in IEC 60335-2-34, which includes the statement that the term motor-compressor is used to designate either a hermetic motor-compressor or semi-hermetic motor-compressor.

NOTE 102 Requirements for containers intended for storage of the heated water included in **sanitary hot water heat pumps** are, in addition, covered by IEC 60335-2-21.

This standard does not take into account refrigerants other than group A1, A2L, A2 and A3 as defined by ISO 817. **Flammable refrigerants** are limited to those of a molar mass of more than or equal to 42 kg/kmol based on WCF (worst case formulation) as specified in ISO 817.

As far as practical, this standard deals with common hazards presented by appliances that are encountered in normal use and assumes that installation, servicing, decommissioning, and disposal are safely handled by competent persons and accidental release of refrigerants is avoided. However, it does not prescribe the criteria to ensure competence of persons during installation, servicing and disposal. Safety requirements during disposal are not specified in this standard.

NOTE 103 Annex HH provides informative requirements on competence of persons. Criteria for competence of personnel for the purpose of certification schemes can be found in ISO 22712¹.

Unless specifications are covered by this standard, including the annexes, requirements for refrigerating safety are covered by:

- ISO 5149-1:2014, ISO 5149-1:2014/AMD1:2015, and ISO 5149-1:2014/AMD2:2021,
- ISO 5149-2:2014 and ISO 5149-2:2014/AMD1:2020.
- ISO 5149-3:2014 and ISO 5149-3:2014/AMD1:2021.

Under preparation. Stage at the time of publication: ISO FDIS 22712:2022

Supplementary heaters, or a provision for their separate installation, are within the scope of this standard, but only heaters which are designed as a part of the appliance package, the controls being incorporated in the appliance.

NOTE 104 Attention is drawn to the fact that

- for appliances intended to be used in vehicles or on-board ships or aircraft, additional requirements can be necessary;
- in many countries, additional requirements are specified, for example, by the national health authorities responsible for the protection of labour and the national authorities responsible for storage, transportation, building constructions and installations.

NOTE 105 This standard does not apply to

- humidifiers intended for use with heating and cooling equipment (IEC 60335-2-88);
- appliances designed exclusively for industrial processing;
- appliances intended to be used in locations where special conditions prevail, such as the presence of a corrosive or explosive atmosphere (dust, vapour or gas).

2 Normative references

This clause of Part 1 is applicable except as follows.

Addition:

IEC 60068-2-52, Environmental testing – Part 2: Tests – Test Kb: Salt mist, cyclic (sodium, chloride solution)

IEC 60079-0, Explosive atmospheres – Part 0: Equipment – General requirements

IEC 60079-7:2015, Explosive atmospheres – Part 7: Equipment protection by increased safety "e"

IEC 60079-7:2015/AMD1:2017

IEC 60079-14:2013, Explosive atmospheres – Part 14: Electrical installations design, selection and erection

IEC 60079-15:2017, Explosive atmospheres – Part 15: Equipment protection by type of protection "n"

IEC 60335-2-34:2021, Household and similar electrical appliances – Safety – Part 2-34: Particular requirements for motor-compressors

IEC 60335-2-51, Household and similar electrical appliances – Safety – Part 2-51: Particular requirements for stationary circulation pumps for heating and service water installations

IEC 60695-1-10, Fire hazard testing – Part 1-10: Guidance for assessing the fire hazard of electrotechnical products – General guidelines

IEC 60695-10-2:2014, Fire hazard testing – Part 10-2: Abnormal heat – Ball pressure test method

IEC 60730-2-6, Automatic electrical controls – Part 2-6: Particular requirements for automatic electrical pressure sensing controls including mechanical requirements

IEC 62471:2006, Photobiological safety of lamps and lamp systems

ISO 817, Refrigerants - Designation and safety classification

ISO 527-3, Plastics – Determination of tensile properties – Part 3: Test conditions for films and sheets

ISO $1302:2002^2$, Geometrical Product Specifications (GPS) – Indication of surface texture in technical product documentation

ISO 2578, Plastics – Determination of time-temperature limits after prolonged exposure to heat

ISO 5149-1:2014, Refrigerating systems and heat pumps – Safety and environmental requirements – Part 1: Definitions, classification and selection criteria

ISO 5149-1:2014/AMD1:2015 ISO 5149-1:2014/AMD2:2021

ISO 5149-2:2014, Refrigerating systems and heat pumps – Safety and environmental requirements – Part 2: Design, construction, testing, marking and documentation ISO 5149-2:2014/AMD1:2020

ISO 5149-3:2014, Refrigerating systems and heat pumps – Safety and environmental requirements – Part 3: Installation site ISO 5149-3:2014/AMD1:2021

ISO 5151:2017, Non-ducted air conditioners and heat pumps — Testing and rating for performance ISO 5151:2017/AMD1:2020

ISO 7010:2019, Graphical symbols – Safety colours and safety signs – Registered safety signs

ISO 13253, Ducted air-conditioners and air-to-air heat pumps — Testing and rating for performance

ISO 13256 (all parts), Water-source heat pumps - Testing and rating for performance

ISO 13355:2016, Packaging - Complete, filled transport packages and unit loads - Vertical random vibration test

ISO 14903, Refrigerating systems and heat pumps – Qualification of tightness of components and joints

ISO 15042, Multiple split-system air-conditioners and air-to-air heat pumps – Testing and rating for performance

Withdrawn.