

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

EXTENDED VERSION

Elektriska hushållsapparater och liknande bruksföremål – Säkerhet –

Del 2-40: Särskilda fordringar på elektriska värmepumpar, luftkonditioneringsaggregat och luftavfuktare

Household and similar electrical appliances –

Safety –

Part 2-40: Particular requirements for electrical heat pumps, air-conditioners and dehumidifiers

En så kallad "Extended Version" (EXV) innehåller både standarden som fastställts som SS och den utökade IEC-standard (EXV) på engelska. Den utökade versionen av IEC-standard innehåller även refererad text från en annan standard och ger användaren ett mer komplett innehåll. SEK Svensk Elstandard kan bara ge ut EXV i de fall den finns tillgänglig från IEC.



INTERNATIONAL STANDARD



This extended version of IEC 60335-2-40 includes the content of the references made to IEC 60335-1:2010+AMD1:2013+AMD2:2016 CSV

**Household and similar electrical appliances – Safety –
Part 2-40: Particular requirements for electrical heat pumps, air-conditioners
and dehumidifiers**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 23.120

ISBN 978-2-8322-5674-9

Warning! Make sure that you obtained this publication from an authorized distributor.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

IEC 60335-1
Edition 5.0 2010-05
Amendment 2: 2016-05

HOUSEHOLD AND SIMILAR ELECTRICAL APPLIANCES – SAFETY –

Part 1: General requirements

INTERPRETATION SHEET 1

This interpretation sheet has been prepared by IEC technical committee 61: Safety of household and similar electrical appliances.

The text of this interpretation sheet is based on the following documents:

DISH	Report on voting
61/5999/DISH	61/6009/RVDISH

Full information on the voting for the approval of this interpretation sheet can be found in the report on voting indicated in the above table.

TC 61 interpretation sheet on: Detachable power supply parts of IEC 60335-1:2010/AMD2:2016

Introduction

Amendment 2 of IEC 60335-1:2010 defines and introduces requirements for a detachable power supply part of an appliance. In this amendment, 24.2 prohibits the use of a power supply in a flexible cord.

QUESTION:

Does Subclause 24.2 prohibit the use of a detachable power supply part?

ANSWER

No, a “detachable power supply part” is a defined term and is not captured by term “power supply” as used in Subclause 24.2.

NOTE A detachable power supply part is captured by the defined term when the output of the power supply part is detachable from the class III construction part of the appliance at:

- the power supply part, or
- the class III construction part of the appliance.

However, the supply cord (if any) does not have to be detachable from the detachable power supply part.

CONTENTS

FOREWORD	7
INTRODUCTION	10
1 Scope	11
2 Normative references	12
3 Terms and definitions	17
4 General requirement	32
5 General conditions for the tests	32
6 Classification	36
7 Marking and instructions	36
8 Protection against access to live parts	49
9 Starting of motor-operated appliances	51
10 Power input and current	51
11 Heating	53
12 Void	60
13 Leakage current and electric strength at operating temperature	60
14 Transient overvoltages	62
15 Moisture resistance	63
16 Leakage current and electric strength	64
17 Overload protection of transformers and associated circuits	66
18 Endurance	66
19 Abnormal operation	66
20 Stability and mechanical hazards	80
21 Mechanical strength	81
22 Construction	83
23 Internal wiring	107
24 Components	109
25 Supply connection and external flexible cords	114
26 Terminals for external conductors	122
27 Provision for earthing	124
28 Screws and connections	126
29 Clearances, creepage distances and solid insulation	129
30 Resistance to heat and fire	137
31 Resistance to rusting	142
32 Radiation, toxicity and similar hazards	142
Annex A (informative) Routine tests	162
Annex B (normative) Appliances powered by rechargeable batteries that are recharged in the appliance	164
Annex C (normative) Ageing test on motors	169

Annex D (normative) Thermal motor protectors	170
Annex E (normative) Needle-flame test	171
Annex F (normative) Capacitors	172
Annex G (normative) Safety isolating transformers	174
Annex H (normative) Switches	175
Annex I (normative) Motors having basic insulation that is inadequate for the rated voltage of the appliance	177
Annex J (normative) Coated printed circuit boards	178
Annex K (normative) Overvoltage categories	179
Annex L (informative) Guidance for the measurement of clearances and creepage distances	180
Annex M (normative) Pollution degree	184
Annex N (normative) Proof tracking test	185
Annex O (informative) Selection and sequence of the tests of Clause 30	186
Annex P (informative) Guidance for the application of this standard to appliances used in tropical climates	192
Annex Q (informative) Sequence of tests for the evaluation of electronic circuits	194
Annex R (normative) Software evaluation	196
Annex S (normative) Battery-operated appliances powered by batteries that are non-rechargeable or not recharged in the appliance	210
Annex T (normative) UV-C radiation effect on non-metallic materials	213
Annex AA (informative) Examples for operating temperatures of the appliance	216
Annex CC (informative) Transportation, marking and storage for units that employ flammable refrigerants	221
Annex DD (normative) Requirements for installation, service, maintenance and repair, and decommissioning manuals of appliances using flammable refrigerants	222
Annex EE (normative) Pressure tests	231
Annex FF (normative) Leak simulation tests	233
Annex GG (normative) Charge limits, ventilation requirements and requirements for secondary circuits	235
Annex HH (informative) Competence of service personnel	268
Annex II (Void)	270
Annex JJ (normative) Allowable openings of relays and similar components to prevent ignition of A2L refrigerants	271
Annex KK (normative) Test method for hot surface ignition temperature for A2L	273
Annex LL (normative) Refrigerant detection systems for flammable refrigerants	277
Annex MM (normative) Refrigerant sensor location confirmation test	288
Annex NN (normative) Flame arrest enclosure verification test for A2L refrigerants	291
Annex OO (Void)	293
Annex PP (normative) Leak detection system confirmation test for flammable refrigerants	294
Annex QQ (normative) Methods for determining releasable charge	300
Bibliography	308
Index of defined terms	308

Figure 1 – Circuit diagram for leakage current measurement at operating temperature for single-phase connection of class II appliances and for parts of class II construction	144
Figure 2 – Circuit diagram for leakage current measurement at operating temperature for single-phase connection of other than class II appliances or parts of class II construction...	145
Figure 3 – Circuit diagram for leakage current measurement at operating temperature for three-phase with neutral class II appliances and for parts of class II construction	146
Figure 4 – Circuit diagram for leakage current measurement at operating temperature for three-phase with neutral appliances other than those of class II or parts of class II construction	147
Figure 5 – Small part.....	148
Figure 6 – Example of an electronic circuit with low-power points	149
Figure 7 – Test finger nail.....	150
Figure 8 – Flexing test apparatus.....	151
Figure 9 – Constructions of cord anchorages	152
Figure 10 – An example of parts of an earthing terminal	153
Figure 11 – Examples of clearances	154
Figure 12 – Example of the placement of the cylinder.....	155
Figure 13 – Small parts cylinder	156
Figure 101 – Example of label for field charged units	157
Figure 102 – Arrangement for heating test of appliances with supplementary air heater.....	159
Figure 103 – Supply circuit for locked-rotor test of a motor of the single-phase type – Revise as needed for three-phase test.....	160
Figure 104 – Power spectral density profile for vibration test in 21.101	160
Figure 105 – Dimensional details for the weight in the area of the pressure ball	160
Figure 106 – Measurement before and after the test.....	161
Figure B.1 – Examples of forms of constructions for appliances covered by Annex B.....	167
Figure L.1 – Sequence for the determination of clearances.....	181
Figure L.2 – Sequence for the determination of creepage distances.....	183
Figure O.1 – Tests for resistance to heat	186
Figure O.2 – Selection and sequence of tests for resistance to fire in hand-held appliances	187
Figure O.3 – Selection and sequence of tests for resistance to fire in attended appliances .	188
Figure O.4 – Selection and sequence of tests for resistance to fire in unattended appliances	189
Figure O.5 – Some applications of the term "within a distance of 3 mm"	191
Figure S.1 – Examples of battery marking representing three batteries	212
Figure GG.1 – Unventilated area	265
Figure GG.2 – Mechanical ventilation	265
Figure GG.3 – Relevant heights h_{inst} , h_0 and h_{rel} for calculation of A_{min} and m_{max}	266
Figure GG.4 – Airflow direction.....	267
Figure KK.1 – Front view of test apparatus labels.....	273
Figure KK.2 – Test apparatus with dimensions	274
Figure KK.3 – Top view of test apparatus.....	275
Figure LL.1 – Example of test chamber design	283

Table 1 – Power input deviation.....	51
Table 2 – Current deviation	52
Table 3 – Maximum normal temperature rises	56
Table 4 – Voltage for electric strength test.....	62
Table 5 – Characteristics of high-voltage sources.....	62
Table 6 – Impulse test voltage	63
Table 7 – Test voltages	65
Table 8 – Maximum winding temperature	69
Table 9 – Maximum abnormal temperature rise	75
Table 10 – Dimensions of cables and conduits	115
Table 11 – Minimum cross-sectional area of conductors	117
Table 12 – Pull force and torque	119
Table 13 – Nominal cross-sectional area of conductors	123
Table 14 – Torque for testing screws and nuts	128
Table 15 – Rated impulse voltage	130
Table 16 – Minimum clearances	130
Table 17 – Minimum creepage distances for basic insulation	134
Table 18 – Minimum creepage distances for functional insulation	135
Table 19 – Minimum thickness for accessible parts of reinforced insulation consisting of a single layer	137
Table 101 – Power spectral density profile for vibration test	83
Table 102 – UV-C spectral irradiance measurement location	143
Table A.1 – Test voltages.....	163
Table C.1 – Test conditions	169
Table R.1 – General fault/error conditions.....	198
Table R.2 – Specific fault/error conditions.....	201
Table R.3 – Semi-formal methods.....	207
Table R.4 – Software architecture specification	207
Table R.5 – Module design specification	208
Table R.6 – Design and coding standards	208
Table R.7 – Software safety validation	209
Table S.101 – Battery source impedance	211
Table T.1 – Minimum property retention limits after UV-C exposure	214
Table T.2 – Minimum electric strength for internal wiring after UV-C exposure	215
Table AA.1 – Examples for operating temperatures of the appliance	216
Table BB.1 – Selected information about refrigerants	217
Table DD.1 – Mandatory clauses in each manual	222
Table GG.1 – Outline of Annex GG (informative).....	236
Table GG.2 – Circulation airflow	241
Table GG.3 – Appliance with packaging	248
Table GG.4 – Appliance without packaging	248
Table GG.5 – Minimum air velocity	260
Table GG.6 – Refrigerant leak rate (\dot{m}_{leak})	263

Table LL.1 – Relationship among alarm set point, tolerance and test gas (informative)	279
Table LL.2 – Gas and vapour concentrations	281
Table LL.3 – Example of the test chamber design	284

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HOUSEHOLD AND SIMILAR ELECTRICAL APPLIANCES – SAFETY –

Part 2-40: Particular requirements for electrical heat pumps, air-conditioners and dehumidifiers

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This extended version (EXV) of the official IEC Standard provides the user with a comprehensive content of the Standard.

IEC 60335-2-40:2022 EXV includes the content of the references made to IEC 60335-1:2010, its Amendment 1:2013 and its Amendment 2:2016.

Particular subclauses of IEC 60335-1:2010+AMD1:2013+AMD2:2016 CSV are displayed in the content on a blue background.

IEC 60335 has been prepared by subcommittee 61D: Appliances for air-conditioning for household and similar purposes, of IEC technical committee 61: Safety of household and similar electrical appliances. It is an International Standard.

This seventh edition cancels and replaces the sixth edition published in 2018. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- Clause 1 – added **thermoelectric heat pumps** to the scope and increased maximum **rated voltage** to 300 V for single phase appliances;
- Clause 7 – revised requirements for marking on the appliance and packaging, including a symbol for minimum floor area and modifying the symbol for **flammable refrigerants** to include the safety group per ISO 817;
- Clause 11 and Clause 19 – restructured for alignment with Part 1 and added requirements for **supplementary air heaters**;
- Clause 13 and Clause 16 – revised requirement for leakage current for **stationary class I motor-operated appliances**;
- Clause 21 – added requirements for **particle foam material** and revised requirements for transport testing;
- Clause 22 – removed limit on the sum of **refrigerant charges** for appliances with multiple **refrigerating systems**, and revised requirements for avoiding ignition sources, **leak detection systems**, **safety shut-off valves**, and **particle foam material**;
- Clause 23 – added requirements to avoid contact between wires and refrigerant piping;
- Clause 24 – revised requirements for motor-compressors;
- Clause 30 – added requirements for resistance to heat of **particle foam material**;
- Annex BB – revised Table BB.1 with refrigerant information and added a link to ISO 817 refrigerant data;
- Annex DD – revised requirements for information in the manual for appliances with **flammable refrigerants**;
- Annex EE – revised requirements for pressure testing;
- Annex FF – revised requirements for leak simulation tests;
- Annex GG – added requirements for applying **releasable charge**, added additional coverage for A2 and A3 refrigerants, including new charge limits for appliances with **circulation airflow** and for **enhanced tightness refrigerating systems**, and revised requirements for **enhanced tightness refrigerating systems** using **A2L refrigerant**;
- Annex LL – revised requirements for **refrigerant detection systems**;
- Annex MM – revised simulated leak rate;
- Annex OO – deleted annex for conditioning internal wiring using UV light.
- Annex PP – new coverage of **leak detection system** confirmation test;
- Annex QQ – new coverage of method for determining **releasable charge**.

The text of this International Standard is based on the following documents:

Draft	Report on voting
61D/491/FDIS	61D/493/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

This part 2-40 is to be used in conjunction with IEC 60335-1:2010, its Amendment 1:2013 and its Amendment 2:2016.

NOTE 1 When "Part 1" is mentioned in this standard, it refers to IEC 60335-1.

This part 2-40 supplements or modifies the corresponding clauses in IEC 60335-1, so as to convert that publication into the IEC standard: Safety requirements for electrical heat pumps, air-conditioners and dehumidifiers.

When a particular subclause of Part 1 is not mentioned in this part 2, that subclause applies as far as is reasonable. When this standard states "addition", "modification" or "replacement", the relevant text in Part 1 is to be adapted accordingly.

NOTE 2 The following numbering system is used:

- subclauses, tables and figures that are numbered starting from 101 are additional to those in Part 1;
- unless notes are in a new subclause or involve notes in Part 1, they are numbered starting from 101, including those in a replaced clause or subclause;
- additional annexes are lettered AA, BB, etc.

NOTE 3 The following print types are used:

- requirements: in roman type;
- *test specifications: in italic type;*
- notes: in small roman type.

Words in **bold** in the text are defined in Clause 3. When a definition concerns an adjective, the adjective and associated noun are also in bold.

The following differences exist in the countries indicated below:

- 6.1: Class 0I appliances are allowed (Japan).
- 11.8: The temperature of the wooden walls in the test casing is limited to 85 °C (Sweden).

A list of all parts of the IEC 60335 series, under the general title: *Household and similar electrical appliances – Safety*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

The content of the corrigendum 1 (2024-10) has been included in this copy.

INTRODUCTION

It has been assumed in the drafting of this International Standard that the execution of its provisions is entrusted to appropriately qualified and experienced persons.

Guidance documents concerning the application of the safety requirements for appliances can be accessed via TC 61 supporting documents on the IEC website

<https://www.iec.ch/tc61/supportingdocuments>

This information is given for the convenience of users of this International Standard and does not constitute a replacement for the normative text in this standard.

This standard recognizes the internationally accepted level of protection against hazards such as electrical, mechanical, thermal, fire and radiation of appliances when operated as in normal use taking into account the instructions. It also covers abnormal situations that can be expected in practice.

This standard takes into account the requirements of IEC 60364 as far as possible so that there is compatibility with the wiring rules when the appliance is connected to the supply mains. However, national wiring rules can differ.

If an appliance within the scope of this standard also incorporates functions that are covered by another part 2 of IEC 60335, the relevant part 2 is applied to each function separately, as far as is reasonable. If applicable, the influence of one function on the other is taken into account.

When a part 2 standard does not include additional requirements to cover hazards dealt with in Part 1, Part 1 applies.

NOTE 1 This means that the technical committees responsible for the part 2 standards have determined that it is not necessary to specify particular requirements for the appliance in question over and above the general requirements.

This standard is a product family standard dealing with the safety of appliances and takes precedence over horizontal and generic standards covering the same subject.

NOTE 2 Horizontal publications, basic safety publications and group safety publications covering a hazard are not applicable since they have been taken into consideration when developing the general and particular requirements for the IEC 60335 series of standards.

An appliance that complies with the text of this standard will not necessarily be considered to comply with the safety principles of the standard if, when examined and tested, it is found to have other features that impair the level of safety covered by these requirements.

An appliance employing materials or having forms of construction differing from those detailed in the requirements of this standard may be examined and tested according to the intent of the requirements and, if found to be substantially equivalent, may be considered to comply with the standard.

HOUSEHOLD AND SIMILAR ELECTRICAL APPLIANCES – SAFETY –

Part 2-40: Particular requirements for electrical heat pumps, air-conditioners and dehumidifiers

1 Scope

This part of IEC 60335 deals with the safety of electric **heat pumps**, **sanitary hot water heat pumps** and **air conditioners**, incorporating motor-compressors as well as **hydronic fan coils units**, **dehumidifiers** (with or without motor-compressors), **thermoelectric heat pumps** and **partial units**. Their maximum **rated voltage** being not more than 300 V for single phase appliances and 600 V for multi-phase appliances.

Appliances not intended for normal household use but which nevertheless can be a source of danger to the public, such as appliances intended to be used by laymen in shops, in light industry and on farms, are within the scope of this standard.

The appliances referenced above can consist of one or more factory-made assemblies. If provided in more than one assembly, the separate assemblies are used together, and the requirements are based on the use of matched assemblies.

NOTE 101 A definition of 'motor-compressor' is given in IEC 60335-2-34, which includes the statement that the term motor-compressor is used to designate either a hermetic motor-compressor or semi-hermetic motor-compressor.

NOTE 102 Requirements for containers intended for storage of the heated water included in **sanitary hot water heat pumps** are, in addition, covered by IEC 60335-2-21.

This standard does not take into account refrigerants other than group A1, A2L, A2 and A3 as defined by ISO 817. **Flammable refrigerants** are limited to those of a molar mass of more than or equal to 42 kg/kmol based on WCF (worst case formulation) as specified in ISO 817.

As far as practical, this standard deals with common hazards presented by appliances that are encountered in normal use and assumes that installation, servicing, decommissioning, and disposal are safely handled by competent persons and accidental release of refrigerants is avoided. However, it does not prescribe the criteria to ensure competence of persons during installation, servicing and disposal. Safety requirements during disposal are not specified in this standard.

NOTE 103 Annex HH provides informative requirements on competence of persons. Criteria for competence of personnel for the purpose of certification schemes can be found in ISO 22712¹.

Unless specifications are covered by this standard, including the annexes, requirements for refrigerating safety are covered by:

- ISO 5149-1:2014, ISO 5149-1:2014/AMD1:2015, and ISO 5149-1:2014/AMD2:2021,
- ISO 5149-2:2014 and ISO 5149-2:2014/AMD1:2020,
- ISO 5149-3:2014 and ISO 5149-3:2014/AMD1:2021.

Supplementary heaters, or a provision for their separate installation, are within the scope of this standard, but only heaters which are designed as a part of the appliance package, the controls being incorporated in the appliance.

¹ Under preparation. Stage at the time of publication: ISO FDIS 22712:2022

NOTE 104 Attention is drawn to the fact that

- for appliances intended to be used in vehicles or on-board ships or aircraft, additional requirements can be necessary;
- in many countries, additional requirements are specified, for example, by the national health authorities responsible for the protection of labour and the national authorities responsible for storage, transportation, building constructions and installations.

NOTE 105 This standard does not apply to

- humidifiers intended for use with heating and cooling equipment (IEC 60335-2-88);
- appliances designed exclusively for industrial processing;
- appliances intended to be used in locations where special conditions prevail, such as the presence of a corrosive or explosive atmosphere (dust, vapour or gas).

2 Normative references

IEC 60034-1, *Rotating electrical machines – Part 1: Rating and performance*

IEC 60061-1, *Lamp caps and holders together with gauges for the control of interchangeability and safety – Part 1: Lamp caps*

IEC 60065:2001, *Audio, video and similar electronic apparatus – Safety requirements*
Amendment 1 (2005)²⁾

IEC 60068-2-2, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-31, *Environmental testing – Part 2-31: Tests – Test Ec: Rough handling shocks, primarily for equipment-type specimens*

IEC 60068-2-52, *Environmental testing – Part 2: Tests – Test Kb: Salt mist, cyclic (sodium, chloride solution)*

IEC 60068-2-75, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

IEC 60068-2-78, *Environmental testing – Part 2-78: Tests – Test Cab: Damp heat, steady state*

IEC 60079-0, *Explosive atmospheres – Part 0: Equipment – General requirements*

IEC 60079-7:2015, *Explosive atmospheres – Part 7: Equipment protection by increased safety "e"*

IEC 60079-7:2015/AMD1:2017

IEC 60079-14:2013, *Explosive atmospheres – Part 14: Electrical installations design, selection and erection*

IEC 60079-15:2017, *Explosive atmospheres – Part 15: Equipment protection by type of protection "n"*

IEC/TR 60083, *Plugs and socket-outlets for domestic and similar general use standardized in member countries of IEC*

IEC 60085:2007, *Electrical insulation – Thermal evaluation and designation*

IEC 60112:2003, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*
Amendment 1 (2009)³⁾

IEC 60127 (all parts), *Miniature fuses*

²⁾ There exists a consolidated edition 7.1 (2005) that includes edition 7 and its Amendment 1.

³⁾ There exists a consolidated edition 4.1 (2009) that includes edition 4 and its Amendment 1.

IEC 60227 (all parts), *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V*

IEC 60238, *Edison screw lampholders*

IEC 60245 (all parts), *Rubber insulated cables – Rated voltages up to and including 450/750 V*

IEC 60252-1, *AC motor capacitors – Part 1: General – Performance testing and rating – Safety requirements – Guide for installation and operation*

IEC 60309 (all parts), *Plugs, socket-outlets and couplers for industrial purposes*

IEC 60320-1, *Appliance couplers for household and similar general purposes – Part 1: General requirements*

IEC 60320-2-2, *Appliance couplers for household and similar general purposes – Part 2-2: Interconnection couplers for household and similar equipment*

IEC 60320-2-3, *Appliance coupler for household and similar general purposes – Part 2-3: Appliance coupler with a degree of protection higher than IPX0*

IEC 60335-2-34:2021, *Household and similar electrical appliances – Safety – Part 2-34: Particular requirements for motor-compressors*

IEC 60335-2-51, *Household and similar electrical appliances – Safety – Part 2-51: Particular requirements for stationary circulation pumps for heating and service water installations*

IEC 60384-14:2005, *Fixed capacitors for use in electronic equipment – Part 14: Sectional specification: Fixed capacitors for electromagnetic interference suppression and connection to the supply mains*

IEC 60417, *Graphical symbols for use on equipment*

IEC 60445:2010, *Basic and safety principles for man-machine interface, marking and identification – Identification of equipment terminals, conductor terminations and conductors*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*
Amendment 1 (1999)⁴⁾

IEC 60598-1:2008, *Luminaires – Part 1: General requirements and tests*

IEC 60664-1:2007, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60664-3:2003, *Insulation coordination for equipment within low-voltage systems – Part 3: Use of coating, potting or moulding for protection against pollution*

IEC 60664-4:2005, *Insulation coordination for equipment within low-voltage systems – Part 4: Consideration of high-frequency voltage stress*

IEC 60691, *Thermal-links – Requirements and application guide*

IEC 60695-1-10, *Fire hazard testing – Part 1-10: Guidance for assessing the fire hazard of electrotechnical products – General guidelines*

IEC 60695-2-11:2000, *Fire hazard testing – Part 2-11: Glowing/hot wire based test methods – Glow-wire flammability test method for end-products*

IEC 60695-2-12, *Fire hazard testing – Part 2-12: Glowing/hot wire based test methods – Glow-wire flammability test method for materials*

⁴⁾ There exists a consolidated edition 2.1 (2001) that includes edition 2 and its Amendment 1.

IEC 60695-2-13, *Fire hazard testing – Part 2-13: Glowing/hot wire based test methods – Glow-wire ignitability test method for materials*

IEC 60695-10-2, *Fire hazard testing – Part 10-2: Abnormal heat – Ball pressure test*

IEC 60695-10-2:2014, *Fire hazard testing – Part 10-2: Abnormal heat – Ball pressure test method*

IEC 60695-11-5:2004, *Fire hazard testing – Part 11-5: Test flames – Needle-flame test method – Apparatus, confirmatory test arrangement and guidance*

IEC 60695-11-10, *Fire hazard testing – Part 11-10: Test flames – 50 W horizontal and vertical flame test methods*

IEC 60730-1:1999, *Automatic electrical controls for household and similar use – Part 1: General requirements*

Amendment 1 (2003)

Amendment 2 (2007)⁵⁾

IEC 60730-2-6, *Automatic electrical controls – Part 2-6: Particular requirements for automatic electrical pressure sensing controls including mechanical requirements*

IEC 60730-2-8:2000, *Automatic electrical controls for household and similar use – Part 2-8: Particular requirements for electrically operated water valves, including mechanical requirements*

Amendment 1 (2002)⁶⁾

IEC 60730-2-9:2008⁷⁾, *Automatic electrical controls for household and similar use – Part 2-9: Particular requirements for temperature sensing controls*

IEC 60730-2-10, *Automatic electrical controls for household and similar use – Part 2-10: Particular requirements for motor-starting relays*

IEC 60738-1, *Thermistors – Directly heated positive temperature coefficient – Part 1: Generic specification*

IEC 60906-1, *IEC system of plugs and socket-outlets for household and similar purposes – Part 1: Plugs and socket-outlets 16 A 250 V a.c.*

IEC 60990:1999, *Methods of measurement of touch current and protective conductor current*

IEC 60999-1:1999, *Connecting devices – Electrical copper conductors – Safety requirements for screw-type and screwless-type clamping units – Part 1: General requirements and particular requirements for clamping units for conductors from 0,2 mm² up to 35 mm² (included)*

IEC 61000-4-2, *Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test*

IEC 61000-4-3, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test*

IEC 61000-4-4, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-5, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*

⁵⁾ There exists a consolidated edition 3.2 (2007) that includes edition 3 and its Amendment 1 and Amendment 2.

⁶⁾ There exists a consolidated edition 2.1 (2003) that includes edition 2 and its Amendment 1.

⁷⁾ There exists a consolidated edition 3.1 (2011) that includes edition 3:2008 and its Amendment 1:2011.

IEC 61000-4-6, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields*

IEC 61000-4-11:2004, *Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests*

IEC 61000-4-13:2002, *Electromagnetic compatibility (EMC) – Part 4-13: Testing and measurement techniques – Harmonics and interharmonics including mains signalling at a.c. power port, low frequency immunity tests*
Amendment 1 (2009)⁸⁾

IEC 61000-4-34:2005, *Electromagnetic compatibility (EMC) - Part 4-34: Testing and measurement techniques - Voltage dips, short interruptions and voltage variations immunity tests for equipment with input current more than 16 A per phase*
Amendment 1 (2009)

IEC 61032:1997, *Protection of persons and equipment by enclosures – Probes for verification*

IEC 61058-1:2000, *Switches for appliances – Part 1: General requirements*
Amendment 1 (2001)
Amendment 2 (2007)⁹⁾

IEC 61180-1, *High-voltage test techniques for low-voltage equipment – Part 1: Definitions, test and procedure requirements*

IEC 61180-2, *High-voltage techniques for low-voltage equipment – Part 2: Test equipment*

IEC 61558-1:2005, *Safety of power transformers, power supply units and similar products – Part 1: General requirements and tests*
Amendment 1 (2009)¹⁰⁾

IEC 61558-2-6:2009, *Safety of transformers, reactors, power supply units and similar products for supply voltages up to 1 100 V – Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers*

IEC 61558-2-16, *Safety of transformers, reactors, power supply units and similar products for supply voltages up to 1 100 V – Part 2-16: Particular requirements and tests for switch mode power supply units and transformers for switch mode power supply units*

IEC 61770, *Electric appliances connected to the water mains – Avoidance of backsiphonage and failure of hose-sets*

IEC 62151, *Safety of equipment electrically connected to a telecommunication network*

IEC 62471:2006, *Photobiological safety of lamps and lamp systems*

IEC 62477-1, *Safety requirements for power electronic converter systems and equipment – Part 1: General*

IEC 62821-1, *Electric cables – Halogen-free, low smoke, thermoplastic insulated and sheathed cables of rated voltages up to and including 450/750 V – Part 1: General requirements*

ISO 178:2010, *Plastics – Determination of flexural properties*
ISO 178:2010/AMD 1:2013

⁸⁾ There exists a consolidated edition 1.1 (2009) that includes edition 1 and its Amendment 1.

⁹⁾ There exists a consolidated edition 3.2 (2008) that includes edition 3 and its Amendment 1 and Amendment 2.

¹⁰⁾ There exists a consolidated edition 2.1 (2009) that includes edition 2 and its Amendment 1.

ISO 179-1:2010, *Plastics – Determination of Charpy impact properties – Part 1: Non-instrumented impact test*

ISO 180:2000, *Plastics – Determination of Izod impact strength*

ISO 180:2000/AMD 1:2006

ISO 180:2000/AMD 2:2013

ISO 527 (all parts), *Plastics – Determination of tensile properties*

ISO 527-3, *Plastics – Determination of tensile properties – Part 3: Test conditions for films and sheets*

ISO 817, *Refrigerants – Designation and safety classification*

ISO 1302:2002¹¹, *Geometrical Product Specifications (GPS) – Indication of surface texture in technical product documentation*

ISO 2578, *Plastics – Determination of time-temperature limits after prolonged exposure to heat*

ISO 2768-1, *General tolerances – Part 1: Tolerances for linear and angular dimensions without individual tolerance indications*

ISO 4892-1:1999, *Plastics – Methods of exposure to laboratory light sources – Part 1: General guidance*

ISO 4892-2: 2013, *Plastics – Methods of exposure to laboratory light sources – Part 2: Xenon-arc lamps*

ISO 5149-1:2014, *Refrigerating systems and heat pumps – Safety and environmental requirements – Part 1: Definitions, classification and selection criteria*

ISO 5149-1:2014/AMD1:2015

ISO 5149-1:2014/AMD2:2021

ISO 5149-2:2014, *Refrigerating systems and heat pumps – Safety and environmental requirements – Part 2: Design, construction, testing, marking and documentation*

ISO 5149-2:2014/AMD1:2020

ISO 5149-3:2014, *Refrigerating systems and heat pumps – Safety and environmental requirements – Part 3: Installation site*

ISO 5149-3:2014/AMD1:2021

ISO 5151:2017, *Non-ducted air conditioners and heat pumps – Testing and rating for performance*

ISO 5151:2017/AMD1:2020

ISO 7000:2004, *Graphical symbols for use on equipment – Index and synopsis*

ISO 7010:2019, *Graphical symbols – Safety colours and safety signs – Registered safety signs*

ISO 8256:2004, *Plastics – Determination of tensile-impact strength*

ISO 9772:2001, *Cellular plastics – Determination of horizontal burning characteristics of small specimens subjected to a small flame*

Amendment 1 (2003)

ISO 9773, *Plastics – Determination of burning behaviour of thin flexible vertical specimens in contact with a small-flame ignition source*

ISO 13253, *Ducted air-conditioners and air-to-air heat pumps – Testing and rating for performance*

¹¹ Withdrawn.

ISO 13256 (all parts), *Water-source heat pumps – Testing and rating for performance*

ISO 13355:2016, *Packaging – Complete, filled transport packages and unit loads – Vertical random vibration test*

ISO 14903, *Refrigerating systems and heat pumps – Qualification of tightness of components and joints*

ISO 15042, *Multiple split-system air-conditioners and air-to-air heat pumps – Testing and rating for performance*

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

Elektriska hushållsapparater och liknande bruksföremål – Säkerhet –

Del 2-40: Särskilda fordringar på elektriska värmepumpar, luftkonditioneringsaggregat och luftavfuktare

Household and similar electrical appliances –

Safety –

Part 2-40: Particular requirements for electrical heat pumps, air-conditioners and dehumidifiers

Som svensk standard gäller europastandarden EN IEC 60335-2-40:2024. Den svenska standarden innehåller de officiella engelska språkversionerna av EN IEC 60335-2-40:2024 och EN IEC 60335-2-40:2024/A11:2024

Nationellt förord

Europastandarden EN IEC 60335-2-40:2024

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 60335-2-40, Seventh edition, 2022 - Household and similar electrical appliances – Safety – Part 2-40: Particular requirements for electrical heat pumps, air-conditioners and dehumidifiers**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN IEC 60335-2-40+A11, utg 4:2024 med eventuella tillägg, ändringar och rättelser gäller ej fr o m 2027-08-12.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1042
172 21 Sundbyberg
Tel 08-444 14 00
elstandard.se

English Version

Household and similar electrical appliances - Safety - Part 2-40:
Particular requirements for electrical heat pumps, air-
conditioners and dehumidifiers
(IEC 60335-2-40:2022 + COR1:2024)

Appareils électrodomestiques et analogues - Sécurité -
Partie 2-40: Exigences particulières pour les pompes à
chaleur électriques, les climatiseurs et les
déshumidificateurs
(IEC 60335-2-40:2022 + COR1:2024)

Sicherheit elektrischer Geräte für den Hausgebrauch und
ähnliche Zwecke - Teil 2-40: Besondere Anforderungen für
elektrisch betriebene Wärmepumpen, Klimageräte und
Raumluft-Entfeuchter
(IEC 60335-2-40:2022 + COR1:2024)

This European Standard was approved by CENELEC on 2024-08-12. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

This document (EN IEC 60335-2-40:2024) consists of the text of IEC 60335-2-40:2022 + COR1:2024 prepared by IEC/TC 61 "Safety of household and similar electrical appliances".

The following dates are fixed:

- latest date by which this document has to be (dop) 2025-08-12 implemented at national level by publication of an identical national standard or by endorsement
- latest date by which the national standards (dow) 2027-08-12 conflicting with this document have to be withdrawn

This document supersedes EN IEC 60335-2-40:2023 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN-CENELEC shall not be held responsible for identifying any or all such patent rights.

This document is read in conjunction with EN IEC 60335-2-40:2024/A11:2024.

This document has been prepared under a standardization request addressed to CENELEC by the European Commission. The Standing Committee of the EFTA States subsequently approves these requests for its Member States.

For the relationship with EU Legislation, see informative Annexes ZZA and ZZB, which are an integral part of EN IEC 60335-2-40:2024/A11:2024.

Any feedback and questions on this document should be directed to the users' national standards body/national committee. A complete listing of these bodies can be found on the CEN and CENELEC websites.

Endorsement notice

The text of the International Standard IEC 60335-2-40:2022 + COR1:2024 was approved by CEN-CENELEC as a European Standard without any modification.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Household and similar electrical appliances – Safety –
Part 2-40: Particular requirements for electrical heat pumps, air-conditioners and
dehumidifiers**

**Appareils électrodomestiques et analogues – Sécurité –
Partie 2-40: Exigences particulières pour les pompes à chaleur électriques, les
climatiseurs et les déshumidificateurs**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 23.120

ISBN 978-2-8322-3437-2

<p>Warning! Make sure that you obtained this publication from an authorized distributor. Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.</p>
--

CONTENTS

FOREWORD	5
INTRODUCTION	8
1 Scope	9
2 Normative references	10
3 Terms and definitions	11
4 General requirement	19
5 General conditions for the tests	19
6 Classification	20
7 Marking and instructions	20
8 Protection against access to live parts	26
9 Starting of motor-operated appliances	26
10 Power input and current	26
11 Heating	26
12 Void	29
13 Leakage current and electric strength at operating temperature	29
14 Transient overvoltages	29
15 Moisture resistance	29
16 Leakage current and electric strength	31
17 Overload protection of transformers and associated circuits	31
18 Endurance	31
19 Abnormal operation	31
20 Stability and mechanical hazards	38
21 Mechanical strength	38
22 Construction	39
23 Internal wiring	51
24 Components	51
25 Supply connection and external flexible cords	52
26 Terminals for external conductors	53
27 Provision for earthing	53
28 Screws and connections	53
29 Clearances, creepage distances and solid insulation	53
30 Resistance to heat and fire	53
31 Resistance to rusting	55
32 Radiation, toxicity and similar hazards	55
Annexes	62
Annex D (normative) Thermal motor protectors	62
Annex I (normative) Motors having basic insulation that is inadequate for the rated voltage of the appliance	62
Annex AA (informative) Examples for operating temperatures of the appliance	63
Annex BB (normative) Selected information about refrigerants	64
Annex CC (informative) Transportation, marking and storage for units that employ flammable refrigerants	68

Annex DD (normative) Requirements for installation, service, maintenance and repair, and decommissioning manuals of appliances using flammable refrigerants	69
Annex EE (normative) Pressure tests	78
Annex FF (normative) Leak simulation tests	80
Annex GG (normative) Charge limits, ventilation requirements and requirements for secondary circuits	82
Annex HH (informative) Competence of service personnel	115
Annex II (Void)	117
Annex JJ (normative) Allowable openings of relays and similar components to prevent ignition of A2L refrigerants	118
Annex KK (normative) Test method for hot surface ignition temperature for A2L	120
Annex LL (normative) Refrigerant detection systems for flammable refrigerants	124
Annex MM (normative) Refrigerant sensor location confirmation test	135
Annex NN (normative) Flame arrest enclosure verification test for A2L refrigerants	138
Annex OO (Void)	140
Annex PP (normative) Leak detection system confirmation test for flammable refrigerants	141
Annex QQ (normative) Methods for determining releasable charge	147
Bibliography	155
Figure 101 – Example of label for field charged units	57
Figure 102 – Arrangement for heating test of appliances with supplementary air heater	59
Figure 103 – Supply circuit for locked-rotor test of a motor of the single-phase type – Revise as needed for three-phase test	60
Figure 104 – Power spectral density profile for vibration test in 21.101	60
Figure 105 – Dimensional details for the weight in the area of the pressure ball	60
Figure 106 – Measurement before and after the test	61
Figure GG.1 – Unventilated area	112
Figure GG.2 – Mechanical ventilation	112
Figure GG.3 – Relevant heights h_{inst} , h_0 and h_{rel} for calculation of A_{min} and m_{max}	113
Figure GG.4 – Airflow direction	114
Figure KK.1 – Front view of test apparatus labels	120
Figure KK.2 – Test apparatus with dimensions	121
Figure KK.3 – Top view of test apparatus	122
Figure LL.1 – Example of test chamber design	130
Table 101 – Power spectral density profile for vibration test	38
Table 102 – UVC spectral irradiance measurement location	56
Table AA.1 – Examples for operating temperatures of the appliance	63
Table BB.1 – Selected information about refrigerants	64
Table DD.1 – Mandatory clauses in each manual	69
Table GG.1 – Outline of Annex GG (informative)	83
Table GG.2 – Circulation airflow	88
Table GG.3 – Appliance with packaging	95

Table GG.4 – Appliance without packaging	95
Table GG.5 – Minimum air velocity	107
Table GG.6 – Refrigerant leak rate (\dot{m}_{leak}).....	110
Table LL.1 – Relationship among alarm set point, tolerance and test gas (informative)	126
Table LL.2 – Gas and vapour concentrations	128
Table LL.3 – Example of the test chamber design	131

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HOUSEHOLD AND SIMILAR ELECTRICAL APPLIANCES – SAFETY –

**Part 2-40: Particular requirements for electrical heat pumps,
air-conditioners and dehumidifiers**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60335 has been prepared by subcommittee 61D: Appliances for air-conditioning for household and similar purposes, of IEC technical committee 61: Safety of household and similar electrical appliances. It is an International Standard.

This seventh edition cancels and replaces the sixth edition published in 2018. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- Clause 1 – added **thermoelectric heat pumps** to the scope and increased maximum **rated voltage** to 300 V for single phase appliances;
- Clause 7 – revised requirements for marking on the appliance and packaging, including a symbol for minimum floor area and modifying the symbol for **flammable refrigerants** to include the safety group per ISO 817;
- Clause 11 and Clause 19 – restructured for alignment with Part 1 and added requirements for **supplementary air heaters**;

- Clause 13 and Clause 16 – revised requirement for leakage current for **stationary class I motor-operated appliances**;
- Clause 21 – added requirements for **particle foam material** and revised requirements for transport testing;
- Clause 22 – removed limit on the sum of **refrigerant charges** for appliances with multiple **refrigerating systems**, and revised requirements for avoiding ignition sources, **leak detection systems**, **safety shut-off valves**, and **particle foam material**;
- Clause 23 – added requirements to avoid contact between wires and refrigerant piping;
- Clause 24 – revised requirements for motor-compressors;
- Clause 30 – added requirements for resistance to heat of **particle foam material**;
- Annex BB – revised Table BB.1 with refrigerant information and added a link to ISO 817 refrigerant data;
- Annex DD – revised requirements for information in the manual for appliances with **flammable refrigerants**;
- Annex EE – revised requirements for pressure testing;
- Annex FF – revised requirements for leak simulation tests;
- Annex GG – added requirements for applying **releasable charge**, added additional coverage for A2 and A3 refrigerants, including new charge limits for appliances with **circulation airflow** and for **enhanced tightness refrigerating systems**, and revised requirements for **enhanced tightness refrigerating systems** using **A2L refrigerant**;
- Annex LL – revised requirements for **refrigerant detection systems**;
- Annex MM – revised simulated leak rate;
- Annex OO – deleted annex for conditioning internal wiring using UV light.
- Annex PP – new coverage of **leak detection system** confirmation test;
- Annex QQ – new coverage of method for determining **releasable charge**.

The text of this International Standard is based on the following documents:

Draft	Report on voting
61D/491/FDIS	61D/493/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

This part 2-40 is to be used in conjunction with IEC 60335-1:2010, its Amendment 1:2013 and its Amendment 2:2016.

NOTE 1 When "Part 1" is mentioned in this standard, it refers to IEC 60335-1.

This part 2-40 supplements or modifies the corresponding clauses in IEC 60335-1, so as to convert that publication into the IEC standard: Safety requirements for electrical heat pumps, air-conditioners and dehumidifiers.

When a particular subclause of Part 1 is not mentioned in this part 2, that subclause applies as far as is reasonable. When this standard states "addition", "modification" or "replacement", the relevant text in Part 1 is to be adapted accordingly.

NOTE 2 The following numbering system is used:

- subclauses, tables and figures that are numbered starting from 101 are additional to those in Part 1;
- unless notes are in a new subclause or involve notes in Part 1, they are numbered starting from 101, including those in a replaced clause or subclause;
- additional annexes are lettered AA, BB, etc.

NOTE 3 The following print types are used:

- requirements: in roman type;
- *test specifications: in italic type;*
- notes: in small roman type.

Words in **bold** in the text are defined in Clause 3. When a definition concerns an adjective, the adjective and associated noun are also in bold.

The following differences exist in the countries indicated below:

- 6.1: Class 0I appliances are allowed (Japan).
- 11.8: The temperature of the wooden walls in the test casing is limited to 85 °C (Sweden).

A list of all parts of the IEC 60335 series, under the general title: *Household and similar electrical appliances – Safety*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

It has been assumed in the drafting of this International Standard that the execution of its provisions is entrusted to appropriately qualified and experienced persons.

Guidance documents concerning the application of the safety requirements for appliances can be accessed via TC 61 supporting documents on the IEC website

<https://www.iec.ch/tc61/supportingdocuments>

This information is given for the convenience of users of this International Standard and does not constitute a replacement for the normative text in this standard.

This standard recognizes the internationally accepted level of protection against hazards such as electrical, mechanical, thermal, fire and radiation of appliances when operated as in normal use taking into account the instructions. It also covers abnormal situations that can be expected in practice.

This standard takes into account the requirements of IEC 60364 as far as possible so that there is compatibility with the wiring rules when the appliance is connected to the supply mains. However, national wiring rules can differ.

If an appliance within the scope of this standard also incorporates functions that are covered by another part 2 of IEC 60335, the relevant part 2 is applied to each function separately, as far as is reasonable. If applicable, the influence of one function on the other is taken into account.

When a part 2 standard does not include additional requirements to cover hazards dealt with in Part 1, Part 1 applies.

NOTE 1 This means that the technical committees responsible for the part 2 standards have determined that it is not necessary to specify particular requirements for the appliance in question over and above the general requirements.

This standard is a product family standard dealing with the safety of appliances and takes precedence over horizontal and generic standards covering the same subject.

NOTE 2 Horizontal publications, basic safety publications and group safety publications covering a hazard are not applicable since they have been taken into consideration when developing the general and particular requirements for the IEC 60335 series of standards.

An appliance that complies with the text of this standard will not necessarily be considered to comply with the safety principles of the standard if, when examined and tested, it is found to have other features that impair the level of safety covered by these requirements.

An appliance employing materials or having forms of construction differing from those detailed in the requirements of this standard may be examined and tested according to the intent of the requirements and, if found to be substantially equivalent, may be considered to comply with the standard.

HOUSEHOLD AND SIMILAR ELECTRICAL APPLIANCES – SAFETY –

Part 2-40: Particular requirements for electrical heat pumps, air-conditioners and dehumidifiers

1 Scope

This clause of Part 1 is replaced by the following.

This part of IEC 60335 deals with the safety of electric **heat pumps**, **sanitary hot water heat pumps** and **air conditioners**, incorporating motor-compressors as well as **hydronic fan coils units**, **dehumidifiers** (with or without motor-compressors), **thermoelectric heat pumps** and **partial units**. Their maximum **rated voltage** being not more than 300 V for single phase appliances and 600 V for multi-phase appliances.

Appliances not intended for normal household use but which nevertheless can be a source of danger to the public, such as appliances intended to be used by laymen in shops, in light industry and on farms, are within the scope of this standard.

The appliances referenced above can consist of one or more factory-made assemblies. If provided in more than one assembly, the separate assemblies are used together, and the requirements are based on the use of matched assemblies.

NOTE 101 A definition of 'motor-compressor' is given in IEC 60335-2-34, which includes the statement that the term motor-compressor is used to designate either a hermetic motor-compressor or semi-hermetic motor-compressor.

NOTE 102 Requirements for containers intended for storage of the heated water included in **sanitary hot water heat pumps** are, in addition, covered by IEC 60335-2-21.

This standard does not take into account refrigerants other than group A1, A2L, A2 and A3 as defined by ISO 817. **Flammable refrigerants** are limited to those of a molar mass of more than or equal to 42 kg/kmol based on WCF (worst case formulation) as specified in ISO 817.

As far as practical, this standard deals with common hazards presented by appliances that are encountered in normal use and assumes that installation, servicing, decommissioning, and disposal are safely handled by competent persons and accidental release of refrigerants is avoided. However, it does not prescribe the criteria to ensure competence of persons during installation, servicing and disposal. Safety requirements during disposal are not specified in this standard.

NOTE 103 Annex HH provides informative requirements on competence of persons. Criteria for competence of personnel for the purpose of certification schemes can be found in ISO 22712¹.

Unless specifications are covered by this standard, including the annexes, requirements for refrigerating safety are covered by:

- ISO 5149-1:2014, ISO 5149-1:2014/AMD1:2015, and ISO 5149-1:2014/AMD2:2021,
- ISO 5149-2:2014 and ISO 5149-2:2014/AMD1:2020,
- ISO 5149-3:2014 and ISO 5149-3:2014/AMD1:2021.

¹ Under preparation. Stage at the time of publication: ISO FDIS 22712:2022

Supplementary heaters, or a provision for their separate installation, are within the scope of this standard, but only heaters which are designed as a part of the appliance package, the controls being incorporated in the appliance.

NOTE 104 Attention is drawn to the fact that

- for appliances intended to be used in vehicles or on-board ships or aircraft, additional requirements can be necessary;
- in many countries, additional requirements are specified, for example, by the national health authorities responsible for the protection of labour and the national authorities responsible for storage, transportation, building constructions and installations.

NOTE 105 This standard does not apply to

- humidifiers intended for use with heating and cooling equipment (IEC 60335-2-88);
- appliances designed exclusively for industrial processing;
- appliances intended to be used in locations where special conditions prevail, such as the presence of a corrosive or explosive atmosphere (dust, vapour or gas).

2 Normative references

This clause of Part 1 is applicable except as follows.

Addition:

IEC 60068-2-52, *Environmental testing – Part 2: Tests – Test Kb: Salt mist, cyclic (sodium, chloride solution)*

IEC 60079-0, *Explosive atmospheres – Part 0: Equipment – General requirements*

IEC 60079-7:2015, *Explosive atmospheres – Part 7: Equipment protection by increased safety "e"*

IEC 60079-7:2015/AMD1:2017

IEC 60079-14:2013, *Explosive atmospheres – Part 14: Electrical installations design, selection and erection*

IEC 60079-15:2017, *Explosive atmospheres – Part 15: Equipment protection by type of protection "n"*

IEC 60335-2-34:2021, *Household and similar electrical appliances – Safety – Part 2-34: Particular requirements for motor-compressors*

IEC 60335-2-51, *Household and similar electrical appliances – Safety – Part 2-51: Particular requirements for stationary circulation pumps for heating and service water installations*

IEC 60695-1-10, *Fire hazard testing – Part 1-10: Guidance for assessing the fire hazard of electrotechnical products – General guidelines*

IEC 60695-10-2:2014, *Fire hazard testing – Part 10-2: Abnormal heat – Ball pressure test method*

IEC 60730-2-6, *Automatic electrical controls – Part 2-6: Particular requirements for automatic electrical pressure sensing controls including mechanical requirements*

IEC 62471:2006, *Photobiological safety of lamps and lamp systems*

ISO 817, *Refrigerants – Designation and safety classification*

ISO 527-3, *Plastics – Determination of tensile properties – Part 3: Test conditions for films and sheets*

ISO 1302:2002², *Geometrical Product Specifications (GPS) – Indication of surface texture in technical product documentation*

ISO 2578, *Plastics – Determination of time-temperature limits after prolonged exposure to heat*

ISO 5149-1:2014, *Refrigerating systems and heat pumps – Safety and environmental requirements – Part 1: Definitions, classification and selection criteria*

ISO 5149-1:2014/AMD1:2015

ISO 5149-1:2014/AMD2:2021

ISO 5149-2:2014, *Refrigerating systems and heat pumps – Safety and environmental requirements – Part 2: Design, construction, testing, marking and documentation*

ISO 5149-2:2014/AMD1:2020

ISO 5149-3:2014, *Refrigerating systems and heat pumps – Safety and environmental requirements – Part 3: Installation site*

ISO 5149-3:2014/AMD1:2021

ISO 5151:2017, *Non-ducted air conditioners and heat pumps – Testing and rating for performance*

ISO 5151:2017/AMD1:2020

ISO 7010:2019, *Graphical symbols – Safety colours and safety signs – Registered safety signs*

ISO 13253, *Ducted air-conditioners and air-to-air heat pumps – Testing and rating for performance*

ISO 13256 (all parts), *Water-source heat pumps – Testing and rating for performance*

ISO 13355:2016, *Packaging – Complete, filled transport packages and unit loads – Vertical random vibration test*

ISO 14903, *Refrigerating systems and heat pumps – Qualification of tightness of components and joints*

ISO 15042, *Multiple split-system air-conditioners and air-to-air heat pumps – Testing and rating for performance*

² Withdrawn.