

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

REDLINE VERSION

Industriell processtyrning – Profiler – Del 5-6: Installation av fältbussar – Installationsprofiler för CPF 6 (Interbus™)

Industrial networks –

Profiles –

Part 5-6: Installation of fieldbuses –

Installation profiles for CPF 6

En så kallad ”Redline version” (RLV) innehåller både standarden som fastställts som SS och en ändringsmarkerad IEC-standard. Alla tillägg och borttagningar sedan den tidigare utgåvan av IEC-standardens är markerade med färg. Med en RLV sparar du mycket tid när du ska identifiera och bedöma aktuella ändringar i standarden. SEK Svensk Elstandard kan bara ge ut RLV i de fall den finns tillgänglig från IEC.



IEC 61784-5-6

Edition 5.0 2024-04
REDLINE VERSION

INTERNATIONAL STANDARD



Industrial **communication** networks – Profiles –
Part 5-6: Installation of fieldbuses – Installation profiles for CPF

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 25.040.40; 35.100.40

ISBN 978-2-8322-8689-0

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	2
1 Scope.....	9
2 Normative references	9
3 Terms, definitions and abbreviated terms	9
4 CPF 6: Overview of installation profiles	10
5 Installation profile conventions.....	10
6 Conformance to installation profiles.....	10
Annex A (normative) CPF 6 Type 8 network specific installation profile.....	12
A.1 Installation profile scope	12
A.2 Normative references.....	12
A.3 Installation profile terms, definitions, and abbreviated terms	13
A.3.1 Terms and definitions	13
A.3.2 Abbreviated terms	14
A.3.3 Conventions for installation profiles	14
A.4 Installation planning.....	14
A.4.1 General	14
A.4.2 Planning requirements.....	15
A.4.3 Network capabilities.....	16
A.4.4 Selection and use of cabling components	20
A.4.5 Cabling planning documentation	29
A.4.6 Verification of cabling planning specification.....	29
A.5 Installation implementation.....	29
A.5.1 General requirements	29
A.5.2 Cable installation	29
A.5.3 Connector installation	32
A.5.4 Terminator installation	34
A.5.5 Device installation	34
A.5.6 Coding and labelling	34
A.5.7 Earthing and bonding of equipment and devices and shield cabling	34
A.5.8 As-implemented cabling documentation.....	34
A.6 Installation verification and installation acceptance test	34
A.6.1 General	34
A.6.2 Installation verification	34
A.6.3 Installation acceptance test	35
A.7 Installation administration	36
A.8 Installation maintenance and installation troubleshooting.....	36
Annex B (normative) CPF 6 Ethernet network specific installation profile	37
B.1 Installation profile scope	37
B.2 Normative references.....	37
B.3 Installation profile terms, definitions, and abbreviated terms	38
B.3.1 Terms and definitions	38
B.3.2 Abbreviated terms	38
B.3.3 Conventions for installation profiles	38
B.4 Installation planning.....	38
B.4.1 General	38

B.4.2	Planning requirements	39
B.4.3	Network capabilities	40
B.4.4	Selection and use of cabling components	43
B.4.5	Cabling planning documentation	49
B.4.6	Verification of cabling planning specification	49
B.5	Installation implementation	49
B.5.1	General requirements	49
B.5.2	Cable installation	49
B.5.3	Connector installation	51
B.5.4	Terminator installation	51
B.5.5	Device installation	51
B.5.6	Coding and labelling	51
B.5.7	Earthing and bonding of equipment and devices and shield cabling	51
B.5.8	As-implemented cabling documentation	52
B.6	Installation verification and installation acceptance test	52
B.6.1	General	52
B.6.2	Installation verification	52
B.6.3	Installation acceptance test	52
B.7	Installation administration	52
B.8	Installation maintenance and installation troubleshooting	52
	Bibliography	53
	Figure 1 – Standards relationships	8
	Figure A.1 – Type 8 network structure example	17
	Figure A.2 – Example of a Type 8 network configuration	18
	Figure A.3 – Sub-D connector pin assignment	32
	Figure A.4 – M23 circular connector pin assignment	33
	Figure A.5 – M12 circular connector pin assignment	33
	Figure A.6 – Terminal connector at the device	33
	Figure B.1 – Terminal connector at the device	51
	Table A.1 – Basic network characteristics for balanced cabling not based on Ethernet	19
	Table A.2 – Network characteristics for optical fibre cabling	20
	Table A.3 – Information relevant to balanced cable: fixed cables	21
	Table A.4 – Information relevant to balanced cable: cords	22
	Table A.5 – Remote bus fibre optic cable length	24
	Table A.6 – Connectors for copper cabling CPs not based on Ethernet	24
	Table A.7 – Optical fibre connecting hardware	25
	Table A.8 – Relationship between FOC and fibre types (Type 8 networks)	25
	Table A.9 – Colour code for balanced cables used by Type 8 networks	27
	Table A.10 – Parameters for balanced cables	29
	Table A.11 – Parameters for silica optical fibre cables	30
	Table A.12 – Parameters for POF optical fibre cables	30
	Table A.13 – Parameters for hard clad silica optical fibre cables	31
	Table A.14 – Pin assignment of the terminal connector	33
	Table B.1 – Network characteristics for balanced cabling based on Ethernet	41

Table B.2 – Network characteristics for optical fibre cabling.....	42
Table B.3 – Information relevant to copper cable: fixed cables.....	43
Table B.4 – Information relevant to copper cable: cords.....	44
Table B.5 – Information relevant to optical fibre cables.....	45
Table B.6 – Connectors for balanced cabling CPs based on Ethernet.....	46
Table B.7 – Connectors for copper cabling CPs not based on Ethernet.....	46
Table B.8 – Optical fibre connecting hardware.....	47
Table B.9 – Relationship between FOC and fibre types (CP 6/2 Ethernet network).....	47
Table B.10 – Parameters for balanced cables.....	49
Table B.11 – Parameters for silica optical fibre cables.....	49
Table B.12 – Parameters for POF optical fibre cables.....	50
Table B.13 – Parameters for hard clad silica optical fibre cables.....	50

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL ~~COMMUNICATION~~ NETWORKS –
PROFILES –****Part 5-6: Installation of fieldbuses –
Installation profiles for CPF 6**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC 61784-5-6:2018. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC 61784-5-6 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial process measurement, control and automation. It is an International Standard.

This document is to be used in conjunction with IEC 61918:2018, IEC 61918:2018/AMD1:2022 and IEC 61918:2018/AMD2:2024.

This fifth edition cancels and replaces the fourth edition published in 2018. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) alignment with IEC 61918:2018, IEC 61918:2018/AMD1:2022 and IEC 61918:2018/AMD2:2024;
- b) addition of new content related to Single Pair Ethernet (SPE) in Annex B, Table B.1, Table B.3, Table B.4, Table B.6.

The text of this International Standard is based on the following documents:

Draft	Report on voting
65C/1283/FDIS	65C/1297/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with the ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of IEC 61784-5 series, under the general title *Industrial networks – Profiles – Installation of fieldbuses*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION


This document is one of a series produced to facilitate the use of communication networks in industrial control systems.

IEC 61918:2018, IEC 61918:2018/AMD1:2022 and IEC 61918:2018/AMD2:2024 provide the common requirements for the installation of communication networks in industrial control systems. This installation profile document provides the installation profiles of the communication profiles (CP) of a specific communication profile family (CPF) by stating which requirements of IEC 61918 fully apply and, where necessary, by supplementing, modifying, or replacing the other requirements (see Figure 1).


For general background on fieldbuses, their profiles, and relationship between the installation profiles specified in this document, see IEC 61158-1.

Each CP installation profile is specified in a separate annex of this document. Each annex is structured exactly as the reference document IEC 61918 for the benefit of the persons representing the roles in the fieldbus installation process as defined in IEC 61918 (planner, installer, verification personnel, validation personnel, maintenance personnel, administration personnel). By reading the installation profile in conjunction with IEC 61918, these persons immediately know which requirements are common for the installation of all CPs and which are modified or replaced. The conventions used to draft this document are defined in Clause 5.

The provision of the installation profiles in one document for each CPF (for example IEC 61784-5-6 for CPF 6) allows readers to work with documents of a convenient size.



IEC



IEC

Figure 1 – Standards relationships

INDUSTRIAL ~~COMMUNICATION~~ NETWORKS – PROFILES –

Part 5-6: Installation of fieldbuses – Installation profiles for CPF 6

1 Scope

This part of IEC 61784-5 specifies the installation profiles for CPF 6 (INTERBUSTM)¹.

The installation profiles are specified in the annexes. These annexes are read in conjunction with IEC 61918:2018, IEC 61918:2018/AMD1:2022 and IEC 61918:2018/AMD2:2024.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61918:2018², *Industrial communication networks – Installation of communication networks in industrial premises*

IEC 61918:2018/AMD1:2022

IEC 61918:2018/AMD2:2024

~~The normative references of IEC 61918:2018, Clause 2, apply.~~

NOTE For profile specific normative references, see Clauses A.2, B.2.

¹ INTERBUSTM is a trade name of INTERBUS Club, an independent organisation of users and vendors of INTERBUS products. This information is given for the convenience of users of this document and does not constitute an endorsement by IEC of the trademark holder or any of its products. Compliance to this profile does not require use of the trade name INTERBUS. Use of the trade name INTERBUS requires permission of the trade name holder.

² The normative references of IEC 61918:2018, Clause 2, IEC 61918:2018/AMD1:2022, Clause 2 and IEC 61918:2018/AMD2:2024, Clause 2, apply.

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

Industriell processtyrning – Profiler – Del 5-6: Installation av fältbussar – Installationsprofiler för CPF 6 (Interbus™)

Industrial networks –

Profiles –

Part 5-6: Installation of fieldbuses –

Installation profiles for CPF 6

Som svensk standard gäller europastandarden EN IEC 61784-5-6:2024. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 61784-5-6:2024.

Nationellt förord

Europastandarden EN IEC 61784-5-6:2024

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 61784-5-6, Fifth edition, 2024 - Industrial networks – Profiles – Part 5-6: Installation of fieldbuses – Installation profiles for CPF 6**

utarbetad inom International Electrotechnical Commission, IEC.

Standarden ska användas tillsammans med SS-EN IEC 61918, utg 3:2018 och dess separat utgivna tillägg, ändringar och rättelser.

Tidigare fastställd svensk standard SS-EN IEC 61784-5-6, utg 4:2019 med eventuella tillägg, ändringar och rättelser gäller ej fr o m 2027-05-08.

ICS 25.040.40; 35.100.40

Denna standard är fastställd av SEK Svensk Elstandard,
som också kan lämna upplysningar om **sakinnehållet** i standarden.
Postadress: Box 1042, 172 21 Sundbyberg
Telefon: 08 - 444 14 00.
E-post: sek@elstandard.se. Internet: elstandard.se

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1042
172 21 Sundbyberg
Tel 08-444 14 00
elstandard.se

English Version

Industrial networks - Profiles - Part 5-6: Installation of fieldbuses
- Installation profiles for CPF 6
(IEC 61784-5-6:2024)

Réseaux industriels - Profils - Partie 5-6: Installation des
bus de terrain - Profils d'installation pour CPF 6
(IEC 61784-5-6:2024)

Industrielle Kommunikationsnetze - Profile - Teil 5-6:
Feldbusinstallation - Installationsprofile für die
Kommunikationsprofilfamilie 6
(IEC 61784-5-6:2024)

This European Standard was approved by CENELEC on 2024-05-08. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 65C/1283/FDIS, future edition 5 of IEC 61784-5-6, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61784-5-6:2024.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2025-02-08 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2027-05-08 document have to be withdrawn

This document supersedes EN IEC 61784-5-6:2018 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document is read in conjunction with EN IEC 61918:2018, and all of its amendments and corrigenda (if any).

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 61784-5-6:2024 was approved by CENELEC as a European Standard without any modification.

Annex ZA
(normative)

**Normative references to international publications
with their corresponding European publications**

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61918	2018	Industrial communication networks - Installation of communication networks in industrial premises	EN IEC 61918	2018 ¹
-	-		+ A11	2019
-	-		+ A12	2023
-	-		+ AC	2019-03
+ AMD1	2022		+ A1	2022
+ AMD2	2024		+ A2	2024

¹ The normative references of EN IEC 61918:2018, EN IEC 61918:2018/A11:2019, EN IEC 61918:2018/A12:2023, EN IEC 61918:2018/AC:2019-03, EN IEC 61918:2018/A1:2022, and EN IEC 61918:2018/A2:2024 apply.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial networks – Profiles –
Part 5-6: Installation of fieldbuses – Installation profiles for CPF 6**

**Réseaux industriels – Profils –
Partie 5-6: Installation des bus de terrain – Profils d'installation pour CPF 6**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 25.040.40, 35.100.40

ISBN 978-2-8322-8404-9

Warning! Make sure that you obtained this publication from an authorized distributor. Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.
--

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references	8
3 Terms, definitions and abbreviated terms	8
4 CPF 6: Overview of installation profiles	9
5 Installation profile conventions.....	9
6 Conformance to installation profiles.....	9
Annex A (normative) CPF 6 Type 8 network specific installation profile.....	11
A.1 Installation profile scope	11
A.2 Normative references.....	11
A.3 Installation profile terms, definitions, and abbreviated terms	11
A.3.1 Terms and definitions	11
A.3.2 Abbreviated terms	12
A.3.3 Conventions for installation profiles	13
A.4 Installation planning.....	13
A.4.1 General	13
A.4.2 Planning requirements.....	13
A.4.3 Network capabilities.....	14
A.4.4 Selection and use of cabling components	18
A.4.5 Cabling planning documentation	27
A.4.6 Verification of cabling planning specification.....	27
A.5 Installation implementation.....	27
A.5.1 General requirements	27
A.5.2 Cable installation	27
A.5.3 Connector installation	30
A.5.4 Terminator installation	32
A.5.5 Device installation	32
A.5.6 Coding and labelling	32
A.5.7 Earthing and bonding of equipment and devices and shield cabling	32
A.5.8 As-implemented cabling documentation.....	32
A.6 Installation verification and installation acceptance test	32
A.6.1 General	32
A.6.2 Installation verification	32
A.6.3 Installation acceptance test	33
A.7 Installation administration	34
A.8 Installation maintenance and installation troubleshooting.....	34
Annex B (normative) CPF 6 Ethernet network specific installation profile	35
B.1 Installation profile scope	35
B.2 Normative references.....	35
B.3 Installation profile terms, definitions, and abbreviated terms	36
B.3.1 Terms and definitions	36
B.3.2 Abbreviated terms	36
B.3.3 Conventions for installation profiles	36
B.4 Installation planning.....	36
B.4.1 General	36

B.4.2	Planning requirements	36
B.4.3	Network capabilities	37
B.4.4	Selection and use of cabling components	40
B.4.5	Cabling planning documentation	46
B.4.6	Verification of cabling planning specification	46
B.5	Installation implementation	46
B.5.1	General requirements	46
B.5.2	Cable installation	46
B.5.3	Connector installation	48
B.5.4	Terminator installation	48
B.5.5	Device installation	48
B.5.6	Coding and labelling	48
B.5.7	Earthing and bonding of equipment and devices and shield cabling	48
B.5.8	As-implemented cabling documentation	48
B.6	Installation verification and installation acceptance test	49
B.6.1	General	49
B.6.2	Installation verification	49
B.6.3	Installation acceptance test	49
B.7	Installation administration	49
B.8	Installation maintenance and installation troubleshooting	49
	Bibliography	50
	Figure 1 – Standards relationships	7
	Figure A.1 – Type 8 network structure example	15
	Figure A.2 – Example of a Type 8 network configuration	16
	Figure A.3 – Sub-D connector pin assignment	30
	Figure A.4 – M23 circular connector pin assignment	31
	Figure A.5 – M12 circular connector pin assignment	31
	Figure A.6 – Terminal connector at the device	31
	Figure B.1 – Terminal connector at the device	48
	Table A.1 – Basic network characteristics for balanced cabling not based on Ethernet	17
	Table A.2 – Network characteristics for optical fibre cabling	18
	Table A.3 – Information relevant to balanced cable: fixed cables	19
	Table A.4 – Information relevant to balanced cable: cords	20
	Table A.5 – Remote bus fibre optic cable length	22
	Table A.6 – Connectors for copper cabling CPs not based on Ethernet	22
	Table A.7 – Optical fibre connecting hardware	23
	Table A.8 – Relationship between FOC and fibre types (Type 8 networks)	23
	Table A.9 – Colour code for balanced cables used by Type 8 networks	25
	Table A.10 – Parameters for balanced cables	27
	Table A.11 – Parameters for silica optical fibre cables	28
	Table A.12 – Parameters for POF optical fibre cables	28
	Table A.13 – Parameters for hard clad silica optical fibre cables	29
	Table A.14 – Pin assignment of the terminal connector	31
	Table B.1 – Network characteristics for balanced cabling based on Ethernet	38

Table B.2 – Network characteristics for optical fibre cabling.....	39
Table B.3 – Information relevant to copper cable: fixed cables.....	40
Table B.4 – Information relevant to copper cable: cords.....	41
Table B.5 – Information relevant to optical fibre cables.....	42
Table B.6 – Connectors for balanced cabling CPs based on Ethernet.....	43
Table B.7 – Connectors for copper cabling CPs not based on Ethernet.....	43
Table B.8 – Optical fibre connecting hardware.....	44
Table B.9 – Relationship between FOC and fibre types (CP 6/2 Ethernet network).....	44
Table B.10 – Parameters for balanced cables.....	46
Table B.11 – Parameters for silica optical fibre cables.....	46
Table B.12 – Parameters for POF optical fibre cables.....	47
Table B.13 – Parameters for hard clad silica optical fibre cables.....	47

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL NETWORKS –
PROFILES –****Part 5-6: Installation of fieldbuses –
Installation profiles for CPF 6****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 61784-5-6 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial process measurement, control and automation. It is an International Standard.

This document is to be used in conjunction with IEC 61918:2018, IEC 61918:2018/AMD1:2022 and IEC 61918:2018/AMD2:2024.

This fifth edition cancels and replaces the fourth edition published in 2018. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) alignment with IEC 61918:2018, IEC 61918:2018/AMD1:2022 and IEC 61918:2018/AMD2:2024;
- b) addition of new content related to Single Pair Ethernet (SPE) in Annex B, Table B.1, Table B.3, Table B.4, Table B.6.

The text of this International Standard is based on the following documents:

Draft	Report on voting
65C/1283/FDIS	65C/1297/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with the ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of IEC 61784-5 series, under the general title *Industrial networks – Profiles – Installation of fieldbuses*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This document is one of a series produced to facilitate the use of communication networks in industrial control systems.

IEC 61918:2018, IEC 61918:2018/AMD1:2022 and IEC 61918:2018/AMD2:2024 provide the common requirements for the installation of communication networks in industrial control systems. This installation profile document provides the installation profiles of the communication profiles (CP) of a specific communication profile family (CPF) by stating which requirements of IEC 61918 fully apply and, where necessary, by supplementing, modifying, or replacing the other requirements (see Figure 1).

For general background on fieldbuses, their profiles, and relationship between the installation profiles specified in this document, see IEC 61158-1.

Each CP installation profile is specified in a separate annex of this document. Each annex is structured exactly as the reference document IEC 61918 for the benefit of the persons representing the roles in the fieldbus installation process as defined in IEC 61918 (planner, installer, verification personnel, validation personnel, maintenance personnel, administration personnel). By reading the installation profile in conjunction with IEC 61918, these persons immediately know which requirements are common for the installation of all CPs and which are modified or replaced. The conventions used to draft this document are defined in Clause 5.

The provision of the installation profiles in one document for each CPF (for example IEC 61784-5-6 for CPF 6) allows readers to work with documents of a convenient size.




Figure 1 – Standards relationships

INDUSTRIAL NETWORKS – PROFILES –

Part 5-6: Installation of fieldbuses – Installation profiles for CPF 6

1 Scope

This part of IEC 61784-5 specifies the installation profiles for CPF 6 (INTERBUS™)¹.

The installation profiles are specified in the annexes. These annexes are read in conjunction with IEC 61918:2018, IEC 61918:2018/AMD1:2022 and IEC 61918:2018/AMD2:2024.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61918:2018², *Industrial communication networks – Installation of communication networks in industrial premises*

IEC 61918:2018/AMD1:2022

IEC 61918:2018/AMD2:2024

NOTE For profile specific normative references, see Clauses A.2, B.2.

¹ INTERBUS™ is a trade name of INTERBUS Club, an independent organisation of users and vendors of INTERBUS products. This information is given for the convenience of users of this document and does not constitute an endorsement by IEC of the trademark holder or any of its products. Compliance to this profile does not require use of the trade name INTERBUS. Use of the trade name INTERBUS requires permission of the trade name holder.

² The normative references of IEC 61918:2018, Clause 2, IEC 61918:2018/AMD1:2022, Clause 2 and IEC 61918:2018/AMD2:2024, Clause 2, apply.