

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

## Industriell processstyrning – Profiler – Del 5-6: Installation av fältbussar – Installationsprofiler för CPF 6 (Interbus™)

*Industrial networks –  
Profiles –  
Part 5-6: Installation of fieldbuses –  
Installation profiles for CPF 6*

Som svensk standard gäller europastandarden EN IEC 61784-5-6:2024. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 61784-5-6:2024.

### Nationellt förord

Europastandarden EN IEC 61784-5-6:2024

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 61784-5-6, Fifth edition, 2024 - Industrial networks – Profiles – Part 5-6: Installation of fieldbuses – Installation profiles for CPF 6**

utarbetad inom International Electrotechnical Commission, IEC.

Standarden ska användas tillsammans med SS-EN IEC 61918, utg 3:2018 och dess separat utgivna tillägg, ändringar och rättelser.

Tidigare fastställd svensk standard SS-EN IEC 61784-5-6, utg 4:2019 med eventuella tillägg, ändringar och rättelser ej fr o m 2027-05-08.

---

ICS 25.040.40; 35.100.40

## **Standarder underlättar utvecklingen och höjer elsäkerheten**

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

## **SEK är Sveriges röst i standardiseringssarbetet inom elområdet**

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

## **Stora delar av arbetet sker internationellt**

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringssarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringssverksamhet och medlemsavgift till IEC och CENELEC.

## **Var med och påverka!**

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakta med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

## **SEK Svensk Elstandard**

Box 1042  
172 21 Sundbyberg  
Tel 08-444 14 00  
[elstandard.se](http://elstandard.se)

**EUROPEAN STANDARD**  
**NORME EUROPÉENNE**  
**EUROPÄISCHE NORM**

**EN IEC 61784-5-6**

May 2024

ICS 25.040.40; 35.100.40

Supersedes EN IEC 61784-5-6:2018

English Version

**Industrial networks - Profiles - Part 5-6: Installation of fieldbuses  
- Installation profiles for CPF 6  
(IEC 61784-5-6:2024)**

Réseaux industriels - Profils - Partie 5-6: Installation des  
bus de terrain - Profils d'installation pour CPF 6  
(IEC 61784-5-6:2024)

Industrielle Kommunikationsnetze - Profile - Teil 5-6:  
Feldbusinstallation - Installationsprofile für die  
Kommunikationsprofilfamilie 6  
(IEC 61784-5-6:2024)

This European Standard was approved by CENELEC on 2024-05-08. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2024 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

Ref. No. EN IEC 61784-5-6:2024 E

## **European foreword**

The text of document 65C/1283/FDIS, future edition 5 of IEC 61784-5-6, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61784-5-6:2024.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2025-02-08 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2027-05-08 document have to be withdrawn

This document supersedes EN IEC 61784-5-6:2018 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document is read in conjunction with EN IEC 61918:2018, and all of its amendments and corrigenda (if any).

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

## **Endorsement notice**

The text of the International Standard IEC 61784-5-6:2024 was approved by CENELEC as a European Standard without any modification.

## Annex ZA

(normative)

### **Normative references to international publications with their corresponding European publications**

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: [www.cencenelec.eu](http://www.cencenelec.eu).

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61918	2018	Industrial communication networks - Installation of communication networks in industrial premises	- EN IEC 61918	2018 <sup>1</sup>
-	-		+ A11	2019
-	-		+ A12	2023
-	-		+ AC	2019-03
+ AMD1	2022		+ A1	2022
+ AMD2	2024		+ A2	2024

---

<sup>1</sup> The normative references of EN IEC 61918:2018, EN IEC 61918:2018/A11:2019, EN IEC 61918:2018/A12:2023, EN IEC 61918:2018/AC:2019-03, EN IEC 61918:2018/A1:2022, and EN IEC 61918:2018/A2:2024 apply.



IEC 61784-5-6

Edition 5.0 2024-04

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE



**Industrial networks – Profiles –**

**Part 5-6: Installation of fieldbuses – Installation profiles for CPF 6**

**Réseaux industriels – Profils –**

**Partie 5-6: Installation des bus de terrain – Profils d'installation pour CPF 6**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

ICS 25.040.40, 35.100.40

ISBN 978-2-8322-8404-9

**Warning! Make sure that you obtained this publication from an authorized distributor.**

**Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD .....	5
INTRODUCTION .....	7
1 Scope .....	8
2 Normative references .....	8
3 Terms, definitions and abbreviated terms .....	8
4 CPF 6: Overview of installation profiles .....	9
5 Installation profile conventions .....	9
6 Conformance to installation profiles .....	9
Annex A (normative) CPF 6 Type 8 network specific installation profile .....	11
A.1 Installation profile scope .....	11
A.2 Normative references .....	11
A.3 Installation profile terms, definitions, and abbreviated terms .....	11
A.3.1 Terms and definitions .....	11
A.3.2 Abbreviated terms .....	12
A.3.3 Conventions for installation profiles .....	13
A.4 Installation planning .....	13
A.4.1 General .....	13
A.4.2 Planning requirements .....	13
A.4.3 Network capabilities .....	14
A.4.4 Selection and use of cabling components .....	18
A.4.5 Cabling planning documentation .....	27
A.4.6 Verification of cabling planning specification .....	27
A.5 Installation implementation .....	27
A.5.1 General requirements .....	27
A.5.2 Cable installation .....	27
A.5.3 Connector installation .....	30
A.5.4 Terminator installation .....	32
A.5.5 Device installation .....	32
A.5.6 Coding and labelling .....	32
A.5.7 Earthing and bonding of equipment and devices and shield cabling .....	32
A.5.8 As-implemented cabling documentation .....	32
A.6 Installation verification and installation acceptance test .....	32
A.6.1 General .....	32
A.6.2 Installation verification .....	32
A.6.3 Installation acceptance test .....	33
A.7 Installation administration .....	34
A.8 Installation maintenance and installation troubleshooting .....	34
Annex B (normative) CPF 6 Ethernet network specific installation profile .....	35
B.1 Installation profile scope .....	35
B.2 Normative references .....	35
B.3 Installation profile terms, definitions, and abbreviated terms .....	36
B.3.1 Terms and definitions .....	36
B.3.2 Abbreviated terms .....	36
B.3.3 Conventions for installation profiles .....	36
B.4 Installation planning .....	36
B.4.1 General .....	36

B.4.2	Planning requirements .....	36
B.4.3	Network capabilities.....	37
B.4.4	Selection and use of cabling components .....	40
B.4.5	Cabling planning documentation .....	46
B.4.6	Verification of cabling planning specification.....	46
B.5	Installation implementation.....	46
B.5.1	General requirements .....	46
B.5.2	Cable installation .....	46
B.5.3	Connector installation .....	48
B.5.4	Terminator installation .....	48
B.5.5	Device installation .....	48
B.5.6	Coding and labelling .....	48
B.5.7	Earthing and bonding of equipment and devices and shield cabling .....	48
B.5.8	As-implemented cabling documentation .....	48
B.6	Installation verification and installation acceptance test .....	49
B.6.1	General .....	49
B.6.2	Installation verification .....	49
B.6.3	Installation acceptance test .....	49
B.7	Installation administration .....	49
B.8	Installation maintenance and installation troubleshooting .....	49
Bibliography.....		50

Figure 1 – Standards relationships.....	7
Figure A.1 – Type 8 network structure example .....	15
Figure A.2 – Example of a Type 8 network configuration.....	16
Figure A.3 – Sub-D connector pin assignment .....	30
Figure A.4 – M23 circular connector pin assignment .....	31
Figure A.5 – M12 circular connector pin assignment .....	31
Figure A.6 – Terminal connector at the device .....	31
Figure B.1 – Terminal connector at the device .....	48

Table A.1 – Basic network characteristics for balanced cabling not based on Ethernet .....	17
Table A.2 – Network characteristics for optical fibre cabling.....	18
Table A.3 – Information relevant to balanced cable: fixed cables .....	19
Table A.4 – Information relevant to balanced cable: cords .....	20
Table A.5 – Remote bus fibre optic cable length .....	22
Table A.6 – Connectors for copper cabling CPs not based on Ethernet.....	22
Table A.7 – Optical fibre connecting hardware .....	23
Table A.8 – Relationship between FOC and fibre types (Type 8 networks).....	23
Table A.9 – Colour code for balanced cables used by Type 8 networks .....	25
Table A.10 – Parameters for balanced cables .....	27
Table A.11 – Parameters for silica optical fibre cables .....	28
Table A.12 – Parameters for POF optical fibre cables .....	28
Table A.13 – Parameters for hard clad silica optical fibre cables.....	29
Table A.14 – Pin assignment of the terminal connector .....	31
Table B.1 – Network characteristics for balanced cabling based on Ethernet .....	38

Table B.2 – Network characteristics for optical fibre cabling.....	39
Table B.3 – Information relevant to copper cable: fixed cables.....	40
Table B.4 – Information relevant to copper cable: cords .....	41
Table B.5 – Information relevant to optical fibre cables .....	42
Table B.6 – Connectors for balanced cabling CPs based on Ethernet .....	43
Table B.7 – Connectors for copper cabling CPs not based on Ethernet.....	43
Table B.8 – Optical fibre connecting hardware .....	44
Table B.9 – Relationship between FOC and fibre types (CP 6/2 Ethernet network) .....	44
Table B.10 – Parameters for balanced cables .....	46
Table B.11 – Parameters for silica optical fibre cables .....	46
Table B.12 – Parameters for POF optical fibre cables .....	47
Table B.13 – Parameters for hard clad silica optical fibre cables.....	47

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**INDUSTRIAL NETWORKS –  
PROFILES –****Part 5-6: Installation of fieldbuses –  
Installation profiles for CPF 6****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 61784-5-6 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial process measurement, control and automation. It is an International Standard.

This document is to be used in conjunction with IEC 61918:2018, IEC 61918:2018/AMD1:2022 and IEC 61918:2018/AMD2:2024.

This fifth edition cancels and replaces the fourth edition published in 2018. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) alignment with IEC 61918:2018, IEC 61918:2018/AMD1:2022 and IEC 61918:2018/AMD2:2024;
- b) addition of new content related to Single Pair Ethernet (SPE) in Annex B, Table B.1, Table B.3, Table B.4, Table B.6.

The text of this International Standard is based on the following documents:

Draft	Report on voting
65C/1283/FDIS	65C/1297/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with the ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/publications](http://www.iec.ch/publications).

A list of all parts of IEC 61784-5 series, under the general title *Industrial networks – Profiles – Installation of fieldbuses*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

**IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION


This document is one of a series produced to facilitate the use of communication networks in industrial control systems.

IEC 61918:2018, IEC 61918:2018/AMD1:2022 and IEC 61918:2018/AMD2:2024 provide the common requirements for the installation of communication networks in industrial control systems. This installation profile document provides the installation profiles of the communication profiles (CP) of a specific communication profile family (CPF) by stating which requirements of IEC 61918 fully apply and, where necessary, by supplementing, modifying, or replacing the other requirements (see Figure 1).

For general background on fieldbuses, their profiles, and relationship between the installation profiles specified in this document, see IEC 61158-1.

Each CP installation profile is specified in a separate annex of this document. Each annex is structured exactly as the reference document IEC 61918 for the benefit of the persons representing the roles in the fieldbus installation process as defined in IEC 61918 (planner, installer, verification personnel, validation personnel, maintenance personnel, administration personnel). By reading the installation profile in conjunction with IEC 61918, these persons immediately know which requirements are common for the installation of all CPs and which are modified or replaced. The conventions used to draft this document are defined in Clause 5.

The provision of the installation profiles in one document for each CPF (for example IEC 61784-5-6 for CPF 6) allows readers to work with documents of a convenient size.



**Figure 1 – Standards relationships**

## INDUSTRIAL NETWORKS – PROFILES –

### Part 5-6: Installation of fieldbuses – Installation profiles for CPF 6

#### 1 Scope

This part of IEC 61784-5 specifies the installation profiles for CPF 6 (INTERBUS™)<sup>1</sup>.

The installation profiles are specified in the annexes. These annexes are read in conjunction with IEC 61918:2018, IEC 61918:2018/AMD1:2022 and IEC 61918:2018/AMD2:2024.

#### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61918:2018<sup>2</sup>, *Industrial communication networks – Installation of communication networks in industrial premises*  
IEC 61918:2018/AMD1:2022  
IEC 61918:2018/AMD2:2024

NOTE For profile specific normative references, see Clauses A.2, B.2.

---

1 INTERBUS™ is a trade name of INTERBUS Club, an independent organisation of users and vendors of INTERBUS products. This information is given for the convenience of users of this document and does not constitute an endorsement by IEC of the trademark holder or any of its products. Compliance to this profile does not require use of the trade name INTERBUS. Use of the trade name INTERBUS requires permission of the trade name holder.

2 The normative references of IEC 61918:2018, Clause 2, IEC 61918:2018/AMD1:2022, Clause 2 and IEC 61918:2018/AMD2:2024, Clause 2, apply.