

© Copyright SEK. Reproduction in any form without permission is prohibited.

Vindkraftverk – Del 21: Mätning och bedömning av elkvalitet för nätanslutna aggregat

Wind turbines –

*Part 21: Measurement and assessment of power quality characteristics
of grid connected wind turbines*

Som svensk standard gäller europastandarden EN 61400-21:2008. Den svenska standarden innehåller den officiella engelska språkversionen av EN 61400-21:2008.

Nationellt förord

Europastandarden EN 61400-21:2008

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 61400-21, Second edition, 2008 - Wind turbines - Part 21: Measurement and assessment of power quality characteristics of grid connected wind turbines**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 61400-21, utgåva 1, 2002, gäller ej fr o m 2011-10-01.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English version

**Wind turbines -
Part 21: Measurement and assessment
of power quality characteristics of grid connected wind turbines
(IEC 61400-21:2008)**

Eoliennes -
Partie 21: Mesurage et évaluation
des caractéristiques de qualité
de puissance des éoliennes
connectées au réseau
(CEI 61400-21:2008)

Windenergieanlagen -
Teil 21: Messung und Bewertung
der Netzverträglichkeit
von netzgekoppelten
Windenergieanlagen
(IEC 61400-21:2008)

This European Standard was approved by CENELEC on 2008-10-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

The text of document 88/317/FDIS, future edition 2 of IEC 61400-21, prepared by IEC TC 88, Wind turbines, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 61400-21 on 2008-10-01.

This European Standard supersedes EN 61400-21:2002.

EN 61400-21:2008 includes the following new items with respect to EN 61400-21:2002:

- interharmonics and current distortions (< 9 kHz),
- response to voltage dips,
- active power ramp rate limitation and set-point control,
- reactive power capabilities and set-point control,
- grid protection and reconnection time after grid faults.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2009-07-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2011-10-01

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 61400-21:2008 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61000-3-3	NOTE Harmonized as EN 61000-3-3:2008 (not modified).
IEC 61000-4-30	NOTE Harmonized as EN 61000-4-30:2003 (not modified).
IEC 61400-1	NOTE Harmonized as EN 61400-1:2005 (not modified).

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60044-1 (mod)	- ¹⁾	Instrument transformers - Part 1: Current transformers	EN 60044-1	1999 ²⁾
IEC 60044-2 (mod)	- ¹⁾	Instrument transformers - Part 2: Inductive voltage transformers	EN 60044-2	1999 ²⁾
IEC 60050-161	- ¹⁾	International Electrotechnical Vocabulary (IEV) - Chapter 161: Electromagnetic compatibility	-	-
IEC 60050-415	- ¹⁾	International Electrotechnical Vocabulary (IEV) - Part 415: Wind turbine generator systems	-	-
IEC 61000-4-7	2002	Electromagnetic compatibility (EMC) - Part 4-7: Testing and measurement techniques - General guide on harmonics and interharmonics measurements and instrumentation, for power supply systems and equipment connected thereto	EN 61000-4-7	2002
IEC 61000-4-15	- ¹⁾	Electromagnetic compatibility (EMC) - Part 4-15: Testing and measurement techniques - Flickermeter - Functional and design specifications	EN 61000-4-15	1998 ²⁾
IEC 61400-12-1	- ¹⁾	Wind turbines - Part 12-1: Power performance measurements of electricity producing wind turbines	EN 61400-12-1	2006 ²⁾
IEC 61800-3	2004	Adjustable speed electrical power drive systems - Part 3: EMC requirements and specific test methods	EN 61800-3	2004
IEC 62008	- ¹⁾	Performance characteristics and calibration methods for digital data acquisition systems and relevant software	EN 62008	2005 ²⁾

¹⁾ Undated reference.

²⁾ Valid edition at date of issue.

CONTENTS

INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	8
4 Symbols and units	11
5 Abbreviations	13
6 Wind turbine power quality characteristic parameters	14
6.1 General.....	14
6.2 Wind turbine specification	14
6.3 Voltage fluctuations.....	14
6.3.1 General	14
6.3.2 Continuous operation	14
6.3.3 Switching operations	15
6.4 Current harmonics, interharmonics and higher frequency components	15
6.5 Response to voltage drops	16
6.6 Active power	16
6.6.1 Maximum measured power	16
6.6.2 Ramp rate limitation	16
6.6.3 Set-point control	17
6.7 Reactive power	17
6.7.1 Reactive power capability	17
6.7.2 Set-point control	17
6.8 Grid protection	18
6.9 Reconnection time.....	18
7 Test procedures	18
7.1 General.....	18
7.1.1 Test validity.....	19
7.1.2 Test conditions	19
7.1.3 Test equipment.....	20
7.2 Wind turbine specification	21
7.3 Voltage fluctuations.....	21
7.3.1 General	21
7.3.2 Fictitious grid.....	21
7.3.3 Continuous operation	23
7.3.4 Switching operations	26
7.4 Current harmonics, interharmonics and higher frequency components	27
7.5 Response to temporary voltage drop	28
7.6 Active power	30
7.6.1 Maximum measured power	30
7.6.2 Ramp rate limitation	31
7.6.3 Set point control	31
7.7 Reactive power	31
7.7.1 Reactive power capability	31
7.7.2 Set point control	32
7.8 Grid protection	32

7.9	Reconnection time.....	33
8	Assessment of power quality	34
8.1	General.....	34
8.2	Voltage fluctuations.....	34
8.2.1	General	34
8.2.2	Continuous operation	35
8.2.3	Switching operations	35
8.3	Current harmonics, interharmonics and higher frequency components	36
Annex A (informative)	Sample report format.....	38
Annex B (informative)	Voltage fluctuations and flicker.....	48
Annex C (informative)	Measurement of active power, reactive power and voltage	56
Bibliography		58
Figure 1	– Adjustment of active power set-point.....	17
Figure 2	– Adjustment of reactive power set-point.....	18
Figure 3	– Assumed elements of measurement system	20
Figure 4	– Fictitious grid for simulation of fictitious voltage	22
Figure 5	– System with short circuit emulator for testing wind turbine response to temporary voltage drop.	29
Figure 6	– Tolerance of voltage drop	30
Figure B.1	– Measurement and assessment procedures for flicker during continuous operation of the wind turbine.....	48
Figure B.2	– Measurement and assessment procedures for voltage changes and flicker during switching operations of the wind turbine.....	49
Figure B.3	– Flicker coefficient as a function of wind speed	50
Table 1	– Specification of voltage drops. The specified magnitudes, duration and shape are for the voltage drop occurring when the wind turbine under test is not connected.....	16
Table 2	– Specification of requirements for measurement equipment.....	21
Table 3	– Specification of exponents according to IEC 61000-3-6	37
Table B.1	– Number of measurements $N_{m,i}$ and frequency of occurrence of $f_{m,i}$ and $f_{y,i}$ for each wind speed bin in the range from cut-in wind speed to 15 m/s	51
Table B.2	– Weighting factor w_i for each wind speed bin.....	51
Table B.3	– Total sum of weighting factor multiplied by number of measurements for all wind speed bins	52
Table B.4	– Weighted accumulated distribution of the flicker coefficients $Pr(c < x)$ for each wind speed distribution.....	52
Table B.5	– Resulting flicker coefficient in continuous operation	53
Table B.6	– Probabilities and percentiles for different wind speeds	53

INTRODUCTION

The purpose of this part of IEC 61400 is to provide a uniform methodology that will ensure consistency and accuracy in the presentation, testing and assessment of power quality characteristics of grid connected wind turbines (WTs). The power quality characteristics here include wind turbine specifications, voltage quality (emissions of flicker and harmonics), voltage drop response, power control (control of active and reactive power), grid protection and reconnection time.

This part of IEC 61400 has been prepared with the anticipation that it would be applied by:

- the WT manufacturer striving to meet well-defined power quality characteristics;
- the WT purchaser in specifying such power quality characteristics;
- the WT operator who may be required to verify that stated, or required power quality characteristics are met;
- the WT planner or regulator who has to be able to accurately and fairly determine the impact of a WT on the voltage quality to ensure that the installation is designed so that voltage quality requirements are respected;
- the WT certification authority or component testing organization in evaluating the power quality characteristics of the wind turbine type;
- the planner or regulator of the electric network who has to be able to determine the grid connection required for a WT.

This part of IEC 61400 provides recommendations for preparing the measurements and assessment of power quality characteristics of grid connected WTs. This part of IEC 61400 will benefit those parties involved in the manufacture, installation planning, obtaining of permission, operation, utilization, testing and regulation of WTs. The measurement and analysis techniques recommended in this part of IEC 61400 should be applied by all parties to ensure that the continuing development and operation of WTs are carried out in an atmosphere of consistent and accurate communication.

This part of IEC 61400 presents measurement and analysis procedures expected to provide consistent results that can be replicated by others.

WIND TURBINES –

Part 21: Measurement and assessment of power quality characteristics of grid connected wind turbines

1 Scope

This part of IEC 61400 includes:

- definition and specification of the quantities to be determined for characterizing the power quality of a grid connected wind turbine;
- measurement procedures for quantifying the characteristics;
- procedures for assessing compliance with power quality requirements, including estimation of the power quality expected from the wind turbine type when deployed at a specific site, possibly in groups.

The measurement procedures are valid for single wind turbines with a three-phase grid connection. The measurement procedures are valid for any size of wind turbine, though this part of IEC 61400 only requires wind turbine types intended for PCC (Point of Common Coupling) at MV or HV to be tested and characterized as specified in this part of IEC 61400.

The measured characteristics are valid for the specific configuration and operational mode of the assessed wind turbine type only. Other configurations, including altered control parameters that cause the wind turbine to behave differently with respect to power quality, require separate assessment.

The measurement procedures are designed to be as non-site-specific as possible, so that power quality characteristics measured at for example a test site can be considered valid also at other sites.

The procedures for assessing compliance with power quality requirements are valid for wind turbines with PCC at MV or HV in power systems with fixed frequency within ± 1 Hz, and sufficient active and reactive power regulation capabilities. In other cases, the principles for assessing compliance with power quality requirements may still be used as a guidance.

This part of IEC 61400 is for testing of wind turbines, though it contains information that may also be useful for testing of wind farms.

NOTE This part of IEC 61400 uses the following terms for system voltage:

- low voltage (LV) refers to $U_n \leq 1$ kV;
- medium voltage (MV) refers to $1 \text{ kV} < U_n \leq 35$ kV;
- high voltage (HV) refers to $U_n > 35$ kV.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60044-1, *Instrument transformers – Part 1: Current transformers*

IEC 60044-2, *Instrument transformers – Part 2: Inductive voltage transformers*