

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

Automatiska elektriska styr- och reglerdon – Del 1: Allmänna fordringar

*Automatic electrical controls –
Part 1: General requirements*

Som svensk standard gäller europastandarden EN IEC 60730-1:2024. Den svenska standarden innehåller de officiella engelska språkversionerna av EN IEC 60730-1:2024 och EN IEC 60730-1:2024/A11:2024.

Nationellt förord

Europastandarden EN IEC 60730-1:2024

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 60730-1, Sixth edition, 2022 - Automatic electrical controls - Part 1: General requirements**

utarbetad inom International Electrotechnical Commission, IEC.

Denna europeiska standard ersätter EN 60730-1:2016 och dess tillägg. EN 60730-1:2016 och dess tillägg förblir dock giltiga tills alla delar 2 som används tillsammans med denna har dragits tillbaka. Inget datum för upphävande (DOW) har angetts i avvaktan på uppdateringen av samtliga delar 2 för att överensstämja med denna EN IEC 60730-1:2024. Tillämpligt datum för upphävande anges i varje del 2. Upphävandedatum för denna del 1 kommer att fastställas när alla delar 2 har uppdaterats.

ICS 97.120.00

Denna standard är fastställd av SEK Svensk Elstandard, som också kan lämna upplysningar om **sakinnehållet** i standarden.
Postadress: Box 1042, 172 21 Sundbyberg
Telefon: 08 - 444 14 00.
E-post: sek@elstandard.se. Internet: elstandard.se

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1042
172 21 Sundbyberg
Tel 08-444 14 00
elstandard.se

ICS 97.120

Supersedes EN 60730-1:2016; EN 60730-1:2016/A1:2019; EN 60730-1:2016/A2:2022; EN 60730-1:2016/prAA:2022

English Version

Automatic electrical controls - Part 1: General requirements
(IEC 60730-1:2022)

Dispositifs de commande électrique automatiques -
Partie 1: Exigences générales
(IEC 60730-1:2022)

Automatische elektrische Regel- und Steuergeräte - Teil 1:
Allgemeine Anforderungen
(IEC 60730-1:2022)

This European Standard was approved by CENELEC on 2024-01-31. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 72/1307/FDIS, future edition 6 of IEC 60730-1, prepared by IEC/TC 72 "Automatic electrical controls" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 60730-1:2024.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2025-04-25 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) – document have to be withdrawn

This document supersedes EN 60730-1:2016 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a standardization request addressed to CENELEC by the European Commission. The Standing Committee of the EFTA States subsequently approves these requests for its Member States.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 60730-1:2022 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

IEC 60990:2016	NOTE	Approved as EN 60990:2016 (not modified)
IEC 60243-1	NOTE	Approved as EN 60243-1
IEC 60669-1	NOTE	Approved as EN 60669-1
IEC 60730-2-5	NOTE	Approved as EN 60730-2-5
IEC 60998-2-1	NOTE	Approved as EN 60998-2-1
IEC 61000-6-7:2014	NOTE	Approved as EN 61000-6-7:2015 (not modified)
IEC 61032:1997	NOTE	Approved as EN 61032:1998 (not modified)
IEC 61058-1-1	NOTE	Approved as EN 61058-1-1
IEC 61140:2016	NOTE	Approved as EN 61140:2016 (not modified)
IEC 61508-3:2010	NOTE	Approved as EN 61508-3:2010 (not modified)
IEC 61508-7:2010	NOTE	Approved as EN 61508-7:2010 (not modified)

IEC 61810-1	NOTE	Approved as EN 61810-1
IEC 63044-3	NOTE	Approved as EN IEC 63044-3
IEC 63044-5-1:2017	NOTE	Approved as EN IEC 63044-5-1:2019 (not modified)
ISO 62:2008	NOTE	Approved as EN ISO 62:2008 (not modified)
ISO 75-1	NOTE	Approved as EN ISO 75-1
ISO 178:2019	NOTE	Approved as EN ISO 178:2019 (not modified)
ISO 527-1:2019	NOTE	Approved as EN ISO 527-1:2019 (not modified)
ISO 16484-2	NOTE	Approved as EN ISO 16484-2

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Automatic electrical controls –
Part 1: General requirements**

**Dispositifs de commande électrique automatiques –
Partie 1: Exigences générales**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 97.120

ISBN 978-2-8322-5387-8

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD	10
1 Scope	14
2 Normative references	15
3 Terms and definitions	19
3.1 Definitions relating to ratings, voltages, currents, frequencies, and wattages	19
3.2 Definitions of types of control according to purpose	21
3.3 Definitions relating to the function of controls	24
3.4 Definitions relating to disconnection and interruption	27
3.5 Definitions of types of control according to construction	28
3.6 Definitions of type of automatic action of a control	29
3.7 Definitions relating to protection against electric shock and type of insulation	30
3.8 Definitions relating to component parts of controls	34
3.9 Definitions of types of terminals and terminations of controls	35
3.10 Definitions relating to the connections to controls	37
3.11 Definitions relating to the performance of type 2 actions	38
3.12 Definitions relating to the requirements for creepage distances and clearances	38
3.13 Miscellaneous definitions	39
3.14 Definitions relating to manufacturer and user	41
3.15 Definitions pertaining to thermistors	41
3.16 Definitions relating to the structure of controls using software	41
3.17 Definitions relating to error avoidance in controls using software	41
3.18 Definitions relating to fault/error control techniques for controls using software	41
3.19 Definitions relating to memory tests for controls using software	41
3.20 Definitions of software terminology – General	41
3.21 Definitions relating to classes of control functions	41
3.22 Definitions relating to functional safety	41
3.23 Definitions related to access to data exchange	42
3.24 Definitions related to EMC performance	42
4 General	44
4.1 General structure of the document	44
4.2 General requirements	45
4.3 General notes on tests	45
5 Required technical information	49
5.1 General requirements	49
5.2 Methods of providing technical information	49
5.3 Class II symbol	57
5.4 Additional requirements for marking	57
5.5 Warning or cautionary markings	59
6 Protection against electric shock	59
6.1 General requirements	59
6.2 Actuating members and actuating means	61
6.3 Capacitors	62
6.4 Covers and uninsulated live or hazardous parts	62

6.5	Battery operated controls provided with a user accessible mains supply input connector	62
7	Provision for protective earthing	63
7.1	Class 0I and Class I controls	63
7.2	Class II and class III controls	63
7.3	Adequacy of earth connections	63
7.4	Corrosion resistance	64
7.5	Other requirements	65
7.6	Protective equipotential bonding	65
8	Terminals and terminations	65
8.1	Terminals and terminations for external copper conductors	65
8.2	Terminals and terminations for internal conductors	70
8.3	Terminals and terminations for integrated conductors	72
9	Constructional requirements	72
9.1	Materials	72
9.2	Protection against electric shock	72
9.3	Actuation and operation	75
9.4	Actions	78
9.5	Openings in enclosures	80
9.6	Mounting of controls	80
9.7	Attachment of cords	82
9.8	Size of cords – non-detachable	83
9.9	Inlet openings	83
9.10	Equipment inlets and socket-outlets	84
9.11	Requirements during mounting, use, maintenance and servicing	85
9.12	Controls using software	87
9.13	Protective controls and components of protective control systems	90
10	Threaded parts and connections	92
10.1	Threaded parts moved during mounting or servicing	92
10.2	Current-carrying connections and connections providing protective earthing continuity	94
11	Creepage distances, clearances and distances through solid insulation	95
11.1	General	95
11.2	Clearances	96
11.3	Creepage distances	100
11.4	Solid insulation	104
12	Components	105
12.1	Transformers	105
12.2	Switch mode power supplies and converters	105
12.3	Capacitors	106
12.4	Fuses	106
12.5	Varistors	106
12.6	Thermistors	106
12.7	Relays	107
12.8	Other components	107
13	Fault assessment on electronic circuits	107
13.1	Fault assessment for inherent safety	107
13.2	Fault assessment to ensure functional safety	113

14	Moisture and dust resistance	113
14.1	Protection against ingress of water and dust	113
14.2	Protection against humid conditions	114
14.3	Touch current test for in-line cord controls and free-standing controls	115
15	Electric strength and insulation resistance	116
15.1	Insulation resistance	116
15.2	Electric strength	116
15.3	Additional tests for in-line cord and free-standing controls	118
16	Heating	119
17	Manufacturing deviation and drift	123
18	Environmental stress	123
18.1	Transportation and storage	123
18.2	Environmental stress of temperature	123
19	Endurance	124
19.1	General requirements	124
19.2	Electrical conditions for the tests	125
19.3	Thermal conditions for the tests	131
19.4	Manual and mechanical conditions for the tests	131
19.5	Dielectric strength requirements	132
19.6	Ageing test	132
19.7	Overvoltage test or overload test in all countries using an overload test of automatic action at accelerated rate	132
19.8	Test of automatic action at accelerated rate	133
19.9	Test of automatic action at slow rate	133
19.10	Overvoltage test or overload test in all countries that use the overload test of manual action at accelerated speed	134
19.11	Test of manual action at slow speed	134
19.12	Test of manual action at high speed which has multiple poles, and where polarity reversal occurs during the action	134
19.13	Test of manual action at accelerated speed	134
19.14	Evaluation of compliance	135
19.15	Test for particular purpose controls	135
20	Mechanical strength	135
20.1	General requirements	135
20.2	Impact resistance	136
20.3	Free-standing controls	137
20.4	In-line cord controls	137
20.5	Pull-cord actuated controls	137
20.6	Foot actuated controls	138
20.7	Actuating member and actuating means	138
20.8	Flexing – test	139
20.9	Cord anchorages – test	139
21	Resistance to heat, fire and tracking	140
21.1	General requirements	140
21.2	Integrated, incorporated and in-line cord controls	140
21.3	Independently mounted, free-standing controls	141
22	Resistance to corrosion	142
22.1	Resistance to rusting	142

23	Electromagnetic compatibility (EMC) requirements – Emission	142
23.1	General requirement	142
23.2	High frequency emission	143
23.3	Low frequency emission	146
24	Normal operation	146
25	Electromagnetic compatibility (EMC) requirements – Immunity	146
25.1	General	146
25.2	EMC test plan and report	147
25.3	Immunity requirements	149
25.4	Performance criteria	152
25.5	Surge immunity test	153
25.6	Electrical fast transient immunity test	153
25.7	Radio-frequency electromagnetic field immunity	154
25.8	Electrostatic discharge	154
25.9	Immunity to power-frequency magnetic fields	154
25.10	Test of the influence of voltage dips and voltage interruption in the power supply network	154
26	Abnormal operation tests	155
26.1	Abnormal temperature test	155
26.2	Overload tests	156
26.3	Battery short-circuit test	157
	Annex A (normative) Indelibility of markings	174
	Annex B (normative) Measurement of creepage distances and clearances in air	176
	Annex C (informative) Nominal voltages of supply systems for different modes of overvoltage control	180
	Annex D (normative) Overvoltage categories	182
	Annex E (informative) Typical usage of controls and related overvoltage categories	183
	Annex F (normative) Pollution degrees	184
	F.1 Pollution	184
	F.2 Degrees of pollution in the micro-environment	184
	Annex G (normative) Resistance to heat, fire and tracking tests	185
	G.1 Glow-wire test	185
	G.2 Proof tracking test	185
	G.3 Ball pressure test	185
	Annex H (normative) Requirements related to functional safety	187
	H.3 Terms and definitions	187
	H.5 Information	198
	H.9 Constructional requirements	199
	H.13 Fault assessment on electronic circuits	216
	H.17 Manufacturing deviation and drift	220
	H.19 Endurance	221
	H.25 Electromagnetic compatibility (EMC) requirements – Immunity	222
	Annex I (normative) Requirements for certain types of DC supplied controls	235
	I.1 Scope	235
	Annex J (normative) Requirements for thermistor elements and controls using thermistors	237
	J.1 Scope	237
	Annex K (normative) Circuit for measuring touch current	254

Annex L (normative) Printed circuit board coating performance test	255
Annex M (normative) Printed circuit board protection	257
Annex N (informative) Explanatory notes for surge immunity test	260
N.1 Different source impedances	260
N.2 Application of the tests	260
N.3 Installation classification	261
Annex O (informative) Guidance for applying Clause 11	264
Annex P (normative) Requirements for SELV and PELV	267
P.1 Overview of the requirements for SELV and PELV	267
P.2 Protection against electric shock by SELV system or PELV system	267
P.3 Protective measures for SELV system and PELV system	268
Annex Q (informative) Regional differences relevant for the member countries of Cenelec	270
Annex R (informative) National differences relevant in the United States of America	274
R.2 Normative references	274
Annex S (informative) National differences relevant in Japan	275
S.2 Normative references	275
Annex T (informative) National differences relevant in Canada	276
T.2 Normative references	276
Bibliography	277
Figure 1 – Example of ports	42
Figure 2 – Structure of the document with respect to inherent safety and functional safety	45
Figure 3 – Example of an electronic circuit with low power points	108
Figure 4 – Test pin probe 13 of IEC 61032:1997	157
Figure 5 – Test finger probe B of IEC 61032:1997	158
Figure 6 – Test fingernail	159
Figure 7 – Impact test for free-standing controls	160
Figure 8 – Tumbling barrel	160
Figure 9 – Apparatus for testing durability of markings on rating labels	161
Figure 10 – Apparatus for flexing test	161
Figure 11 – Screw terminals and stud terminals	162
Figure 12 – Pillar terminals	163
Figure 13 – Mantle terminals	164
Figure 14 – Saddle and lug terminals	165
Figure 15 – Tabs	166
Figure 16 – Tabs for non-reversible connectors	167
Figure 17 – Receptacles	168
Figure 18 – Measurement of creepage distance and clearance	169
Figure 19 – Diagram for touch current measurement at operating temperature for single-phase connection of class II controls	170
Figure 20 – Diagram for touch current measurement at operating temperature for single-phase connection of controls other than class II	170
Figure 21 – Diagram for touch current measurement at operating temperature for three-phase connection of class II controls	171

Figure 22 – Diagram for touch current measurement at operating temperature for three-phase connection of controls other than class II.....	172
Figure 23 – Diagram for touch current measurement at operating temperature for single-phase connection of controls to three-wire, ground neutral supply other than class II.....	172
Figure 24 – Diagram for touch current measurement at operating temperature for two-phase connection of controls to three-wire, ground neutral supply other than class II.....	173
Figure B.1 – Narrow groove	177
Figure B.2 – Wide groove	177
Figure B.3 – V-shaped groove	177
Figure B.4 – Rib.....	177
Figure B.5 – Uncemented joint with narrow groove	178
Figure B.6 – Uncemented joint with wide groove	178
Figure B.7 – Uncemented joint with narrow and wide grooves.....	178
Figure B.8 – Diverging side walls	179
Figure B.9 – Narrow recess	179
Figure B.10 – Wide recess.....	179
Figure B.11 – Conductive floating part	179
Figure H.1 – V-Model for the software life cycle	207
Figure H.2 – Voltage variation test.....	225
Figure J.1 – Generic test circuit for inrush-current limiting thermistor endurance test.....	253
Figure K.1 – Circuit for measuring touch currents	254
Figure L.1 – Test sample	256
Figure M.1 – Example of type 1 protection	258
Figure M.2 – Example of type 2 protection	259
Figure N.1 – Example of surge protection by shielding in buildings with common earth reference systems	262
Figure N.2 – Example of secondary surge protection in buildings with separate common earth reference systems	263
Figure N.3 – Example of primary and secondary surge protection of indoor/outdoor equipment.....	263
Figure O.1 – Guidance flowchart for application of requirements of Clause 11	265
Table 1 – Required technical information and methods of providing these information	52
Table 2 – Cross-sectional area of conductors	66
Table 3 – Terminal conductors.....	68
Table 4 – Conductor pull test values	68
Table 5 – Nominal cross-sectional areas of conductors.....	70
Table 6 – Axial force values for tab insertion and withdrawal	71
Table 7 – Minimum cord conductor sizes	83
Table 8 – Data exchange	88
Table 9 – Threaded parts torque test values	94
Table 10 – Rated impulse voltage for equipment energized directly from the supply mains (from IEC 60664-1:2007, Table F.1)	97
Table 11 – Clearances for insulation co-ordination (from IEC 60664-1:2007, Table F.2).....	98

Table 12 – Minimum creepage distances for basic insulation	102
Table 13 – Minimum creepage distances for functional insulation	103
Table 14 – Electrical/electronic component fault modes	109
Table 15 – Minimum insulation resistance.....	116
Table 16 – Insulation or disconnection test voltages	117
Table 17 – Maximum heating temperatures.....	121
Table 18 – Electrical conditions for the overvoltage and endurance tests	127
Table 19 – Electrical conditions for the overload tests of 19.7 and 19.10	129
Table 20 – Electrical conditions for the endurance tests of 19.8, 19.9, 19.11, 19.12 and 19.13	130
Table 21 – Pull-cord force test values	138
Table 22 – Pull and torque values	139
Table 23 – Emission limit for residential electromagnetic environment	144
Table 24 – Emission limit for industrial electromagnetic environment	145
Table 25 – The applicable EMC test in relation to the class of control function and type of Action	147
Table 26 – Immunity test requirements for residential electromagnetic environments	149
Table 27 – Immunity test requirements for industrial electromagnetic environment	151
Table 28 – Performance criteria	153
Table 29 – Maximum winding temperature (for test of mechanical blocked output conditions).....	156
Table B.1 – Value of X	176
Table C.1 – Inherent control or equivalent protective control.....	180
Table C.2 – Cases where protective control is necessary and control is provided by surge arresters having a ratio of clamping voltage to rated voltage not smaller than that specified by IEC 60099-1	181
Table E.1 – Typical usage.....	183
Table H.1 – Additional items to Table 1.....	198
Table H.2 – Acceptable measures to address fault/errors ^a	201
Table H.3 – Examples of techniques/measures for semi-formal methods	208
Table H.4 – Examples of techniques/measures for software architecture specification	208
Table H.5 – Examples of techniques/measures for module design specification	209
Table H.6 – Examples of techniques/measures for design and coding standards	209
Table H.7 – Examples of techniques/measures for software module testing	210
Table H.8 – Examples of techniques/measures for software integration testing	211
Table H.9 – Examples of techniques/measures for software safety validation	211
Table H.10 – Combinations of analytical measures during hardware development	213
Table H.11 – Examples of defences against unauthorised access and transmission failure modes	214
Table H.12 – Applicable test levels in addition to Clause 25.....	223
Table H.13 – Voltage dips, short interruptions and voltage variations.....	224
Table H.14 – Test values for voltage variations.....	225
Table H.15 – Test voltages for test level 2 (depending on the installation class conditions).....	228
Table H.16 – Test level for electrical fast transient burst test	229

Table H.17 – Test levels for conducted disturbances on mains and I/O lines.....	230
Table H.18 – Test level for immunity to radiated electromagnetic fields	231
Table H.19 – Increased test level for radiated immunity	232
Table H.20 – Test level for supply frequency variations	233
Table H.21 – Test level for continuous fields.....	233
Table I.1 – Electrical transient conduction immunity in accordance with ISO 7637-2	235
Table I.2 – Electrical transient conduction immunity in accordance with ISO 7637-3	236
Table J.1 – Maximum current.....	239
Table J.2 – Normal operating conditions	240
Table J.3 – Samples for the test (clause reference)	241
Table J.4 – Electrical and thermal ratings of a thermistor	242
Table J.5 – Additional items to Table 1	243
Table J.6 – Sequence of calibration and conditioning tests for PTC thermistors	245
Table J.7 – Classes for PTC sensing thermistors	246
Table J.8 – Sequence of calibration and conditioning tests for NTC thermistors.....	247
Table J.9 – Classes for NTC sensing thermistors	247
Table J.10 – Number of cycles for endurance test.....	251
Table J.11 – Ageing test temperature	251
Table J.12 – Number of cycles for endurance test.....	252
Table L.1 – Environmental cycling conditions.....	255
Table M.1 – IEC 60664-3 test levels or conditions.....	257
Table O.1 – Example A – Using Annex O guidance for applying Clause 11	266
Table O.2 – Example B – Using Annex O guidance for applying Clause 11	266
Table Q.1 – Additional aging parameters for windings.....	271

INTERNATIONAL ELECTROTECHNICAL COMMISSION

AUTOMATIC ELECTRICAL CONTROLS –

Part 1: General requirements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60730-1 has been prepared by IEC technical committee 72: Automatic electrical controls. It is an International Standard.

This sixth edition cancels and replaces the fifth edition published in 2013, Amendment 1:2015 and Amendment 2:2020. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- | | | |
|----|-----------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| a) | Structure of the main clauses | <p>The clauses of the standard are grouped into two sections of requirements, where</p> <ul style="list-style-type: none"> • the first section consists of the Clauses 5 to 13 that, in general, addresses the construction of the product. It is noted that certain construction requirements may have verification requirements integrated within the clause to facilitate usage of the standard, and • the second section consists of Clauses 14 to 26 that addresses the verification requirements; |
| b) | Scope | Relocated and deleted clauses to better reflect the products covered under the part 1 and for easier reading; |
| c) | Normative references | Updated references; |
| d) | Terms and definitions | Revised text in certain clauses and relocated relevant Clause H.3 subclauses into Clause 3; |
| e) | General requirements | General structure of the standard explained along with a figure to depict the intent; |
| f) | General notes on tests | Reduced sample size from 3 to 1, yet requiring analysis; order of tests more flexible; relocation of battery requirements from Annex V; |
| g) | Rating | Deleted – covered under the scope; |
| h) | Classification | Deleted – covered under information; |
| i) | Information | Updated Table 1 to reflect entries from the classification clause, and all cross-references; |
| j) | Protection against electric shock | Revised Clause 8 to include Clause H.8 and Clause V.8 subclauses, revised clauses as appropriate to distinguish between a live part and a hazardous live part; |
| k) | Provision for protective earthing | |
| l) | Construction requirements | One Y1 capacitor allowed; relocated relevant requirements of Clause H.11 and Clause V.11 into Subclause 9.2.5 and Subclause 9.13.4.4 respectively; |
| m) | Moisture and dust | Relocated IP table from classification to Clause 14; updated references; |
| n) | Manufacturing deviation and drift | All clauses moved to Annex H since the requirements pertain to functional safety of controls; |
| o) | EMC-Emissions | Moved Clause H.23 into Clause 23; |
| p) | EMC-Immunity | New EMC requirements (performance) for all controls except incorporated/integrated controls with Class A control functions. Products intended for HBES/BACS are also subjected to these requirements; |
| q) | Fault assessment on electronic circuits | Fault assessment moved from Annex H to Clause 13; deleted test abnormal voltage for electronic disconnection; |

- r) Annex H Relocated all relevant requirements for electronics to the respective clauses within the body of the standard and retained requirements related to functional safety in this annex;
- s) Annex T Revised clauses for clarity in Annex P;
- t) Annex U Removed, the necessity of the annex was not seen anymore;
- u) Annex V Included in the main part of the standard.

The text of this International Standard is based on the following documents:

Draft	Report on voting
72/1307/FDIS	72/1320/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at <https://www.iec.ch/publications>.

A list of all parts of the IEC 60730 series, under the general title: *Automatic electrical controls*, can be found on the IEC website.

In the development of a fully international standard to cover automatic electrical controls, it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

The "in some countries" clauses have been moved to the regional respectively national differences in Annex Q to Annex T.

It is envisaged that in the next edition of this document, it will be found possible to remove those differences that are covered by new IEC standards now being prepared by other technical committees.

This part 1 is to be used in conjunction with the appropriate part 2 for a particular type of control, or for controls for particular applications. This part 1 may also be applied, so far as reasonable, to controls not mentioned in a part 2, and to controls designed on new principles, in which cases additional requirements may be considered to be necessary.

Where, for a particular clause or subclause, the text of part 2 indicates:

- Addition:** the part 1 text applies with the additional requirement indicated in a part 2;
- Modification:** the part 1 text applies with a minor change as indicated in a part 2;
- Replacement:** the part 2 text contains a change which replaces the part 1 text in its entirety.

Where no change is necessary, the part 2 indicates that the relevant clause or subclause applies.

NOTE In this document the following print types are used:

- Requirements proper: in roman type;
- *Test specifications: in italic type;*
- Explanatory matter: in smaller roman type;
- Defined terms: **bold type**.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

AUTOMATIC ELECTRICAL CONTROLS –

Part 1: General requirements

1 Scope

This document applies to automatic electrical controls

- for use in, on, or in association with equipment for household appliance and similar use;

NOTE 1 Throughout this document, the word "equipment" means "appliance and equipment".

- for building automation within the scope of ISO 16484 series and IEC 63044 series (HBES/BACS);

EXAMPLE 1 Independently mounted water valves, controls in smart grid systems and controls for building automation systems within the scope of ISO 16484-2.

- for equipment that is used by the public, such as equipment intended to be used in shops, offices, hospitals, farms and commercial and industrial applications;

EXAMPLE 2 Controls for commercial catering, heating and air-conditioning equipment.

- that are **smart enabled controls**;

EXAMPLE 3 Smart grid control, remote interfaces/control of energy-consuming equipment including computer or smart phone.

- that are AC or DC powered controls with a rated voltage not exceeding 690 V AC or 600 V DC where the DC source is provided by primary or secondary batteries;
- used in, on, or in association with equipment that use electricity, gas, oil, solid fuel, solar thermal energy, etc., or a combination thereof;
- utilized as part of a control system or controls which are mechanically integral with multifunctional controls having non-electrical outputs;
- using NTC or **PTC thermistors** and to discrete **thermistors**, requirements for which are contained in Annex J;
- that are mechanically or electrically operated, responsive to or controlling such characteristics as temperature, pressure, passage of time, humidity, light, electrostatic effects, flow, or liquid level, current, voltage, acceleration, or combinations thereof;
- as well as manual controls when such are electrically and/or mechanically integral with automatic controls.

NOTE 2 Requirements for manually actuated mechanical switches not forming part of an automatic control are contained in IEC 61058-1-1.

This document applies to

- the inherent safety of automatic electrical controls, and
- functional safety of automatic electrical controls and safety related systems,
- controls where the performance (for example the effect of EMC phenomena) of the product can impair the overall safety and performance of the controlled system,
- the operating values, operating times, and operating sequences where such are associated with equipment safety.

This document specifies the requirements for construction, operation and testing of automatic electrical controls used in, on, or in association with an equipment.

This document does not

- apply to automatic **electronic controls** intended exclusively for industrial process applications unless explicitly mentioned in the relevant part 2 or the equipment standard. However, this document can be applied to evaluate automatic electrical controls intended specifically for industrial applications in cases where no relevant safety standard exists.
- take into account the response value of an automatic action of a control, if such a response value is dependent upon the method of mounting the control in the equipment. Where a response value is of significant purpose for the protection of the user, or surroundings, the value defined in the appropriate equipment standard or as determined by the manufacturer will apply.
- address the integrity of the output signal to the network devices, such as interoperability with other devices unless it has been evaluated as part of the control system.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038, *IEC standard voltages*

IEC 60065:2014, *Audio, video and similar electronic apparatus – Safety requirements*

IEC 60068-2-75, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

IEC 60085, *Electrical insulation – Thermal evaluation and designation*

IEC 60099-1:1991, *Surge arresters – Part 1: Non-linear resistor type gapped surge arresters for a.c. systems*¹

IEC 60112:2020, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60127 (all parts), *Miniature fuses*

IEC 60227-1, *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V – Part 1: General requirements*

IEC 60245-1, *Rubber insulated cables – Rated voltages up to and including 450/750 V – Part 1: General requirements*

IEC 60269 (all parts), *Low-voltage fuses*

IEC 60335-1:2020, *Household and similar electrical appliances – Safety – Part 1: General requirements*

IEC 60384-14, *Fixed capacitors for use in electronic equipment – Part 14: Sectional specification – Fixed capacitors for electromagnetic interference suppression and connection to the supply mains*

¹ Withdrawn.

IEC 60384-16, *Fixed capacitors for use in electronic equipment – Part 16: Sectional specification – Fixed metallized polypropylene film dielectric DC capacitors*

IEC 60384-17, *Fixed capacitors for use in electronic equipment – Part 17: Sectional specification – Fixed metallized polypropylene film dielectric AC and pulse capacitors*

IEC 60417, *Graphical symbols for use on equipment*

IEC 60423, *Conduit systems for cable management – Outside diameters of conduits for electrical installations and threads for conduits and fittings*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP code)*

IEC 60529:1989/AMD1:1999

IEC 60529:1989/AMD2:2013

IEC 60539 (all parts), *Directly heated negative temperature coefficient thermistors*

IEC 60664-1:2007², *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC TR 60664-2 (all parts), *Insulation coordination for equipment within low-voltage systems*

IEC 60664-3:2016, *Insulation coordination for equipment within low-voltage systems – Part 3: Use of coating, potting or moulding for protection against pollution*

IEC 60664-4, *Insulation coordination for equipment within low-voltage systems – Part 4: Consideration of high-frequency voltage stress*

IEC 60695-2-10, *Fire hazard testing – Part 2-10: Glowing/hot-wire based test methods – Glow-wire apparatus and common test procedure*

IEC 60695-2-11:2021, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products (GWEPT)*

IEC 60695-10-2, *Fire hazard testing – Part 10-2: Abnormal heat – Ball pressure test method*

IEC 60738 (all parts), *Thermistors – Directly heated positive temperature coefficient*

IEC 60747-5-5, *Semiconductor devices – Part 5-5: Optoelectronic devices – Photocouplers*

IEC 60884-1, *Plugs and socket-outlets for household and similar purposes – Part 1: General requirements*

IEC 60884-2-5:2017, *Plugs and socket-outlets for household and similar purposes – Part 2-5: Particular requirements for adaptors*

IEC 60998-2-2, *Connecting devices for low-voltage circuits for household and similar purposes – Part 2-2: Particular requirements for connecting devices as separate entities with screwless-type clamping units*

² Withdrawn.

IEC 60998-2-3, *Connecting devices for low-voltage circuits for household and similar purposes – Part 2-3: Particular requirements for connecting devices as separate entities with insulation-piercing clamping units*

IEC 60999-1, *Connecting devices – Electrical copper conductors – Safety requirements for screw-type and screwless-type clamping units – Part 1: General requirements and particular requirements for clamping units for conductors from 0,2 mm² up to 35 mm² (included)*

IEC 61000-3-2, *Electromagnetic compatibility (EMC) – Part 3-2: Limits – Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)*

IEC 61000-3-3, *Electromagnetic compatibility (EMC) – Part 3-3: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection*

IEC 61000-3-11, *Electromagnetic compatibility (EMC) – Part 3-11: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems – Equipment with rated current ≤ 75 A and subject to conditional connection*

IEC 61000-3-12, *Electromagnetic compatibility (EMC) – Part 3-12: Limits – Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current > 16 A and ≤ 75 A per phase*

IEC 61000-4-2:2008, *Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test*

IEC 61000-4-3, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test*

IEC 61000-4-4, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-5:2014, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*
IEC 61000-4-5:2014/AMD1:2017

IEC 61000-4-6, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields*

IEC 61000-4-8, *Electromagnetic compatibility (EMC) – Part 4-8: Testing and measurement techniques – Power frequency magnetic field immunity test*

IEC 61000-4-11, *Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests for equipment with current up to 16 A per phase*

IEC 61000-4-13:2002, *Electromagnetic compatibility (EMC) – Part 4-13: Testing and measurement techniques – Harmonics and interharmonics including mains signalling at a.c. power port, low frequency immunity tests*
IEC 61000-4-13:2002 /AMD1:2009
IEC 61000-4-13:2002 /AMD2:2015

IEC 61000-4-20, *Electromagnetic compatibility (EMC) – Part 4-20: Testing and measurement techniques – Emission and immunity testing in transverse electromagnetic (TEM) waveguides*

IEC 61000-4-21, *Electromagnetic compatibility (EMC) – Part 4-21: Testing and measurement techniques – Reverberation chamber test methods*

IEC 61000-4-22, *Electromagnetic compatibility (EMC) – Part 4-22: Testing and measurement techniques – Radiated emissions and immunity measurements in fully anechoic rooms (FARs)*

IEC 61000-4-28, *Electromagnetic compatibility (EMC) – Part 4-28: Testing and measurement techniques – Variation of power frequency, immunity test for equipment with input current not exceeding 16A per phase*

IEC 61000-6-1:2016, *Electromagnetic compatibility (EMC) – Part 6-1: Generic standards – Immunity standard for residential, commercial and light-industrial environments*

IEC 61000-6-2:2016, *Electromagnetic compatibility (EMC) – Part 6-2: Generic standards – Immunity standard for industrial environments*

IEC 61000-6-3:2020, *Electromagnetic compatibility (EMC) – Part 6-3: Generic standards – Emission standard for equipment in residential environments*

IEC 61000-6-4:2018, *Electromagnetic compatibility (EMC) – Part 6-4: Generic standards – Emission standard for industrial environments*

IEC 61051-1, *Varistors for use in electronic equipment – Part 1: Generic specification*

IEC 61051-2, *Varistors for use in electronic equipment – Part 2: Sectional specification for surge suppression varistors*

IEC 61051-2-2, *Varistors for use in electronic equipment – Part 2: Blank detail specification for zinc oxide surge suppression varistors. Assessment level E*

IEC 61210, *Connecting devices – Flat quick-connect terminations for electrical copper conductors – Safety requirements*

IEC 61249 (all parts), *Materials for printed boards and other interconnecting structures*

IEC 61558-2-6, *Safety of transformers, reactors, power supply units and combinations thereof – Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers for general applications*

IEC 61558-2-16, *Safety of transformers, reactors, power supply units and combinations thereof – Part 2-16: Particular requirements and tests for switch mode power supply units and transformers for switch mode power supply units for general applications*

IEC 61810-3, *Electromechanical elementary relays – Part 3: Relays with forcibly guided (mechanically linked) contacts*

IEC 62151, *Safety of equipment electrically connected to a telecommunication network*

IEC 62319 (all parts), *Polymeric thermistors – Directly heated positive step function temperature coefficient*

IEC 62326 (all parts), *Printed boards*

IEC 62368-1, *Audio/video, information and communication technology equipment – Part 1: Safety requirements*

IEC 63044 (all parts), *Home and Building Electronic Systems (HBES) and Building Automation and Control Systems (BACS)*

CISPR 11, *Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement*

CISPR 14-1:2020, *Electromagnetic compatibility – Requirements for household appliances, electric tools and similar apparatus – Part 1: Emission*

CISPR 32:2015, *Electromagnetic compatibility of multimedia equipment – Emission requirements*

CISPR 32:2015/AMD1:2019

ISO 4046-4:2016, *Paper, board, pulps and related terms – Vocabulary – Part 4: Paper and board grades and converted products*

ISO 7637-2:2011, *Road vehicles – Electrical disturbances from conduction and coupling – Part 2: Electrical transient conduction along supply lines only*

ISO 7637-3:2016, *Road vehicles – Electrical disturbances from conduction and coupling – Part 3: Electrical transient transmission by capacitive and inductive coupling via lines other than supply lines*

ISO 16484 (all parts), *Building automation and control systems (BACS)*