

SVENSK STANDARD

SS-EN IEC 61000-2-4, utg 3:2025

Fastställd 2025-05-07 ^{Sida} 1 (50) Ansvarig kommitté SEK TK EMC

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

Elektromagnetisk kompatibilitet (EMC) – Del 2-4: Miljöbetingelser – Kompatibilitetsnivåer för lågfrekventa ledningsbundna störningar i industrimiljö

Electromagnetic compatibility (EMC) – Part 2-4: Environment – Compatibility levels in power distribution systems in industrial locations for low-frequency conducted disturbances

Som svensk standard gäller europastandarden EN IEC 61000-2-4:2024. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 61000-2-4:2024.

Nationellt förord

Europastandarden EN IEC 61000-2-4:2024

består av:

- europastandardens ikraftsättningsdokument, utarbetat inom CENELEC
- IEC 61000-2-4, Third edition, 2024 Electromagnetic compatibility (EMC) Part 2-4: Environment - Compatibility levels in power distribution systems in industrial locations for low-frequency conducted

disturbances utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 61000-2-4, utg 2:2003 med eventuella tillägg, ändringar och rättelser gäller ej fr o m 2027-08-29.

ICS 33.100.10; 33.100.20

Denna standard är fastställd av SEK Svensk Elstandard, som också kan lämna upplysningar om **sakinnehållet** i standarden. Postadress: Box 1042, 172 21 Sundbyberg Telefon: 08 - 444 14 00. E-post: sek@elstandard.se. Internet: elstandard.se

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1042 172 21 Sundbyberg Tel 08-444 14 00 elstandard.se

EUROPEAN STANDARD NORME EUROPÉENNE EUROPÄISCHE NORM

EN IEC 61000-2-4

September 2024

ICS 33.100.10; 33.100.20

Supersedes EN 61000-2-4:2002; EN 61000-2-4:2002/AC:2014

English Version

Electromagnetic compatibility (EMC) - Part 2-4: Environment -Compatibility levels in power distribution systems in industrial locations for low-frequency conducted disturbances (IEC 61000-2-4:2024)

Compatibilité électromagnétique (CEM) - Partie 2-4: Environnement - Niveaux de compatibilité dans les réseaux de distribution d'électricité sur des sites industriels pour les perturbations conduites à basse fréquence (IEC 61000-2-4:2024) Elektromagnetische Verträglichkeit (EMV) - Teil 2-4: Umgebungsbedingungen - Verträglichkeitspegel für niederfrequente leitungsgeführte Störgrößen in Industrieanlagen (IEC 61000-2-4:2024)

This European Standard was approved by CENELEC on 2024-08-29. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization Comité Européen de Normalisation Electrotechnique Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2024 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

Ref. No. EN IEC 61000-2-4:2024 E

European foreword

The text of document 77A/1215/FDIS, future edition 3 of IEC 61000-2-4, prepared by SC 77A "EMC - Low frequency phenomena" of IEC/TC 77 "Electromagnetic compatibility" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 61000-2-4:2024.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2025-05-29 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2027-08-29 document have to be withdrawn

This document supersedes EN 61000-2-4:2002 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a standardization request addressed to CENELEC by the European Commission. The Standing Committee of the EFTA States subsequently approves these requests for its Member States.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 61000-2-4:2024 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

IEC 60038:2009	NOTE	Approved as EN 60038:2011
IEC 61000-1-2	NOTE	Approved as EN 61000-1-2
IEC 61000-4-15:2010	NOTE	Approved as EN 61000-4-15:2011 (not modified)
IEC 61511-1:2016	NOTE	Approved as EN 61511-1:2017 (not modified)

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cencenelec.eu.

Publication	Year	Title	<u>EN/HD</u>	<u>Year</u>
IEC 61000-2-2	2002	Electromagnetic compatibility (EMC) - Part 2-2: Environment - Compatibility levels for low-frequency conducted disturbances and signalling in public low-voltage power supply systems	EN 61000-2-2	2002
+ A1	2017		+ A1	2017
+ A2	2018		+ A2	2019
IEC 61000-2-12	-	Electromagnetic compatibility (EMC) - Part 2-12: Environment - Compatibility levels for low-frequency conducted disturbances and signalling in public medium-voltage power supply systems	EN 61000-2-12	-
IEC 61000-4-7	-	Electromagnetic compatibility (EMC) - Part 4-7: Testing and measurement techniques - General guide on harmonics and interharmonics measurements and instrumentation, for power supply systems and equipment connected thereto	EN 61000-4-7	-
CISPR 16-1-1	-	Specification for radio disturbance and immunity measuring apparatus and methods - Part 1-1: Radio disturbance and immunity measuring apparatus - Measuring apparatus	EN IEC 55016-1-1	-
CISPR 16-2-1	-	Specification for radio disturbance and immunity measuring apparatus and methods - Part 2-1: Methods of measurement of disturbances and immunity - Conducted disturbance measurements	EN 55016-2-1	-



Edition 3.0 2024-07

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Electromagnetic compatibility (EMC) – Part 2-4: Environment – Compatibility levels in power distribution systems in industrial locations for low-frequency conducted disturbances

Compatibilité électromagnétique (CEM) – Partie 2-4: Environnement – Niveaux de compatibilité dans les réseaux de distribution d'électricité sur des sites industriels pour les perturbations conduites à basse fréquence

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMISSION ELECTROTECHNIQUE INTERNATIONALE

ICS 33.100.10; 33.100.20

ISBN 978-2-8322-9416-1

Warning! Make sure that you obtained this publication from an authorized distributor. Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

 Registered trademark of the International Electrotechnical Commission Marque déposée de la Commission Electrotechnique Internationale

SEK Svensk Elstandard

CONTENTS

	DRD	5
INTROD	JCTION	7
1 Sco	be	8
2 Norr	native references	9
3 Terr	ns, definitions and abbreviated terms	9
3.1	General definitions	
3.2	Phenomena-related definitions	
3.3	Abbreviated terms	
	tromagnetic environment classes	
5 Intro	duction to the setting of compatibility levels for different types of tromagnetic disturbances	
5.1	General comment	
5.2	Voltage deviations	
5.3	Voltage dips and short interruptions	
5.4	Voltage imbalance	
5.5	Temporary power-frequency variation	
5.6	Harmonics	
5.7	Interharmonics	
5.8	Voltage components at higher frequencies (above 40 th harmonic)	
5.9	Transient overvoltages	
5.10	DC component	
	patibility levels	
Annex A	(informative) Explanations and examples for interharmonics	24
	(informative) Explanations and examples for interharmonics	
A.1	Resolution of non-sinusoidal voltages and currents	24
A.1 A.2	Resolution of non-sinusoidal voltages and currents Time varying phenomena	24
A.1 A.2 Annex B	Resolution of non-sinusoidal voltages and currents	24 25
A.1 A.2 Annex B	Resolution of non-sinusoidal voltages and currents Time varying phenomena (informative) Examples of expected disturbance levels in typical industrial	24 25 26
A.1 A.2 Annex B networks	Resolution of non-sinusoidal voltages and currents Time varying phenomena (informative) Examples of expected disturbance levels in typical industrial	24 25 26 26
A.1 A.2 Annex B networks B.1	Resolution of non-sinusoidal voltages and currents Time varying phenomena (informative) Examples of expected disturbance levels in typical industrial General	24 25 26 26 26
A.1 A.2 Annex B networks B.1 B.2	Resolution of non-sinusoidal voltages and currents Time varying phenomena (informative) Examples of expected disturbance levels in typical industrial General Voltage disturbance levels in industrial networks due to large converters	24 25 26 26 26 28
A.1 A.2 Annex B networks B.1 B.2 B.3	Resolution of non-sinusoidal voltages and currents Time varying phenomena (informative) Examples of expected disturbance levels in typical industrial General Voltage disturbance levels in industrial networks due to large converters Voltage disturbance levels in industrial networks at high load Voltage dips and short interruptions	24 25 26 26 26 28 30
A.1 A.2 Annex B networks B.1 B.2 B.3 B.4	Resolution of non-sinusoidal voltages and currents Time varying phenomena (informative) Examples of expected disturbance levels in typical industrial General Voltage disturbance levels in industrial networks due to large converters Voltage disturbance levels in industrial networks at high load Voltage dips and short interruptions 1 Description	24 25 26 26 26 28 30 30
A.1 A.2 Annex B networks B.1 B.2 B.3 B.4 B.4.	Resolution of non-sinusoidal voltages and currents Time varying phenomena (informative) Examples of expected disturbance levels in typical industrial General Voltage disturbance levels in industrial networks due to large converters Voltage disturbance levels in industrial networks at high load Voltage dips and short interruptions 1 Description	24 25 26 26 26 28 30 31
A.1 A.2 Annex B networks B.1 B.2 B.3 B.4 B.4 B.4. B.5 Annex C	Resolution of non-sinusoidal voltages and currents Time varying phenomena (informative) Examples of expected disturbance levels in typical industrial General Voltage disturbance levels in industrial networks due to large converters Voltage disturbance levels in industrial networks at high load Voltage dips and short interruptions	24 25 26 26 26 28 30 30 31 31
A.1 A.2 Annex B networks B.1 B.2 B.3 B.4 B.4 B.4. B.5 Annex C	Resolution of non-sinusoidal voltages and currents Time varying phenomena (informative) Examples of expected disturbance levels in typical industrial General Voltage disturbance levels in industrial networks due to large converters Voltage disturbance levels in industrial networks at high load Voltage dips and short interruptions 1 Description 2 Adaptation Transient overvoltages (informative) Interharmonics and voltages at higher frequencies and	24 25 26 26 28 30 31 31 31
A.1 A.2 Annex B networks B.1 B.2 B.3 B.4 B.4 B.4. B.4. B.5 Annex C mitigation	Resolution of non-sinusoidal voltages and currents Time varying phenomena (informative) Examples of expected disturbance levels in typical industrial General Voltage disturbance levels in industrial networks due to large converters Voltage disturbance levels in industrial networks at high load Voltage dips and short interruptions 1 Description 2 Adaptation Transient overvoltages (informative) Interharmonics and voltages at higher frequencies and methods Sources of interharmonics	24 25 26 26 26 28 30 31 31 31 33 33
A.1 A.2 Annex B networks B.1 B.2 B.3 B.4 B.4 B.4. B.5 Annex C mitigation C.1	Resolution of non-sinusoidal voltages and currents Time varying phenomena (informative) Examples of expected disturbance levels in typical industrial General. Voltage disturbance levels in industrial networks due to large converters Voltage disturbance levels in industrial networks at high load Voltage disturbance levels in industrial networks at high load Voltage dips and short interruptions 1 Description 2 Adaptation Transient overvoltages (informative) Interharmonics and voltages at higher frequencies and methods Sources of interharmonics 1 Identification	24 25 26 26 26 30 31 31 31 33 33 33
A.1 A.2 Annex B networks B.1 B.2 B.3 B.4 B.4 B.4 B.5 Annex C mitigation C.1 C.1.	Resolution of non-sinusoidal voltages and currents	24 25 26 26 26 28 30 31 31 31 31 33 33 33 35
A.1 A.2 Annex B networks B.1 B.2 B.3 B.4 B.4 B.4 B.4 B.5 Annex C mitigation C.1 C.1 C.1. C.1. C.1.	Resolution of non-sinusoidal voltages and currents Time varying phenomena	24 25 26 26 28 30 31 31 31 33 33 33 35 35
A.1 A.2 Annex B networks B.1 B.2 B.3 B.4 B.4 B.4 B.5 Annex C mitigation C.1 C.1 C.1 C.1 C.1 C.1 C.1	Resolution of non-sinusoidal voltages and currents	24 25 26 26 28 30 31 31 31 33 33 33 35 35
A.1 A.2 Annex B networks B.1 B.2 B.3 B.4 B.4. B.5 Annex C mitigation C.1 C.1. C.1. C.1. C.1. C.1. C.2 C.2.	Resolution of non-sinusoidal voltages and currents	24 25 26 26 26 26 30 30 31 31 31 31 33 33 33 33 35 35 37 37
A.1 A.2 Annex B networks B.1 B.2 B.3 B.4 B.4 B.4 B.4 B.5 Annex C mitigation C.1 C.1 C.1. C.1. C.1. C.1. C.1. C.1.	Resolution of non-sinusoidal voltages and currents	24 25 26 26 28 30 31 31 31 31 33 33 33 33 33 35 35 37 37 37
A.1 A.2 Annex B networks B.1 B.2 B.3 B.4 B.4. B.5 Annex C mitigation C.1 C.1. C.1. C.1. C.1. C.1. C.2 C.2.	Resolution of non-sinusoidal voltages and currents	24 25 26 26 26 26 30 30 31 31 31 31 33 33 33 35 35 37 37 37 38

Annex D (informative) Proving compatibility in the frequency range above 2 kHz in industrial MV networks	39
Annex E (informative) Examples of locations and installations covered by	
IEC 61000-2-4	
E.1 General	40
E.2 Mixed locations	
E.3 Examples for industrial locations	40
Annex F (informative) Rationale for increased individual even and triplen compatibility levels and for splitting class 2 into class 2a, class 2b and class 2L	44
F.1 Rationale for increased individual even and triplen compatibility levels	44
F.1.1 Target	44
F.1.2 The needs of modern power electronic equipment	44
F.1.3 Maintaining the overall disturbance level	45
F.2 Rationale for splitting class 2 into class 2a, class 2b and class 2L	45
F.2.1 Target	45
F.2.2 Class 2a	45
F.2.3 Class 2b	45
F.2.4 Class 2L	46
Bibliography	47
Figure 1 – Examples of the application of different electromagnetic environment classes in different industrial locations	16
Figure 2 – Example of different parts of an installation separated by filters, where different electromagnetic environment classes are applied	16
Figure 3 – Interharmonic compatibility levels (flickermeter response for <i>P</i> _{st} = 1 related to 60 W incandescent lamps)	23
Figure B.1 – Example of power distribution in industry with rolling mills	
Figure B.2 – Example of power distribution in the paper industry	
Figure B.2 – Example of power distribution in a generic manufacturing industry	

rigure b.z Example of power distribution in the paper industry	.20
Figure B.3 – Example of power distribution in a generic manufacturing industry	.30
Figure B.4 – ITI (CBEMA) – Curve of tolerance envelope of ITE	. 32
Figure E.1 – Example of class 1 environment	.40
Figure E.2 – Example of class 2a and class 2b environments	.41
Figure E.3 – Example of an LV grid in a building supplied by a dedicated transformer	.41
Figure E.4 – Example of an LV grid in a building including residential and industrial locations	.42
Figure E.5 – Example of an LV grid for a data center	.42
Figure F.1 – Emission spectrum of an active infeed converter	.44

Table 1 – Compatibility levels for voltage tolerance, voltage imbalance and power- frequency variations	20
Table 2 – Compatibility levels for harmonics – Harmonic voltage components	21
Table 3 – Compatibility levels for total voltage harmonic distortion	22
Table 4 – Compatibility levels for low voltage networks in the frequency range from2 kHz to 9 kHz	22
Table 5 – Compatibility levels for low voltage networks in the frequency range from9 kHz to 150 kHz	22
Table B.1 – Type of network	26

Table B.2 – Voltage disturbance levels in a typical manufacturing industry	29
Table C.1 – Indicative values for interharmonic voltages in low-voltage networks with	
respect to the flicker effect	36

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTROMAGNETIC COMPATIBILITY (EMC) -

Part 2-4: Environment – Compatibility levels in power distribution systems in industrial locations for low-frequency conducted disturbances

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 61000-2-4 has been prepared by subcommittee 77A: EMC – Low frequency phenomena, of IEC technical committee 77: Electromagnetic compatibility. It is an International Standard.

This third edition cancels and replaces the second edition published in 2002. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) introduction of new classes 2a, 2b and 2L (former class 2);
- b) modification of existing compatibility levels for class 3;
- c) addition of compatibility levels in the frequency range 2 kHz to 150 kHz;

d) addition of compatibility levels using a new quantity: partial weighted harmonic distortion (PWHD).

The text of this International Standard is based on the following documents:

Draft	Report on voting
77A/1215/FDIS	77A/1221/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 61000 series, published under the general title *Electromagnetic compatibility* (*EMC*), can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC 61000 is published in separate parts according to the following structure:

Part 1: General

General considerations (introduction, fundamental principles) Definitions, terminology

Part 2: Environment

Description of the environment

Classification of the environment

Compatibility levels

Part 3: Limits

Emission limits

Immunity limits (in so far as they do not fall under the responsibility of the product committees)

Part 4: Testing and measurement techniques

Measurement techniques

Testing techniques

Part 5: Installation and mitigation guidelines

Installation guidelines

Mitigation methods and devices

Part 6: Generic standards

Part 9: Miscellaneous

Each part is further subdivided into several parts, published either as International Standards, technical specifications or technical reports, some of which have already been published as sections. Others will be published with the part number followed by a dash and a second number identifying the subdivision (example: IEC 61000-3-11).

Detailed information on the various types of disturbances that can be expected on public power supply systems can be found in IEC 61000-2-1 and IEC 61000-2-12.

ELECTROMAGNETIC COMPATIBILITY (EMC) -

Part 2-4: Environment – Compatibility levels in power distribution systems in industrial locations for low-frequency conducted disturbances

1 Scope

This part of IEC 61000 is related to conducted disturbances in the frequency range from 0 kHz to 150 kHz. It gives compatibility levels in differential mode (L-L and L-N) for industrial locations, with a nominal voltage up to 35 kV and a nominal frequency of 50 Hz or 60 Hz.

NOTE 1 Industrial locations are defined in 3.1.8.

Power distribution systems on ships, aircraft, offshore platforms and railways are not included.

NOTE 2 See also Annex E. The compatibility levels specified in this document apply at the in-plant point of coupling (IPC). The level of the low-frequency disturbances at the terminals of equipment receiving its supply from the IPC is generally assumed to be similar to the disturbance level at the IPC itself. However, in some situations this is not the case, particularly when a long feeder is dedicated to the supply of a particular load, or when a disturbance is generated or amplified within the installation of which the equipment forms a part.

Compatibility levels are specified for the types of low-frequency electromagnetic disturbances expected at any in-plant point of coupling (IPC) within industrial locations, for guidance in the definition of:

a) limits for disturbance emissions in industrial power distribution systems (including the planning levels defined in 3.1.5);

NOTE 3 A very wide range of conditions is possible in the electromagnetic environments of industrial networks. These are approximated in this document by the three classes described in Clause 4. However, it is the responsibility of the operator of such a network to take account of the particular electromagnetic and economic conditions, including equipment characteristics, in setting the above-mentioned limits.

b) immunity levels for the equipment within these systems.

The disturbance phenomena considered are:

- voltage deviations;
- voltage dips and short interruptions;
- voltage imbalance;
- power-frequency variations;
- harmonics up to order 40;
- interharmonics up to the 40th harmonic;
- voltage components above the 40th harmonic up to 150 kHz;
- DC component;
- transient overvoltages.

The compatibility levels are given for different classes of environment determined by the characteristics of the supply network and loads.

NOTE 4 Compatibility levels at the point of common coupling (PCC) on public networks are specified in IEC 61000-2-2 for low-voltage networks and IEC 61000-2-12 for medium-voltage networks. IEC TR 61000-3-6 and IEC TR 61000-3-7 describe the approach of power distribution system operators to the limitation of emissions from installations and large loads.

IEC 61000-2-4:2024 © IEC 2024 - 9 -

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61000-2-2:2002, Electromagnetic compatibility (EMC) – Part 2-2: Environment – Compatibility levels for low-frequency conducted disturbances and signalling in public lowvoltage power supply systems IEC 61000-2-2:2002/AMD1:2017 IEC 61000-2-2:2002/AMD2:2018

IEC 61000-2-12, Electromagnetic compatibility (EMC) – Part 2-12: Environment – Compatibility levels for low-frequency conducted disturbances and signalling in public medium-voltage power supply systems

IEC 61000-4-7, Electromagnetic compatibility (EMC) – Part 4-7: Testing and measurement techniques – General guide on harmonics and interharmonics measurements and instrumentation, for power supply systems and equipment connected thereto

CISPR 16-1-1, Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-1: Radio disturbance and immunity measuring apparatus – Measuring apparatus

CISPR 16-2-1, Specification for radio disturbance and immunity measuring apparatus and methods – Part 2-1: Methods of measurement of disturbances and immunity – Conducted disturbance measurements