

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

## Högspänningsprovning – Del 1: Allmän terminologi och provningsanvisningar

*High-voltage test techniques –*

*Part 1: General terminology and test requirements*

Som svensk standard gäller europastandarden EN IEC 60060-1:2025. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 60060-1:2025.

### Nationellt förord

Europastandarden EN IEC 60060-1:2025

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 60060-1, Fourth edition, 2025 - High-voltage test techniques – Part 1: General terminology and test requirements**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 60060-1, utg 2:2011 med eventuella tillägg, ändringar och rättelser gäller ej fr o m 2028-06-30.

---

ICS 17.220.20

---

Denna standard är fastställd av SEK Svensk Elstandard, som också kan lämna upplysningar om **sakinnehållet** i standarden.  
Postadress: Box 1042, 172 21 Sundbyberg  
Telefon: 08 - 444 14 00.  
E-post: [sek@elstandard.se](mailto:sek@elstandard.se). Internet: [elstandard.se](http://elstandard.se)

---

## Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

## SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

## Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

## Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

## SEK Svensk Elstandard

Box 1042  
172 21 Sundbyberg  
Tel 08-444 14 00  
elstandard.se

English Version

**High-voltage test techniques - Part 1: General terminology and  
test requirements  
(IEC 60060-1:2025)**

Techniques d'essais à haute tension - Partie 1:  
Terminologie générale et exigences d'essai  
(IEC 60060-1:2025)

Hochspannungs-Prüftechnik - Teil 1: Allgemeine Begriffe  
und Prüfbedingungen  
(IEC 60060-1:2025)

This European Standard was approved by CENELEC on 2025-05-22. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

## **European foreword**

The text of document 42/444/FDIS, future edition 4 of IEC 60060-1, prepared by TC 42 "High-voltage and high-current test techniques" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 60060-1:2025.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2026-06-30 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2028-06-30 document have to be withdrawn

This document supersedes EN 60060-1:2010 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

### **Endorsement notice**

The text of the International Standard IEC 60060-1:2025 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

IEC 60270	NOTE	Approved as EN 60270
IEC 60507	NOTE	Approved as EN 60507
IEC 60060-3	NOTE	Approved as EN 60060-3
IEC 60071-1	NOTE	Approved as EN IEC 60071-1
IEC 60071-2	NOTE	Approved as EN IEC 60071-2
IEC 62271-1	NOTE	Approved as EN 62271-1

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: [www.cencenelec.eu](http://www.cencenelec.eu).

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60060-2	-	High-voltage test techniques - Part 2: Measuring systems	EN IEC 60060-2	-
IEC 61083-1	-	Instruments and software used for measurement in high-voltage impulse tests - Part 1: Requirements for instruments	EN 61083-1	-
IEC 61083-2	-	Instruments and software used for measurement in high-voltage and high-current tests - Part 2: Requirements for software for tests with impulse voltages and currents	EN 61083-2	-
IEC 62475	-	High-current test techniques - Definitions and requirements for test currents and measuring systems	EN 62475	-



IEC 60060-1

Edition 4.0 2025-04

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

---

**High-voltage test techniques –  
Part 1: General terminology and test requirements**

**Techniques d'essais à haute tension –  
Partie 1: Terminologie générale et exigences d'essai**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

---

ICS 17.220.20

ISBN 978-2-8327-0328-1

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD.....	6
1 Scope.....	8
2 Normative references .....	8
3 Terms and definitions .....	8
3.1 Terms related to characteristics of discharges .....	9
3.2 Terms related to characteristics of the test voltage .....	9
3.3 Terms related to tolerance and uncertainty .....	10
3.4 Terms related to statistical characteristics of disruptive discharge voltage values.....	10
3.5 Terms related to classification of insulation in test objects .....	12
3.6 Definitions for direct voltage tests .....	13
3.7 Terms for alternating voltage tests .....	13
3.8 Terms for lightning impulse voltage tests .....	14
3.9 Terms for switching impulse voltage tests .....	22
3.10 Terms for combined voltage tests .....	24
3.11 Terms for composite voltage tests.....	26
4 General requirements .....	29
4.1 General requirements for test procedures .....	29
4.2 Arrangement of the test object in dry tests .....	29
4.3 Atmospheric corrections in dry tests.....	30
4.3.1 Standard reference atmosphere.....	30
4.3.2 Atmospheric correction factors for air gaps.....	30
4.3.3 Application of correction factors.....	30
4.3.4 Correction factor components .....	31
4.3.5 Measurement of atmospheric parameters .....	35
4.3.6 Conflicting requirements for testing internal and external insulation .....	36
4.4 Wet tests .....	37
4.4.1 Wet test procedure .....	37
4.4.2 Atmospheric corrections for wet tests .....	38
4.5 Artificial pollution tests .....	38
5 Tests with direct voltage .....	39
5.1 Test voltage .....	39
5.1.1 Requirements for the test voltage .....	39
5.1.2 Generation of the test voltage.....	39
5.1.3 Measurement of the test voltage .....	39
5.1.4 Measurement of the test current .....	39
5.2 Test procedures .....	40
5.2.1 Withstand voltage tests.....	40
5.2.2 Disruptive discharge voltage tests .....	40
5.2.3 Assured disruptive discharge voltage tests .....	41
6 Tests with alternating voltage .....	41
6.1 Test voltage .....	41
6.1.1 Requirements for the test voltage .....	41
6.1.2 Generation of the test voltage.....	42
6.1.3 Measurement of the test voltage .....	43
6.1.4 Measurement of the test current .....	43
6.2 Test procedures .....	43

6.2.1	Withstand voltage tests.....	43
6.2.2	Disruptive discharge voltage tests .....	44
6.2.3	Assured disruptive discharge voltage tests .....	44
7	Tests with lightning impulse voltage.....	44
7.1	Test voltage .....	44
7.1.1	Requirements for test voltages .....	44
7.1.2	Generation of the test voltage.....	45
7.1.3	Measurement of the test voltage and determination of impulse shape.....	45
7.1.4	Measurement of current during tests with impulse voltages .....	46
7.2	Test procedures .....	46
7.2.1	Withstand voltage tests.....	46
7.2.2	Assured disruptive discharge voltage tests .....	47
8	Tests with switching impulse voltage .....	47
8.1	Test voltage .....	47
8.1.1	Requirements for test voltages .....	47
8.1.2	Generation of the test voltage.....	48
8.1.3	Measurement of test voltage and determination of impulse shape.....	48
8.1.4	Measurement of current during tests with impulse voltages .....	48
8.2	Test procedures .....	48
9	Tests with combined voltages .....	49
9.1	General.....	49
9.2	Test voltage .....	49
9.2.1	Requirements for the test voltage .....	49
9.2.2	Generation of test voltages .....	49
9.2.3	Measurement of the test voltage .....	50
9.3	Test procedures .....	50
10	Tests with composite voltages .....	50
10.1	General.....	50
10.2	Test voltage .....	50
10.2.1	Requirements for the test voltage .....	50
10.2.2	Generation of test voltages .....	51
10.2.3	Measurement of the test voltage .....	51
10.3	Test procedures .....	51
Annex A (informative)	Statistical treatment of test results .....	52
A.1	Classification of tests .....	52
A.1.1	General .....	52
A.1.2	Class 1: Multiple-level tests (Figure A.1).....	52
A.1.3	Class 2: Up-and-down tests (Figure A.2) .....	52
A.1.4	Class 3: Progressive stress tests (Figure A.3) .....	53
A.2	Statistical behaviour of disruptive discharge.....	53
A.2.1	General .....	53
A.2.2	Confidence limits .....	53
A.3	Analysis of test results .....	54
A.3.1	General .....	54
A.3.2	Treatment of results from Class 1 tests.....	57
A.3.3	Treatment of results from Class 2 tests.....	58
A.3.4	Treatment of results from Class 3 tests.....	59
A.4	Application of maximum likelihood methods .....	60

Annex B (normative) Procedures for calculation of parameters of standard lightning impulse voltages without or with superimposed overshoot or oscillations .....	62
B.1 General remarks .....	62
B.2 Basis of the procedures .....	62
B.3 Procedure for evaluation of parameters of full lightning impulses .....	62
B.4 Procedure for evaluation of parameters of tail chopped lightning impulses .....	65
Annex C (informative) Procedure for manual calculation from graphical waveforms .....	67
Annex D (informative) Guidance for implementing software for evaluation of lightning impulse voltage parameters .....	68
D.1 Guidance for implementing base curve fitting .....	68
D.2 Example of a digital filter for implementation of the test voltage function .....	68
Annex E (informative) Iterative calculation method in the converse procedure for the determination of the atmospheric correction factor .....	70
E.1 Introductory remarks .....	70
E.2 Change of atmospheric pressure with altitude .....	70
E.3 Sensitivity of $K_t$ to $U_{50}$ .....	71
E.4 Calculation with the iterative calculation procedure .....	72
E.5 Comment .....	77
Annex F (informative) Front time and time to peak of switching impulse voltage .....	78
F.1 Front time of switching impulse .....	78
F.2 Time to peak for standard switching impulse voltage .....	78
F.3 Time to peak and front time for standard switching impulse voltage .....	78
F.4 Non-standard switching impulse voltage .....	79
Bibliography .....	80
Figure 1 – Full lightning impulse voltage .....	14
Figure 2 – Test voltage function .....	16
Figure 3 – Full impulse voltage time parameters .....	17
Figure 4 – Voltage time interval .....	18
Figure 5 – Voltage integral .....	19
Figure 6 – Lightning impulse voltage chopped on the front .....	20
Figure 7 – Lightning impulse voltage chopped on the tail .....	20
Figure 8 – Linearly rising front-chopped impulse .....	21
Figure 9 – Voltage versus time curve for impulses of constant prospective shape .....	22
Figure 10 – Switching impulse voltage .....	23
Figure 11 – Circuit for a combined voltage test .....	24
Figure 12 – Schematic example for combined voltage (AC + positive impulse) between two HV terminals .....	25
Figure 13 – Examples of time delay $\Delta t$ .....	26
Figure 14 – Circuit for a composite voltage test .....	27
Figure 15 – Schematic example for composite voltage (AC and positive impulse) between one HV terminal and earth .....	28
Figure 16 – Examples of time delay $\Delta t$ .....	28
Figure 17 – Recommended minimum clearance $D$ of extraneous live or earthed objects to the energized electrode of a test object, during an AC or positive switching impulse test at the maximum voltage $U$ applied during the test .....	29

Figure 18 – $k$ as a function of the ratio of the absolute humidity $h$ to the relative air density $\delta$ (see 4.3.4.2 for limits of applicability) .....	33
Figure 19 – Values of exponents $m$ (a) and $w$ (b) for humidity correction as a function of parameter $g$ .....	34
Figure 20 – Absolute humidity of air as a function of dry and wet-bulb thermometer readings.....	36
Figure A.1 – Example of a multiple-level (Class 1) test .....	55
Figure A.2 – Examples of decreasing and increasing up-and-down (Class 2) tests for determination of 10 % and 90 % disruptive discharge probabilities respectively .....	56
Figure A.3 – Examples of progressive stress (Class 3) tests .....	57
Figure B.1 – Recorded and base curves showing overshoot and residual curve .....	63
Figure B.2 – Test voltage curve (addition of base curve and filtered residual curve).....	63
Figure B.3 – Recorded and test voltage curves .....	64
Figure E.1 – Atmospheric pressure as a function of altitude .....	71
Table 1 – Values of exponents, $m$ for air density correction and $w$ for humidity correction, as a function of the parameter $g$ .....	34
Table 2 – Precipitation conditions for standard procedure .....	38
Table A.1 – Discharge probabilities in up-and-down testing .....	59
Table E.1 – Altitudes and air pressure of some locations .....	71
Table E.2 – Initial $K_t$ and its sensitivity coefficients with respect to $U_{50}$ for the example of the standard phase-to-earth AC test voltage of 395 kV .....	72
Table E.3 – Initial and converged $K_t$ values for the example of the standard phase-to-earth AC test voltage of 395 kV.....	77

# INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

## HIGH-VOLTAGE TEST TECHNIQUES –

### Part 1: General terminology and test requirements

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60060-1 has been prepared by IEC technical committee 42: High-voltage and high-current test techniques. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2010. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) The general layout and text have been updated and improved to make the standard easier to use, particularly the clauses for combined and composite test voltages.
- b) The positive tolerance of the front time of lightning impulse voltage has been extended for  $U_m > 800$  kV to 100 % (= 2,4  $\mu$ s).

- c) For switching impulse voltage, a front time has been introduced, similar to lightning impulse voltage and with the new front time the standard switching impulse is defined as 170/2 500  $\mu$ s.
- d) The requirements for precipitations in wet tests have been adjusted depending on  $U_m$ .
- e) A new Annex C, "Procedure for manual calculation from graphical waveforms" has been incorporated.
- f) Examples of software packages have been removed in Annex D, "Guidance for implementing software for evaluation of lightning impulse voltage parameters".
- g) The annex relating to the "Background to the introduction of the test voltage factor for evaluation of impulses with overshoot" has been deleted.
- h) A new informative Annex F, "New definition of the front time of switching impulse voltage" has been incorporated.

The text of this International Standard is based on the following documents:

Draft	Report on voting
42/444/FDIS	42/454A/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/publications](http://www.iec.ch/publications).

A list of all the parts in the IEC 60060 series, published under the general title *High-voltage test techniques*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

## HIGH-VOLTAGE TEST TECHNIQUES –

### Part 1: General terminology and test requirements

#### 1 Scope

This part of IEC 60060 is applicable to:

- dielectric tests with direct voltage;
- dielectric tests with alternating voltage;
- dielectric tests with impulse voltage;
- dielectric tests with combinations of the above.

This document is applicable to tests on equipment having its highest voltage for equipment  $U_m$  above 1,0 kV AC and 1,5 kV DC.

NOTE 1 Alternative test procedures can be required to obtain reproducible and significant results. The choice of a suitable test procedure is considered by the relevant Technical Committee.

NOTE 2 For voltages  $U_m$  above 800 kV it is possible that some specified procedures, tolerances and uncertainties will not be achievable.

#### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060-2, *High-voltage test techniques – Part 2: Measuring systems*

IEC 61083-1, *Instruments and software used for measurements in high-voltage and high-current tests – Part 1: Requirements for instruments for impulse tests*

IEC 61083-2, *Instruments and software used for measurement in high-voltage and high-current tests – Part 2: Requirements for software for tests with impulse voltages and currents*

IEC 62475, *High-current test techniques – Definitions and requirements for test currents and measuring systems*