

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

Elmätare – Allmänna fordringar och provning – Del 31: Säkerhetsfordringar och provningsmetoder

*Electricity metering equipment –
General requirements, tests and test conditions –
Part 31: Product safety requirements and tests*

Som svensk standard gäller europastandarden EN IEC 62052-31:2024. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 62052-31:2024.

Nationellt förord

Europastandarden EN IEC 62052-31:2024

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 62052-31, Second edition, 2024 - Electricity metering equipment (AC) - General requirements, tests and test conditions - Part 31: Product safety requirements and tests**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 62052-31, utg 1:2017 med eventuella tillägg, ändringar och rättelser gäller ej fr o m 2027-12-31.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1042
172 21 Sundbyberg
Tel 08-444 14 00
elstandard.se

English Version

Electricity metering equipment - General requirements, tests and test conditions - Part 31: Product safety requirements and tests (IEC 62052-31:2024)

Équipement de comptage de l'électricité - Exigences générales, essais et conditions d'essai - Partie 31: Exigences et essais sur la sécurité de produit (IEC 62052-31:2024)

Wechselstrom-Elektrizitätszähler - Allgemeine Anforderungen, Prüfungen und Prüfbedingungen - Teil 31: Sicherheitsanforderungen und Prüfungen (IEC 62052-31:2024)

This European Standard was approved by CENELEC on 2024-11-29. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

The text of document 13/1923/FDIS, future edition 2 of IEC 62052-31, prepared by TC 13 "Electrical energy measurement and control" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62052-31:2024.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2025-12-31
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2027-12-31

This document supersedes EN 62052-31:2016 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 62052-31:2024 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

IEC 60060-1:2010	NOTE Approved as EN 60060-1:2010 (not modified)
IEC 60068-1:2013	NOTE Approved as EN 60068-1:2014 (not modified)
IEC 60079-0:2017	NOTE Approved as EN IEC 60079-0:2018 (not modified) +A11:2024
IEC 60079-11:2023	NOTE Approved as EN IEC 60079-11:2024 (not modified)
IEC 60228:2004	NOTE Approved as EN 60228:2005 (not modified)
IEC 60255-27:2023	NOTE Approved as EN IEC 60255-27:— (not modified) ¹
IEC 60364-1:2005	NOTE Approved as HD 60364-1:2008 +A11:2017
IEC 60364-4-41:2005	NOTE Approved as HD 60364-4-41:2007 +A11:2017 +A12:2019
IEC 60664-3:2016	NOTE Approved as EN 60664-3:2017 (not modified)
IEC 60670-24:2011	NOTE Approved as EN 60670-24:2013 +A11:2023
IEC 60898-1:2015	NOTE Approved as EN 60898-1:2019 +A11:2024

¹ Under preparation. Stage at the time of publication: FprEN IEC 60255-27:2022.

IEC 60947-1:2020	NOTE Approved as EN IEC 60947-1:2021 (not modified)
IEC 60990:2016	NOTE Approved as EN 60990:2016 (not modified)
IEC 61051-2:2021	NOTE Approved as EN IEC 61051-2:2021 (not modified)
IEC 61558-1:2017	NOTE Approved as EN IEC 61558-1:2019 (not modified)
IEC 61558-2-16:2021	NOTE Approved as EN IEC 61558-2-16:— (not modified) ²
IEC 61643-11:2011	NOTE Approved as EN 61643-11:2012 +A11:2018
IEC 61643-311	NOTE Approved as EN 61643-311
IEC 61643-321	NOTE Approved as EN 61643-321
IEC 61643-331:2020	NOTE Approved as EN IEC 61643-331:2020 (not modified)
IEC 61643-341	NOTE Approved as EN IEC 61643-341
IEC 61869 (series)	NOTE Approved as EN IEC 61869 (series)
IEC 61869-99:2022	NOTE Approved as EN IEC 61869-99:2022 (not modified)
IEC 62052-21:2004	NOTE Approved as EN 62052-21:2004 (not modified)
IEC 62054-11:2004	NOTE Approved as EN 62054-11:2004 (not modified)
IEC 62054-21:2004	NOTE Approved as EN 62054-21:2004 (not modified)
IEC 62057-1:2023	NOTE Approved as EN IEC 62057-1:2023 (not modified)
IEC 62058-11:2008	NOTE Approved as EN 62058-11:2010 (modified)
IEC 62477-1:2022	NOTE Approved as EN IEC 62477-1:2023 (not modified)
ISO 14971:2019	NOTE Approved as EN ISO 14971:2019 (not modified) +A11:2021

² Under preparation. Stage at the time of publication: FprEN IEC 61558-2-16:2021.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cencenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60027-1	1992	Letters symbols to be used in electrical technology - Part 1: General	EN 60027-1	2006
+ A1	1997		-	-
+ A2	2005		+ A2	2007
IEC 60068-2-75	2014	Environmental testing - Part 2-75: Tests - Test Eh: Hammer tests	EN 60068-2-75	2014
IEC 60068-2-78	2012	Environmental testing - Part 2-78: Tests - Test Cab: Damp heat, steady state	EN 60068-2-78	2013
IEC 60085	2007	Electrical insulation - Thermal evaluation and designation	EN 60085	2008
IEC 60112	2020	Method for the determination of the proof and the comparative tracking indices of solid insulating materials	EN IEC 60112	2020
IEC 60269-3 (mod)	2010	Low-voltage fuses - Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household or similar applications) - Examples of standardized systems of fuses A to F	HD 60269-3	2010
IEC 60332-1-2	2004	Tests on electric and optical fibre cables under fire conditions - Part 1-2: Test for vertical flame propagation for a single insulated wire or cable - Procedure for 1 kW pre-mixed flame	EN 60332-1-2	2004
-	-		+ A11	2016
-	-		+ A12	2020
IEC 60332-2-2	2004	Tests on electric and optical fibre cables under fire conditions - Part 2-2: Test for vertical flame propagation for a single small insulated wire or cable - Procedure for diffusion flame	EN 60332-2-2	2004

IEC 60364-4-44 (mod)	2007	Low-voltage electrical installations - Part 4-44: Protection for safety - Protection against voltage disturbances and electromagnetic disturbances	HD 60364-4-442	2012
			HD 60364-4-444	2010
IEC 60384-14	2023	Fixed capacitors for use in electronic equipment - Part 14: Sectional specification - Fixed capacitors for electromagnetic interference suppression and connection to the supply mains	EN IEC 60384-14	2023
IEC 60417-DB-12M -		Graphical symbols for use on equipment	-	-
IEC 60529	1989	Degrees of protection provided by enclosures (IP Code)	EN 60529	1991
-	-		+ corrigendum	May 1993
+ A1	1999		+ A1	2000
+ A2	2013		+ A2	2013
IEC 60617-DB-12M -		Graphical symbols for diagrams	-	-
IEC 60664-1	2020	Insulation coordination for equipment within low-voltage supply systems - Part 1: Principles, requirements and tests	EN IEC 60664-1	2020
IEC 60695-2-11	2021	Fire hazard testing - Part 2-11: Glowing/hot-wire based test methods - Glow-wire flammability test method for end products (GWEPT)	EN IEC 60695-2-11	2021
IEC 60695-11-10	2013	Fire hazard testing - Part 11-10: Test flames - 50 W horizontal and vertical flame test methods	EN 60695-11-10	2013
IEC 60721-3-0	2020	Classification of environmental conditions - Part 3-0: Classification of groups of environmental parameters and their severities - Introduction	EN IEC 60721-3-0	2020
IEC 60721-3-3	2019	Classification of environmental conditions - Part 3-3: Classification of groups of environmental parameters and their severities - Stationary use at weather protected locations	EN IEC 60721-3-3	2019
IEC 60950-1	2005	Information technology equipment - Safety - Part 1: General requirements		-
+ A1	2009		-	-
+ A2	2013		-	-
IEC 61000-4-5	2014	Electromagnetic compatibility (EMC) - Part 4-5: Testing and measurement techniques - Surge immunity test	EN 61000-4-5	2014
+ A1	2017		+ A1	2017
IEC 61010-1	2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements	EN 61010-1	2010
+ A1 (mod)	2016		+ A1	2019

EN IEC 62052-31:2024 (E)

+ A2	— ³		+ A2	— ⁴
IEC 61010-2-030	2017	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 2-030: Particular requirements for equipment having testing or measuring circuits	EN IEC 61010-2-030	2021
-	-		+ A11	2021
IEC 61032	1997	Protection of persons and equipment by enclosures - Probes for verification	EN 61032	1998
IEC 61180	2016	High-voltage test techniques for low-voltage equipment - Definitions, test and procedure requirements, test equipment	EN 61180	2016
IEC 61851-23	2014	Electric vehicle conductive charging system - Part 23: DC electric vehicle charging station	EN 61851-23	2014
IEC 62052-11	2020	Electricity metering equipment - General requirements, tests and test conditions - Part 11: Metering equipment	EN IEC 62052-11	2021
-	-		+ A11	2022
-	-		+ A12	2024
IEC 62052-31	2015	Electricity metering equipment (AC) - General requirements, tests and test conditions - Part 31: Product safety requirements and tests	EN 62052-31	2016
IEC 62368-1	2018	Audio/video, information and communication technology equipment - Part 1: Safety requirements	EN IEC 62368-1	2020
-	-		+ A11	2020
ISO 75-2	2013	Plastics - Determination of temperature of deflection under load - Part 2: Plastics and ebonite	EN ISO 75-2	2013
ISO 3864-1	2011	Graphical symbols - Safety colours and safety signs - Part 1: Design principles for safety signs and safety markings	-	-
ISO 7000	2019	Graphical symbols for use on equipment - Registered symbols	-	-

³ Under preparation. Stage at time of publication: IEC 61010-1:2010/A2 (ED.3) CDV.

⁴ Under preparation. Stage at time of publication: EN 61010-1:2010/prA2.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Electricity metering equipment – General requirements, tests and test conditions –
Part 31: Product safety requirements and tests**

**Équipement de comptage de l'électricité – Exigences générales, essais et conditions d'essai –
Partie 31: Exigences et essais sur la sécurité de produit**

CONTENTS

FOREWORD.....	9
INTRODUCTION.....	12
1 Scope.....	13
1.1 General.....	13
1.2 Aspects included in scope.....	14
1.3 Aspects excluded from scope.....	15
1.4 Verification.....	15
1.5 Environmental conditions	15
1.5.1 Normal environmental conditions	15
1.5.2 Extended environmental conditions	16
1.5.3 Extreme environmental conditions	16
2 Normative references	17
3 Terms and definitions	19
3.1 Equipment and states of equipment	19
3.2 Parts, accessories, and functional elements.....	19
3.3 Quantities	25
3.4 Tests	28
3.5 Safety terms	28
3.6 Insulation	33
3.7 Terms related to switches of metering equipment.....	37
4 Tests	39
4.1 General.....	39
4.2 Type test – sequence of tests	40
4.3 Reference test conditions.....	40
4.3.1 Atmospheric conditions.....	40
4.3.2 State of the equipment.....	41
4.4 Testing in single fault condition.....	44
4.4.1 General	44
4.4.2 Application of fault conditions	44
4.4.3 Duration of tests	47
4.4.4 Conformity after application of fault conditions.....	47
5 Information and marking requirements.....	47
5.1 General.....	47
5.2 Labels, signs and signals	50
5.2.1 General	50
5.2.2 Durability of markings	53
5.3 Information for selection	53
5.3.1 General	53
5.3.2 General information	53
5.3.3 Information specific for meters.....	54
5.3.4 Information specific for stand-alone tariff and load control equipment	54
5.3.5 Information related to LCS.....	54
5.4 General information for installation and commissioning.....	55
5.4.1 General	55
5.4.2 Handling and mounting	55
5.4.3 Enclosure	55

5.4.4	Connections	56
5.4.5	Auxiliary power supply	58
5.4.6	Supply for external devices	58
5.4.7	Self-consumption	59
5.4.8	Commissioning	59
5.5	General information for use	59
5.5.1	General	59
5.5.2	Display, push buttons and other controls	59
5.5.3	Switches	60
5.5.4	Connection to user's equipment	60
5.6	General information for maintenance	60
5.6.1	Maintenance instructions	60
5.6.2	Cleaning	60
5.6.3	Batteries	60
6	Protection against electrical shock	61
6.1	General requirements	61
6.2	Determination of accessible parts	62
6.2.1	General	62
6.2.2	Examination	62
6.2.3	Openings above parts that are hazardous live	63
6.2.4	Openings for pre-set controls	63
6.2.5	Wiring terminals	63
6.3	Limit values for accessible parts	64
6.3.1	General	64
6.3.2	Levels in normal condition	64
6.3.3	Levels in single fault condition	65
6.4	Primary means of protection (protection against direct contact)	67
6.4.1	General	67
6.4.2	Equipment case	68
6.4.3	Basic insulation	68
6.4.4	Impedance	68
6.5	Additional means of protection in case of single fault conditions (protection against indirect contact)	68
6.5.1	General	68
6.5.2	Protective bonding	69
6.5.3	Supplementary insulation and reinforced insulation	72
6.5.4	Protective impedance	73
6.5.5	Automatic disconnection of the supply	73
6.5.6	Current- or voltage-limiting device	73
6.6	Connection to external circuits	74
6.6.1	General	74
6.6.2	Terminals for external circuits	74
6.6.3	Terminals for stranded conductors	74
6.7	Insulation requirements	75
6.7.1	General – electric stresses, overvoltages and working voltages	75
6.7.2	The nature of insulation	78
6.7.3	Insulation requirements for mains circuits	81
6.7.4	Insulation requirements for non-mains circuits	90

6.7.5	Insulation in circuits with special voltage values not addressed in 6.7.3 or 6.7.4.....	97
6.7.6	Reduction of transient overvoltages by the use of overvoltage limiting devices.....	104
6.7.7	Insulation requirements between circuits and parts.....	104
6.8	Constructional requirements for protection against electric shock.....	108
6.8.1	General.....	108
6.8.2	Insulating materials.....	108
6.8.3	Color coding.....	108
6.8.4	Equipment case.....	108
6.8.5	Terminal blocks.....	109
6.8.6	Insulating materials of SCS and LCS.....	109
6.8.7	Terminals.....	110
6.8.8	Requirements for current circuits.....	112
6.9	Safety related electrical tests.....	119
6.9.1	Overview.....	119
6.9.2	Test conditions.....	121
6.9.3	Dielectric test methods.....	123
6.9.4	Dielectric testing on complete equipment.....	126
6.9.5	Dielectric tests on sub-assemblies.....	132
6.9.6	Electrical tests on current circuits of directly connected meters without SCS.....	137
6.9.7	Electrical tests on current circuits of directly connected meters with SCS.....	137
6.9.8	Electrical tests on LCS.....	144
6.9.9	Cemented joints test.....	147
6.9.10	Thermal cycling.....	148
7	Protection against mechanical hazards.....	148
7.1	General.....	148
7.2	Sharp edges.....	148
7.3	Provisions for lifting and carrying.....	149
7.4	Wall mounting.....	149
8	Resistance to mechanical stresses.....	150
8.1	General.....	150
8.2	Spring hammer test.....	150
9	Protection against spread of fire.....	150
9.1	General.....	150
9.2	Eliminating or reducing the sources of ignition within the equipment.....	151
9.3	Containment of fire within the equipment, should it occur.....	151
9.3.1	General.....	151
9.3.2	Construction requirements.....	152
9.4	Limited-energy circuit.....	153
9.5	Overcurrent protection.....	154
10	Equipment temperature limits and resistance to heat.....	154
10.1	Surface temperature limits for protection against burns.....	154
10.2	Temperature limits for terminals.....	155
10.3	Temperatures of internal parts.....	156
10.4	Temperature test.....	158
10.5	Resistance to heat.....	159

10.5.1	Non-metallic enclosures	159
10.5.2	Insulating materials	160
11	Protection against penetration of dust and water	160
11.1	General.....	160
11.2	Test for protection against ingress of dust and foreign objects	161
11.3	Test for protection against ingress of water.....	161
12	Protection against liberated gases and substances explosion and implosion	162
12.1	Batteries and battery charging	162
12.1.1	Mounting of batteries	162
12.1.2	Battery circuits.....	162
12.1.3	Tests related to batteries and charging circuits	163
13	Components and sub-assemblies	164
13.1	General.....	164
13.2	Mains transformers tested outside equipment	165
13.3	Printed wiring boards	165
13.4	Components bridging insulation	166
13.5	Surge protective devices (SPDs, transient overvoltage limiting circuits)	166
13.5.1	General use of SPDs	166
13.5.2	SPD overheating test.....	167
13.6	Capacitors	167
14	Hazards resulting from application – Reasonably foreseeable misuse	168
15	Risk assessment	168
Annex A (normative)	Measuring circuits for touch current	169
A.1	Measuring circuit for AC with frequencies up to 1 MHz and for DC.....	169
A.2	Measuring circuits for sinusoidal AC with frequencies up to 100 Hz and for DC	170
A.3	Current measuring circuit for electrical burns at high frequencies.....	170
A.4	Current measuring circuit for wet location	171
Annex B (informative)	Examples for insulation between parts	173
B.1	General.....	173
B.2	Example of a meter protected by reinforced insulation	173
B.3	Example of a meter protected by double insulation	175
Annex C (informative)	Examples for directly connected meters equipped with SCS and LCS	177
Annex D (normative)	Test circuit diagram for the test of long-term overvoltage withstand	179
Annex E (normative)	Test circuit diagram for short current test on the current circuit of directly connected meters	180
Annex F (informative)	Examples of voltage tests	182
F.1	General.....	182
F.2	Example of a directly connected meter with SCS	182
F.3	Example of a transformer operated meter with auxiliary power supply.....	186
F.4	Example of an LPCT-operated meter with direct voltage connections.....	191
Annex G (normative)	Additional AC voltage tests for electromechanical meters	196
Annex H (normative)	Test equipment for cable flexion and pull test	197
Annex I (normative)	Routine tests	199
I.1	General.....	199
I.2	Protective earth	199

I.3	High-voltage test for mains circuits	199
I.4	Mains circuits with voltage-limiting devices	200
Annex J (informative)	Examples of battery protection	201
Annex K (informative)	Transient overvoltage requirements in TC 13 standards	202
Annex L (informative)	Electricity meters in LVDC systems	203
Annex M (informative)	Component standards	205
Bibliography	206
Figure 1	– Measurements through openings in enclosures	63
Figure 2	– Capacitance level versus voltage in normal condition and single fault condition (see 6.3.2c) and 6.3.3c)	66
Figure 3	– Maximum duration of short-term accessible voltages in single fault condition (see 6.3.3a)	67
Figure 4	– Acceptable arrangements of protection means against electric shock	69
Figure 5	– Examples of binding screw assemblies	71
Figure 6	– Distance between conductors on an interface between two layers	88
Figure 7	– Distance between adjacent conductors along an interface of an inner layer	88
Figure 8	– Distance between adjacent conductors located between the same two layers	90
Figure 9	– Example of recurring peak voltage	102
Figure 10	– Flowchart of safety related electrical tests – part 1	120
Figure 11	– Flowchart of safety related electrical tests – part 2	121
Figure 12	– Flowchart to explain the requirements for protection against the spread of fire	151
Figure 13	– Flowchart for conformity options 13.1 a), b), c) and d)	165
Figure A.1	– Measuring circuit for AC with frequencies up to 1 MHz and for DC	169
Figure A.2	– Measuring circuits for sinusoidal AC with frequencies up to 100 Hz and for DC	170
Figure A.3	– Current measuring circuit for electrical burns	171
Figure A.4	– Current measuring circuit for wet location	172
Figure B.1	– Insulation between parts – example of a meter protected by reinforced insulation	174
Figure B.2	– Insulation between parts – example of a meter protected by double insulation	175
Figure C.1	– Single phase two wire meter with UC2 SCS and 25A LCS	177
Figure C.2	– Three phase four wire meter with UC2 SCS and 2A ACS	178
Figure D.1	– Circuit for three-phase four-wire meters to simulate long term overvoltage, voltage moved to L3	179
Figure D.2	– Voltages at the meter under test	179
Figure E.1	– Test circuit for verification of short-time withstand current test on current circuits with and without SCS (meter example is with SCS)	180
Figure E.2	– Example of short-circuit carrying test record in the case of a single-pole equipment on single-phase AC	181
Figure F.1	– Example terminal arrangement of a directly connected meter with SCS	182
Figure F.2	– Example terminal arrangement of a transformer operated meter with auxiliary power supply	186
Figure F.3	– Example terminal arrangement of a LPCT-operated meter with direct voltage connections	191

Figure H.1 – Test equipment for cable flexion and pull test (see 6.8.7.3)	197
Figure J.1 – Non-rechargeable battery protection.....	201
Figure J.2 – Rechargeable battery protection.....	201
Figure L.1 – Unipolar, balanced and bipolar DC systems	203
Table 1 – Test copper conductors for current and switch terminals	43
Table 2 – Information requirements.....	48
Table 3 – IEC 60417-DB-12M and ISO 7000:2019 symbols that may be used on metering equipment	52
Table 4 – Tightening torque for binding screw assemblies	72
Table 5 – Multiplication factors for clearance for altitudes up to 5 000 m.....	78
Table 6 – Overview of clauses specifying requirements for insulations.....	81
Table 7 – Nominal / rated voltages and rated impulse voltages	82
Table 8 – Clearances for mains circuits	84
Table 9 – Creepage distances for mains circuits	85
Table 10 – Test voltages for solid insulation in mains circuits	86
Table 11 – Test voltages for testing long-term stress of solid insulation in mains circuits	87
Table 12 – Minimum values for distance or thickness of solid insulation in mains circuits.....	89
Table 13 – Clearances and test voltages for non-mains circuits derived from mains circuits of overvoltage category III	92
Table 14 – Creepage distances for non-mains circuits and functional insulation.....	94
Table 15 – Minimum values for distance or thickness (see 6.7.4.4.2 to 6.7.4.4.4)	96
Table 16 – Clearance values for the calculation of 6.7.5.2	99
Table 17 – Test voltages based on clearances.....	100
Table 18 – Clearances for basic insulation in circuits having recurring peak voltages	103
Table 19 – Isolation classes for non-mains circuits	105
Table 20 – Insulation requirements between circuits	106
Table 21 – Summary of requirements for current circuits of directly connected meters without SCS.....	115
Table 22 – Summary of requirements for current circuits of directly connected meters with SCS.....	116
Table 23 – Summary of requirements for LCS.....	118
Table 24 – Correction factors according to test site altitude for test voltages for clearances	122
Table 25 – AC voltage test.....	130
Table 26 – DC voltage test.....	131
Table 27 – Voltage tests for verification of clearance in mains circuits	133
Table 28 – Voltage tests for verification of clearance in non-mains circuits	133
DC test voltages equal to the AC test voltages from Table 13	133
Table 29 – Voltage tests for verification of clearance in circuits with special voltage values.....	134
Table 30 – Voltage tests for verification of solid insulation in mains circuits	135
Table 31 – Voltage tests for verification of solid insulation in non-mains circuits	136
Table 32 – Voltage tests for verification of solid insulation in circuits with special voltage values.....	136

Table 33 – Test sequence and sample plan for SCS	138
Table 34 – Power factor ranges of the test circuit	141
Table 35 – Test sequence and sample plan for LCS	144
Table 36 – Limits for power sources without an overcurrent protective device	153
Table 37 – Limits for power sources with an overcurrent protection device	154
Table 38 – Surface temperature limits in normal condition	155
Table 39 – Temperature limits for terminals	156
Table 40 – Maximum measured temperatures for internal materials and components	157
Table F.1 – Application of impulse test voltages according to 6.9.4.4	183
Table F.2 – Application of AC power frequency test voltages according to 6.9.4.5 or DC test voltages according to 6.9.4.6	183
Table F.3 – Application of AC long-term overvoltage test voltages according to 6.9.4.3.2	184
Table F.4 – Application of surge test voltages according to 6.9.4.7	185
Table F.5 – Application of impulse test voltages according to 6.9.4.4	187
Table F.6 – Application of AC power frequency test voltages according to 6.9.4.5 or DC test voltages according to 6.9.4.6	188
Table F.7 – Application of AC long-term overvoltage test voltages according to 6.9.4.3.2	189
Table F.8 – Application of surge test voltages according to 6.9.4.7	190
Table F.9 – Application of impulse test voltages according to 6.9.4.4	192
Table F.10 – Application of AC power frequency test voltages according to 6.9.4.5 or DC test voltages according to 6.9.4.6	193
Table F.11 – Application of AC long-term overvoltage test voltages according to 6.9.4.3.2	194
Table F.12 – Application of surge test voltages according to 6.9.4.7	195
Table G.1 – AC voltage tests of electromechanical meters	196
Table H.1 – Test values for flexion and pull-out tests for round copper conductors	198
Table L.1 – Voltage between lines (unipolar systems) or line and midpoint (bipolar systems) for installation domain	204
Table L.2 – Voltage between lines (unipolar systems) or line and midpoint (bipolar systems) for distribution domain	204

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRICITY METERING EQUIPMENT –
GENERAL REQUIREMENTS, TESTS AND TEST CONDITIONS –****Part 31: Product safety requirements and tests**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62052-31 has been prepared by IEC technical committee 13: Electrical energy measurement and control. It is an International Standard.

This second edition cancels and replaces the first edition published in 2015. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Title modified (removed "AC");
- b) Scope modified: Extended scope to 1 000 V AC and 1 500 V DC including DC meters. This has led to many changes in various clauses, in particular in Clause 6; Included transducer-operated meters or meters designed for operation with Low Power Instrument Transformers (LPIT) or sensors; Aligned environmental conditions with those of IEC 62052-11:2020, 1.5.2;
- c) Tests: Several clarifications added;
- d) Information and marking requirements: Table 2 aligned widely with IEC 62052-11:2020; Requirements for batteries added;
- e) Protection against electrical shock: Multiple modifications done in different; Clause 6 re-numbered and re-organized; Requirements for touch currents clarified (6.3.1); Specified, in which cases OVC II (resp. CAT II) and OVC IV (resp. CAT IV) requirements shall be applied (6.7.1.3); Added requirements for working voltages (6.7.1.5) and cemented joints (6.7.2.4.2); Table 7 updated and extended; Flowcharts for electrical tests (Figure 10 and Figure 11) and related test procedures updated;
- f) Protection against spread of fire: Requirements for limited energy circuits updated (9.4);
- g) Equipment temperature limits and resistance to heat: Table 40 modified to include additional insulation classes;
- h) Protection against liberated gases and substances explosion and implosion: Requirements for batteries updated;
- i) Components and sub-assemblies Requirements for surge protective devices (13.5);
- j) Annex B revised;
- k) Annex F revised and new examples added;
- l) Annex K revised (see related changes in 6.7.1.3);
- m) Annex L: Removed Annex L "Overview of Safety Aspects Covered", added new Annex L "Electricity Meters in LVDC Systems";
- n) Annex M: Removed Annex M "Index of Defined Terms" and added new Annex M "Component Standards";
- o) General alignment with IEC 61010-1 AMD2 Ed.3 (CDV in preparation) done where possible, however this standard is still in development;
- p) Temperature and humidity ranges (1.5.1 and 1.5.2) revised.

The text of this International Standard is based on the following documents:

Draft	Report on voting
13/1923/FDIS	13/1926/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of IEC 62052 series, under the general title *Electricity metering equipment – General requirements, tests and test conditions*, can be found on the IEC website.

Future documents in this series will carry the new general title as cited above. Titles of existing documents in this series will be updated at the time of the next edition.

In this document, the following print types are used:

- requirements and definitions: in roman type;
- NOTES: in smaller roman type;
- *conformity and tests: in italic type.*

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The IEC addresses safety aspects by establishing *basic*, *group* and *product* safety publications.

A *basic safety publication* covers a specific safety-related matter, applicable to many electrotechnical products. It is primarily intended for use by technical committees in the preparation of standards in accordance with the principles laid down in IEC Guide 104 and ISO/IEC Guide 51. It is not intended for use by manufacturers or certification bodies. One of the responsibilities of a technical committee is, wherever applicable, to make use of basic safety publications in the preparation of its publications. The requirements, test methods or test conditions of basic safety publications will not apply unless specifically referred to or included in the relevant publications.

A *group safety publication* covers all safety aspects of a specific group of products within the scope of two or more product technical committees (TCs). Group safety publications are primarily intended to be stand-alone product safety publications but may also be used by TCs as source material in the preparation of their publications.

A *product safety publication* covers all safety aspects of one or more products within the scope of a single product TC.

The objectives of the development of this document are the following:

- to specifically reference and include relevant requirements, test methods or test conditions of relevant basic safety publications so that they become applicable;
- to specifically reference and include – where appropriate, in a modified form – relevant requirements, test methods or test conditions of relevant group safety publications;
- to consider the latest developments in the technology used for the design and manufacture of equipment for electrical energy measurement and control;
- to achieve a uniform approach to product safety throughout the international metering industry.

This *product safety standard* is based on, among others, the following:

- the *basic safety standard* IEC 60664-1:2020, established by TC 109;
- standards from the IEC 60364 series related to electrical installations of buildings, established by TC 64;
- the *group safety standard* IEC 61010-1:2016 established by TC 66;
- the *group safety standard* IEC 62477-1:2022 established by TC 22;
- IEC 60255-27:2023, a *product safety standard* for measuring relays and protection equipment, established by TC 95. These products are similar in their design and to some extent in their use in equipment for electrical energy measurement and control.

To facilitate the use of this document, an integral text has been prepared, with appropriate references to source documents.

Being a product safety standard, this document takes precedence over the group safety standards IEC 61010-1:2016 and IEC 62477-1:2022.

ELECTRICITY METERING EQUIPMENT – GENERAL REQUIREMENTS, TESTS AND TEST CONDITIONS –

Part 31: Product safety requirements and tests

1 Scope

1.1 General

This part of IEC 62052 specifies general safety requirements and associated tests, with their appropriate conditions for type testing of directly connected, transformer-operated or transducer-operated AC and DC electricity meters and load control equipment.

NOTE 1 For other general requirements, such as EMC, dependability, etc., see the relevant IEC 62052 or IEC 62059 standards. For accuracy requirements and other requirements specific to class indices, see the relevant IEC 62053 standards.

This document applies to electricity metering equipment designed to:

- measure and control electrical energy on electrical networks (mains) with voltage up to 1 000 V AC or 1 500 V DC;

NOTE 2 The voltage mentioned above is the line-to-neutral voltage AC RMS or DC derived from nominal voltages. See Table 7.

- have all functional elements, including add-on communication modules, enclosed in, or forming a single meter case with exception of indicating displays;
- operate with integrated displays (electromechanical or static meters);
- operate with detached indicating displays or without an indicating display (static meters only);
- wall-mounted or to be installed in specified matching sockets or racks;
- optionally provide additional functions other than those for measurement of electrical energy.

NOTE 3 Modern electricity meters typically contain additional functions such as measurement of voltage magnitude, current magnitude, power, frequency, power factor, etc.; measurement of power quality parameters; load control functions; delivery, time, test, accounting, and recording functions; data communication interfaces and associated data security functions. The relevant standards for these functions may apply in addition to the requirements of this document. However, the requirements for such functions are outside the scope of this document.

NOTE 4 Product requirements for Power Metering and Monitoring Devices (PMDs) and measurement functions such as voltage magnitude, current magnitude, power, frequency, etc., are covered in IEC 61557-12. However, devices compliant with IEC 61557-12 are not intended to be used as billing meters unless they are also compliant with the IEC 62052-11:2020 and one or more relevant IEC 62053-xx particular requirements (accuracy class) standard.

NOTE 5 Product requirements for Power Quality Instruments (PQIs) are covered in IEC 62586-1. Requirements for power quality measurement techniques (functions) are covered in IEC 61000-4-30. Requirements for testing of the power quality measurement functions are covered in IEC 62586-2.

This document also applies to transducer-operated meters or meters designed for operation with Low Power Instrument Transformers (LPIT) or sensors (as defined in the IEC 61869 series).

NOTE 6 For meters designed for operation with LPITs, only the metering unit is considered a low voltage device. If the LPITs are rated for voltages exceeding 1 000 V AC, or 1 500 V DC, the combination of the metering unit and LPITs is not a low voltage device.

When equipment in scope of this document is designed to be installed in a specified matching socket, then the requirements apply to, and the tests are performed on, equipment installed in its specified matching socket. However, requirements for sockets and inserting / removing the meters from the socket are outside the scope of this document.

This document is also applicable to auxiliary input and output circuits, operation indicators, and test outputs of equipment for electrical energy measurement.

NOTE 7 Some examples include impulse inputs and outputs, control inputs and outputs, energy test outputs, and circuits for meter data exchange.

Equipment used in conjunction with equipment for electrical energy measurement and control may need to comply with additional safety requirements. See also Clause 13.

NOTE 8 Examples are telecommunication modems and customer information units.

This document does not apply to:

- meters rated to operate with voltage exceeding 1 000 V AC, or 1 500 V DC;
- metering systems comprising multiple devices physically remote from one another;
- portable meters;

NOTE 9 Portable meters are meters that are not permanently connected.

- meters used in rolling stock, vehicles, ships and airplanes;
- laboratory and mobile meter test equipment;
- reference standard meters;

NOTE 10 Nominal values, accuracy classes, requirements and test methods for reference standard meters are specified in IEC 62057-1: 2023.

- conventional or low power instrument transformers;

NOTE 11 Safety of conventional power transformers and low power instrument transformers is covered in the IEC 61869 series of standards.

- equipment with solid-state or other non-electromechanical supply and load control switches.

NOTE 12 For components and sub-assemblies, see Clause 13.

The safety requirements of this document are based on the following assumptions:

- metering equipment has been installed correctly;
- metering equipment is used generally by ordinary persons, including meter readers and consumers of electrical energy. In many cases, it is installed in a way that it is freely accessible. Its terminal covers cannot be removed, and its case cannot be opened without removing seals (if present) and using a tool;
- during normal use all terminal covers, covers and barriers providing protection against accessing hazardous live parts are in place;
- for installation, configuration, maintenance and repair it may be necessary to remove terminal cover(s), (a part of) the case or barriers so that hazardous live parts may become accessible. Such activities are performed by skilled persons, who have been suitably trained to be aware of working procedures necessary to ensure safety. Therefore, safety requirements covering these conditions are out of the scope of this document.

1.2 Aspects included in scope

NOTE 1 Subclause 1.2 is based on IEC 61010-1:2016, 1.2.

The purpose of the requirements of this document is to ensure that hazards to the user and the surrounding area are reduced to a tolerable level.

Requirements for protection against particular types of hazards are given in Clauses 6 to 12 as follows:

- a) electrical shock or burn (see Clause 6);
- b) mechanical hazards and stresses (see Clauses 7 and 8);
- c) spread of fire from the equipment (see Clause 9);
- d) excessive temperature (see Clause 10);
- e) penetration of dust and water (see Clause 11);
- f) liberated gases, explosion and implosion (see Clause 12).

Requirements for components and sub-assemblies are specified in Clause 13.

Requirements for protection against hazards arising from reasonably foreseeable misuse are specified in Clause 14.

Risk assessment for hazards or environments not fully covered above is specified in Clause 15.

NOTE 2 Attention is drawn to the existence of additional requirements specified by national authorities responsible for health and safety.

1.3 Aspects excluded from scope

This document does not cover:

- a) performance, reliability or other properties of the equipment not related to safety;
- b) EMC requirements, which are covered by the relevant type testing standards;

NOTE 1 For EMC requirements and test methods, see, IEC 62052-11:2020, IEC 62052-21:2004 and IEC 62055-31:2021.

- c) protective measures for explosive atmospheres (see IEC 60079-0:2017);
- d) functional safety requirements;
- e) effectiveness of transport packaging;
- f) safety requirements of installations.

NOTE 2 The latter is generally subject to national regulation.

1.4 Verification

NOTE This subclause reproduces IEC 61010-1:2016, 1.3.

This document also specifies methods of verifying that the equipment meets the requirements of this document, through inspection, type tests, risk assessment and routine tests. See Clauses 4, 15 and Annex I respectively.

1.5 Environmental conditions

1.5.1 Normal environmental conditions

NOTE 1 This subclause is based on IEC 61010-1:2016, 1.4.

This document applies to metering equipment designed to be safe at least under the following conditions:

- a) indoor use;
- b) altitude up to 2 000 m;

- c) climatic conditions according to IEC 62052-11:2020, 8.2, limit range of operation for indoor use.

NOTE 2 In IEC 62052-11:2020, the limit range of operation for indoor use is specified according to IEC 60721-1:1990, climatic class 3K6. The closest climatic class in IEC 60721-3-3:2019, is class 3K24 defined in Table 1, with low air temperature -25 °C, high air temperature +55 °C, low relative humidity 5 %, and high relative humidity 100 %. However, for special applications other temperature limit ranges of operation are allowed according to purchase contract.

- d) variation in voltage magnitude up to ± 10 % of the nominal voltage. The equipment may have several nominal voltages;
- e) transient overvoltages up to the levels of overvoltage category III;
- f) transient overvoltages occurring on the mains supply (see 6.7.1.1);
- g) applicable pollution degree of the intended environment (pollution degree 2 in most cases).

Manufacturers may specify more restricted environmental conditions for operation; nevertheless, the equipment shall be safe within these normal environmental conditions.

1.5.2 Extended environmental conditions

This document applies to metering equipment designed to be safe not only under the environmental conditions specified in 1.5.1, but also under any of the following conditions for which the equipment is rated by the manufacturer:

- a) outdoor use;
- b) altitude above 2 000 m;
- c) climatic conditions according to IEC 62052-11:2020, 8.2, limit range of operation for outdoor use.

NOTE 1 In IEC 62052-11:2020, the limit range of operation for outdoor use is specified according to IEC 60721-1:1990, climatic class 3K7. The closest climatic class in IEC 60721-3-4:2019, is class 4K23 defined in Table 1, but with low air temperature -40 °C (instead of -45 °C), high air temperature +70 °C, low relative humidity 4 %, and high relative humidity 100 %. However, for special applications other temperature limit ranges of operation are allowed according to purchase contract.

- d) variation in voltage magnitude up to -20...15 % of the nominal voltage;

NOTE 2 See IEC 62368:2018, B 2.3.

- e) rated impulse voltage U_{imp} higher than what is required for overvoltage category III (see 3.3.8).

1.5.3 Extreme environmental conditions

NOTE 1 The following text is based on IEC 60721-3-0:2020, 5.2.

It is recognized that extreme environmental conditions may exist.

Elements determining the environmental conditions may occur with any of their severities in combination with other elements and their respective severities. An assumption that each element may occur with its highest severity would lead to unnecessary overdesign and cost. Therefore, specifications for products to operate under such extreme environmental conditions are a matter for negotiation between the manufacturer and the purchaser.

NOTE 2 For specific climatic conditions, see IEC 60721-3-3:2019.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60027-1:1992, *Letters symbols to be used in electrical technology – Part 1: General*
IEC 60027-1:1992/AMD1:1997
IEC 60027-1:1992/AMD2:2005

IEC 60068-2-75:2014, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

IEC 60068-2-78:2012, *Environmental testing – Part 2-78: Tests – Test Cab: Damp heat, steady state*

IEC 60085:2007, *Electrical insulation – Thermal evaluation and designation*

IEC 60112:2020, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60269-3:2010, *Low-voltage fuses – Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household or similar applications) – Examples of standardized systems of fuses A to F*

IEC 60332-1-2:2004, *Tests on electric and optical fiber cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame*

IEC 60332-2-2:2004, *Tests on electric and optical fiber cables under fire conditions – Part 2-2: Test for vertical flame propagation for a single small insulated wire or cable – Procedure for diffusion flame*

IEC 60364-4-44:2007, *Low-voltage electrical installations – Part 4-44: Protection for safety – Protection against voltage disturbances and electromagnetic disturbances*

IEC 60384-14:2023, *Fixed capacitors for use in electronic equipment – Part 14: Sectional specification – Fixed capacitors for electromagnetic interference suppression and connection to the supply mains*

IEC 60417-DB-12M, *Graphical symbols for use on equipment*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*
IEC 60529:1989/AMD1:1999
IEC 60529:1989/AMD2:2013

IEC 60617-DB-12M, *Graphical symbols for diagrams*

IEC 60664-1:2020, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60695-2-11:2021, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products (GWEPT)*

IEC 60695-11-10:2013, *Fire hazard testing – Part 11-10: Test flames – 50 W horizontal and vertical flame test methods*

IEC 60721-3-0:2020, *Classification of environmental conditions – Part 3: Classification of groups of environmental parameters and their severities – Introduction*

IEC 60721-3-3:2019, *Classification of environmental conditions – Part 3-3: Classification of groups of environmental parameters and their severities – Stationary use at weather protected locations*

IEC 60950-1:2005, *Information technology equipment – Safety – Part 1: General requirements*
IEC 60950-1:2005/AMD1:2009
IEC 60950-1:2005/AMD2:2013

IEC 61000-4-5:2014, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*
IEC 61000-4-5:2014/AMD1:2017

IEC 61010-1:2016, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 1: General requirements*
IEC 61010-1:2016/AMD1:2016
IEC 61010-1 AMD2 ED. 3 CDV in preparation

IEC 61010-2-030:2017, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 2-030: Particular requirements for testing and measuring circuits*

IEC 61032:1997, *Protection of persons and equipment by enclosures – Probes for verification*

IEC 61180:2016, *High-voltage test techniques for low voltage equipment – Definitions, test and procedure requirements, test equipment*

IEC 61851-23:2014, *Electric vehicle conductive charging system – Part 23: DC electric vehicle charging station*

IEC 62052-11:2020, *Electricity metering equipment – General requirements, tests and test conditions – Part 11: Metering equipment*

IEC 62052-31:2015, *Electricity metering equipment (AC) – General requirements, tests and test conditions – Part 31: Product safety requirements and tests*

IEC 62368-1:2018, *Audio/video, information and communication technology equipment – Part 1: Safety requirements*

ISO 75-2:2013, *Plastics – Determination of temperature of deflection under load – Part 2: Plastics and ebonite*

ISO 3864-1:2011, *Graphical symbols, Safety colors and safety signs – Part 1: Design principles for safety signs and safety markings*

ISO 7000:2019, *Graphical symbols for use on equipment – Registered symbols*