

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

## Kopplingsapparater för högst 1000 V – Part 7-1: Övrig hithörande materiel – Kopplingsplintar för kopparledare

*Low-voltage switchgear and controlgear –  
Part 7-1: Ancillary equipment –  
Terminal blocks for copper conductors*

Som svensk standard gäller europastandarden EN IEC 60947-7-1:2025. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 60947-7-1:2025.

### Nationellt förord

Europastandarden EN IEC 60947-7-1:2025

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 60947-7-1, Fourth edition, 2025 - Low-voltage switchgear and controlgear - Part 7-1: Ancillary equipment - Terminal blocks for copper conductors**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 60947-7-1, utg 3:2009 med eventuella tillägg, ändringar och rättelser gäller ej fr o m 2028-06-30.

## Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

## SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

## Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

## Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

## SEK Svensk Elstandard

Box 1042  
172 21 Sundbyberg  
Tel 08-444 14 00  
elstandard.se

English Version

**Low-voltage switchgear and controlgear - Part 7-1: Ancillary  
equipment - Terminal blocks for copper conductors  
(IEC 60947-7-1:2025)**

Appareillage à basse tension - Partie 7-1: Matériels  
accessoires - Blocs de jonction pour conducteurs en cuivre  
(IEC 60947-7-1:2025)

Niederspannungsschaltgeräte - Teil 7-1: Hilfseinrichtungen  
- Reihenklemmen für Kupferleiter  
(IEC 60947-7-1:2025)

This European Standard was approved by CENELEC on 2025-05-20. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

## **European foreword**

The text of document 121A/646/FDIS, future edition 4 of IEC 60947-7-1, prepared by SC 121A "Low-voltage switchgear and controlgear" of IEC/TC 121 "Switchgear and controlgear and their assemblies for low voltage" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 60947-7-1:2025.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2026-06-30 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2028-06-30 document have to be withdrawn

This document supersedes EN 60947-7-1:2009 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document is read in conjunction with EN IEC 60947-1:2021.

This document has been prepared under a standardization request addressed to CENELEC by the European Commission. The Standing Committee of the EFTA States subsequently approves these requests for its Member States.

For the relationship with EU Legislation, see informative Annex ZZ, which is an integral part of this document.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

### **Endorsement notice**

The text of the International Standard IEC 60947-7-1:2025 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

- |                  |      |  |
|------------------|------|--|
| IEC 60228:2023   | NOTE | Approved as EN IEC 60228:2024 (not modified)   |
| IEC 60352-4:2020 | NOTE | Approved as EN IEC 60352-4:2020 (not modified) |
| IEC 60715        | NOTE | Approved as EN 60715                           |

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: [www.cencenelec.eu](http://www.cencenelec.eu).

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60068-2-1	2007	Environmental testing - Part 2-1: Tests - Test A: Cold	EN 60068-2-1	2007
IEC 60068-2-2	2007	Environmental testing - Part 2-2: Tests - Test B: Dry heat	EN 60068-2-2	2007
IEC 60695-11-5	2016	Fire hazard testing – Part 11-5: Test flames – Needle-flame test method – Apparatus, confirmatory test arrangement and guidance	EN 60695-11-5	2017
IEC 60947-1	2020	Low-voltage switchgear and controlgear Part 1: General rules	EN IEC 60947-1	2021
			+AC	2023
			+AC	2024
ISO 4046-4	2016	Paper, board, pulps and related terms — Vocabulary — Part 4: Paper and board grades and converted products	–	–

**Annex ZZ**  
(informative)

**Relationship between this European standard and the safety objectives of Directive 2014/35/EU [2014 OJ L96] aimed to be covered**

This European Standard has been prepared under a Commission's standardization request relating to harmonized standards in the field of the Low Voltage Directive, M/511, to provide one voluntary means of conforming to safety objectives of Directive 2014/35/EU of the European Parliament and of the Council of 26 February 2014 on the harmonization of the laws of the Member States relating to the making available on the market of electrical equipment designed for use within certain voltage limits [2014 OJ L96].

Once this standard is cited in the Official Journal of the European Union under that Directive, compliance with the normative clauses of this standard given in Table ZZ.1 confers, within the limits of the scope of this standard, a presumption of conformity with the corresponding safety objectives of that Directive, and associated EFTA regulations.

**Table ZZ.1 — Correspondence between this European standard and Annex I of Directive 2014/35/EU [2014 OJ L96]**

Safety objectives of Directive 2014/35/EU	Clause(s) / sub-clause(s) of this EN	Remarks / Notes
1 a) The essential characteristics, the recognition and observance of which will ensure that electrical equipment will be used safely and in applications for which it was made, shall be marked on the electrical equipment, or, if this is not possible, on an accompanying document.	6.1, 8.1.4, Annex D.6	* Subclause 6.1.1 is to be excluded, because is already covered by LVD
1 b) the electrical equipment, together with its component parts, shall be made in such a way as to ensure that it can be safely and properly assembled and connected.	6.1, 6.2, 7, 8.1, Annex D.6, D.7 and D.8.1	
1 c) The electrical equipment shall be so designed and manufactured as to ensure that protection against the hazards set out in points 2 and 3 is assured, providing that the equipment is used in applications for which it was made and is adequately maintained.	1 2 <sup>nd</sup> para *, 8.2, 8.3, and Annex D.1, D.8.2, D.8.3 and D.8.4	

Safety objectives of Directive 2014/35/EU	Clause(s) / sub-clause(s) of this EN	Remarks / Notes
2 a) Measures of a technical nature shall be laid down in accordance with point 1, in order to ensure that persons and domestic animals are adequately protected against the danger of physical injury or other harm which might be caused by direct or indirect contact.	1 2 <sup>nd</sup> para and Annex D.1	
2 b) Measures of a technical nature shall be laid down in accordance with point 1, in order to ensure that temperatures, arcs or radiation which would cause a danger, are not produced.	8.2.1, 8.1.5, 9.4.5, 9.5 and Annex D.8.2.1, D.9.4.5, D.9.5	
2 c) Measures of a technical nature shall be laid down in accordance with point 1, in order to ensure that persons, domestic animals and property are adequately protected against non-electrical dangers caused by the electrical equipment which are revealed by experience.	1 2 <sup>nd</sup> para and Annex D.1	
2 d) Measures of a technical nature shall be laid down in accordance with point 1, in order to ensure that the insulation is suitable for foreseeable conditions.	8.1.3, 8.2.2, 9.4.2, 9.4.3 and Annex D.8.1.3, D.8.2.2, D.9.4.2, D.9.4.3	
3 a) Technical measures shall be laid down in accordance with point 1, in order to ensure that the electrical equipment meets the expected mechanical requirements in such a way that persons, domestic animals and property are not endangered.	1 2 <sup>nd</sup> para and Annex D.1	
3 b) Technical measures shall be laid down in accordance with point 1, in order to ensure that the electrical equipment is resistant to non-mechanical influences in expected environmental conditions, in such a way that persons, domestic animals and property are not endangered.	1 2 <sup>nd</sup> para and Annex D.1	

## EN IEC 60947-7-1:2025 (E)

Safety objectives of Directive 2014/35/EU	Clause(s) / sub-clause(s) of this EN	Remarks / Notes
3 c) Technical measures shall be laid down in accordance with point 1, in order to ensure that the electrical equipment does not endanger persons, domestic animals and property in foreseeable conditions of overload.	8.2.3, 9.4.6 and Annex D.8.2.3, D.9.4.6	

**WARNING 1** — Presumption of conformity stays valid only as long as a reference to this European standard is maintained in the list published in the Official Journal of the European Union. Users of this standard should consult frequently the latest list published in the Official Journal of the European Union.

**WARNING 2** — Other Union legislation may be applicable to the product(s) falling within the scope of this standard.



# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

---

**Low-voltage switchgear and controlgear –  
Part 7-1: Ancillary equipment – Terminal blocks for copper conductors**

**Appareillage à basse tension –  
Partie 7-1: Matériels accessoires – Blocs de jonction pour conducteurs en  
cuivre**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

---

ICS 29.130.20

ISBN 978-2-8327-0335-9

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD.....	5
1 Scope.....	7
2 Normative references .....	7
3 Terms and definitions .....	8
4 Classification.....	8
5 Characteristics .....	9
5.1 Summary of characteristics.....	9
5.2 Type of terminal block.....	9
5.3 Rated and limiting values.....	9
5.3.1 Rated voltages .....	9
5.3.2 Short-time withstand current.....	9
5.3.3 Standard cross-sections .....	9
5.3.4 Rated cross-section.....	9
5.3.5 Rated connecting capacity.....	9
6 Product information .....	10
6.1 Marking.....	10
6.1.1 Manufacturer or trade mark .....	10
6.1.2 Type reference .....	10
6.2 Additional information .....	10
7 Normal service, mounting and transport conditions.....	11
8 Constructional and performance requirements.....	11
8.1 Constructional requirements .....	11
8.1.1 Clamping units.....	11
8.1.2 Mounting .....	11
8.1.3 Clearances and creepage distances .....	11
8.1.4 Terminal block identification and marking .....	12
8.1.5 Resistance to abnormal heat and fire.....	12
8.1.6 Rated cross-section and rated connecting capacity.....	12
8.2 Performance requirements.....	12
8.2.1 Temperature-rise.....	12
8.2.2 Dielectric properties.....	12
8.2.3 Short-time withstand current.....	12
8.2.4 Voltage drop.....	12
8.2.5 Electrical performance after ageing (for screwless-type terminal blocks only).....	13
8.2.6 Contact pressure via insulating material (CoPI) .....	13
8.3 Electromagnetic compatibility.....	13
9 Tests .....	13
9.1 Kinds of test.....	13
9.2 General.....	13
9.3 Verification of mechanical characteristics.....	14
9.3.1 General .....	14
9.3.2 Attachment of the terminal block on its support.....	14
9.3.3 Mechanical properties of clamping units .....	15
9.4 Verification of electrical characteristics .....	17
9.4.1 General .....	17

9.4.2	Verification of clearances and creepage distances.....	17
9.4.3	Dielectric tests.....	17
9.4.4	Verification of the voltage drop.....	18
9.4.5	Temperature-rise test.....	19
9.4.6	Short-time withstand current test.....	20
9.4.7	Ageing test (for screwless-type terminal blocks only).....	20
9.4.8	Contact pressure via insulating material (CoPI) test.....	21
9.5	Verification of thermal characteristics.....	22
9.6	Verification of EMC characteristics.....	23
9.6.1	General.....	23
9.6.2	Immunity.....	23
9.6.3	Emission.....	24
Annex A (informative)	Main characteristics for terminal blocks.....	32
A.1	General.....	32
A.2	Properties of terminal blocks.....	32
A.3	Properties of test disconnect terminal blocks.....	32
Annex B (informative)	Items subject to extended tests for special product applications.....	33
Annex C (informative)	Examples for verifying the connecting capacity based on tests with both metric and AWG/kcmil conductors.....	34
C.1	General.....	34
C.2	Example 1: Testing with metric conductors.....	34
C.3	Example 2: Testing with metric and AWG/kcmil conductors.....	34
C.4	Example 3: Testing with AWG/kcmil conductors.....	34
Annex D (normative)	Requirements for test disconnect terminal blocks.....	35
D.1	Scope.....	35
D.2	Normative references.....	35
D.3	Terms and definitions.....	35
D.4	Classification.....	35
D.5	Characteristics.....	35
D.5.1	Summary of characteristics.....	35
D.5.2	Type of test disconnect terminal block.....	36
D.5.3	Rated and limiting values.....	36
D.6	Product information.....	36
D.6.1	Marking.....	36
D.6.2	Additional information.....	37
D.7	Normal service, mounting and transport conditions.....	37
D.8	Constructional and performance requirements.....	37
D.8.1	Constructional requirements.....	37
D.8.2	Performance requirements.....	38
D.8.3	Service life.....	39
D.8.4	Electromagnetic compatibility.....	39
D.9	Tests.....	40
D.9.1	Kinds of test.....	40
D.9.2	General.....	40
D.9.3	Verification of mechanical characteristics.....	40
D.9.4	Verification of electrical characteristics.....	40
D.9.5	Verification of thermal characteristics.....	44
D.9.6	Service life.....	44
D.9.7	Verification of EMC characteristics.....	44

Annex E (informative) Electrical and mechanical parameters for terminal blocks used with conductors of rated cross-section above 300 mm<sup>2</sup>/600 kcmil..... 47

Bibliography..... 49

  

Figure 1 – Arrangement for test according to 9.3.2..... 15

Figure 2 – Arrangement for tests according to 9.4.5 and 9.4.7, and for the verification of voltage drop..... 19

Figure 3 – Arrangement for test according to 9.5 ..... 23

Figure 4 – Point of test flame contact (view from the layer place below the terminal block)..... 23

Figure D.1 – Test requirements according to D.9.4.4 for verification of the voltage drop ..... 42

  

Table 1 – Test current for standard cross-sections and minimal requirement of rated connecting capacity (see 9.3.3.4 and 9.4.4, 9.4.5) ..... 24

Table 2 – Attachment test parameter, test values for flexion and pull-out and relationship between conductor cross-section and diameter for standard cross-section (see 9.3.2, 9.3.3.2 and 9.3.3.3)..... 27

Table B.1 – Additional items subject to agreement between manufacturer and user..... 33

Table D.1 – Operating cycles ..... 44

Table D.2 – Short-time withstand current and corresponding wire sizes ..... 45

Table E.1 – Electrical parameters for terminal blocks used with conductors of rated cross-section above 300 mm<sup>2</sup>/600 kcmil..... 47

Table E.2 – Mechanical parameters for terminal blocks used with conductors of rated cross-section above 300 mm<sup>2</sup>/600 kcmil..... 48

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –****Part 7-1: Ancillary equipment –  
Terminal blocks for copper conductors**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60947-7-1 has been prepared by subcommittee 121A: Low-voltage switchgear and controlgear, of IEC technical committee 121: Switchgear and controlgear and their assemblies for low-voltage. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2009. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Scope extension for smaller conductor cross-sections;
- b) Implementation of a contact pressure via insulation material (CoPI) test;
- c) Introduction of new informative Annex E for larger cross-sections;

- d) Reorganisation of all tables merged into two tables for electrical and mechanical values;
- e) Implementation of AWG-sizes conductor types as an equivalent type of metric conductor with examples in Annex C;
- f) Reorganisation of Annex D test disconnect terminal blocks to enhance readability;
- g) Introduction of new informative Annex A for main characteristics of terminal blocks.

This document shall be read in conjunction with IEC 60947-1:2020. The provisions of the general rules dealt with in IEC 60947-1:2020 are applicable to this document, where specifically called for. Clauses and subclauses, tables, figures and annexes thus applicable are identified by reference to IEC 60947-1:2020, e.g. 1.2 of IEC 60947-1:2020, Table 4 of IEC 60947-1:2020 or Annex A of IEC 60947-1:2020.

The text of this International Standard is based on the following documents:

Draft	Report on voting
121A/646/FDIS	121A/674/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

A list of all parts in the IEC 60947 series, published under the general title *Low-voltage switchgear and controlgear*, can be found on the IEC website.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/publications](http://www.iec.ch/publications).

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

## LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

### Part 7-1: Ancillary equipment – Terminal blocks for copper conductors

#### 1 Scope

This part of IEC 60947 specifies requirements for terminal blocks and test disconnect terminal blocks according to Annex D with screw-type or screw-less-type clamping units primarily intended for industrial or similar use and to be fixed to a support to provide electrical and mechanical connection between copper conductors. It applies to terminal blocks intended to connect round copper conductors, with or without special preparation, having a cross-section between 0,05 mm<sup>2</sup>/30 AWG and 300 mm<sup>2</sup>/600 kcmil, intended to be used in circuits of a rated voltage not exceeding 1 000 V AC up to 1 000 Hz or 1 500 V DC. The tests on terminal blocks are made with AC or DC supply as required in relevant clauses of this document.

NOTE 1 This document is not intended for connecting devices for household purposes according to IEC 60998-1.

NOTE 2 AWG is the abbreviation of "American Wire Gage" (Gage (US) = Gauge (UK));

kcmil = 1 000 cmil;

1 cmil = 1 circular mil = surface area of a circle having a diameter of 1 mil;

1 mil = 1/1 000 inch.

NOTE 3 This document can be used as a guide in conjunction with an additional product risk assessment for:

- terminal blocks requiring the fixing of special devices to the conductors, for example quick connect terminations or wrapped connection, etc.;
- terminal blocks providing wire-binding screw (see IEC 60947-1:2020, Figure D.2), stud and nut terminations (see IEC 60947-1:2020, Figures D.4 and D.5), lug terminations (see IEC 60947-1:2020, Figure D.6) and terminal blocks providing direct contact to the conductors by means of edges or points penetrating the insulation, for example insulation displacement connection (IDC) (see IEC 60352-4:2020, Figure 2), etc.;
- special types of terminal blocks, for example with diodes or varistors or similar component holders, etc.;
- terminal blocks with capability to connect conductors with cross sections larger than 300 mm<sup>2</sup>/600 kcmil, see Annex E.

Where applicable in this document, the term "clamping unit" has been used instead of the term "terminal". This is taken into account in case of reference to IEC 60947-1:2020.

#### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-1:2007, *Environmental testing – Part 2-1: Tests – Test A: Cold*

IEC 60068-2-2:2007, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60695-11-5:2016, *Fire hazard testing – Part 11-5: Test flames – Needle-flame test method – Apparatus, confirmatory test arrangement and guidance*

IEC 60947-1:2020, *Low-voltage switchgear and controlgear – Part 1: General rules*

ISO 4046-4:2016, *Paper, board, pulps and related terms – Vocabulary – Part 4: Paper and board grades and covered products*