

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

Kopplingsapparater för högst 1000 V – Del 4-1: Kontakter och startkopplare – Elektromekaniska kontakter och startkopplare

*Low-voltage switchgear and controlgear –
Part 4-1: Contactors and motor-starters –
Electromechanical contactors and motor-starters*

Som svensk standard gäller europastandarden EN IEC 60947-4-1:2025. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 60947-4-1:2025.

Nationellt förord

Europastandarden EN IEC 60947-4-1:2025

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 60947-4-1, Fifth edition, 2023 - Low-voltage switchgear and controlgear – Part 4-1: Contactors and motor-starters – Electromechanical contactors and motor-starters**

utarbetad inom International Electrotechnical Commission, IEC.

Standarden ska användas tillsammans med SS-EN IEC 60947-1, utg 6:2021.

Tidigare fastställd svensk standard SS-EN IEC 60947-4-1, utg 4:2019 med eventuella tillägg, ändringar och rättelser gäller ej fr o m 2028-09-30.

ICS 29.120.99; 29.130.20

Denna standard är fastställd av SEK Svensk Elstandard,
som också kan lämna upplysningar om **sakinnehållet** i standarden.
Postadress: Box 1042, 172 21 Sundbyberg
Telefon: 08 - 444 14 00.
E-post: sek@elstandard.se. Internet: elstandard.se

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1042
172 21 Sundbyberg
Tel 08-444 14 00
elstandard.se

EUROPEAN STANDARD

EN IEC 60947-4-1

NORME EUROPÉENNE

EUROPÄISCHE NORM

September 2025

ICS 29.120.99; 29.130.20

Supersedes EN IEC 60947-4-1:2019; EN IEC 60947-4-1:2019/AC:2020-05; EN IEC 60947-4-1:2019/AC:2021-04

English Version

**Low-voltage switchgear and controlgear - Part 4-1: Contactors and motor-starters - Electromechanical contactors and motor-starters
(IEC 60947-4-1:2023)**

Appareillage à basse tension - Partie 4-1: Contacteurs et démarreurs de moteurs - Contacteurs et démarreurs électromécaniques
(IEC 60947-4-1:2023)

Niederspannungsschaltgeräte - Teil 4-1: Schütze und Motorstarter - Elektromechanische Schütze und Motorstarter
(IEC 60947-4-1:2023)

This European Standard was approved by CENELEC on 2023-12-13. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2025 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

Ref. No. EN IEC 60947-4-1:2025 E

SEK Svensk Elstandard

SS-EN IEC 60947-4-1, utg 5:2026

European foreword

The text of document 121A/571/FDIS, future edition 5 of IEC 60947-4-1, prepared by SC 121A "Low-voltage switchgear and controlgear" of IEC/TC 121 "Switchgear and controlgear and their assemblies for low voltage" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 60947-4-1:2025.

The following dates are fixed:

- latest date by which the document has to be implemented at national (dop) 2026-09-30 level by publication of an identical national standard or by endorsement
- latest date by which the national standards conflicting with the (dow) 2028-09-30 document have to be withdrawn

This document supersedes EN IEC 60947-4-1:2019 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document is read in conjunction with EN IEC 60947-1:2021.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 60947-4-1:2023 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

IEC 60068-2-2:2007	NOTE	Approved as EN 60068-2-2:2007 (not modified)
IEC 60072-1:2022	NOTE	Approved as EN IEC 60072-1:2022 (not modified)
IEC 60079 series	NOTE	Approved as EN IEC 60079 series
IEC 60079-7	NOTE	Approved as EN 60079-7
IEC 60079-29-3:2014	NOTE	Approved as EN 60079-29-3:2014 (not modified)
IEC 60204-1	NOTE	Approved as EN 60204-1
IEC 60269-1:2006	NOTE	Approved as EN 60269-1:2007 (not modified)
IEC 60269-2:2013	NOTE	Approved as HD 60269-2:2013
IEC 60384-17:2019	NOTE	Approved as EN IEC 60384-17:2019 (not modified)
IEC 60664-1:2020	NOTE	Approved as EN IEC 60664-1:2020 (not modified)
IEC 60721-3-3	NOTE	Approved as EN IEC 60721-3-3
IEC 60812:2018	NOTE	Approved as EN IEC 60812:2018 (not modified)

IEC 60947-3:2020	NOTE	Approved as EN IEC 60947-3:2021 (not modified)
IEC 60947-4-2	NOTE	Approved as EN IEC 60947-4-2
IEC 60947-6-2	NOTE	Approved as EN IEC 60947-6-2
IEC 60947-8	NOTE	Approved as EN IEC 60947-8
IEC 60990:2016	NOTE	Approved as EN 60990:2016 (not modified)
IEC 61000-6-5	NOTE	Approved as EN 61000-6-5
IEC 61032	NOTE	Approved as EN 61032
IEC 61508-2	NOTE	Approved as EN 61508-2
IEC 61508-3	NOTE	Approved as EN 61508-3
IEC 61508-4:2010	NOTE	Approved as EN 61508-4:2010 (not modified)
IEC 61508-6:2010	NOTE	Approved as EN 61508-6:2010 (not modified)
IEC 61557-12:2018	NOTE	Approved as EN IEC 61557-12:2022 (not modified)
IEC 61557-12:2018/A1:2021	NOTE	Approved as EN IEC 61557-12:2022/A1:2022 (not modified)
IEC 61649	NOTE	Approved as EN 61649
IEC 61915-2:2011	NOTE	Approved as EN 61915-2:2012 (not modified)
IEC 62061	NOTE	Approved as EN IEC 62061
IEC 62443 series	NOTE	Approved as EN IEC 62443 series
IEC 62477-1:2022	NOTE	Approved as EN IEC 62477-1:2023 (not modified)
IEC 62683-1	NOTE	Approved as EN 62683-1
IEC 63365	NOTE	Approved as EN IEC 63365
IEC 63404	NOTE	Approved as EN IEC 63404
ISO/IEC 80079-34	NOTE	Approved as EN ISO/IEC 80079-34

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cencenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60034-1	2022	Rotating electrical machines - Part 1: Rating and performance	-	-
IEC 60034-12	2016	Rotating electrical machines - Part 12: Starting performance of single-speed three-phase cage induction motors	EN 60034-12	2017
IEC 60034-30-1	2014	Rotating electrical machines - Part 30-1: Efficiency classes of line operated AC motors (IE code)	EN 60034-30-1	2014
IEC 60068-2-14	2023	Environmental testing - Part 2-14: Tests - Test N: Change of temperature	EN IEC 60068-2-14	2023
IEC 60079-14	-	Explosive atmospheres - Part 14: Electrical installation design, selection and installation of equipment, including initial inspection	EN IEC 60079-14	-
IEC 60085	2007	Electrical insulation - Thermal evaluation and designation	EN 60085	2008
IEC 60364-1 (mod)	2005	Low-voltage electrical installations - Part 1: Fundamental principles, assessment of general characteristics, definitions	HD 60364-1	2008
-	-		+ A11	2017
IEC 60715	2017	Dimensions of low-voltage switchgear and controlgear - Standardized mounting on rails for mechanical support of switchgear, controlgear and accessories	EN 60715	2017
IEC 60730-1	-	Automatic electrical controls - Part 1: General requirements	EN IEC 60730-1	-
IEC 60947-1	2020	Low-voltage switchgear and controlgear - Part 1: General rules	EN IEC 60947-1	2021
IEC 60947-2	2016	Low-voltage switchgear and controlgear - Part 2: Circuit-breakers	EN 60947-2	2017

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60947-5-1	2016	Low-voltage switchgear and controlgear - Part 5-1: Control circuit devices and switching elements - Electromechanical control circuit devices	EN 60947-5-1	2017
IEC 61051-2	-	Varistors for use in electronic equipment - Part 2: Sectional specification for surge suppression varistors	EN IEC 61051-2	-
IEC 61095	2023	Electromechanical contactors for household and similar purposes	EN IEC 61095	2025
IEC 61140	2016	Protection against electric shock - Common aspects for installation and equipment	EN 61140	2016
IEC 61439	series	Low-voltage switchgear and controlgear assemblies	EN IEC 61439	series
IEC 61643-331	-	Components for low-voltage surge protection - Part 331: Performance requirements and test methods for metal oxide varistors (MOV)	EN IEC 61643-331	-
IEC 61800-5-1	2022	Adjustable speed electrical power drive systems - Part 5-1: Safety requirements - Electrical, thermal and energy	EN IEC 61800-5-1	2023
IEC 61810-1	-	Electromechanical elementary relays - Part 1: General and safety requirements	EN 61810-1	-
IEC/TS 63058	-	Switchgear and controlgear and their assemblies for low voltage - Environmental aspects	-	-
IEC/TS 63208	-	Low-voltage switchgear and controlgear - Security aspects	-	-
IEC/TR 63216	2019	Low-voltage switchgear and controlgear - Electromagnetic compatibility assessment for switchgear and controlgear and their assemblies	CLC IEC/TR 63216	2020
CISPR 11 (mod)	2015	Industrial, scientific and medical equipment - Radio-frequency disturbance characteristics - Limits and methods of measurement	EN 55011	2016
+ A1	2016		+ A1	2017
-	-		+ A11	2020
+ A2	2019		+ A2	2021
ISO 2859-1	-	Sampling procedures for inspection by attributes - Part 1: Sampling schemes indexed by acceptance quality limit (AQL) for lot-by-lot inspection	-	-
ISO 3864-2	-	Graphical symbols - Safety colours and safety signs - Part 2: Design principles for product safety labels	-	-

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Low-voltage switchgear and controlgear –
Part 4-1: Contactors and motor-starters – Electromechanical contactors and
motor-starters**

**Appareillage à basse tension –
Partie 4-1: Contacteurs et démarreurs de moteurs – Contacteurs et démarreurs
électromécaniques**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.120.99, 29.130.20

ISBN 978-2-8322-7773-7

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	10
1 Scope.....	13
2 Normative references	14
3 Terms, definitions, symbols and abbreviated terms.....	15
3.1 General.....	15
3.2 Alphabetical index of terms	15
3.3 Terms and definitions concerning contactors	18
3.4 Terms and definitions of the functions of starters	19
3.5 Terms and definitions concerning starters	20
3.6 Terms and definitions concerning characteristic quantities.....	26
3.7 Terms and definitions concerning safety aspects	28
3.8 Terms and definitions concerning electric motor characteristics	31
3.9 Symbols and abbreviated terms	31
4 Classification.....	32
5 Characteristics of contactors and starters	33
5.1 Summary of characteristics	33
5.2 Type of equipment	33
5.2.1 Kind of equipment.....	33
5.2.2 Number of poles	34
5.2.3 Kind of current (AC or DC).....	34
5.2.4 Interrupting medium (air, oil, gas, vacuum, etc.)	34
5.2.5 Operating conditions of the equipment.....	34
5.2.6 Methods of overload protection of motors	34
5.3 Rated and limiting values for main circuits	35
5.3.1 Rated voltages	35
5.3.2 Currents or powers	36
5.3.3 Rated frequency	38
5.3.4 Rated duties	38
5.3.5 Normal load and overload characteristics	39
5.3.6 Short-circuit characteristics	41
5.3.7 Pole impedance of a contactor (Z) or starter	41
5.4 Utilization category	41
5.4.1 General	41
5.4.2 Assignment of utilization categories based on the results of tests	42
5.5 Control circuits.....	43
5.6 Auxiliary circuits.....	44
5.7 Characteristics of relay and release of overload relays and of motor protective switching device (MPSD)	44
5.7.1 Summary of characteristics.....	44
5.7.2 Types of relay or release	44
5.7.3 Characteristic values	45
5.7.4 Designation and current settings of overload relays	46
5.7.5 Time-current characteristics of overload relays	47
5.7.6 Influence of ambient air temperature.....	47
5.8 Co-ordination with short-circuit protective devices.....	47
5.9 Void.....	47

5.10	Types and characteristics of automatic change-over devices and automatic acceleration control devices	47
5.10.1	Types	47
5.10.2	Characteristics	47
5.11	Types and characteristics of auto-transformers for two-step auto-transformer starters	48
5.12	Types and characteristics of starting resistors for rheostatic rotor starters	48
6	Product information	49
6.1	Nature of information	49
6.1.1	Identification	49
6.1.2	Characteristics, basic rated values and utilization	49
6.2	Marking	51
6.3	Instructions for installation, operation, maintenance, decommissioning and dismantling	52
6.4	Environmental information	52
6.5	Instruction for equipment capable to be reused, repaired and upgraded	53
7	Normal service, mounting and transport conditions	53
8	Constructional and performance requirements	53
8.1	Constructional requirements	53
8.1.1	General	53
8.1.2	Materials	54
8.1.3	Current-carrying parts and their connections	54
8.1.4	Clearances and creepage distances	54
8.1.5	Actuator	55
8.1.6	Indication of the contact position	55
8.1.7	Additional requirements for equipment suitable for isolation	55
8.1.8	Terminals	56
8.1.9	Additional requirements for equipment provided with a neutral pole	56
8.1.10	Provisions for protective earthing	56
8.1.11	Enclosures for equipment	56
8.1.12	Degrees of protection of enclosed equipment	56
8.1.13	Conduit pull-out, torque and bending with metallic conduits	56
8.1.14	Limited energy source	57
8.1.15	Stored charge energy circuit	59
8.1.16	Fault and abnormal conditions	59
8.1.17	Short-circuit and overload protection of ports	60
8.1.18	Use of voltage transient limiting device	60
8.2	Performance requirements	60
8.2.1	Operating conditions	60
8.2.2	Temperature-rise	66
8.2.3	Dielectric properties	69
8.2.4	Normal load and overload performance requirements	70
8.2.5	Co-ordination with short-circuit protective devices	75
8.3	Electromagnetic compatibility (EMC)	77
8.3.1	General	77
8.3.2	Immunity	78
8.3.3	Emission	78
8.4	Embedded software	79
8.5	Security	79

9	Tests	79
9.1	Kinds of test.....	79
9.1.1	General	79
9.1.2	Type tests.....	79
9.1.3	Routine tests	79
9.1.4	Sampling tests.....	80
9.1.5	Special tests.....	80
9.2	Compliance with constructional requirements.....	81
9.2.1	General	81
9.2.2	Electrical performance of screwless-type clamping units.....	81
9.2.3	Ageing test for screwless-type clamping units.....	82
9.2.4	Limited energy source test.....	82
9.2.5	Breakdown of components.....	83
9.2.6	Wire flexing test.....	83
9.3	Compliance with performance requirements.....	84
9.3.1	Test sequences	84
9.3.2	General test conditions.....	84
9.3.3	Performance under no load, normal load and overload conditions.....	85
9.3.4	Performance under short-circuit conditions	98
9.3.5	Overload current withstand capability of contactors and IMPSDs	104
9.3.6	Routine tests and sampling tests	104
9.4	EMC tests	106
9.4.1	General	106
9.4.2	Immunity.....	106
9.4.3	Emission.....	108
Annex A (normative) Marking and identification of terminals of contactors, starters and associated overload relays.....		110
A.1	General.....	110
A.2	Marking and identification of terminals of main circuits.....	110
A.3	Marking and identification of terminals of overload relays	110
Annex B (normative) Special tests		112
B.1	General.....	112
B.2	Mechanical durability	112
B.2.1	General	112
B.2.2	Verification of mechanical durability.....	112
B.3	Electrical durability	114
B.3.1	General	114
B.3.2	Results to be obtained	115
B.3.3	Statistical analysis of test results for contactors or starters.....	115
B.4	Co-ordination at the crossover current between the starter and associated SCPD	116
B.4.1	General	116
B.4.2	Condition for the test for the verification of co-ordination at the crossover current by a direct method	116
B.4.3	Test currents and test circuits.....	116
B.4.4	Test procedure and results to be obtained	117
B.4.5	Verification of co-ordination at the crossover current by an indirect method	117

Annex C (informative) Electric motor evolutions and motor starting methods.....	120
C.1 General.....	120
C.1.1 Major changes on the market concerning electrical motors	120
C.1.2 Electric motor characteristics	121
C.1.3 Efficiency motor analysis	121
C.1.4 Impacts on switchgear and controlgear	123
C.2 Typical variants direct-on-line starters.....	123
C.3 Functional aspects of motor starters	126
C.4 Currents and torques during a star-delta start	128
C.5 Currents and torques during an auto-transformer start	131
C.6 Currents waveform of the different modes of operation of a starter	133
Annex D (informative) Items subject to agreement between manufacturer and user	135
Annex E (Void)	136
Annex F (normative) Requirements for auxiliary contact linked with power contact (mirror contact).....	137
F.1 Application and object.....	137
F.1.1 Application.....	137
F.1.2 Object.....	137
F.2 Characteristics	137
F.3 Product information.....	137
F.4 Normal service, mounting and transport conditions	138
F.5 Constructional and performance requirements	138
F.6 Tests	138
F.6.1 General	138
F.6.2 Tests on products in a new condition	138
F.6.3 Test after conventional operational performance (defined under Table 10).....	139
Annex G (informative) Rated operational currents and rated operational powers of switching devices for electrical motors	140
G.1 General.....	140
G.2 Rated operational powers and rated operational currents.....	140
Annex H (normative) Extended functions to electronic overload relays.....	144
H.1 General.....	144
H.2 Limits of operation of control functions	144
H.2.1 General	144
H.2.2 Limits of electronic overload relay with main circuit undervoltage restarting function.....	144
H.3 Test of the control functions	144
Annex I (informative) AC-1 contactors for use with semiconductor controlled motor load 145	
Annex J (Void).....	146
Annex K (normative) Procedure to determine data for electromechanical contactors used in functional safety applications.....	147
K.1 General.....	147
K.2 Test requirements	147
K.3 Characterization of a failure mode	147
K.4 Failure ratios of a contactor	147

Annex L (normative) Assessment procedure for electromechanical overload protection used in safety applications and especially in explosive atmospheres	149
L.1 Application and object.....	149
L.1.1 Application.....	149
L.1.2 Object.....	149
L.2 Procedure	149
L.2.1 General	149
L.2.2 Safety design process	150
L.3 Requirements	150
L.3.1 General	150
L.3.2 Safety plan	150
L.3.3 Design	151
L.3.4 Failure mode and effects analysis of the safety function	151
L.3.5 Design plan	152
L.3.6 Verification	152
L.3.7 Function assessed.....	152
L.4 Documentation.....	152
L.4.1 Technical safety documentation.....	152
L.4.2 Safety instructions	152
L.5 Example.....	153
L.5.1 architecture description	153
L.5.2 FMEA	154
Annex M (normative) DC contactors for use in photovoltaic (PV) applications	162
M.1 Application	162
M.2 Object.....	162
M.3 Classification	162
M.4 Characteristics.....	162
M.4.1 General	162
M.4.2 Rated impulse withstand voltage.....	162
M.4.3 Utilization category	163
M.5 Product information.....	163
M.6 Normal service, mounting and transport conditions	164
M.6.1 General	164
M.6.2 Ambient air temperature	164
M.6.3 Altitude	164
M.7 Constructional and performance requirements	164
M.7.1 Constructional requirements	164
M.7.2 Performance requirements.....	164
M.7.3 Electromagnetic compatibility (EMC)	165
M.8 Tests	166
M.8.1 General	166
M.8.2 Type tests.....	166
M.8.3 Making and breaking capacities and conventional operational performance	166
M.8.4 Thermal cycling test.....	166
M.8.5 Climatic test.....	167
M.8.6 Dielectric test	167
M.8.7 Critical load current test.....	167
M.8.8 Mechanical and electrical properties of terminals.....	168

M.8.9	Degree of protection of enclosed contactors	168
M.8.10	EMC	168
M.8.11	Clearance and creepage distances	168
Annex N (normative)	Additional requirements and tests for equipment with protective separation.....	169
N.1	General.....	169
N.2	Terms and definitions.....	169
N.3	Requirements	169
N.3.1	Test method for implementing protective impedance.....	169
N.3.2	Touch current measurement	170
Annex O (normative)	Load monitoring indicators	172
O.1	General.....	172
O.2	Indicators list	172
O.3	Uncertainty	174
O.4	Tests	175
O.4.1	Routine tests	175
O.4.2	Type tests.....	175
Annex P (normative)	Short-circuit breaking tests of MPSD.....	177
P.1	General test conditions	177
P.2	Rated service short-circuit breaking capacity	178
P.2.1	General	178
P.2.2	Test of rated service short-circuit breaking capacity.....	178
P.2.3	Verification of operational performance capability	178
P.2.4	Verification of dielectric withstand.....	178
P.2.5	Verification of temperature-rise.....	179
P.2.6	Verification of overload releases	179
P.3	Rated ultimate short-circuit breaking capacity	179
P.3.1	General	179
P.3.2	Verification of overload releases	179
P.3.3	Test of rated ultimate short-circuit breaking capacity	180
P.3.4	Verification of dielectric withstand.....	180
P.3.5	Verification of overload releases	180
P.4	Test of MPSD for IT system	180
P.4.1	General	180
P.4.2	Individual pole short-circuit	181
P.4.3	Verification of dielectric withstand.....	181
P.4.4	Verification of overload releases	181
P.4.5	Marking	182
Bibliography.....		183
Figure 1 – Multiple of current setting limits for ambient air temperature compensated time-delay overload relays		63
Figure 2 – Thermal memory test		64
Figure 3 – Example of different parts		67
Figure 4 – Examples of co-ordination characteristics of a starter.....		77
Figure 5 – Voltage drop measurement at contact point of the clamping terminal		82
Figure 6 – Peak current envelope		89
Figure A.1 – Main circuit		110

Figure A.2 – Overload relays	111
Figure B.1 – Examples of time-current withstand characteristic.....	119
Figure C.1 – Electric motor characteristics.....	121
Figure C.2 – Rated current of different energy efficiency classes	122
Figure C.3 – Ratio of the rated locked-rotor current to the nominal current.....	122
Figure C.4 – Ratio of the inrush current to the nominal current	123
Figure C.5 – Connections to motor windings	124
Figure C.6 – Current and torque during direct-on-line starting.....	125
Figure C.7 – Typical variants of protected starters, combination starters, protected switching devices and combination switching devices	126
Figure C.8 – Functional view of motor starters	127
Figure C.9 – Motor overload protection embedded into a circuit-breaker.....	128
Figure C.10 – Typical curves of currents and torques during a star-delta start	129
Figure C.11 – Timing of star-delta-switching	130
Figure C.12 – Typical method and diagram of starting alternating-current induction motors by means of star-delta starter.....	131
Figure C.13 – Typical curves of currents and torques during an auto-transformer starting of a motor.....	132
Figure C.14 – Typical schematic diagrams for starting alternating-current induction motors by means of auto-transformers.....	133
Figure C.15 – Examples of current and time curves of motor starting and stopping in one or two directions.....	134
Figure F.1 – Mirror contact.....	138
Figure L.1 – Safety design process	150
Figure L.2 – Typical structure of a thermal overload relay	153
Figure L.3 – typical structure of MPSD	154
Figure N.1 – Protection by means of protective impedance	170
Figure N.2 – Measuring instrument	171
Figure O.1 – Example of quantification of a process change	174
Table 1 – Utilization categories.....	43
Table 2 – Trip classes of overload relays	46
Table 19 – Limits for limited energy sources without an overcurrent protective device	58
Table 20 – Limits for limited energy sources with an overcurrent protective device	58
Table 21 – Limits for limited energy source with current limiting impedance	59
Table 3 – Limits of operation of time-delay overload relays when energized on all poles.....	63
Table 4 – Limits of operation of three-pole time-delay overload relays when energized on two poles only.....	65
Table 5 – Temperature-rise limits for insulated coils in air and in oil	66
Table 6 – Intermittent duty test cycle data.....	69
Table 7 – Making and breaking capacities – Making and breaking conditions according to utilization category.....	70
Table 8 – Relationship between the test current and off-time for the verification of rated making and breaking capacities	72
Table 9 – Operational current determination for utilization categories AC-6a and AC-6b when derived from AC-3 ratings	72

Table 10 – Conventional operational performance – Making and breaking conditions according to utilization category	73
Table 11 – Overload current withstand requirements	74
Table 12 – Specific acceptance criteria for immunity tests	78
Table 13 – Value of the prospective test current according to the rated operational current	101
Table 14 – Value of the conventional prospective test current according to the rated operational current (harmonized table)	101
Table 15 – Test conditions for I_{Cd}	104
Table 16 – EMC immunity tests	107
Table 17 – Terminal disturbance voltage limits for conducted radio-frequency emission (for mains ports)	109
Table 18 – Radiated emission test limits	109
Table B.1 – Verification of the number of on-load operating cycles – Conditions for making and breaking corresponding to the several utilization categories	115
Table B.2 – Test conditions	118
Table F.1 – Test voltage according to altitude	139
Table G.1 – Rated operational powers and rated operational currents of motors	141
Table K.1 – Failure mode of contactors	147
Table K.2 – Typical failure ratios for normally open contactors	148
Table L.1 – Severity	154
Table L.2 – Occurrence	155
Table L.3 – Detection levels	155
Table L.4 – Conclusion	156
Table L.5 – Example of failure mode and effects analysis for thermal overload relay	157
Table M.1 – Rated impulse voltage levels for PV contactors	163
Table M.2 – Utilization categories	163
Table M.3 – Ambient air temperature conditions	164
Table M.4 – Verification of rated making and breaking capacities – Conditions for making and breaking corresponding to the DC-PV category	165
Table M.5 – Conventional operational performance – Making and breaking condition corresponding to the DC-PV category	165
Table M.6 – Overall scheme of test sequences	166
Table M.7 – Number of operating cycles corresponding to the critical load current	168
Table M.8 – Critical load current performance	168
Table O.1 – AC monitoring indicators list	173
Table O.2 – Different possibilities authorized for verification of indicators	175
Table O.3 – Reference for verification conditions	176
Table O.4 – Harmonic levels	176

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –**Part 4-1: Contactors and motor-starters –
Electromechanical contactors and motor-starters**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60947-4-1 has been prepared by subcommittee 121A: Low-voltage switchgear and controlgear, of IEC technical committee 121: Switchgear and controlgear and their assemblies for low voltage. It is an International Standard.

This fifth edition cancels and replaces the fourth edition published in 2018. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) objective in the scope;
- b) instantaneous only motor protective switching device IMPSD (3.5.33);
- c) kinds of equipment (5.2.1);

- d) methods of overload protection of motors (5.2.6);
- e) adoption of the AC-7d from IEC 61095:2023 (in 5.4.2);
- f) separately mounted overload relay of a starter (in 5.7.3 b));
- g) starter and contactor suitable for use downstream to basic drive module (6.1.2 w));
- h) reference to IEC TS 63058 for environmental aspects (in 6.4);
- i) wiring subject to movement (in 8.1.3);
- j) use of voltage transient limiting device (8.1.18);
- k) accessible parts subject to temperature limits (in 8.2.2.3);
- l) reference to Annex X of IEC 60947-1:2020 for the co-ordination of MPSD with SCPD (8.2.5.4);
- m) reference to IEC TR 63216 with different EMC environments (8.3.1);
- n) reference to IEC TR 63201 for the embedded software design (8.4);
- o) reference to IEC TS 63208 for cybersecurity aspects (8.5);
- p) update and completion of the measurement method of the power consumption of the electromagnet (9.3.3.2.1.2);
- q) update of Annex C including rational about AC-3e;
- r) determination of the critical load current for photovoltaic applications (M.8.7).

The text of this International Standard is based on the following documents:

Draft	Report on voting
121A/571/FDIS	121A/580/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 60947 series can be found, under the general title *Low-voltage switchgear and controlgear*, on the IEC website.

This document shall be read in conjunction with IEC 60947-1:2020, *Low voltage switchgear and controlgear – Part 1: General rules*. The provisions of the general rules are applicable to this document, where specifically called for.

The provisions of the general rules dealt with IEC 60947-1 are applicable to this part of IEC 60947 series where specifically called for. Clauses and subclauses, tables, figures and annexes of the general rules thus applicable are identified by reference to IEC 60947-1:2020. For example, 5.3.4.1 of IEC 60947-1:2020, Table 4 of IEC 60947-1:2020, or Annex A of IEC 60947-1:2020.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 4-1: Contactors and motor-starters – Electromechanical contactors and motor-starters

1 Scope

This part of IEC 60947 is applicable to the following equipment:

- electromechanical contactors and starters including motor protective switching devices (MPSD and IMPSD);
- actuators of contactor relays;
- contacts dedicated exclusively to the coil circuit of the contactor or the contactor relay;
- dedicated accessories (e.g. dedicated wiring, dedicated latch accessory);

intended to be connected to distribution circuits, motors circuits and other load circuits, the rated voltage of which does not exceed 1 000 V AC or 1 500 V DC.

This document does not apply to:

- starters for DC motors;
- auxiliary contacts of contactors and contacts of contactor relays. These are covered by IEC 60947-5-1;
- the short-circuit protective device integrated within starters, other than MPSDs. This is covered by IEC 60947-2 and IEC 60947-3;
- motor overload protection function performed by control units for built-in thermal protection (PTC). They are covered by IEC 60947-8;
- the use of the equipment with additional measures within explosive atmospheres. These are given in IEC 60079 series;

The objective of this document is to state:

- the characteristics and composition of the equipment (Clause 5);
- the conditions applicable to the equipment with reference to:
 - its operation (5.2.5) and protection functions (5.2.6, 5.7, 5.8),
 - its intended environments (6.5, 8.3.1) and applications (5.4, Annex C, Annex D, Annex G, Annex H, Annex I, Annex M, Annex O) including safety applications (Annex F, Annex K, Annex L),
 - its construction and performance (Clause 8) including requirements to reduce risks of electric shock, thermal hazard, energy hazard, fire hazard and mechanical hazard, reasonably foreseeable misuse, electromagnetic compatibility (EMC) issues, software errors and security issues;
- the tests intended for confirming that these conditions have been met, and the methods to be adopted for these tests (Clause 9);
- the information to be included with the equipment or in the product documentation (Clause 6).

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60034-1:2022, *Rotating electrical machines – Part 1: Rating and performance*

IEC 60034-12:2016, *Rotating electrical machines – Part 12: Starting performance of single-speed three-phase cage induction motors*

IEC 60034-30-1:2014, *Rotating electrical machines – Part 30-1: Efficiency classes of line operated AC motors (IE code)*

IEC 60068-2-14:2023, *Environmental testing – Part 2-14: Tests – Test N: Change of temperature*

IEC 60079-14, *Explosive atmospheres – Part 14: Electrical installations design, selection and erection*

IEC 60085:2007, *Electrical insulation – Thermal evaluation and designation*

IEC 60364-1:2005, *Low-voltage electrical installations – Part 1: Fundamental principles, assessment of general characteristics, definitions*

IEC 60715:2017, *Dimensions of low-voltage switchgear and controlgear – Standardized mounting on rails for mechanical support of switchgear, controlgear and accessories*

IEC 60730-1, *Automatic electrical controls – Part 1: General requirements*

IEC 60947-1:2020, *Low-voltage switchgear and controlgear – Part 1: General rules*

IEC 60947-2:2016, *Low-voltage switchgear and controlgear – Part 2: Circuit-breakers*

IEC 60947-5-1:2016, *Low-voltage switchgear and controlgear – Part 5-1: Control circuit devices and switching elements – Electromechanical control circuit devices*

IEC 61051-2, *Varistors for use in electronic equipment – Part 2: Sectional specification for surge suppression varistors*

IEC 61095:2023, *Electromechanical contactors for household and similar purposes*

IEC 61140:2016, *Protection against electric shock – Common aspects for installation and equipment*

IEC 61439 (all parts), *Low-voltage switchgear and controlgear assemblies*

IEC 61643-331, *Components for low-voltage surge protection – Part 331: Performance requirements and test methods for metal oxide varistors (MOV)*

IEC 61800-5-1:2022, *Adjustable speed electrical power drive systems – Part 5-1: Safety requirements – Electrical, thermal and energy*

IEC 61810-1, *Electromechanical elementary relays – Part 1: General and safety requirements*

IEC TS 63058, *Switchgear and controlgear and their assemblies for low voltage – Environmental aspects*

IEC TS 63208, *Low-voltage switchgear and controlgear – Security aspects*

IEC TR 63216:2019, *Low-voltage switchgear and controlgear – Electromagnetic compatibility assessment for switchgear and controlgear and their assemblies*

CISPR 11:2015, *Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement*

CISPR 11:2015/AMD1:2016

CISPR 11:2015/AMD2:2019

ISO 2859-1:1999, *Sampling procedures for inspection by attributes – Part 1: Sampling schemes indexed by acceptance quality limit (AQL) for lot-by-lot inspection*

ISO 3864-2, *Graphical symbols – Safety colours and safety signs – Part 2: Design principles for product safety labels*