SVENSK STANDARD

SS-EN IEC 62351-7, utg 2:2026

Fastställd	Sida	Ansvarig kommitté
2026-09-23	1 (135)	SEK TK 57

© Copyright SEK Svensk Elstandard. Reproduction in any form without permission is prohibited.

Styrning av kraftsystem och tillhörande informationsutbyte – IT-säkerhet – Del 7: Dataobjektmodeller för styrning av nät och system (NSM)

Power systems management and associated information exchange – Data and communications security – Part 7: Network and System Management (NSM) data object models

Som svensk standard gäller europastandarden EN IEC 62351-7:2026. Den svenska standarden innehåller den officiella engelska språkversionen av EN IEC 62351-7:2026.

Nationellt förord

Europastandarden EN IEC 62351-7:2026

består av:

– **europastandardens ikraftsättningsdokument,** utarbetat inom CENELEC

– **IEC 62351-7, Second edition, 2025 - Power systems management and associated information exchange – Data and communications security – Part 7: Network and System Management (NSM) data object models**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 62351-7, utg 1:2018 med eventuella tillägg, ändringar och rättelser gäller ej fr o m 2029-01-31.

ICS 33.200.00

Denna standard är fastställd av SEK Svensk Elstandard,
som också kan lämna upplysningar om **sakinnehållet** i standarden.
Postadress: Box 1042, 172 21 Sundbyberg
Telefon: 08 - 444 14 00.
E-post: sek@elstandard.se. Internet: elstandard.se

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a mätning, säkerhet och provning och för utförande, skötsel och dokumentation av elprodukter och elanläggningar.

Genom att utforma sådana standarder blir säkerhetsfordringar tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1042
172 21 Sundbyberg
Tel 08-444 14 00
elstandard.se

EUROPEAN STANDARD

NORME EUROPÉENNE

EUROPÄISCHE NORM

EN IEC 62351-7

January 2026

ICS 33.200

Supersedes EN 62351-7:2017

English Version

Power systems management and associated information exchange - Data and communications security - Part 7: Network and System Management (NSM) data object models (IEC 62351-7:2025)

Gestion des systèmes de puissance et échanges d'informations associés - Sécurité des communications et des données - Partie 7: Modèles d'objets de données de gestion de réseaux et de systèmes (NSM)
(IEC 62351-7:2025)

Datenmodelle, Schnittstellen und Informationsaustausch für Planung und Betrieb von Energieversorgungsunternehmen - Daten- und Kommunikationssicherheit - Teil 7: Datenobjektmodelle für Netzwerk- und Systemmanagement (NSM)
(IEC 62351-7:2025)

This European Standard was approved by CENELEC on 2026-01-07. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2026 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

Ref. No. EN IEC 62351-7:2026 E

SEK Svensk Elstandard

SS-EN IEC 62351-7, utg 2:2026

European foreword

The text of document 57/2798/FDIS, future edition 2 of IEC 62351-7, prepared by TC 57 "Power systems management and associated information exchange" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 62351-7:2026.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2027-01-31
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2029-01-31

This document supersedes EN 62351-7:2017 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a standardization request addressed to CENELEC by the European Commission. The Standing Committee of the EFTA States subsequently approves these requests for its Member States.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice

The text of the International Standard IEC 62351-7:2025 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standard indicated:

IEC 61850-7-2	NOTE	Approved as EN 61850-7-2
IEC 61850-7-4	NOTE	Approved as EN 61850-7-4
IEC 61850-8-1	NOTE	Approved as EN 61850-8-1
IEC 61850-9-2	NOTE	Approved as EN 61850-9-2

Annex ZA
(normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cencenelec.eu.

Publication	Year	Title	EN/HD	Year
IEC/TS 62351-1	-	Power systems management and associated information exchange - Data and communications security - Part 1: Communication network and system security - Introduction to security issues	-	-
IEC/TS 62351-2	-	Power systems management and associated information exchange - Data and communications security - Part 2: Glossary of terms	-	-
IEC 62351-3	-	Power systems management and associated information exchange - Data and communications security - Part 3: Communication network and system security - Profiles including TCP/IP	EN IEC 62351-3	-
IEC 62351-4	-	Power systems management and associated information exchange - Data and communications security - Part 4: Profiles including MMS and derivatives	EN IEC 62351-4	-
IEC 62351-5	2023	Power systems management and associated information exchange - Data and communications security - Part 5: Security for IEC 60870-5 and derivatives	EN IEC 62351-5	2023
IEC 62351-8	-	Power systems management and associated information exchange - Data and communications security - Part 8: Role-based access control for power system management	EN IEC 62351-8	-
IEC 62351-9	-	Power systems management and associated information exchange - Data and communications security - Part 9: Cyber security key management for power system equipment	EN IEC 62351-9	-
IEEE 754	2008	IEEE Standard for Binary Floating-Point Arithmetic	-	-
IETF RFC 2578	-	Structure of Management Information Version 2 (SMIv2), April 1999, http://tools.ietf.org/html/rfc2578	-	-

Publication	Year	Title	EN/HD	Year
IETF RFC 3414	-	User-based Security Model (USM) for version 3 of the Simple Network Management Protocol (SNMPv3), December 2002, http://tools.ietf.org/rfc/rfc3414	-	-
IETF RFC 3826	-	The Advanced Encryption Standard (AES) Cipher Algorithm in the SNMP User-based Security Model, June 2004, http://www.rfc-editor.org/rfc/rfc3826	-	-
IETF RFC 4022	-	Management Information Base for the Transmission Control Protocol (TCP), March 2005, http://tools.ietf.org/html/rfc4022	-	-
IETF RFC 4113	-	Management Information Base for the User-Datagram Protocol (UDP), June 2005, http://tools.ietf.org/html/rfc4113	-	-
IETF RFC 4292	-	IP Forwarding Table MIB, April 2006, http://www.rfc-editor.org/rfc/rfc4292	-	-
IETF RFC 4293	-	Management Information Base for the Internet Protocol (IP), April 2006, http://tools.ietf.org/rfc/rfc4293	-	-
IETF RFC 4898	-	TCP Extended Statistics MIB, May 2007, http://tools.ietf.org/rfc/rfc4898	-	-
IETF RFC 5132	-	IP Multicast MIB, December 2007, http://tools.ietf.org/rfc/rfc5132	-	-
IETF RFC 5905	-	Network Time Protocol Version_4: Protocol and Algorithms Specification	-	-
IETF RFC 5590	-	Transport Subsystem for the Simple Network Management Protocol (SNMP), June 2009, http://tools.ietf.org/rfc/rfc5590	-	-
IETF RFC 5591	-	Transport Security Model for the Simple Network Management Protocol (SNMP), June 2009, http://tools.ietf.org/rfc/rfc5591	-	-
IETF RFC 5592	-	Secure Shell Transport Model for the Simple Network Management Protocol (SNMP), June 2009, http://www.rfc-editor.org/rfc/rfc5592	-	-
IETF RFC 5953	-	Transport Layer Security (TLS) Transport Model for the Simple Network Management Protocol (SNMP), August 2010, http://www.rfc-editor.org/rfc/rfc5953	-	-
IETF RFC 6347	-	Datagram Transport Layer Security Version 1.2, January 2012, http://tools.ietf.org/rfc/rfc6347	-	-
IETF RFC 6353	-	Transport Layer Security (TLS) Transport Model for the Simple Network Management Protocol (SNMP), July 2011, http://tools.ietf.org/rfc/rfc6353	-	-
IETF RFC 7860	-	HMAC-SHA-2, Authentication Protocols in User-Based Security Model (USM) for SNMPv3, April 2016, http://tools.ietf.org/rfc/rfc7860	-	-
IETF RFC 8915	-	Protocol Security for the Network Time Protocol, September 2020, http://tools.ietf.org/rfc/rfc8915	-	-

IEC 62351-7

Edition 2.0 2025-12

INTERNATIONAL STANDARD

Power systems management and associated information exchange - Data and communications security -
Part 7: Network and System Management (NSM) data object models

ICS 33.200

ISBN 978-2-8327-0699-2

IEC 62351-7:2025-12(en)

SEK Svensk Elstandard

SS-EN IEC 62351-7, utg 2:2026

CONTENTS

FOREWORD 8
1 Scope 10
2 Normative references 10
3 Terms and definitions 12
4 Abbreviated terms and acronyms 14
5 Overview of Network and System Management (NSM) 14
5.1 Objectives 14
5.2 NSM concepts 16
5.2.1 Simple Network Management Protocol (SNMP) 16
5.2.2 ISO NSM categories 16
5.2.3 NSM "data objects" for power system operations 16
5.2.4 Other NSM protocols 17
5.3 Communication network management 17
5.3.1 Network configuration 17
5.3.2 Network backup 17
5.3.3 Communications failures and degradation 18
5.4 Communication protocols 18
5.5 End systems management 19
5.6 Intrusion detection systems (IDS) 20
5.6.1 IDS guidelines 20
5.6.2 IDS: Passive observation techniques 21
5.6.3 IDS: Active security monitoring architecture with NSM data objects 21
5.7 End-to-end security 22
5.7.1 End-to-end security concepts 22
5.7.2 Role of NSM in end-to-end security 23
5.8 NSM requirements: detection functions 25
5.8.1 Detecting unauthorized access 25
5.8.2 Detecting resource exhaustion as a denial of service (DoS) attack 25
5.8.3 Detecting invalid buffer access DoS attacks 26
5.8.4 Detecting tampered/malformed PDUs 26
5.8.5 Detecting physical access disruption 26
5.8.6 Detecting invalid network access 27
5.8.7 Detecting coordinated attacks 27
5.9 Abstract object and agent UML descriptions 28
5.9.1 Purpose of UML 28
5.9.2 Abstract types and base types 28
5.9.3 Enumerated Types 29
5.9.4 Abstract agents 29
5.9.5 Unsolicited Event Notification 32
5.9.6 UML Model extension 32
5.10 Abstract Object UML translation to SNMP 33
5.10.1 Simple Network Management Protocol (SNMP) 33
5.10.2 Management information bases (MIBs) 33
5.11 SNMP mapping of UML model Objects 34
5.12 SNMP Security 36
6 Abstract objects 38

6.1 General 38
6.2 Package Abstract Types 39
6.2.1 General 39
6.2.2 BooleanValue 39
6.2.3 BooleanValueTs 39
6.2.4 CounterTs 40
6.2.5 CntRs 40
6.2.6 Floating 40
6.2.7 FloatingTs 41
6.2.8 EntityIndex 41
6.2.9 Integer 41
6.2.10 IntegerTs 41
6.2.11 InetAddress 42
6.2.12 InetAddressType 42
6.2.13 MacAddress 42
6.2.14 Selector 43
6.2.15 Timestamp 43
6.2.16 CharString 43
6.2.17 CharStringTs 43
6.2.18 AbstractBaseType root class 44
6.2.19 AbstractAgent root class 44
6.3 Package EnumeratedTypes 44
6.3.1 General 44
6.3.2 AppDatStKind enumeration 44
6.3.3 PhyHealthKind enumeration 44
6.3.4 ExtKind enumeration 45
6.3.5 IntKind enumeration 45
6.3.6 LnkKind enumeration 45
6.3.7 PSPAccKind enumeration 46
6.3.8 ProtIdKind enumeration 46
6.3.9 EventKind enumeration 46
6.3.10 TimSyncIssueKind enumeration 47
6.3.11 SecurityProfileKind enumeration 47
6.3.12 TimSyncSrcKind enumeration 47
6.3.13 AppDatStType 48
6.3.14 PhyHealthType 48
6.3.15 ExtType 48
6.3.16 IntType 49
6.3.17 EventType 49
6.3.18 PSPAccType 49
6.3.19 ProtIdType 49
6.3.20 TimSyncIssueType 50
6.3.21 SecurityProfileType 50
6.3.22 TimSyncSrcType 50
6.3.23 GseSubsStKind enumeration 50
6.3.24 GseSubsStType 51
6.3.25 LnkType 51
7 Agents 51

7.1 Package Overview 51
7.2 Package Environmental Agent 52
7.2.1 General 52
7.2.2 (nsmAgent) Environmental 53
7.2.3 (nsmEntry) PSUPEntry 54
7.2.4 (nsmEvent) Notification 54
7.2.5 (nsmEvent) SecurityNotification 55
7.3 Package IED Agent 55
7.3.1 General 55
7.3.2 (nsmAgent) IED 56
7.3.3 (nsmEntry) CPUEntry 58
7.3.4 (nsmEntry) EXTEntry 58
7.3.5 (nsmEntry) STOREEntry 59
7.3.6 (nsmEvent) Notification 59
7.3.7 (nsmEvent) SecurityNotification 60
7.4 Package Application Protocols Agents 60
7.4.1 General 60
7.4.2 Package Common objects 61
7.4.3 Package IEC62351-3 ed.2 Agent 62
7.4.4 Package IEEE 1815 and IEC 60870-5 Agent 74
7.4.5 Package IEEE 1815 and IEC 60870-5 Agent – ed2 84
7.4.6 Package IEC61850 Agent 96
7.5 Package Interfaces Agent 117
7.5.1 General 117
7.5.2 Interface 118
7.5.3 (nsmAgent) Interfaces 119
7.5.4 (nsmEntry) ETHEntry 120
7.5.5 (nsmEntry) KEYEntry 120
7.5.6 (nsmEntry) SEREntry 120
7.5.7 (nsmEntry) ALGEntry 121
7.5.8 (nsmEntry) USBEntry 121
7.5.9 (nsmEvent) Notification 121
7.6 Package Clocks Agent 122
7.6.1 General 122
7.6.2 (nsmAgent) Clock 123
7.6.3 (nsmEntry) ClockEntry 123
7.6.4 (nsmEvent) SecurityNotification 124
7.7 Network and Transport Agents 124
7.7.1 TCP 124
7.7.2 User Datagram Protocol (UDP) 125
7.7.3 IP 125
8 SNMP security 125
9 Secured time synchronization 126
Annex A (informative) Mapping of relevant IEC 61850 Objects 127
Bibliography 128

Figure 1 – Example of a power system SCADA architecture extended with NSM Data Objects 15

Figure 2 – IDS Information exchange between applications: generic communication topology 20
Figure 3 – Active security monitoring architecture with NSM data objects 22
Figure 4 – Comparison of NSM data objects with IEC 61850 objects 24
Figure 5 – Management of both the power system infrastructure and the information infrastructure 24
Figure 6 – Abstract types 28
Figure 7 – Enumerated types 29
Figure 8 – Subagents 30
Figure 9 – Environmental agent 31
Figure 10 – Model stereotypes 32
Figure 11 – Object identifier structure 34
Figure 12 – SNMP table 36
Figure 13 – SNMP RFCs map and security 37
Figure 14 – SNMP Entity 38
Figure 15 – Class diagram Overview::Part7 Classes Overview 52
Figure 16 – Class diagram Environmental Agent::Environmental 53
Figure 17 – Class diagram IED Agent::IED 56
Figure 18 – Class diagram Common objects::Application Protocol common objects 61
Figure 19 – Class diagram IEC62351-3 ed.2 Agent::IEC 62351-3 ed.2 Agent Relationships 63
Figure 20 – Class diagram IEEE 1815 and IEC 60870-5 Agent::IEEE 1815 and IEC 60870-5 Agent 75
Figure 21 – Class diagram IEEE 1815 and IEC 60870-5 Agent – ed2::IEEE 1815 and IEC 60870 Agent Relationships 85
Figure 22 – Class diagram ACSI::ACSI 97
Figure 23 – Class diagram MMS::MMS 99
Figure 24 – Class diagram SV and GSE common objects::SV and GSE common objects 104
Figure 25 – Class diagram SV::SV 106
Figure 26 – Class diagram GSE::GSE 111
Figure 27 – Class diagram Interfaces Agent::Interfaces 118
Figure 28 – Class diagram Clocks Agent::Clocks Agent 122

Table 1 – Attributes of Abstract Types::BooleanValue 39
Table 2 – Attributes of Abstract Types::BooleanValueTs 40
Table 3 – Attributes of Abstract Types::CounterTs 40
Table 4 – Attributes of Abstract Types::CntRs 40
Table 5 – Attributes of Abstract Types::Floating 40
Table 6 – Attributes of Abstract Types::FloatingTs 41
Table 7 – Attributes of Abstract Types::EntityIndex 41
Table 8 – Attributes of Abstract Types::Integer 41
Table 9 – Attributes of Abstract Types::IntegerTs 42
Table 10 – Attributes of Abstract Types::InetAddress 42

Table 11 – Attributes of Abstract Types::InetAddressType 42
Table 12 – Attributes of Abstract Types::MacAddress 43
Table 13 – Attributes of Abstract Types::Selector 43
Table 14 – Attributes of Abstract Types::Timestamp 43
Table 15 – Attributes of Abstract Types::CharString 43
Table 16 – Attributes of Abstract Types::CharStringTs 44
Table 17 – Literals of EnumeratedTypes::AppDatStKind 44
Table 18 – Literals of EnumeratedTypes::PhyHealthKind 45
Table 19 – Literals of EnumeratedTypes::ExtKind 45
Table 20 – Literals of EnumeratedTypes::IntKind 45
Table 21 – Literals of EnumeratedTypes::LnkKind 45
Table 22 – Literals of EnumeratedTypes::PSPAccKind 46
Table 23 – Literals of EnumeratedTypes::ProtIdKind 46
Table 24 – Literals of EnumeratedTypes::EventKind 46
Table 25 – Literals of EnumeratedTypes::TimSyncIssueKind 47
Table 26 – Literals of EnumeratedTypes::SecurityProfileKind 47
Table 27 – Literals of EnumeratedTypes::TimSyncSrcKind 47
Table 28 – Attributes of EnumeratedTypes::AppDatStType 48
Table 29 – Attributes of EnumeratedTypes::PhyHealthType 48
Table 30 – Attributes of EnumeratedTypes::ExtType 48
Table 31 – Attributes of EnumeratedTypes::IntType 49
Table 32 – Attributes of EnumeratedTypes::EventType 49
Table 33 – Attributes of EnumeratedTypes::PSPAccType 49
Table 34 – Attributes of EnumeratedTypes::ProtIdType 49
Table 35 – Attributes of EnumeratedTypes::TimSyncIssueType 50
Table 36 – Attributes of EnumeratedTypes::SecurityProfileType 50
Table 37 – Attributes of EnumeratedTypes::TimSyncSrcType 50
Table 38 – Literals of EnumeratedTypes::GseSubsStKind 50
Table 39 – Attributes of EnumeratedTypes::GseSubsStType 51
Table 40 – Attributes of EnumeratedTypes::LnkType 51
Table 41 – Attributes of Environmental Agent::Environmental 54
Table 42 – Attributes of Environmental Agent::PSUPEntry 54
Table 43 – Attributes of Environmental Agent::Notification 55
Table 44 – Attributes of Environmental Agent::SecurityNotification 55
Table 45 – Attributes of IED Agent::IED 57
Table 46 – Attributes of IED Agent::CPUEntry 58
Table 47 – Attributes of IED Agent::EXTEntry 59
Table 48 – Attributes of IED Agent::STOREEntry 59
Table 49 – Attributes of IED Agent::Notification 60
Table 50 – Attributes of IED Agent::SecurityNotification 60
Table 51 – Attributes of Common objects::CommonProtocolInfo 62
Table 52 – Attributes of IEC62351-3 ed.2 Agent::IEC62351-3ed2security 64
Table 53 – Attributes of IEC62351-3 ed.2 Agent::TLSSession 66

Table 54 – Attributes of IEC62351-3 ed.2 Agent::Summary 68
Table 55 – Attributes of IEC62351-3 ed.2 Agent::IEC62351part3ed2SecurityNotification 70
Table 56 – Attributes of IEC62351-3 ed.2 Agent::ClientTLS 71
Table 57 – Attributes of IEC62351-3 ed.2 Agent::ServerTLS 73
Table 58 – Attributes of IEEE 1815 and IEC 60870-5 Agent::60870andDNPProtocolInfo 76
Table 59 – Attributes of IEEE 1815 and IEC 60870-5 Agent::Association 77
Table 60 – Attributes of IEEE 1815 and IEC 60870-5 Agent::Summary 79
Table 61 – Attributes of IEEE 1815 and IEC 60870-5 Agent::60870andDNPSecurityNotification 80
Table 62 – Attributes of IEEE 1815 and IEC 60870-5 Agent::60870andDNPNotification 81
Table 63 – Attributes of IEEE 1815 and IEC 60870-5 Agent::MasterAssociation 81
Table 64 – Attributes of IEEE 1815 and IEC 60870-5 Agent::OutstationAssociation 83
Table 65 – Attributes of IEEE 1815 and IEC 60870-5 Agent – ed2::60870andDNPProtocolInfoEd2 86
Table 66 – Attributes of IEEE 1815 and IEC 60870-5 Agent – ed2::IEC62351part5 87
Table 67 – Attributes of IEEE 1815 and IEC 60870-5 Agent – ed2::Association 88
Table 68 – Attributes of IEEE 1815 and IEC 60870-5 Agent – ed2::Summary 90
Table 69 – Attributes of IEEE 1815 and IEC 60870-5 Agent – ed2::60870andDNPSecurityNotificationEd2 92
Table 70 – Attributes of IEEE 1815 and IEC 60870-5 Agent – ed2::MasterAssociation 92
Table 71 – Attributes of IEEE 1815 and IEC 60870-5 Agent – ed2::OutstationAssociation 94
Table 72 – Attributes of ACSI::ACSISummary 97
Table 73 – Attributes of MMS::MMSProtocolInfo 100
Table 74 – Attributes of MMS::MMSProvider 101
Table 75 – Attributes of MMS::MMSAssociation 102
Table 76 – Attributes of MMS::MMSSecurityNotification 103
Table 77 – Attributes of MMS::MMSNotification 104
Table 78 – Attributes of SV and GSE common objects::GSEandSVCommon 105
Table 79 – Attributes of SV and GSE common objects::GSEandSVPublisherAssociation 105
Table 80 – Attributes of SV and GSE common objects::GSEandSVSubscriberAssociation 105
Table 81 – Attributes of SV::SVProvider 107
Table 82 – Attributes of SV::SVPublisherAssociationIP 107
Table 83 – Attributes of SV::SVPublisherAssociationL2 108
Table 84 – Attributes of SV::SVSubcriberAssociationIP 109
Table 85 – Attributes of SV::SVSubcriberAssociationL2 109
Table 86 – Attributes of SV::SVNotification 110
Table 87 – Attributes of GSE::GSESubscriberAssociation 112
Table 88 – Attributes of GSE::GSEProvider 113
Table 89 – Attributes of GSE::GSEPublisherAssociationIP 114
Table 90 – Attributes of GSE::GSEPublisherAssociationL2 114
Table 91 – Attributes of GSE::GSESubcriberAssociationIP 115

Table 92 – Attributes of GSE::GSESubcriberAssociationL2 116
Table 93 – Attributes of GSE::GSENotification 117
Table 94 – Attributes of Interfaces Agent::Interface 119
Table 95 – Attributes of Interfaces Agent::Interfaces 119
Table 96 – Attributes of Interfaces Agent::ETHEntry 120
Table 97 – Attributes of Interfaces Agent::KEYEntry 120
Table 98 – Attributes of Interfaces Agent::SEREntry 120
Table 99 – Attributes of Interfaces Agent::ALGEntry 121
Table 100 – Attributes of Interfaces Agent::USBEntry 121
Table 101 – Attributes of Interfaces Agent::Notification 122
Table 102 – Attributes of Clocks Agent::Clock 123
Table 103 – Attributes of Clocks Agent::ClockEntry 123
Table 104 – Attributes of Clocks Agent::SecurityNotification 124
Table A.1 – IEC 61850-7-4 objects mapping 127

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

Power systems management and associated information exchange - Data and communications security - Part 7: Network and System Management (NSM) data object models

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62351-7 has been prepared by IEC technical committee 57: Power systems management and associated information exchange. It is an International Standard.

This edition of IEC 62351-7 cancels and replaces IEC 62351-7 published in 2017. This new edition constitutes a technical revision and includes the following significant technical changes with respect to IEC 62351-7:

a) Reviewed and enriched the NSM object data model;
b) UML model adopted for NSM objects description;
c) SNMP protocol MIBs translation included as Code Components.

The text of this International Standard is based on the following documents:

Draft	Report on voting
57/2798/FDIS	57/2829/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 62351 series, under the general title: *Power systems management and associated information exchange – Data and communications security*, can be found on the IEC website.

This IEC standard includes Code Components i.e components that are intended to be directly processed by a computer. Such content is any text found between the markers <CODE BEGINS> and <CODE ENDS>, or otherwise is clearly labeled in this standard as a Code Component.

The purchase of this IEC standard carries a copyright license for the purchaser to sell software containing Code Components from this standard directly to end users and to end users via distributors, subject to IEC software licensing conditions, which can be found at: http://www.iec.ch/CCv1.

The Code Components included in this IEC standard are also available as electronic machine readable file at: http://www.iec.ch/TC57/supportdocuments.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

– reconfirmed,
– withdrawn, or
– revised.

1 Scope

This part of IEC 62351 defines network and system management (NSM) data object models that are specific to power system operations. These NSM data objects will be used to monitor the health of networks and systems, to detect possible security intrusions, and to manage the performance and reliability of the information infrastructure. The goal is to define a set of abstract objects that will allow the remote monitoring of the health and condition of IEDs (Intelligent Electronic Devices), RTUs (Remote Terminal Units), DERs (Distributed Energy Resources) systems and other systems that are important to power system operations.

Power systems operations are increasingly reliant on information infrastructures, including communication networks, IEDs, and self-defining communication protocols. Therefore, management of the information infrastructure has become crucial to providing the necessary high levels of security and reliability in power system operations.

The telecommunication infrastructure that is in use for the transport of telecontrol and automation protocols is already subject to health and condition monitoring control, using the concepts developed in the IETF Simple Network Management Protocol (SNMP) standards for network management. However, power system specific devices (like teleprotection, telecontrol, substation automation, synchrophasors, inverters and protections) need instead a specific solution for monitoring their health.

The NSM objects provide monitoring data for IEC protocols used for power systems (IEC 61850, IEC 60870-5-104) and device specific environmental and security status. As a derivative of IEC 60870-5-104, IEEE 1815 DNP3 is also included in the list of monitored protocols. The NSM data objects use the naming conventions developed for IEC 61850, expanded to address NSM issues. For the sake of generality these data objects, and the data types of which they are comprised, are defined as abstract models of data objects.

In addition to the abstract model, in order to allow the integration of the monitoring of power system devices within the NSM environment in this part of IEC 62351, a mapping of objects to the SNMP protocol of Management Information Base (MIBs) is provided.

The objects that are already covered by existing MIBs are not defined here but are expected to be compliant with existing MIB standards. For example protocols including EST, SCEP, RADIUS, LDAP, GDOI are not in scope.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC TS 62351-1, *Power systems management and associated information exchange – Data and communications security – Part 1: Communication network and system security – Introduction to security issues*

IEC TS 62351-2, *Power systems management and associated information exchange – Data and communications security – Part 2: Glossary of terms*

IEC 62351-3, *Power systems management and associated information exchange – Data and communications security – Part 3: Communication network and system security – Profiles including TCP/IP*

IEC 62351-4, *Power systems management and associated information exchange – Data and communications security – Part 4: Profiles including MMS*[1]

IEC 62351-5:2023, *Power systems management and associated information exchange – Data and communications security – Part 5: Security for IEC 60870-5 and derivatives*

IEC 62351-8, *Power systems management and associated information exchange – Data and communications security – Part 8: Role-based access control*

IEC 62351-9, *Power systems management and associated information exchange – Data and communications security – Part 9: Cyber security key management for power system equipment*

IEEE 754:2008, *IEEE Standard for Floating-Point Arithmetic*

IETF RFC 2578, *Structure of Management Information Version 2 (SMIv2),* April 1999, http://tools.ietf.org/html/rfc2578

IETF RFC 3414, *User-based Security Model (USM) for version 3 of the Simple Network Management Protocol (SNMPv3),* December 2002, http://tools.ietf.org/rfc/rfc3414

IETF RFC 3826, *The Advanced Encryption Standard (AES) Cipher Algorithm in the SNMP User-based Security Model,* June 2004, http://www.rfc-editor.org/rfc/rfc3826

IETF RFC 4022, *Management Information Base for the Transmission Control Protocol (TCP)*, March 2005, http://tools.ietf.org/html/rfc4022

IETF RFC 4113, *Management Information Base for the User Datagram Protocol (UDP)*, June 2005, http://tools.ietf.org/html/rfc4113

IETF RFC 4292, *IP Forwarding Table MIB*, April 2006, http://www.rfc-editor.org/rfc/rfc4292

IETF RFC 4293, *Management Information Base for the Internet Protocol (IP)*, April 2006, http://tools.ietf.org/rfc/rfc4293

IETF RFC 4898, *TCP Extended Statistics MIB*, May 2007, http://tools.ietf.org/rfc/rfc4898

IETF RFC 5132, *IP Multicast MIB*, December 2007, http://tools.ietf.org/rfc/rfc5132

IETF RFC 5905, *Network Time Protocol Version 4: Protocol and Algorithms Specification*, June 2010, http://tools.ietf.org/rfc/rfc5905

IETF RFC 5590, *Transport Subsystem for the Simple Network Management Protocol (SNMP)*, June 2009, http://tools.ietf.org/rfc/rfc5590

IETF RFC 5591, *Transport Security Model for the Simple Network Management Protocol (SNMP)*, June 2009, http://tools.ietf.org/rfc/rfc5591

IETF RFC 5592, *Secure Shell Transport Model for the Simple Network Management Protocol (SNMP)*, June 2009, http://www.rfc-editor.org/rfc/rfc5592

IETF RFC 5953, *Transport Layer Security (TLS) Transport Model for the Simple Network Management Protocol (SNMP)*, August 2010, http://www.rfc-editor.org/rfc/rfc5953

1 Under preparation. Stage at the time of publication: IEC CDV 62351-4:2017

IETF RFC 6347, *Datagram Transport Layer Security Version 1.2*, January 2012, *http://tools.ietf.org/rfc/rfc6347*

IETF RFC 6353, *Transport Layer Security (TLS) Transport Model for the Simple Network Management Protocol (SNMP)*, July 2011, *http://tools.ietf.org/rfc/rfc6353*

IETF RFC 7860, *HMAC-SHA-2, Authentication Protocols in User-Based Security Model (USM) for SNMPv3*, April 2016, http://tools.ietf.org/rfc/rfc7860

IETF RFC 8915, *Protocol Security for the Network Time Protocol*, September 2020, http://tools.ietf.org/rfc/rfc8915