

© Copyright SEK. Reproduction in any form without permission is prohibited.

Varvtalsstyrda elektriska drivsystem – Del 7-304: Generellt gränssnitt och användning av profiler för drivsystem – Mappning av profil av typ 4 på nät

*Adjustable speed electrical power drive systems –
Part 7-304: Generic interface and use of profiles for power drive systems –
Mapping of profile type 4 to network technologies*

Som svensk standard gäller europastandarden EN 61800-7-304:2008. Den svenska standarden innehåller den officiella engelska språkversionen av EN 61800-7-304:2008.

Nationellt förord

Europastandarden EN 61800-7-304:2008

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 61800-7-304, First edition, 2007 - Adjustable speed electrical power drive systems - Part 7-304: Generic interface and use of profiles for power drive systems - Mapping of profile type 4 to network technologies**

utarbetad inom International Electrotechnical Commission, IEC.

Standarden ersätter delvis SS-EN 61491, utgåva 1, 1998, fr om 2011-02-01.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

**Adjustable speed electrical power drive systems -
Part 7-304: Generic interface and use of profiles for power drive systems -
Mapping of profile type 4 to network technologies
(IEC 61800-7-304:2007)**

Entraînements électriques de puissance
à vitesse variable -
Partie 7-304: Interface et utilisation
génériques de profils
pour les entraînements électriques
de puissance -
Mapping des profils de type 4
pour technologies réseaux
(CEI 61800-7-304:2007)

Elektrische Leistungsantriebssysteme
mit einstellbarer Drehzahl -
Teil 7-304: Generisches Interface
und Nutzung von Profilen
für Leistungsantriebssysteme (PDS) -
Abbildung von Profil-Typ 4
auf Netzwerktechnologien
(IEC 61800-7-304:2007)

This European Standard was approved by CENELEC on 2008-02-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

The text of document 22G/185/FDIS, future edition 1 of IEC 61800-7-304, prepared by SC 22G, Adjustable speed electric drive systems incorporating semiconductor power converters, of IEC TC 22, Power electronic systems and equipment, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 61800-7-304 on 2008-02-01.

This European Standard, together with its companion parts for Profile type 4 (SERCOS), partially replaces EN 61491:1998 which is at present being revised (to be issued as a Technical Report).

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2008-11-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2011-02-01

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 61800-7-304:2007 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61158	NOTE	Harmonized in EN 61158 series (not modified).
IEC 61499-1	NOTE	Harmonized as EN 61499-1:2005 (not modified).
IEC 61800	NOTE	Harmonized in EN 61800 series (not modified).
IEC 61800-7-1	NOTE	Harmonized as EN 61800-7-1:2008 (not modified).
IEC 61800-7-201	NOTE	Harmonized as EN 61800-7-201:2008 (not modified).
IEC 61800-7-202	NOTE	Harmonized as EN 61800-7-202:2008 (not modified).
IEC 61800-7-203	NOTE	Harmonized as EN 61800-7-203:2008 (not modified).
IEC 61800-7-301	NOTE	Harmonized as EN 61800-7-301:2008 (not modified).
IEC 61800-7-302	NOTE	Harmonized as EN 61800-7-302:2008 (not modified).
IEC 61800-7-303	NOTE	Harmonized as EN 61800-7-303:2008 (not modified).

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61158-2	- ¹⁾	Industrial communication networks - Fieldbus specifications - Part 2: Physical layer specification and service definition	EN 61158-2	2008 ²⁾
IEC 61158-4-16	- ¹⁾	Industrial communication networks - Fieldbus specifications - Part 4-16: Data-link layer protocol specification - Type 16 elements	EN 61158-4-16	2008
IEC 61158-5-16	- ¹⁾	Industrial communication networks - Fieldbus specifications - Part 5-16: Application layer service definition - Type 16 elements	EN 61158-5-16	2008 ²⁾
IEC 61158-6-16	- ¹⁾	Industrial communication networks - Fieldbus specifications - Part 6-16: Application layer protocol specification - Type 16 elements	EN 61158-6-16	2008 ²⁾
IEC 61491	2002	Electrical equipment of industrial machines - Serial data link for real-time communication between controls and drives	-	-
IEC 61784-1	- ¹⁾	Industrial communication networks - Profiles - Part 1: Fieldbus profiles	EN 61784-1	2008 ²⁾
IEC 61784-2	- ¹⁾	Industrial communication networks - Profiles - Part 2: Additional fieldbus profiles for real-time networks based on ISO/IEC 8802-3	EN 61784-2	2008 ²⁾
IEC 61800-7	Series	Adjustable speed electrical power drive systems - Part 7: Generic interface and use of profiles for power drive systems	EN 61800-7	Series
IEC 61800-7-204	- ¹⁾	Adjustable speed electrical power drive systems - Part 7-204: Generic interface and use of profiles for power drive systems - Profile type 4 specification	EN 61800-7-204	2008 ²⁾

¹⁾ Undated reference.

²⁾ Valid edition at date of issue.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
ISO/IEC 8802-3	2000	Information technology - Telecommunications - and information exchange between systems - Local and metropolitan area networks - Specific requirements - Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications	-	-

CONTENTS

INTRODUCTION.....	8
1 Scope.....	11
2 Normative references	11
3 Terms, definitions and abbreviated terms	12
3.1 Terms and definitions	12
3.2 Abbreviated terms	17
4 General	17
5 Mapping to CP16/1 (SERCOS I) and CP16/2 (SERCOS II)	18
5.1 Reference to communication standards	18
5.2 Overview	18
5.3 Physical layer and topology	20
5.4 Synchronisation mechanism	21
5.4.1 General	21
5.4.2 Handling of command and feedback values	22
5.4.3 Position loop with fine interpolator	23
5.5 Telegram contents.....	24
5.5.1 General	24
5.5.2 Data block	25
5.5.3 Communication function group telegrams	25
5.5.4 Standard telegrams	26
5.5.5 Application telegrams	28
5.6 Non-cyclic data transfer.....	29
5.7 Real-time bits	29
5.7.1 Functions of Real time bits	29
5.7.2 Allocation of real-time bits	30
5.7.3 Possible cases	31
5.8 Signal control word and signal status word	33
5.9 Data container	34
5.10 Drive shutdown functions	36
5.11 Communication classes	37
5.11.1 General	37
5.11.2 Communication class A	38
5.11.3 Communication class B (Extended Functions)	41
5.11.4 Communication class C (Additional Functions)	42
5.11.5 Communication cycle time granularity.....	43
6 Mapping to CP16/3 (SERCOS III)	43
6.1 Reference to communication standards	43
6.2 Overview	43
6.3 Physical layer and topology.....	45
6.4 Synchronisation mechanism and telegram content	46
6.5 Non-cyclic data transfer.....	47
6.6 Real-time bits	47
6.7 Signal control word and signal status word	47
6.8 Data container	47

6.9	Drive shutdown functions	47
6.10	Communication classes	48
7	Mapping to EtherCAT	48
7.1	Reference to communication standards	48
7.2	Overview	48
7.3	SoE Synchronisation	49
7.3.1	General	49
7.3.2	CP16 Phase 0-2	50
7.3.3	CP16 Phase 3-4	50
7.4	SoE Application Layer Management	50
7.4.1	EtherCAT State Machine and IEC 61784 CPF 16 State Machine	50
7.4.2	Multiple Drives	51
7.4.3	IDN Usage	51
7.5	SoE Process Data Mapping	52
7.6	SoE Service Channel Services	55
7.6.1	Overview	55
7.6.2	SSC Read	55
7.6.3	SSC Write	60
7.6.4	SSC Procedure Commands	64
7.6.5	SSC Slave Info	66
7.7	SoE Coding General	67
7.8	SoE Protocol Data Unit Coding	69
7.8.1	SSC Read	69
7.8.2	SSC Write	72
7.8.3	Notify SSC Command Execution Request	76
7.8.4	SSC Slave Info	77
	Bibliography	79
	Figure 1 – Structure of IEC 61800-7	10
	Figure 2 – Topology	21
	Figure 3 – Validity of command values and feedback acquisition time in the PDSs	22
	Figure 4 – Synchronisation of cycle times	23
	Figure 5 – Synchronisation of the control loops and the fine interpolator	23
	Figure 6 – AT configuration (example)	29
	Figure 7 – Function of the real-time bits	30
	Figure 8 – Allocation of IDN ≠ 0 to the real-time bits	31
	Figure 9 – Allocation of IDN = 0 to the real-time bits	32
	Figure 10 – Allocation of IDN ≠ 0 to the real-time bits	33
	Figure 11 – Configuration example of signal status word	34
	Figure 12 – Data container configuration without acknowledge (slave)	35
	Figure 13 – Data container configuration with acknowledge (slave)	36
	Figure 14 – Structure of Communication classes	37
	Figure 15 – Topology	45
	Figure 16 – Telegram sequence	46
	Figure 17 – General communication cycle	47

Figure 18 – ESM and IEC 61158-4-16 State Machine	51
Figure 19 – Successful SSC Read sequence	56
Figure 20 – Unsuccessful SSC Read sequence	56
Figure 21 – Successful SSC Fragmented Read sequence.....	57
Figure 22 – Successful SSC Write sequence	60
Figure 23 – Unsuccessful SSC Write sequence	61
Figure 24 – Successful SSC Fragmented Write sequence.....	61
Figure 25 – Successful SSC Procedure Command sequence.....	64
Figure 26 – Aborted SSC Procedure Command sequence	65
Figure 27 – Slave Info sequence.....	66
Table 1 – CP16/1 and CP16/2 feature summary.....	18
Table 2 – Number of PDSs per network (examples)	19
Table 3 – Communication Profile Interoperability within a network	20
Table 4 – Typical operation data for cyclic transmission.....	24
Table 5 – Typical data for non-cyclic transmission	25
Table 6 – IDN for choice and parameterisation of telegrams	26
Table 7 – Structure of standard telegram-0	26
Table 8 – Structure of standard telegram-1	26
Table 9 – Structure of standard telegram-2	26
Table 10 – Structure of standard telegram-3	27
Table 11 – Structure of standard telegram-4	27
Table 12 – Structure of standard telegram-5	27
Table 13 – Structure of standard telegram-6	28
Table 14 – IDN for configuration of MDT	28
Table 15 – IDN for configuration of AT	28
Table 16 – IDN for real-time bits	29
Table 17 – Real-time bits assignment IDNs.....	30
Table 18 – IDN for configuring control and status words	33
Table 19 – Data containers IDN	34
Table 20 – Ring configuration – Timing.....	38
Table 21 – Ring configuration – Telegram configuration.....	39
Table 22 – Ring configuration – Phase run-up	39
Table 23 – Service channel protocol	39
Table 24 – Information & diagnostics	40
Table 25 – Communication class A settings	40
Table 26 – Ring configuration – Telegram configuration.....	41
Table 27 – Information & diagnostics	41
Table 28 – Real-time control bits	41
Table 29 – Real-time status bits.....	42
Table 30 – Communication class B settings	42
Table 31 – CP16/3 features summary	44
Table 32 – Number of PDSs per network (examples)	45

Table 33 – Synchronisation performance classes.....	47
Table 34 – EtherCAT feature summary	49
Table 35 – Number of PDSs per network (examples)	49
Table 36 – Obsolete IDNs.....	52
Table 37 – Changed IDNs.....	52
Table 38 – Status word of drive	53
Table 39 – Control word for drive	54
Table 40 – Mapping of SSC services to EtherCAT services.....	55
Table 41 – SSC Read Service.....	58
Table 42 – Read SSC Fragment Service.....	59
Table 43 – SSC Write Service.....	62
Table 44 – Write SSC Fragment Service	63
Table 45 – Notify SSC Command Execution Service.....	65
Table 46 – SSC Slave Info Service	67
Table 47 – SoE Mailbox Protocol	68
Table 48 – SSC Read Request	69
Table 49 – SSC Read Response.....	70
Table 50 – Read SSC Fragment Request.....	72
Table 51 – SSC Write Request	73
Table 52 – SSC Write Response.....	74
Table 53 – Write SSC Fragment Request.....	76
Table 54 – Notify SSC Command Execution Request.....	77
Table 55 – Slave Info Request.....	78

INTRODUCTION

The IEC 61800 series is intended to provide a common set of specifications for adjustable speed electrical power drive systems.

IEC 61800-7 describes a generic interface between control systems and power drive systems. This interface can be embedded in the control system. The control system itself can also be located in the drive (sometimes known as "smart drive" or "intelligent drive").

A variety of physical interfaces is available (analogue and digital inputs and outputs, serial and parallel interfaces, fieldbuses and networks). Profiles based on specific physical interfaces are already defined for some application areas (e.g. motion control) and some device classes (e.g. standard drives, positioner). The implementations of the associated drivers and application programmers interfaces are proprietary and vary widely.

IEC 61800-7 defines a set of common drive control functions, parameters, and state machines or description of sequences of operation to be mapped to the drive profiles.

IEC 61800-7 provides a way to access functions and data of a drive that is independent of the used drive profile and communication interface. The objective is a common drive model with generic functions and objects suitable to be mapped on different communication interfaces. This makes it possible to provide common implementations of motion control (or velocity control or drive control applications) in controllers without any specific knowledge of the drive implementation.

There are several reasons to define a generic interface:

For a drive device manufacturer

- Less effort to support system integrators
- Less effort to describe drive functions because of common terminology
- The selection of drives does not depend on availability of specific support

For a control device manufacturer

- No influence of bus technology
- Easy device integration
- Independent of a drive supplier

For a system integrator

- Less integration effort for devices
- Only one understandable way of modeling
- Independent of bus technology

Much effort is needed to design a motion control application with several different drives and a specific control system. The tasks to implement the system software and to understand the functional description of the individual components may exhaust the project resources. In some cases, the drives do not share the same physical interface. Some control devices just support a single interface which will not be supported by a specific drive. On the other hand, the functions and data structures are often specified with incompatibilities. This requires the system integrator to write special interfaces for the application software and this should not be his responsibility.

Some applications need device exchangeability or integration of new devices in an existing configuration. They are faced with different incompatible solutions. The efforts to adopt a solution to a drive profile and to manufacturer specific extensions may be unacceptable. This will reduce the degree of freedom to select a device best suited for this application to the selection of the unit which will be available for a specific physical interface and supported by the controller.

IEC 61800-7-1 is divided into a generic part and several annexes as shown in Figure 1. The drive profile types for CiA 402¹, CIP Motion^{TM2}, PROFIdrive³ and SERCOS interface^{TM4} are mapped to the generic interface in the corresponding annex. The annexes have been submitted by open international network or fieldbus organizations which are responsible for the content of the related annex and use of the related trademarks.

The different profile types 1, 2, 3 and 4 are specified in IEC 61800-7-201, IEC 61800-7-202, IEC 61800-7-203 and IEC 61800-7-204.

This part of IEC 61800-7 specifies how the profile type 4 (SERCOSTM) is mapped to the network technologies SERCOS I, II, III and EtherCAT^{TM5}.

IEC 61800-7-301, IEC 61800-7-302 and IEC 61800-7-303 specify how the profile types 1, 2 and 3 are mapped to different network technologies (such as CANopen⁶, EtherCATTM, Ethernet Powerlink^{TM7}, DeviceNet^{TM8}, ControlNet^{TM9}, EtherNet/IP^{TM10}, PROFIBUS¹¹ and PROFINET¹²).

¹ CiA 402 is a trade name of CAN in Automation, e.V. This information is given for the convenience of users of this International Standard and does not constitute an endorsement by IEC of the trade name holder or any of its products. Compliance to this profile does not require use of the trade name CiA 402.

² CIP MotionTM is a trade name of Open DeviceNet Vendor Association, Inc. This information is given for the convenience of users of this International Standard and does not constitute an endorsement by IEC of the trademark holder or any of its products. Compliance to this profile does not require use of the trade name CIP MotionTM. Use of the trade name CIP MotionTM requires permission of Open DeviceNet Vendor Association, Inc.

³ PROFIdrive is a trade name of PROFIBUS International. This information is given for the convenience of users of this International Standard and does not constitute an endorsement by IEC of the trade name holder or any of its products. Compliance to this profile does not require use of the trade name PROFIdrive. Use of the trade name PROFIdrive requires permission of PROFIBUS International.

⁴ SERCOSTM and SERCOS interfaceTM are trade names of SERCOS International e.V. This information is given for the convenience of users of this International Standard and does not constitute an endorsement by IEC of the trade name holder or any of its products. Compliance to this profile does not require use of the trade names SERCOS or SERCOS interface. Use of the trade names SERCOS and SERCOS interface requires permission of the trade name holder.

⁵ EtherCATTM is a trade name of Beckhoff, Verl. This information is given for the convenience of users of this International Standard and does not constitute an endorsement by IEC of the trademark holder or any of its products. Compliance to this profile does not require use of the trade name EtherCATTM. Use of the trade name EtherCATTM requires permission of the trade name holder.

⁶ CANopen is an acronym for Controller Area Network *open* and is used to refer to EN 50325-4.

⁷ Ethernet PowerlinkTM is a trade name of B&R, control of trade name use is given to the non profit organization EPSG. This information is given for the convenience of users of this International Standard and does not constitute an endorsement by IEC of the trademark holder or any of its products. Compliance to this profile does not require use of the trade name Ethernet PowerlinkTM. Use of the trade name Ethernet PowerlinkTM requires permission of the trade name holder.

⁸ DeviceNetTM is a trade name of Open DeviceNet Vendor Association, Inc. This information is given for the convenience of users of this International Standard and does not constitute an endorsement by IEC of the trademark holder or any of its products. Compliance to this profile does not require use of the trade name DeviceNetTM. Use of the trade name DeviceNetTM requires permission of Open DeviceNet Vendor Association, Inc.

⁹ ControlNetTM is a trade name of ControlNet International, Ltd. This information is given for the convenience of users of this International Standard and does not constitute an endorsement by IEC of the trademark holder or any of its products. Compliance to this profile does not require use of the trade name ControlNetTM. Use of the trade name ControlNetTM requires permission of ControlNet International, Ltd.

¹⁰ EtherNet/IPTM is a trade name of ControlNet International, Ltd. and Open DeviceNet Vendor Association, Inc. This information is given for the convenience of users of this International Standard and does not constitute an endorsement by IEC of the trademark holder or any of its products. Compliance to this profile does not require use of the trade name EtherNet/IPTM. Use of the trade name EtherNet/IPTM requires permission of either ControlNet International, Ltd. or Open DeviceNet Vendor Association, Inc.

¹¹ PROFIBUS is a trade name of PROFIBUS International. This information is given for the convenience of users of this International Standard and does not constitute an endorsement by IEC of the trade name holder or any of its products. Compliance to this profile does not require use of the trade name PROFIBUS. Use of the trade name PROFIBUS requires permission of PROFIBUS International.

¹² PROFINET is a trade name of PROFIBUS International. This information is given for the convenience of users of this International Standard and does not constitute an endorsement by IEC of the trade name holder or any of its products. Compliance to this profile does not require use of the trade name PROFINET. Use of the trade name PROFINET requires permission of PROFIBUS International.




Figure 1 – Structure of IEC 61800-7

ADJUSTABLE SPEED ELECTRICAL POWER DRIVE SYSTEMS –

Part 7-304: Generic interface and use of profiles for power drive systems – Mapping of profile type 4 to network technologies

1 Scope

IEC 61800-7 specifies profiles for Power Drive Systems (PDS) and their mapping to existing communication systems by use of a generic interface model.

The functions specified in this part of IEC 61800-7 are not intended to ensure functional safety. This requires additional measures according to the relevant standards, agreements and laws.

This part of IEC 61800-7 specifies the mapping of the profile type 4 (SERCOS) specified in IEC 61800-7-204 onto different network technologies.

- SERCOS I / II, see Clause 5,
- SERCOS III, see Clause 6,
- EtherCAT, see Clause 7.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61158-2, *Industrial communication networks – Fieldbus specifications – Part 2: Physical layer specification and service definition*

IEC 61158-4-16, *Industrial communication networks – Fieldbus specifications – Part 4-16: Data-link layer protocol specification – Type 16 elements*

IEC 61158-5-16, *Industrial communication networks – Fieldbus specifications – Part 5-16: Application layer service definition – Type 16 elements*

IEC 61158-6-16, *Industrial communication networks – Fieldbus specifications – Part 6-16: Application layer protocol specification – Type 16 elements*

IEC 61491:2002, *Electrical equipment of industrial machines – Serial data link for real-time communication between controls and drives*

IEC 61784-1, *Industrial communication networks – Profiles – Part 1: Fieldbus profiles*

IEC 61784-2, *Industrial communication networks – Profiles – Part 2: Additional fieldbus profiles for real-time networks based on ISO/IEC 8802-3*

IEC 61800-7 (all parts), *Adjustable speed electrical power drive systems – Generic interface and use of profiles for power drive systems*